

Leak Detection For Piping

FACILITY:

ID #:

| Pressurized Piping: Must have ONE from EACH SET | Tank 1 | Tank2 | Tank 3 | Tank 4 |
|--|--|--------------|---------------|---------------|
| Set 1 | | | | |
| Automatic Line Leak Detector Indicate: Mech, Elec, or Sump Sensor | | | | |
| Date of Last Function Test Mech and Sensors | | | | |
| Set 2 | | | | |
| Date of last Line Tightness Test (annual) or | | | | |
| Monthly Monitoring (circle method) | Methods: CLM, SIR, Sec. Con., VM, GWM | | | |
| Records for last 12 months (yes/no) | | | | |

| Suction Piping: Indicate date of last test or monthly data | | | | |
|---|---|--|--|--|
| Line Tightness Test (every 3 years) or | | | | |
| Monthly Monitoring (circle method) | Methods: SIR, Sec. Con., VM, GWM | | | |
| Records for last 12 months (yes/no) | | | | |

| Safe Suction Piping: No Leak Detection Required (must answer yes to all of the following questions) | | | | |
|--|--|--|--|--|
| Has only one check valve in line, which is located directly under pump | | | | |
| Slope of piping allows product to drain back into tank when suction is released | | | | |
| All above information on suction piping is verifiable | | | | |

Comments/Site Information:

LIST THE FOLLOWING:

1. LD EQUIPMENT & MANUFACTURE

2. TESTING VENDORS

3. RECORDS NOT AVAILABLE

4. LINE LD VIOLATIONS

Inspectors Signature: _____ **Date:** _____