

**BASE Buildings Test Space HVAC Characteristics:** Filtration Systems - Filter Ratings

Filtration System Filter Ratings	Number of Test Space Filtration Systems <sup>1</sup>
0-20 percent	38
20-40 percent	95
40-60 percent	7
60-80 percent	15
80-99 percent	27
Total Number of Test Space Filtration Systems	182
<u>Notes:</u> <sup>1</sup> Summary based on total number of filtration systems for which filter efficiency ratings were specified.	

Variable Descriptions:

**Filtration System Filter Rating** as determined from the manufacturer's specifications. Values reported as average efficiency in accordance with ASHRAE Standard 52-76.