




10250 Middlebelt Rd
Romulus MI
48174-2713 US

Notes:

Only text visible within note field will print.



All rights reserved. Use Subject to License/Copyright

This map is informational only. No representation is made or warranty given as to its content. User assumes all risk of use. MapQuest and its suppliers assume no responsibility for any loss or delay resulting from such use.

WATER WELL AND PUMP RECORD

5427

PERMIT NUMBER


WELL #2

1 LOCATION OF WELL

County WAYNE Township Name CITY OF TAYLOR Fraction 1/4 Section Number 20 Town Number 3 NS Range Number 10 EW

Distance And Direction From Road Intersection
LOCATED BETWEEN BEECH DALY & TELEGRAPH RDS.

Street Address & City of Well Location 25505 NORTHLINE TAYLOR



3 OWNER OF WELL:
LAKES OF TAYLOR GOLF COURSE
 Address 25505 NORTHLINE RD.
TAYLOR, MI 48180
 Address Same As Well Location? Yes No

4 WELL DEPTH: Date Completed MO. DAY YEAR New Well
 FT. 68 Replacement Well

5 Cable tool Rotary Driven Dug
 Hollow rod Auger Jetted

6 USE: Domestic Type I Public Type III Public
 Irrigation Type IIa Public Heat pump
 Test Well Type IIb Public

7 CASING: Diameter Steel Threaded Height: Above Below
 Plastic Welded Surface 1 ft.
6 in. to _____ ft. depth Weight _____ lbs./ft.
 _____ in. to _____ ft. depth
 Grouted Drill Hole Diameter Drive Shoe Yes
 _____ in. to _____ ft. depth No

2 FORMATION DESCRIPTION THICKNESS OF STRATUM DEPTH TO BOTTOM OF STRATUM

8 SCREEN: Not Installed
 Type _____ Diameter _____
 Slot/Gauze _____ Length _____
 Set between _____ ft. and _____ ft.
 FITTINGS: K-Packer Lead Packer Bremer Check
 Blank above screen _____ ft. Other _____

9 STATIC WATER LEVEL: 65 ft. below land surface Flow

10 PUMPING LEVEL: below land surface
80 ft. after 2 hrs. pumping at 50 G.P.M.
 _____ ft. after _____ hrs. pumping at _____ G.P.M.

11 WELL HEAD COMPLETION: Pitless adapter 12" above grade
 Basement offset Approved pit

12 WELL GROUTED? No Yes From _____ to _____ ft.
 Neat cement Bentonite Other _____
 No. of bags of cement _____ Additives _____

13 Nearest source of possible contamination
 Type _____ Distance _____ ft. Direction _____
 Well disinfected upon completion? Yes No
 Was old well plugged? Yes No

14 PUMP: Not Installed Pump Installation Only
 Manufacturer's name GOULD
 Model number 706550412 HP 5 Volts 230
 Length of Drop Pipe 140 ft. capacity 120 G.P.M.
 TYPE: Submersible Jet
 PRESSURE TANK:
 Manufacturer's name _____
 Model number _____ Capacity _____ Gallons

15. Remarks, elevation, source of data, etc.
SUBMERSIBLE PUMP INSTALL ONLY.

17. Rig Operator's Name:

16. WATER WELL CONTRACTOR'S CERTIFICATION:
 This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
CHAS. OEHNING WELL DRILLING 0003
 REGISTERED BUSINESS NAME REGISTRATION NO.
 Address 13035 TELEGRAPH RD. FLAT ROCK MI.
 Signed Charles Oehning Date 6-23-95
 AUTHORIZED REPRESENTATIVE



USE A 2ND SHEET IF NEEDED

Authority: Act 368 PA 1978
 Completion: Required
 Penalty: Conviction of a violation of any provision is a misdemeanor.