

## The Use of 40 CFR 63 Appendix C in Determining Fraction Biodegraded (F<sub>bio</sub>) in a Biological Treatment Unit

Ed O'Neill, EPA- Region 6  
Brenda Shine, EPA/OAQPS  
C. Clark Allen, RTA Inc.



---

---

---

---

---

---

---

---

## What is Appendix C?

- Located in 40 CFR Part 63 (at the end..)
- Provides procedures for calculating biodegradation of organic compounds in a biological treatment unit.

---

---

---

---


---

---

---

---

## Industrial Wastewater Treatment



$$F_r \text{ (fraction removed)} = F_e \text{ (fraction emitted)} + F_{bio} \text{ (fraction biodegraded)}$$

---

---

---

---

---

---

---

---




---

---

---

---

---

---

---

---

**Where is Appendix C Used ?**

- Used for compliance with MACT and NSPS governing air emissions from industrial wastewater treatment systems
  - HON, MON, Pharmaceuticals, P&R
  - SOCOMI NSPS YYY (not final yet)
  - Petroleum Refineries (Subpart CC) Proposed amendments
- Used for developing air emission estimates from industrial wastewater treatment systems
  - Emission inventories
  - Permits

---

---

---

---

---

---

---

---

**Fe and Fbio Calculations- CSTR System**

- $QC_o = QC_L + VK_{max}(b)C_L / (K_s + C_L) + KVC_L$
- $F_e = KAC_L / QC_o$ 
  - K= Mass transfer coefficient
  - A= Area
  - $C_L$ = Concentration in the effluent;
  - Q = flow
  - $C_o$ = Initial concentration
- $F_{bio} = VK_{max}(b)C_L / [(K_s + C_L)QC_o]$ 
  - V= Volume of reactor
  - b = biomass
  - $K_{max}$  = Monod constant
  - $K_s$  = Half saturation constant

---

---

---

---

---


---

---

---



## Bioflow 3000\*



Bioreactor

---

---

---

---

---

---

---

---

## Bioreactor – Controls, Sampling and Measurements



- Inflow-to match RT of full scale unit. Mass flow controller.
- Outflow- Level Control–gravimetric check.
- pH, DO & temperature set & (data logged).
- Exit vent – the real replacement for Henry's Law. Mass Flow Meter.
- Sludge – controlled manually by levels.
- Biomass – VSS representing cell mass. Some accumulation on the sides.
- Physical measurements on bench top unit

---

---

---

---

---

---

---

---

## Methods

- ✓pH – standard methods and calibration. Data logged.
- ✓DO – standard methods and calibration. Data logged.
- ✓Volatiles – SW-846, 8260, Purge and Trap
- ✓Exit vent – TO-15, average response factor.
- ✓Flow rates NIST (within 2 years) calibrated
- ✓Biology – See protocol slide later.

---

---

---

---

---

---

---

---

Physical Controls

Biomass (VSS) Measurements

- ❖ pH between 7.2 & 7.8 and automatically regulated (tighter than full scale unit)
- ❖ DO at 3.0 but for this unit at from 5.0 to 7.0 because recycler/blower not used.
- ❖ Temperature at 26° C and easiest to control.
- ❖ Agitation rate/DO cascaded with agitation set to lower limit.
- ❖ All parameters measured more frequently than sample collection.

Biomass from TCEQ determinations.			
Work Order	date	VSS	
		mg/l	g/l
0611031-03	22-Nov-06	1160	1.160
0611036-06	24-Nov-06	1080	1.080
0611031-10	25-Nov-06	928	0.928
0611031-14	26-Nov-06	1020	1.020
0611035-02	27-Nov-06	1434	1.434
0611035-05	28-Nov-06	928	0.928
average			1.092
(mg/l)(1g/1000 mg) = g/l			

These were contracted out but other solids determinations, not used in the calculations, were done during sample collection in order to return sludge.

Exit Vent Flow Measurements

N	28-Nov-06	27-Nov-06	27-Nov-06	25-Nov-06	26-Nov-06	average	
1	357	349	371	376	336	358	
2	361	372	349	355	350	357	
3	311	371	326	365	352	345	
4	347	366	317	346	335	342	
5	360	344	311	365	341	344	
6	354	366	294	348	358	344	
7	313	370	331	352	354	344	
8	361	359	316	332	359	345	
9	323	325	319	347	324	328	
10	319	359	327	357	323	337	
11	336	331	334	339	323	333	
12	333	342	297	336	313	324	
13	328	333	329	345	313	330	
14	352	367	309	338	316	336	
15	332	333	321	324	321	326	
16	340	306	322		341	327	
17	333	313	329		341	329	
18	342	348	301		342	333	
19	345	323	317		324	327	
20	310	335	304		319	317	
21	346	325	322			331	
22	330	327	289			315	
23	299	331	296			309	
24	331	346	331			336	
25	292	285	326			301	
average	334.20	341.04	319.52	348.33	334.25	335	ml/min
						333	scfm
						334	
						0.0000657	m <sup>3</sup> /s
							(scf/m)(60s/min)(1000000 cc/meter <sup>3</sup> )

Volatiles Result

Date	Inlet Concentration	Outlet concentration	Diff
22-Nov-06	1620	1	1619
24-Nov-06	1800	1	1799
25-Nov-06	1830	1	1829
26-Nov-06	1680	1	1679
27-Nov-06	1640	1	1639
28-Nov-06	1540	1	1539
average	1685	1	1684
%RSD=	6.59		
	g/m <sup>3</sup> =	(µg/l)/(g/1,000,000 µg)(1000 l/m <sup>3</sup> )	
	1.685	g/m <sup>3</sup>	0.001 g/m <sup>3</sup>
			1.684 g/m <sup>3</sup>

note that the MDL was used for the outlet concentration.

## Vent Concentration

25-Nov-06	ppbv	1.01	0611031-09		
26-Nov-06	ppbv	1.31	0611031-13	RSD =	14.42
27-Nov-06	ppbv	1.37	0611035-06		
28-Nov-06	ppbv	1.09	0611035-07		
		1.195000 average			
ppbv = 1 liter/10 <sup>9</sup> liters					
$\text{g/m}^3 = (1 \text{ liter benzene}/10^9 \text{ liters sample})(78\text{g}/(22.4(299/273)))(1000/\text{m}^3)(1\text{liter benzene}/10^9 \text{ l ppbv})$					
		g/m <sup>3</sup> = 3.79932E-06			

---

---

---

---

---

---

---

---

---

---

## Biology Measurements

- ❖ *P. Putida* commercial strain – no degradation.
- ❖ Special sub-strain, F1, obtained from Ga. Tech.
- ❖ Growth in TSA. None in MSA.
- ❖ Benzene atmosphere provided – carbon source.
- ❖ Other compounds - competition/inhibition.

### Acknowledgements

Elizabeth Cannon, EPA Toxics Enforcement Section, Dallas

Mark Rodgers, EPA ORD, Cincinnati

Abel Euresiti, EPA Region 6 Lab, Houston

---

---

---

---

---

---

---

---

---

---

## Calculations ....




---

---

---

---

---

---

---

---

---

---





## Projected

- Variety of positive & negative systems controls.
- Adjusting for non-zero effluent concentrations.
- Addition of vacuum controller for recirculation.  
or
- Use of injected air/O<sub>2</sub> only (to conform with unit changes).
- Use of mobile lab for real time analyses at unit w/hot work permit.



---

---

---

---

---

---

---

---

## On-site Sampling & Analysis



---

---

---

---

---

---

---

---

## Use of Site Specific Biorate to Model Fbio for a Full Scale System

- Use WATER9 to do the calculations in Appendix C.
  - WATER9 will calculate  $K_t$  based on system parameters
  - $K_t$  from the bioreactor is also an input
  - Consider additional factors for the full scale system with WATER9

---

---

---

---

---

---

---

---

### Flow diagram overview sketch



**SKETCH OF PROCESS**

---

---

---

---


---

---

---

---

### Flow diagram sketch with process information



**SKETCH OF PROCESS**

---

---

---

---


---

---

---

---

### WATER9 Flow diagram



---

---

---

---

---

---

---

---

## Special Considerations I

- Thoroughly Mixed Units
  - How to tell?
  - How to remodel?
  - What tools are available?
    - <http://www.epa.gov/ttn/atw/nsps/socww/socwwpg.html>

---

---

---

---

---

---

---

---

## Special Considerations II

- WATER9 Mixing Analysis
  - Hydraulic residence time is 18 hours
  - Air stripping half life is 14 minutes if quickly mixed
  - Time for both air and biological removal is 11 seconds if quickly mixed
  - Pump mixing time is 90 minutes
- Mixing tests
  - Feed bypassing
  - Tracer testing in full scale reactor

---

---

---

---


---

---

---

---

## Mixing Tracer Testing



---

---

---

---

---

---

---

---

## Special QA Procedures

- Laboratory reactor with no biomass
- Laboratory reactor with lower residence time (to enable measurement of reactor concentrations)
- Laboratory reactor with Henry's law constant verification
- Laboratory reactor with higher air purge rate (simulate higher mass transfer).
- Scale-up problems: volatiles rapidly lost in full scale system, no biological adjustment for those.

---

---

---

---

---

---

---

---

**Further Acknowledgments:** Rusty Herbert, Nghia Nguyen & Mel Ritter.

\*Bioflow 3000, which is shown and mentioned in this presentation, is a product name for the bench top bioreactor made by New Brunswick Scientific, Edison, N.J.

\*No endorsement, either implicit or explicit, is made by the Environmental Protection Agency, or the presenters, as to the usefulness, preference or applicability of any product mentioned in this presentation.



Questions?

---

---

---

---

---

---

---

---