

SITE: BCX Facility
BREAK: 11.1
OTHER: v. 4

**CEASE AND DESIST
CITATION
HM-01-34**

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

International Processing Specialists, Inc.
Attn.: Kurt Hollfelder
1859 East Adams Street
Jacksonville, Florida 32202

**RE: Duval County – Hazardous Materials
International Processing Specialists, Inc.
1903 East Adams Street, Jacksonville, FL 32202
Alleged violation(s) of petroleum storage system rules.**

PLEASE TAKE NOTICE that pursuant to Florida Statutes (FS) Chapter 403 and Jacksonville Ordinance Code Title X, Chapters 360 and 362, International Processing Specialists, Inc. is hereby notified that it is in violation of FS Chapter 403, Florida Administrative Code (FAC) Chapter 62-761, and Jacksonville Environmental Protection Board (JEPB) Rule 3.

Failure to meet performance standards for exterior coatings is a violation of FS §403.161(1)(b), FAC 62-761. 500(1)(b), and JEPB Rule 3.701 (which adopts and incorporates by reference FAC 62-761).

Failure to repair any component that has or could cause a discharge or release is a violation of FS §403.161(1)(b), FAC 62-761. 700(1)(a)1, and JEPB Rule 3.701 (which adopts and incorporates by reference FAC 62-761).

Failure to repair secondary containment in accordance with to 62-761.500(1)(e) is a violation of FS §403.161(1)(b), FAC 62-700(3)(e), and JEPB Rule 3.701 (which adopts and incorporates by reference FAC 62-761).

The violations were determined by staff of the Regulatory and Environmental Services Department from a file review and on site inspections which indicate that:

On or about March 27, 2001, International Processing Specialists, Inc., located at 1903 East Adams Street, Jacksonville, Florida 32202, failed to meet performance standards for exterior coatings.



10445688

International Processing Specialists, Inc.

Citation HM-01-34

Page 2

On or about March 27, 2001, International Processing Specialists, Inc., located at 1903 East Adams Street, Jacksonville, Florida 32202, failed to repair any component that has or could cause a discharge or release.

On or about March 27, 2001, International Processing Specialists, Inc., located at 1903 East Adams Street, Jacksonville, Florida 32202, failed to repair secondary containment.

CORRECTIVE ACTION REQUIRED

1. Cease the violation(s) of the petroleum storage system rules.
2. Respond to this Citation (in writing) within ten (10) calendar days from the date of receipt of this Citation.
3. Remove or abate the cause of the violation(s).
4. Contact Ms. Dana L. Brown at (904) 630-4900 immediately upon receipt of this Citation to arrange a conference to discuss the aforesaid violation(s).

FS §§ 403.121 and 403.182(8) and Jacksonville Ordinance Code § 362.110 each provides for a continuing maximum potential penalty of \$10,000 per day of violation. If litigation or an administrative hearing is required to achieve compliance, full penalties and recovery of legal fees will be sought.

DATED this _____ day of _____, 2001

City of Jacksonville
REGULATORY AND ENVIRONMENTAL
SERVICES DEPARTMENT

by:

Mario L. Taylor, Director

MLT/KL/

c: Mr. Tracey I. Arpen, Jr., OGC
Mr. Marshall Mott-Smith, FDEP – Tallahassee
AWQD Enforcement File