

# ICR TREATMENT STUDY ANALYSIS

## Base Analysis and Data Review Comments

<b>Treatment Study ID</b>	4011
<b>Study Protocol</b>	Two-Stage Pilot-Scale Membrane Study
<b>Plant ICR Number</b>	283
<b>PWS Name</b>	City of Melbourne Water System
<b>City, State, Zip</b>	Melbourne, FL 32934

### General Comments:

1. This study was grandfathered into the ICR, and therefore does not meet all of the specific requirements listed in the ICR and rule-by-reference manuals. This pilot-scale study (study ID 4011) was conducted in conjunction with a pilot-scale study (study ID 4111) and a single-element study (study ID 4211). This study was part of a larger study conducted by the University of Central Florida for the USEPA Risk Reduction Engineering Laboratory, published in a report entitled “*Reduction of Disinfection By-Product Precursors by Nanofiltration*” in April 1992 (EPA/600/SR-92/023).
2. The TriSep TS80 TSA (formerly known as the Dupont A15S) was evaluated during this study, using a surface water source with an average TOC of 20 mg/L. Due to the nature of this raw water source, advanced membrane pretreatment was needed. The resulting integrated membrane system included the following pretreatments: coagulation, sedimentation, rapid sand filtration, pH reduction, and microfiltration. A schematic of the integrated membrane system, including the 4-2 staged array nanofiltration system, is shown in Figure 2 of the Summary Report (Part 1)
3. This system was operated from July 1990 through February 1991; however, treatment study data was only collected during the first 185 days of operation, resulting in seven sets of water quality data.
4. Section 1 of the Summary Report (Part 1) lists the significant conclusions and recommendations from this study.
5. Cost information is provided in Section 4 and Tables 15 and 16 of the Summary Report (Part 1).

## **Water Quality Comments:**

1. Three water quality outliers were identified and removed prior to base analysis.
2. The reported target SDS conditions during this study were to dose and incubate the samples at 22°C, for 96 hours at a pH of 7.6, with a target residual of 0.2 mg/L. However, the chlorination procedure was more similar to a Formation Potential test, than a SDS test, since only a measurable residual (i.e., above 0.2 mg/L) after 96 hours was necessary for DBPs to be analyzed from that sample. No measured residuals were reported during this study – only the presence of a residual.
3. The following parameters were not measured during this study: ammonia, UV<sub>254</sub>, bromide, and BCAA (thus HAA6).

## **Productivity Comments:**

1. Twenty productivity outliers were identified and removed prior to base analysis.
2. This membrane system was operated between 10 and 15 gfd, at recoveries ranging from 45 to 65%. The experimental design for this study (denoted as the AC-A15S) is listed in Table 7 (Part 1).
3. The membrane system was cleaned every 2 to 4 weeks, as needed, with a phosphate detergent and NaOH solution.
4. New membranes were installed after 73 days of operation, resulting in an ~ 80% increase in the temperature normalized MTCw. Due to this significant change in performance, only productivity data from the period of operation with the new membranes was considered during this analysis.
5. During productivity analysis, the average slope and cleaning interval were calculated to be  $-2.49 \times 10^{-3}$  gfd/psi/day and 35 days, respectively. This slope is similar to the average slope and reported by the researchers:  $-3.63 \times 10^{-3}$  gfd/psi/day (the cleaning interval calculated from this slope is 29 days).

## ICR Information

ID / ICR#: FL3051447 / 283  
 ICR Contact: Mr. Ralph Sigman  
 Phone No.: (407) 255-4623  
 Period: 7/4/90 - 8/27/97 (2611 days)

## Membrane Information

Manufacturer: Trisep  
 Trade Name: TS80  
 Membrane Model: 4040 TS80 TSA  
 MWCO: 200 - 300 Daltons  
 Element Size: 4" X 40"  
 Element Area: 92.0 ft<sup>2</sup>  
 Design Flux: 22.7 gfd  
 Mfr. NDP: 105.0 psi  
 Mfr. MTC<sub>w</sub>: 0.216 (gfd/psi)  
 Mfr. Temp: 25.0 °C  
 Maximum Flow: 20.0 gpm  
 Minimum Flow: 7.0 gpm  
 Total Width : 14.0 ft  
 Feed Spacer Thickness: 0.0023 ft  
 840 Element Area 360.0 ft<sup>2</sup>  
 840 Purchase Price: 750 - 900

## Design Parameters

Norm Temp: 24.5 °C  
 Temp Norm MTC-w: 0.213 TavGC  
 Design Recovery: 0.65  
 Avg Sys Flux F<sub>w</sub>: 15.0 gfd  
 # of Elem in P.V.: 3  
 # Pres Ves in Stg 1: 2  
 # Pres Ves in Stg 2: 1  
 Pres Ves in Stg 3: NA  
 Design Flux: 15.0 gfd  
 Recycle Ratio: 0.00  
 Osmotic P Stage 1: 3.0 psi  
 Osmotic P Stage 2: 6.0 psi  
 Osmotic P Stage 3: NA

## Water Quality Summary

Feed (System)					Permeate (System)				Concentrate (System)							
Summary	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max				
pH	6.3	0.8	2	5.7 - 6.8	5.9	0.4	2	5.6 - 6.1	5.8	0.1	2	5.7 - 5.9				
Temp	28.6	0.4	2	28.3 - 28.9	28.6	0.4	2	28.3 - 28.9	28.6	0.4	2	28.3 - 28.9				
Alk	67	13	2	57 - 76	10	8	2	4 - 16	58	1	2	57 - 58				
TDS	530	14	2	520 - 540	42	5	2	38 - 45	995	7	2	990 - 1000				
TotHard	220	0	2	220 - 220	8	1	2	7 - 9	405	7	2	400 - 410				
CaHard	180	14	2	170 - 190	7	1	2	6 - 8	325	7	2	320 - 330				
Turb	1.55	1.9	2	0.20 - 2.90	0.23	0.2	2	0.06 - 0.40	0.77	0.2	2	0.63 - 0.90				
Amm	NA	NA	0	NA	NA	NA	0	NA	NA	NA	0	0.0 - 0.0				
TOC	8.4	2.3	2	6.8 - 10.0	0.4	0.2	2	0.3 - 0.6	18.0	1.4	2	17.0 - 19.0				
UV254	NA	NA	0	0.000 - 0.000	NA	NA	0	0.000 - 0.000	NA	NA	0	0.000 - 0.000				
SUVA	NA	NA	0	NA	NA	NA	0	NA	NA	NA	0	NA				
Bromide	NA	NA	0	0 - 0	NA	NA	0	0 - 0								
TOX	1135	375	2	870 - 1400	49	17	2	37 - 61	Mass Balance Closure Errors (%)							
CHCl3	180.0	127.3	2	90.0 - 270.0	3.0	4.2	2	0.0 - 6.0								
BDCM	114.5	36.1	2	89.0 - 140.0	4.5	2.1	2	3.0 - 6.0	WQP	Count	Avg	SD/RD				
DBCM	50.5	6.4	2	46.0 - 55.0	3.0	1.4	2	2.0 - 4.0	Alk	2	-88	26				
CHBr3	4.0	5.7	2	0.0 - 8.0	0.0	0.0	2	0.0 - 0.0	TDS	2	11	4				
THM4	349.0	151.3	2	242.0 - 456.0	10.5	7.8	2	5.0 - 16.0	TotHard	2	7	3				
MCAA	9.0	1.4	2	8.0 - 10.0	0.0	0.0	2	0.0 - 0.0	CaHard	2	6	6				
DCAA	94.5	36.1	2	69.0 - 120.0	3.0	1.4	2	2.0 - 4.0	Turb	2	-191	244				
TCAA	105.0	77.8	2	50.0 - 160.0	1.0	1.4	2	0.0 - 2.0	Amm	0	n/a	n/a				
MBAA	2.0	0.0	2	2.0 - 2.0	0.0	0.0	2	0.0 - 0.0	TOC	1	42	n/a				
DBAA	15.0	0.0	2	15.0 - 15.0	4.5	6.4	2	0.0 - 9.0	UV254	0	n/a	n/a				
BCAA	NA	NA	0	NA	NA	NA	0	NA	TDS <sub>t</sub>	1	7	#DIV/0!				
TBAA	NA	NA	0	NA	NA	NA	0	NA	Comments:							
CDBAA	NA	NA	0	NA	NA	NA	0	NA								
DCBAA	NA	NA	0	NA	NA	NA	0	NA								
HAA5	225.5	115.3	2	144.0 - 307.0	8.5	9.2	2	2.0 - 15.0								
HAA6	NA	NA	0	NA	NA	NA	0	NA	Pretreatment Information							
HAA9	NA	NA	0	NA	NA	NA	0	NA								
SDS Conditions																
WQP	Avg	SD	Count	Min - Max	Process	Description	Scale									
Res (0)	0.20	0.00	4	0.20 - 0.20	Alum Coagulation	Aluminum Sulfate dose: 151.4 mg/L	Full-scale									
Temp (°C)	22.0	0.0	4	22.0 - 22.0	Sedimentation	Circular Clarifier	Full-scale									
pH (unit)	7.6	0.0	4	7.6 - 7.6	Rapid Sand Filtration	Sand/anthracite	Full-scale									
Time (hr)	96.0	0.0	4	96.0 - 96.0	Sulfuric Acid Feed	Approx. 85 mg/L to pH 3.5 to 4.5	Pilot-scale									
					Microfiltration	5um Filter Specialists Bag filter	Pilot-scale									

## Mass Balance Errors

Pressure	RPD	SD	Flow	RPD	SD	TDS	RPD	SD
System Inf - Stg 1 Inf	0.0%	0.0%	System Inf - Stg 1 Inf	-0.2%	1.1%	System Inf - Stg 1 Inf	0.0%	0.0%
Sys Conc - Stg 2 Conc	0.1%	1.4%	Sys Conc - Stg 2 Conc	0.0%	0.0%	Sys Conc - Stg 2 Conc	0.0%	0.0%
Stg 1 Conc - Stg 2 Inf	0.0%	0.0%	Stg 1 Conc - Stg 2 Inf	0.0%	0.6%	Stg 1 Conc - Stg 2 Inf	0.0%	0.0%
Sys Perm - Avg Stg Perm	9.7%	4.2%	Sys Perm - Sum Stg Per	-0.3%	1.8%	Sys Perm - Avg Stg Perm	-18.9%	11.8%

## Stage Summary

WQP	Stage 1 Influent						Stage 1 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			0.30	0.02	2	0.28 - 0.31					
pH	6.3	5.8	6.3	0.8	2	5.7 - 6.8	5.9	6.3	0.8	2	5.7 - 6.8
Temp	28.6	28.6	28.6	0.4	2	28.3 - 28.9	28.6	28.6	0.4	2	28.3 - 28.9
Alk	67	58	67	13	2	57 - 76	10	36	43	2	5 - 66
TDS	530	995	530	14	2	520 - 540	42	47	13	2	38 - 56
TotHard	220	405	220	0	2	220 - 220	8	17	13	2	7 - 26
CaHard	180	325	180	14	2	170 - 190	7	27	30	2	5 - 48
Turb	1.55	0.77	1.55	2	2	0.20 - 2.90	0.23	0.29	0.30	2	0 - 1
TOC	8.4	18.0	8.4	2.3	2	6.8 - 10.0	0.4	0.4	0.2	2	0.3 - 0.5
UV254	NA	NA	NA	NA	0	0.000 - 0.000	NA	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	NA	NA	0	NA	NA	NA	NA	0	NA

WQP	Stage 2 Influent						Stage 2 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			0.23	0.01	2	0.22 - 0.23					
pH	6.3	5.8	5.4	1.3	2	4.5 - 6.3	5.9	6.2	0.2	2	6.0 - 6.3
Temp	28.6	28.6	28.6	0.4	2	28.3 - 28.9	28.6	28.6	0.4	2	28.3 - 28.9
Alk	67	58	10	14	2	0 - 20	10	14	1	2	13 - 15
TDS	530	995	755	7	2	750 - 760	42	53	13	2	44 - 62
TotHard	220	405	300	14	2	290 - 310	8	7	1	2	6 - 8
CaHard	180	325	260	28	2	240 - 280	7	8	1	2	7 - 9
Turb	1.55	0.77	0.73	1	2	0.25 - 1.20	0.23	0.45	0.49	2	0 - 1
TOC	8.4	18.0	12.5	0.7	2	12.0 - 13.0	0.4	0.4	0.2	2	0.3 - 0.5
UV254	NA	NA	NA	NA	0	0.000 - 0.000	NA	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	NA	NA	0.00	NA	NA	NA	NA	0.00	NA


WQP	Stage 3 Influent						Stage 3 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery											
pH											
Temp											
Alk											
TDS											
TotHard											
CaHard											
Turb											
TOC											
UV254											
SUVA											

This was only a two stage study.












## Chart Legend:

- Feed (System)
- Permeate (System)


## Water Quality Parameter Graphs



## Water Quality Graphs (Continued)



## Productivity Graphs



## ICR Information

ID / ICR#: FL3051447 / 283  
 ICR Contact: Mr. Ralph Sigman  
 Phone No.: (407) 255-4623  
 Period: 9/13/90 - 11/21/90 (69 days)

## Membrane Information

Manufacturer: Trisep  
 Trade Name: TS80  
 Membrane Model: 4040 TS80 TSA  
 MWCO: 200 - 300 Daltons  
 Element Size: 4" X 40"  
 Element Area: 92.0 ft<sup>2</sup>  
 Design Flux: 22.7 gfd  
 Mfr. NDP: 105.0 psi  
 Mfr. MTC<sub>w</sub>: 0.216 (gfd/psi)  
 Mfr. Temp: 25.0 °C  
 Maximum Flow: 20.0 gpm  
 Minimum Flow: 7.0 gpm  
 Total Width : 14.0 ft  
 Feed Spacer Thickness: 0.0023 ft  
 840 Element Area 360.0 ft<sup>2</sup>  
 840 Purchase Price: 750 - 900

## Design Parameters

Norm Temp: 24.5 °C  
 Temp Norm MTC-w: 0.213 TavGC  
 Design Recovery: 0.65  
 Avg Sys Flux F<sub>w</sub>: 15.0 gfd  
 # of Elem in P.V.: 3  
 # Pres Ves in Stg 1: 2  
 # Pres Ves in Stg 2: 1  
 Pres Ves in Stg 3: NA  
 Design Flux: 15.0 gfd  
 Recycle Ratio: 0.00  
 Osmotic P Stage 1: 3.0 psi  
 Osmotic P Stage 2: 6.0 psi  
 Osmotic P Stage 3: NA

## Water Quality Summary

Feed (System)					Permeate (System)				Concentrate (System)							
Summary	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max				
pH	4.5	1.2	3	3.8 - 5.9	4.7	2.0	3	3.5 - 7.0	3.9	1.5	3	2.9 - 5.6				
Temp	27.2	2.4	3	24.4 - 28.9	27.2	2.4	3	24.4 - 28.9	27.2	2.4	3	24.4 - 28.9				
Alk	75	16	2	63 - 86	0	0	2	0 - 0	3	5	3	0 - 9				
TDS	423	72	3	340 - 470	120	10	3	110 - 130	970	113	3	900 - 1100				
TotHard	187	15	3	170 - 200	44	41	3	20 - 91	430	62	3	380 - 500				
CaHard	144	49	3	92 - 190	39	45	3	7 - 90	353	59	3	310 - 420				
Turb	0.17	0.0	3	0.13 - 0.21	0.09	0.2	3	0.00 - 0.27	0.14	0.0	3	0.11 - 0.18				
Amm	NA	NA	0	NA	NA	NA	0	NA	NA	NA	0	0.0 - 0.0				
TOC	7.7	0.9	3	6.7 - 8.4	0.3	0.0	3	0.3 - 0.3	19.3	5.0	3	14.0 - 24.0				
UV254	NA	NA	0	0.000 - 0.000	NA	NA	0	0.000 - 0.000	NA	NA	0	0.000 - 0.000				
SUVA	NA	NA	0	NA	NA	NA	0	NA	NA	NA	0	NA				
Bromide	NA	NA	0	0 - 0	NA	NA	0	0 - 0								
TOX	1267	208	3	1100 - 1500	54	19	3	33 - 69	Mass Balance Closure Errors (%)							
CHCl3	246.7	20.8	3	230.0 - 270.0	5.0	1.0	3	4.0 - 6.0								
BDCM	100.7	9.0	3	92.0 - 110.0	9.7	3.8	3	7.0 - 14.0	WQP	Count	Avg	SD/RD				
DBCM	30.3	3.8	3	26.0 - 33.0	8.0	3.0	3	5.0 - 11.0	Alk	0	n/a	n/a				
CHBr3	0.0	0.0	3	0.0 - 0.0	0.0	0.0	3	0.0 - 0.0	TDS	3	12	18				
THM4	377.7	27.4	3	348.0 - 402.0	22.7	7.6	3	16.0 - 31.0	TotHard	3	10	16				
MCAA	7.3	6.4	3	0.0 - 12.0	0.0	0.0	3	0.0 - 0.0	CaHard	3	20	43				
DCAA	120.0	17.3	3	110.0 - 140.0	3.3	1.2	3	2.0 - 4.0	Turb	1	152	n/a				
TCAA	126.7	20.8	3	110.0 - 150.0	1.7	0.6	3	1.0 - 2.0	Amm	0	n/a	n/a				
MBAA	0.0	0.0	3	0.0 - 0.0	0.0	0.0	3	0.0 - 0.0	TOC	0	n/a	n/a				
DBAA	10.7	8.6	3	3.0 - 20.0	8.3	6.1	3	3.0 - 15.0	UV254	0	n/a	n/a				
BCAA	NA	NA	0	NA	NA	NA	0	NA	TDS <sub>t</sub>	2	3	11				
TBAA	NA	NA	0	NA	NA	NA	0	NA	Comments:							
CDBAA	NA	NA	0	NA	NA	NA	0	NA								
DCBAA	NA	NA	0	NA	NA	NA	0	NA								
HAA5	264.7	49.7	3	233.0 - 322.0	13.3	7.5	3	6.0 - 21.0								
HAA6	NA	NA	0	NA	NA	NA	0	NA	Pretreatment Information							
HAA9	NA	NA	0	NA	NA	NA	0	NA								
SDS Conditions																
WQP	Avg	SD	Count	Min - Max	Process	Description	Scale									
Res (0)	0.20	0.00	6	0.20 - 0.20	Alum Coagulation	Aluminum Sulfate dose: 151.4 mg/L	Full-scale									
Temp (°C)	22.0	0.0	6	22.0 - 22.0	Sedimentation	Circular Clarifier	Full-scale									
pH (unit)	7.6	0.0	6	7.6 - 7.6	Rapid Sand Filtration	Sand/anthracite	Full-scale									
Time (hr)	96.0	0.0	6	96.0 - 96.0	Sulfuric Acid Feed	Approx. 85 mg/L to pH 3.5 to 4.5	Pilot-scale									
					Microfiltration	5um Filter Specialists Bag filter	Pilot-scale									

## Mass Balance Errors

Pressure	RPD	SD	Flow	RPD	SD	TDS	RPD	SD
System Inf - Stg 1 Inf	0.0%	0.0%	System Inf - Stg 1 Inf	0.0%	0.5%	System Inf - Stg 1 Inf	0.0%	0.0%
Sys Conc - Stg 2 Conc	0.0%	0.0%	Sys Conc - Stg 2 Conc	0.0%	0.0%	Sys Conc - Stg 2 Conc	0.0%	0.0%
Stg 1 Conc - Stg 2 Inf	0.0%	0.0%	Stg 1 Conc - Stg 2 Inf	0.1%	0.6%	Stg 1 Conc - Stg 2 Inf	0.0%	0.0%
Sys Perm - Avg Stg Perr	1.5%	1.2%	Sys Perm - Sum Stg Per	0.0%	1.3%	Sys Perm - Avg Stg Perm	20.0%	17.4%

## Stage Summary

	Stage 1 Influent						Stage 1 Permeate				
WQP	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			0.39	0.01	3	0.38 - 0.40					
pH	4.5	3.9	4.5	1.2	3	3.8 - 5.9	4.7	4.5	1.2	3	3.8 - 5.9
Temp	27.2	27.2	27.2	2.4	3	24.4 - 28.9	27.2	27.2	2.4	3	24.4 - 28.9
Alk	75	3	75	16	2	63 - 86	0	3	5	3	0 - 8
TDS	423	970	423	72	3	340 - 470	120	87	21	3	68 - 110
TotHard	187	430	187	15	3	170 - 200	44	18	5	3	14 - 23
CaHard	144	353	144	49	3	92 - 190	39	12	4	3	7 - 15
Turb	0.17	0.14	0.17	0	3	0.13 - 0.21	0.09	0.00	0.00	3	0 - 0
TOC	7.7	19.3	7.7	0.9	3	6.7 - 8.4	0.3	0.3	0.0	3	0.3 - 0.3
UV254	NA	NA	NA	NA	0	0.000 - 0.000	NA	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	NA	NA	0	NA	NA	NA	NA	0	NA

	Stage 2 Influent						Stage 2 Permeate				
WQP	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			0.32	0.02	3	0.31 - 0.34					
pH	4.5	3.9	4.2	1.4	3	3.1 - 5.8	4.7	4.4	1.1	3	3.6 - 5.7
Temp	27.2	27.2	27.2	2.4	3	24.4 - 28.9	27.2	27.2	2.4	3	24.4 - 28.9
Alk	75	3	3	6	3	0 - 10	0	2	4	3	0 - 7
TDS	423	970	677	55	3	640 - 740	120	111	19	3	93 - 130
TotHard	187	430	287	21	3	270 - 310	44	16	6	3	9 - 21
CaHard	144	353	243	49	3	210 - 300	39	15	6	3	9 - 20
Turb	0.17	0.14	0.10	0	3	0.10 - 0.11	0.09	0.02	0.03	3	0 - 0
TOC	7.7	19.3	12.0	1.7	3	10.0 - 13.0	0.3	0.3	0.0	3	0.3 - 0.3
UV254	NA	NA	NA	NA	0	0.000 - 0.000	NA	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	NA	NA	0.00	NA	NA	NA	NA	0.00	NA





  

	Stage 3 Influent						Stage 3 Permeate				
WQP	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery											
pH											
Temp											
Alk											
TDS											
TotHard											
CaHard											
Turb											
TOC											
UV254											
SUVA											

## Water Quality Parameter Graphs


## Chart Legend:

- Feed (System)
- ▲ Permeate (System)






## Water Quality Graphs (Continued)



## Productivity Graphs



## ICR Information

ID / ICR#: FL3051447 / 283  
 ICR Contact: Mr. Ralph Sigman  
 Phone No.: (407) 255-4623  
 Period: 11/22/90 - 2/2/91 (72 days)

## Membrane Information

Manufacturer: Trisep  
 Trade Name: TS80  
 Membrane Model: 4040 TS80 TSA  
 MWCO: 200 - 300 Daltons  
 Element Size: 4" X 40"  
 Element Area: 92.0 ft<sup>2</sup>  
 Design Flux: 22.7 gfd  
 Mfr. NDP: 105.0 psi  
 Mfr. MTC<sub>w</sub>: 0.216 (gfd/psi)  
 Mfr. Temp: 25.0 °C  
 Maximum Flow: 20.0 gpm  
 Minimum Flow: 7.0 gpm  
 Total Width : 14.0 ft  
 Feed Spacer Thickness: 0.0023 ft  
 840 Element Area 360.0 ft<sup>2</sup>  
 840 Purchase Price: 750 - 900

## Design Parameters

Norm Temp: 24.5 °C  
 Temp Norm MTC-w: 0.213 TavGC  
 Design Recovery: 0.65  
 Avg Sys Flux F<sub>w</sub>: 15.0 gfd  
 # of Elem in P.V.: 3  
 # Pres Ves in Stg 1: 2  
 # Pres Ves in Stg 2: 1  
 Pres Ves in Stg 3: NA  
 Design Flux: 15.0 gfd  
 Recycle Ratio: 0.00  
 Osmotic P Stage 1: 3.0 psi  
 Osmotic P Stage 2: 6.0 psi  
 Osmotic P Stage 3: NA

## Water Quality Summary

Summary	Feed (System)				Permeate (System)				Concentrate (System)			
	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max
pH	3.3	0.8	2	2.7 - 3.8	3.8	1.1	2	3.0 - 4.6	2.8	0.4	2	2.5 - 3.1
Temp	22.0	1.2	2	21.1 - 22.8	22.0	1.2	2	21.1 - 22.8	22.0	1.2	2	21.1 - 22.8
Alk	NA	NA	0	0 - 0	1	NA	1	1 - 1	0	0	2	0 - 0
TDS	430	42	2	400 - 460	66	13	2	56 - 75	650	28	2	630 - 670
TotHard	185	7	2	180 - 190	17	13	2	8 - 26	285	7	2	280 - 290
CaHard	146	6	2	142 - 150	14	11	2	6 - 22	225	7	2	220 - 230
Turb	0.15	0.0	2	0.11 - 0.18	0.03	0.0	2	0.00 - 0.06	0.06	0.1	2	0.00 - 0.12
Amm	NA	NA	0	NA	NA	NA	0	NA	NA	NA	0	0.0 - 0.0
TOC	8.5	1.1	2	7.7 - 9.2	0.3	0.0	2	0.3 - 0.3	13.0	1.4	2	12.0 - 14.0
UV254	NA	NA	0	0.000 - 0.000	NA	NA	0	0.000 - 0.000	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	0	NA	NA	NA	0	NA	NA	NA	0	NA
Bromide	NA	NA	0	0 - 0	NA	NA	0	0 - 0				
TOX	1370	99	2	1300 - 1440	65	41	2	36 - 94				
CHCl3	245.0	21.2	2	230.0 - 260.0	1.5	2.1	2	0.0 - 3.0	Mass Balance Closure Errors (%)			
BDCM	125.0	7.1	2	120.0 - 130.0	5.0	1.4	2	4.0 - 6.0				
DBCM	49.0	5.7	2	45.0 - 53.0	9.0	4.2	2	6.0 - 12.0	WQP	Count	Avg	SD/RD
CHBr3	7.5	10.6	2	0.0 - 15.0	9.0	5.7	2	5.0 - 13.0	Alk	0	n/a	n/a
THM4	426.5	2.1	2	425.0 - 428.0	24.5	13.4	2	15.0 - 34.0	TDS	2	49	47
MCAA	10.0	1.4	2	9.0 - 11.0	8.0	4.2	2	5.0 - 11.0	TotHard	2	47	54
DCAA	114.5	36.1	2	89.0 - 140.0	1.5	0.7	2	1.0 - 2.0	CaHard	2	50	51
TCAA	122.0	39.6	2	94.0 - 150.0	0.0	0.0	2	0.0 - 0.0	Turb	1	56	n/a
MBAA	0.0	0.0	2	0.0 - 0.0	1.0	1.4	2	0.0 - 2.0	Amm	0	n/a	n/a
DBAA	5.5	0.7	2	5.0 - 6.0	2.0	1.4	2	1.0 - 3.0	TOC	1	-5	n/a
BCAA	NA	NA	0	NA	NA	NA	0	NA	UV254	0	n/a	n/a
TBAA	NA	NA	0	NA	NA	NA	0	NA				
CDBAA	NA	NA	0	NA	NA	NA	0	NA	TDS <sub>t</sub>	1	2	#DIV/0!
DCBAA	NA	NA	0	NA	NA	NA	0	NA	Comments:			
HAA5	252.0	76.4	2	198.0 - 306.0	12.5	7.8	2	7.0 - 18.0				
HAA6	NA	NA	0	NA	NA	NA	0	NA				
HAA9	NA	NA	0	NA	NA	NA	0	NA				
SDS Conditions					Pretreatment Information							
WQP	Avg	SD	Count	Min - Max	Process		Description		Scale			
Res (0)	0.20	0.00	4	0.20 - 0.20	Alum Coagulation		Aluminum Sulfate dose: 151.4 mg/L		Full-scale			
Temp (°C)	22.0	0.0	4	22.0 - 22.0	Sedimentation		Circular Clarifier		Full-scale			
pH (unit)	7.6	0.0	4	7.6 - 7.6	Rapid Sand Filtration		Sand/anthracite		Full-scale			
Time (hr)	96.0	0.0	4	96.0 - 96.0	Sulfuric Acid Feed		Approx. 85 mg/L to pH 3.5 to 4.5		Pilot-scale			
					Microfiltration		5um Filter Specialists Bag filter		Pilot-scale			

## Mass Balance Errors

Pressure	RPD	SD	Flow	RPD	SD	TDS	RPD	SD
System Inf - Stg 1 Inf	0.0%	0.0%	System Inf - Stg 1 Inf	0.0%	0.3%	System Inf - Stg 1 Inf	0.0%	0.0%
Sys Conc - Stg 2 Conc	0.1%	0.6%	Sys Conc - Stg 2 Conc	0.0%	0.0%	Sys Conc - Stg 2 Conc	0.0%	0.0%
Stg 1 Conc - Stg 2 Inf	0.0%	0.0%	Stg 1 Conc - Stg 2 Inf	0.0%	0.0%	Stg 1 Conc - Stg 2 Inf	0.0%	0.0%
Sys Perm - Avg Stg Perm	6.9%	3.3%	Sys Perm - Sum Stg Per	0.0%	0.8%	Sys Perm - Avg Stg Perm	-25.1%	3.7%

## Stage Summary

WQP	Stage 1 Influent						Stage 1 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			<b>0.27</b>	<b>0.01</b>	<b>2</b>	<b>0.26 - 0.27</b>					
pH	3.3	2.8	3.3	0.8	2	2.7 - 3.8	3.8	3.3	0.8	2	2.7 - 3.8
Temp	22.0	22.0	22.0	1.2	2	21.1 - 22.8	22.0	22.0	1.2	2	21.1 - 22.8
Alk	NA	0	80	NA	1	80 - 80	1	0	0	2	0 - 0
<b>TDS</b>	<b>430</b>	<b>650</b>	430	<b>42</b>	<b>2</b>	<b>400 - 460</b>	<b>66</b>	<b>57</b>	<b>13</b>	<b>2</b>	<b>48 - 66</b>
TotHard	185	285	185	7	2	180 - 190	17	13	6	2	8 - 17
CaHard	146	225	146	6	2	142 - 150	14	10	7	2	5 - 15
Turb	0.15	0.06	0.15	0	2	0.11 - 0.18	0.03	0.03	0.04	2	0 - 0
<b>TOC</b>	<b>8.5</b>	<b>13.0</b>	8.5	<b>1.1</b>	<b>2</b>	<b>7.7 - 9.2</b>	<b>0.3</b>	<b>0.3</b>	<b>0.0</b>	<b>2</b>	<b>0.3 - 0.3</b>
UV254	NA	NA	NA	NA	0	0.000 - 0.000	NA	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	NA	NA	0	NA	NA	NA	NA	0	NA

WQP	Stage 2 Influent						Stage 2 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			<b>0.18</b>	<b>0.01</b>	<b>2</b>	<b>0.17 - 0.19</b>					
pH	3.3	2.8	2.9	0.5	2	2.5 - 3.2	3.8	3.5	0.3	2	3.3 - 3.7
Temp	22.0	22.0	22.0	1.2	2	21.1 - 22.8	22.0	22.0	1.2	2	21.1 - 22.8
Alk	NA	0	0	0	2	0 - 0	1	0	0	2	0 - 0
<b>TDS</b>	<b>430</b>	<b>650</b>	555	<b>21</b>	<b>2</b>	<b>540 - 570</b>	<b>66</b>	<b>111</b>	<b>41</b>	<b>2</b>	<b>82 - 140</b>
TotHard	185	285	235	7	2	230 - 240	17	28	26	2	<b>9 - 46</b>
CaHard	146	225	190	14	2	180 - 200	14	26	25	2	<b>8 - 44</b>
Turb	0.15	0.06	<b>0.04</b>	0	2	0.00 - 0.08	0.03	0.03	0.04	2	0 - 0
<b>TOC</b>	<b>8.5</b>	<b>13.0</b>	11.0	<b>1.4</b>	<b>2</b>	<b>10.0 - 12.0</b>	<b>0.3</b>	<b>0.3</b>	<b>0.0</b>	<b>2</b>	<b>0.3 - 0.3</b>
UV254	NA	NA	NA	NA	0	0.000 - 0.000	NA	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	NA	NA	0.00	NA	NA	NA	NA	0.00	NA





WQP	Stage 3 Influent						Stage 3 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery											
pH											
Temp											
Alk											
<b>TDS</b>											
TotHard											
CaHard											
Turb											
<b>TOC</b>											
UV254											
SUVA											

This was **only** a two stage study.


## Water Quality Parameter Graphs

## Chart Legend:

- Feed (System)
- ▲ Permeate (System)



## Water Quality Graphs (Continued)



## Productivity Graphs

