

ICR TREATMENT STUDY ANALYSIS

Base Analysis and Data Review Comments

Treatment Study ID	4005
Study Protocol	Pilot-Scale Membrane Study
Plant ICR Number	685
PWS Name	Fairfax County Water Authority
City, State, Zip	Herndon, VA 20170

General Comments:

1. This study was grandfathered into the ICR, and therefore does not meet all of the specific requirements listed in the ICR and rule-by-reference manuals. This pilot-scale study (study ID 4005) was conducted in conjunction with a single element study (study ID 4006). Both studies were conducted during the period of September 1995 through June 1996.
2. During this pilot-scale study, the FilmTec NF70 was evaluated over a two-month period for a total of 1200 hours.
3. Microfiltration, acid addition and scale control served as pretreatment to the nanofiltration system. The Summary Report contains additional performance data for the microfiltration system.
4. No cost information is provided in the Summary Report.

Water Quality Comments:

1. Two water quality outliers were identified and removed prior to base analysis.
2. SDS conditions are summarized in Table 7 of the Summary Report. All SDS conditions remained constant over the course of the pilot-scale study: the target free chlorine residual was 1.0 mg/L; the pH was 7.5; the incubation time was 72 hours; and the incubation temperature was 19°C.
3. The following parameters were not measured during this study: calcium hardness, ammonia, bromide, and TOX. Feed water bromide was measured during the single element study (4006) and the average concentration was 30 µg/L.

Productivity Comments:

1. The nanofiltration membrane was cleaned using a 0.5% NaOH solution heated to 40°C. Cleanings were performed after a 20% decline in the temperature-normalized specific flux.
2. During the study, the rate of fouling was observed to vary inversely with the flux rate, i.e., lower fluxes resulted in longer cleaning intervals.
3. During EPA data analysis the sustained specific flux and flux was calculated as 0.273 ± 0.036 gfd/psi and 16.42 ± 1.49 gfd, respectively. The corresponding projected cleaning interval for this study was 21 days, which compares well to that projected by the consultant, of 28 days.

ICR Information

ID / ICR#: VA6059501 / 685
 ICR Contact: Ms. Jeanne Bailey
 Phone No.: 703-404-5048
 Period: 4/7/92 - 5/31/92 (54 days)

Membrane Information

Manufacturer: FilmTec Corp.
 Trade Name: FilmTec NF70
 Membrane Model: NF70-4040
 MWCO: 200 Daltons
 Element Size: 4" x 40"
 Element Area: 72.2 ft²
 Design Flux: 25.0 gfd
 Mfr. NDP: 70.0 psi
 Mfr. MTC_w: 0.357 (gfd/psi)
 Mfr. Temp: 25.0 °C
 Maximum Flow: 16.0 gpm
 Minimum Flow: 4.0 gpm
 Total Width: 12.0 ft
 Feed Spacer Thickness: 0.0028 ft
 840 Element Area: 400.0 ft²
 840 Purchase Price: \$600

Design Parameters

Norm Temp: 17.9 °C
 Temp Norm MTC-w: 0.290 TavGC
 Design Recovery: 0.85
 Avg Sys Flux F_w: 18.0 gfd
 # of Elem in P.V.: 6
 # Pres Ves in Stg 1: 2
 # Pres Ves in Stg 2: 1
 Pres Ves in Stg 3: NA
 Design Flux: 18.0 gfd
 Recycle Ratio: 0.00
 Osmotic P Stage 1: 1.4 psi
 Osmotic P Stage 2: 3.0 psi
 Osmotic P Stage 3: NA

Water Quality Summary

	Feed (System)				Permeate (System)				Concentrate (System)			
Summary	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max
pH	6.1	0.2	5	5.9 - 6.4	5.6	0.2	5	5.4 - 6.0	6.3	0.2	5	6.0 - 6.5
Temp	14.4	3.1	6	10.0 - 17.1	15.5	3.0	6	11.2 - 18.1	14.1	4.2	6	7.6 - 18.4
Alk	14	3	6	9 - 18	3	2	6	1 - 6	62	18	6	31 - 81
TDS	87	6	6	82 - 98	12	2	6	10 - 16	390	76	6	270 - 501
TotHard	65	15	6	49 - 83	22	15	6	1 - 46	248	58	6	145 - 308
CaHard	NA	NA	0	0 - 0	NA	NA	0	0 - 0	NA	NA	0	0 - 0
Turb	0.09	0.0	5	0.08 - 0.10	0.07	0.0	4	0.05 - 0.09	0.20	0.1	4	0.16 - 0.28
Amm	NA	NA	0	NA	NA	NA	0.00	NA	NA	NA	0	0.0 - 0.0
TOC	5.5	0.5	6	4.8 - 6.1	0.3	0.0	6	0.3 - 0.3	28.8	5.0	6	23.0 - 34.9
UV254	0.166	0.0	6	0.111 - 0.190	0.005	0.0	6	0.005 - 0.005	0.928	0.2	6	0.684 - 1.124
SUVA	3.04	0.37	6	2.31 - 3.40	1.80	0.00	6	1.80 - 1.80	3.29	0.80	6	2.72 - 4.89
Bromide	NA	NA	0	0 - 0	NA	NA	0	0 - 0				
TOX	NA	NA	0	0 - 0	NA	NA	0	0 - 0				
CHCl3	94.2	21.4	3	81.9 - 118.9	0.0	0.0	3	0.0 - 0.0	Mass Balance			
BDCM	12.4	3.5	3	8.3 - 14.4	0.0	0.0	3	0.0 - 0.0	Closure Errors (%)			
DBCM	0.0	0.0	3	0.0 - 0.0	0.0	0.0	3	0.0 - 0.0	WQP	Count	Avg	SD/RD
CHBr3	0.0	0.0	3	0.0 - 0.0	0.0	0.0	3	0.0 - 0.0	Alk	6	-10	12
THM4	106.6	17.8	3	96.3 - 127.2	0.0	0.0	3	0.0 - 0.0	TDS	6	-16	12
MCAA	3.0	0.0	3	3.0 - 3.0	0.0	0.0	3	0.0 - 0.0	TotHard	6	-10	15
DCAA	49.0	12.1	3	42.0 - 63.0	1.0	0.0	3	1.0 - 1.0	CaHard	0	n/a	n/a
TCAA	66.0	5.2	3	63.0 - 72.0	0.7	0.6	3	0.0 - 1.0	Turb	4	-5	52
MBAA	0.0	0.0	3	0.0 - 0.0	0.0	0.0	3	0.0 - 0.0	Amm	0	n/a	n/a
DBAA	5.3	4.6	3	0.0 - 8.0	0.0	0.0	3	0.0 - 0.0	TOC	0	n/a	n/a
BCAA	4.0	1.7	3	2.0 - 5.0	0.0	0.0	3	0.0 - 0.0	UV254	5	-4	9
TBAA	NA	NA	0	NA	NA	NA	0	NA				
CDBAA	NA	NA	0	NA	NA	NA	0	NA	TDS _t	48	-13	12
DCBAA	NA	NA	0	NA	NA	NA	0	NA	Comments:			
HAA5	123.3	12.7	3	116.0 - 138.0	1.7	0.6	3	1.0 - 2.0				
HAA6	127.3	11.0	3	121.0 - 140.0	1.7	0.6	3	1.0 - 2.0				
HAA9	NA	NA	0	NA	NA	NA	0	NA				
SDS Conditions					Pretreatment Information							
WQP	Avg	SD	Count	Min - Max	Process		Description		Scale			
Res (1)	0.68	0.34	6	0.04 - 1.03	Microfiltration		0.2 micron nominal pore size		pilot-scale			
Temp (°C)	19.0	0.0	6	19.0 - 19.0	Sulfuric acid addition		pH = 6.0		Pilot-scale			
pH (unit)	7.5	0.0	6	7.5 - 7.5	Cartridge filtration		5 um nominal pore size		pilot-scale			
Time (hr)	72.0	0.0	6	72.0 - 72.0								

Mass Balance Errors

Pressure	RPD	SD	Flow	RPD	SD	TDS	RPD	SD
System Inf - Stg 1 Inf	0.0%	0.0%	System Inf - Stg 1 Inf	0.0%	0.0%	System Inf - Stg 1 Inf	0.0%	0.0%
Sys Conc - Stg 2 Conc	0.0%	0.0%	Sys Conc - Stg 2 Conc	0.0%	0.0%	Sys Conc - Stg 2 Conc	0.0%	0.0%
Stg 1 Conc - Stg 2 Inf	0.0%	0.0%	Stg 1 Conc - Stg 2 Inf	0.0%	0.0%	Stg 1 Conc - Stg 2 Inf	0.0%	0.0%
Sys Perm - Avg Stg Perm	-14.7%	40.2%	Sys Perm - Sum Stg Per	0.0%	0.0%	Sys Perm - Avg Stg Perm	-17.1%	6.4%

Stage Summary


WQP	Stage 1 Influent						Stage 1 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			0.59	0.02	6	0.56 - 0.62					
pH	6.1	6.3	6.0	0.3	5	5.7 - 6.4	5.6	NA	NA	0	0.0 - 0.0
Temp	14.4	14.1	14.6	3.2	6	10.0 - 17.1	15.5	NA	NA	0	0.0 - 0.0
Alk	14	62	14	3	6	9 - 18	3	NA	NA	0	0 - 0
TDS	87	390	87	6	6	82 - 98	12	9	1	6	8 - 12
TotHard	65	248	67	18	5	49 - 86	22	NA	NA	0	0 - 0
CaHard	NA	NA	NA	NA	0	0 - 0	NA	NA	NA	0	0 - 0
Turb	0.09	0.20	0.10	0	5	0.08 - 0.12	0.07	NA	NA	0	0 - 0
TOC	5.5	28.8	5.5	0.5	6	4.8 - 6.1	0.3	NA	NA	0	0.0 - 0.0
UV254	0.166	0.928	0.166	0.028	6	0.111 - 0.190	0.005	0.005	0.000	6	0.005 - 0.005
SUVA	3.04	3.29	3.04	0.37	6	2.31 - 3.40	1.80	NA	NA	0	NA
WQP	Stage 2 Influent						Stage 2 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			0.56	0.04	6	0.49 - 0.60					
pH	6.1	6.3	6.3	0.1	5	6.1 - 6.4	5.6	NA	NA	0	0.0 - 0.0
Temp	14.4	14.1	15.6	3.0	6	11.4 - 18.2	15.5	NA	NA	0	0.0 - 0.0
Alk	14	62	30	7	6	20 - 37	3	NA	NA	0	0 - 0
TDS	87	390	189	18	6	164 - 219	12	19	4	6	15 - 26
TotHard	65	248	143	24	6	116 - 173	22	NA	NA	0	0 - 0
CaHard	NA	NA	NA	NA	0	0 - 0	NA	NA	NA	0	0 - 0
Turb	0.09	0.20	0.14	0	5	0.12 - 0.17	0.07	NA	NA	0	0 - 0
TOC	5.5	28.8	12.1	2.2	6	9.5 - 14.6	0.3	0.3	NA	1	0.3 - 0.3
UV254	0.166	0.928	0.403	0.066	6	0.284 - 0.471	0.005	0.005	0.000	6	0.005 - 0.005
SUVA	3.04	3.29	3.36	0.43	6.00	2.99 - 4.02	1.80	NA	NA	1.00	NA
WQP	Stage 3 Influent						Stage 3 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery											
pH											
Temp											
Alk											
TDS											
TotHard											
CaHard											
Turb											
TOC											
UV254											
SUVA											

This was only a two stage study.


Chart Legend:

- Feed (System)
- Permeate (System)

Water Quality Parameter Graphs



Water Quality Graphs (Continued)



Productivity Graphs

