

ICR TREATMENT STUDY ANALYSIS

Base Analysis and Data Review Comments

Treatment Study ID	1054
Study Protocol	Membrane RBSMT treatment study
Plant ICR Number	294
PWS Name	Broward County, District 1A WTP
City, State, Zip	Pompano Beach, FL 33069

General Comments:

1. During this bench-scale study, three membranes were evaluated: the Koch-Fluid Systems TFC-SR40, the Hydranautics NTR7450, and the FilmTec NF200B. The SR40 was evaluated over four quarters (Spring, Summer, Fall and Winter); the NF200 was evaluated over three quarters (Spring, Summer and Fall – however the Fall quarter of testing was incomplete); and the NTR7450 was evaluated over two quarters (Fall and Winter – however the Fall quarter of testing was abbreviated). The sampling and testing dates are summarized in Table 5 of the Summary Report.
2. During the third (Fall) quarter of testing, problems were encountered with the performance of the NF200B membrane. Increases in permeate flux were observed as the run progressed, accompanied by an increase in permeate TDS and UV concentrations. This was observed for two different NF200B membrane samples. These problems are summarized on pages 29 and 30 of the Summary Report. The third quarter run with the NF200B membrane was terminated and a new run with the NTR7450 was initiated; however, the NTR7450 was only evaluated at recoveries of 50% and 70% during the third quarter.
3. The only pretreatment applied to this groundwater (Biscayne aquifer) was cartridge filtration. Relatively loose membranes (i.e., low rejection of most inorganic salts) were used during this study. However, these membranes did reject calcium hardness in the range of 25 to 60%, and at high recoveries, this level of rejection may have resulted in concentration factors high enough to cause salt precipitation. Thus, the addition of acid or antiscalant to control inorganic scale formation may have resulted in longer cleaning intervals than those observed during this study.
4. Recovery was very erratic during the fourth quarter of testing (using the NTR7450 membrane).
5. In general, it appears that variability among membrane samples may have impacted the results for all three membranes investigated during this study. Interpretation of these results

should be made by evaluating the performance of a specific membrane over all quarters in which it was tested.

6. During analysis, a temperature of 26°C was used for productivity analysis during all four quarters. The average temperature for this source is reported as 26°C and varies between 25°C and 27°C.
7. No cost information was provided in the Summary Report.

Water Quality Comments:

1. 73 water quality outliers were identified and removed prior to base analysis. Most of these outliers were reported for the 70% recovery runs with the SR40 membrane. The concentrations of most water quality parameters reported during these runs were significantly lower than concentrations reported at other recoveries. The 70% recovery runs are always conducted first, so it is possible that the rejection characteristics of the membrane were not stable during this early period of operation. Water quality data reported for the other three recoveries evaluated (30%, 50% and 70%) was used to assess permeate water quality.
2. Constant SDS conditions were used throughout all four quarters: incubation temperature = 25°C; pH = 9.0; incubation time = 24 hours; and free residual = 1 mg/L. SDS time and temperature reported in the spreadsheet appear to be target values.
3. During testing with the SR40 membrane, a significant increase in permeate THMs, TOX and UV was observed during the third and fourth quarters of testing as compared to the first and second quarters. Corresponding changes in the permeate TOC and HAA levels were not observed.

Productivity Comments:

1. No productivity outliers were identified and removed prior to base analysis.
2. Severe flux loss was observed at 90% recovery during the fourth quarter of the TFC SR40 run. Summary Report indicates that this could be due to inorganic scale formation.
3. The standard membrane cleaning procedure utilized a sodium hydroxide solution (pH ≈ 12, at 40°C). When this cleaner was not effective, a sulfuric acid solutions (pH > 2.5) was also used. Additional information on membrane cleaning is given in Section 3 of the Summary Report.

ICR Information

ID / ICR#: 4060167 / 294
ICR Contact: Mr. Jerry Baker
Phone No.: (954) 960-3061
Period: 5/6/98 - 5/13/98 (7 days)

Membrane Information


Manufacturer: FilmTec Corporation
Trade Name: NF200B-400
MWCO: 200-400 Daltons
Mfr. Flux: 21.1 gfd
Mfr. NDP: 71.0 psi
Mfr. MTCw: 0.284 gfd/psi

Mfr. Temp: 25.0 °C
840 Element Area: 400.0 ft²
840 Purchase Price: \$800
840 Maximum Flow: 70.0 gpm
840 Minimum Flow: 16.0 gpm
840 Total Width: 70.5 ft
840 Feed Spacer Thickness: 0.0023 ft


Water Quality Summary

Source ->	Feed		Permeate				Concentrate				Mass Balance Closure Err (%)																														
Recovery ->	Avg	Diff	0.31	0.52	0.69	0.89	0.31	0.52	0.69	0.89	WQP	Count	Avg	SD																											
pH	8.3	0.2	8.4	8.3	8.3	8.3	8.8	8.8	8.7	8.8	TDS	16	0	8																											
Temp	24.0	0.0	23.0	23.0	23.0	23.0	23.0	23.0	23.0	23.0	Alk	4	30	7																											
Alk	191	25	160	184	177	188	262	284	320	354	TDS	4	-47	65																											
TDS	297	3	214	223	223	223	295	357	364	367	TotHard	4	32	16																											
TotHard	195	5	163	184	195	196	244	292	285	390	CaHard	4	50	38																											
CaHard	161	3	144	154	176	182	212	226	262	352	Turb	4	-618	517																											
Turb	0.96	0.01	0.09	0.12	0.15	0.13	0.43	0.42	0.42	0.52	Amm	0	n/a	n/a																											
Amm	0.00	NA	0.13	0.00	0.00	0.00	NA	NA	NA	0.00	TOC	4	7	27																											
TOC	14.4	NA	0.6	0.9	0.9	1.4	18.8	42.7	61.5	97.6	UV254	4	-4	46																											
UV254	0.523	0.048	0.016	0.026	0.023	0.038	0.742	1.446	2.270	2.600	<div>Pretreatment Information</div> <table><thead><tr><th>Process</th><th>Description</th><th>Scale</th></tr></thead><tbody><tr><td>Cartridge filtration</td><td>5 micron filter</td><td>bench</td></tr></tbody></table>				Process	Description	Scale	Cartridge filtration	5 micron filter	bench																					
Process	Description	Scale																																							
Cartridge filtration	5 micron filter	bench																																							
SUVA	#N/A	NA	2.67	2.89	2.56	2.71	3.95	3.39	3.69	2.66																															
Bromide	140	NA	120	120	120	120	<div>Design Parameters</div> <table><tr><td>Active memb area:</td><td>0.167 ft²</td><td rowspan="2">ID#</td><td rowspan="2">Recov (dec.)</td><td rowspan="2">F_{W-des} (gfd)</td></tr><tr><td>Active width:</td><td>0.330 ft</td></tr><tr><td>Norm Temp:</td><td>24.6 °C</td><td>1</td><td>0.70</td><td>15.0</td></tr><tr><td>Feed TDS:</td><td>300.0 mg/L</td><td>2</td><td>0.90</td><td>15.0</td></tr><tr><td>Manuf rep TDS rej:</td><td>50%</td><td>3</td><td>0.50</td><td>15.0</td></tr><tr><td>Temp Norm MTC-w:</td><td>0.281 gfd/psi</td><td>4</td><td>0.30</td><td>15.0</td></tr></table>								Active memb area:	0.167 ft ²	ID#	Recov (dec.)	F _{W-des} (gfd)	Active width:	0.330 ft	Norm Temp:	24.6 °C	1	0.70	15.0	Feed TDS:	300.0 mg/L	2	0.90	15.0	Manuf rep TDS rej:	50%	3	0.50	15.0	Temp Norm MTC-w:	0.281 gfd/psi	4	0.30	15.0
Active memb area:	0.167 ft ²	ID#	Recov (dec.)	F _{W-des} (gfd)																																					
Active width:	0.330 ft																																								
Norm Temp:	24.6 °C	1	0.70	15.0																																					
Feed TDS:	300.0 mg/L	2	0.90	15.0																																					
Manuf rep TDS rej:	50%	3	0.50	15.0																																					
Temp Norm MTC-w:	0.281 gfd/psi	4	0.30	15.0																																					
TOX	1300	NA	49	72	76	110																																			
CHCl3	490.0	NA	3.6	5.4	6.3	13.0																																			
BDCM	69.0	NA	7.8	13.0	13.0	23.0																																			
DBCM	7.1	NA	15.0	23.0	23.0	28.0																																			
CHBr3	0.0	NA	12.0	16.0	14.5	10.0																																			
THM4	566.1	NA	38.4	57.4	56.8	74.0																																			
MCAA	8.6	NA	0.0	0.0	0.0	2.2																																			
DCAA	120.0	NA	2.2	2.3	3.0	4.7																																			
TCAA	89.0	NA	0.0	0.0	0.0	2.7																																			
MBAA	1.0	NA	0.0	0.0	0.0	0.0																																			
DBAA	1.3	NA	4.4	6.3	6.1	6.3																																			
BCAA	16.0	NA	2.6	3.7	3.9	6.5																																			
TBAA	0.0	NA	0.0	4.1	0.0	0.0																																			
CDBAA	0.0	NA	3.0	3.7	4.1	5.2																																			
DCBAA	12.0	NA	1.6	2.1	2.6	5.0																																			
HAA5	219.9	NA	6.6	8.6	9.1	15.9																																			
HAA6	235.9	NA	9.2	12.3	13.0	22.4																																			
HAA9	247.9	NA	13.8	22.2	19.7	32.6																																			
SDS Conditions																																									
WQP	Avg	SD	Count	Min - Max																																					
Res (mg/L) (0)	2.07	0.75	6	1.23 - 3.12																																					
Temp (°C)	25.0	0.0	6	25.0 - 25.0																																					
pH (unit)	8.6	0.1	6	8.5 - 8.7																																					
Time (hr)	24.0	0.0	6	24.0 - 24.0																																					
Comments:																																									


Water Quality Parameter Graphs



Water Quality Parameter Graphs (Continued)



Productivity Graphs



ICR Information

ID / ICR#: 4060167 / 294
ICR Contact: Mr. Jerry Baker
Phone No.: (954) 960-3061
Period: 7/16/98 - 7/22/98 (6 days)

Membrane Information


Manufacturer: FilmTec Corporation
Trade Name: NF200B-400
MWCO: 200-400 Daltons
Mfr. Flux: 21.1 gfd
Mfr. NDP: 71.0 psi
Mfr. MTCw: 0.284 gfd/psi

Mfr. Temp: 25.0 °C
840 Element Area: 400.0 ft²
840 Purchase Price: \$800
840 Maximum Flow: 70.0 gpm
840 Minimum Flow: 16.0 gpm
840 Total Width: 70.5 ft
840 Feed Spacer Thickness: 0.0023 ft









Water Quality Summary

Source ->	Feed		Permeate				Concentrate				Mass Balance Closure Err (%)			
Recovery ->	Avg	Diff	0.30	0.50	0.67	0.91	0.30	0.50	0.67	0.91	WQP	Count	Avg	SD
pH	7.9	0.3	8.3	8.0	7.7	7.5	8.3	8.3	8.4	8.5	TDS	42	-16	28
Temp	24.0	0.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	Alk	4	-156	145
Alk	205	2	114	118	114	132	151	161	185	199	TDS	4	-19	18
TDS	317	2	250	260	258	288	332	338	381	422	TotHard	4	-52	54
TotHard	299	9	186	208	204	230	314	310	349	430	CaHard	4	-22	28
CaHard	256	4	172	196	191	216	282	302	329	406	Turb	4	-286	304
Turb	1.26	0.14	0.11	0.07	0.09	0.08	1.51	1.71	0.64	1.83	Amm	0	n/a	n/a
Amm	0.31	0.17	0.00	0.00	0.00	0.00	NA	NA	NA	NA	TOC	4	3	6
TOC	13.3	0.5	1.2	1.6	1.1	2.8	18.1	27.0	41.3	116.6	UV254	4	-20	19
UV254	0.635	0.030	0.042	0.051	0.024	0.106	0.837	1.172	1.520	4.100				
SUVA	4.77	0.05	3.50	3.19	2.24	3.79	4.62	4.34	3.68	3.52				
Bromide	150	0	140	150	150	150								
TOX	1435	5	88	115	68	235								
CHCl3	480.0	0.0	11.0	18.0	5.9	67.0								
BDCM	53.5	5.5	16.0	21.0	10.1	30.0								
DBCM	5.4	0.0	25.0	27.0	19.0	18.0								
CHBr3	0.0	0.0	16.0	11.0	15.5	2.6								
THM4	538.9	5.5	68.0	77.0	50.5	117.6								
MCAA	10.4	0.6	0.0	0.0	0.0	0.0								
DCAA	130.0	0.0	4.1	8.3	2.3	16.0								
TCAA	103.0	7.0	1.1	2.9	0.0	3.9								
MBAA	0.0	0.0	0.0	0.0	0.0	0.0								
DBAA	1.5	0.0	6.4	6.4	5.4	4.3								
BCAA	16.0	1.0	3.9	5.5	2.8	8.3								
TBAA	0.0	0.0	0.0	0.0	0.0	0.0								
CDBAA	0.0	0.0	0.0	2.0	0.0	0.0								
DCBAA	12.5	1.5	1.2	1.7	0.0	2.3								
HAA5	244.9	6.4	11.6	17.6	7.7	24.2								
HAA6	260.9	7.4	15.5	23.1	10.5	32.5								
HAA9	273.4	8.9	16.7	26.8	10.5	34.8								
SDS Conditions														
WQP	Avg	SD	Count	Min - Max										
Res (mg/L) (0)	1.21	0.40	6	0.59 - 1.80										
Temp (°C)	25.0	0.0	6	25.0 - 25.0										
pH (unit)	9.1	0.1	6	8.9 - 9.3										
Time (hr)	24.0	0.0	6	24.0 - 24.0										
Pretreatment Information														
Process			Description			Scale								
Cartridge filtration			5 micron filter			bench								
Design Parameters														
Active memb area:		0.167 ft ²				ID#		Recov (dec.)		F _{W-des} (gfd)				
Active width:		0.330 ft				1		0.70		15.0				
Norm Temp:		24.6 °C				2		0.90		15.0				
Feed TDS:		300.0 mg/L				3		0.50		15.0				
Manuf rep TDS rej:		50%				4		0.30		15.0				
Temp Norm MTC-w:		0.281 gfd/psi												
Comments:														


Water Quality Parameter Graphs



Water Quality Parameter Graphs (Continued)



Productivity Graphs



ICR Information

ID / ICR#: 4060167 / 294
ICR Contact: Mr. Jerry Baker
Phone No.: (954) 960-3061
Period: 12/1/98 - 12/4/98 (3 days)

Membrane Information


Manufacturer: FilmTec Corporation
Trade Name: NF200B-400
MWCO: 200-400 Daltons
Mfr. Flux: 21.1 gfd
Mfr. NDP: 71.0 psi
Mfr. MTCw: 0.284 gfd/psi

Mfr. Temp: 25.0 °C
840 Element Area: 400.0 ft²
840 Purchase Price: \$800
840 Maximum Flow: 70.0 gpm
840 Minimum Flow: 16.0 gpm
840 Total Width: 70.5 ft
840 Feed Spacer Thickness: 0.0023 ft


Water Quality Summary

Source ->	Feed	Diff	Permeate				Concentrate				Mass Balance Closure Err (%)			
Recovery ->	Avg		0.00	0.00	0.73	0.00	0.00	0.00	0.73	0.00	WQP	Count	Avg	SD
pH	8.0	0.4			8.0				8.2		TDS	30	-16	51
Temp	23.5	0.5			24.0				24.0					
Alk	421	15			NA				NA		Alk	0	n/a	n/a
TDS	280	2			244				336		TDS	1	-12	n/a
TotHard	217	3			NA				NA		TotHard	0	n/a	n/a
CaHard	205	1			NA				NA		CaHard	0	n/a	n/a
Turb	0.62	0.26			NA				NA		Turb	0	n/a	n/a
Amm	0.00	0.00			NA				NA		Amm	0	n/a	n/a
TOC	12.0	0.3			NA				NA		TOC	0	n/a	n/a
UV254	0.570	0.043			0.273				1.078		UV254	1	-27	n/a
SUVA	4.74	0.24	#####	#VALUE!	#N/A	#VALUE!			#####					
Bromide	140	0			NA						Pretreatment Information			
TOX	1095	25			NA						Process	Description	Scale	
CHCl3	405.0	45.0			NA						Cartridge filtration	5 micron filter	bench	
BDCM	52.0	7.0			NA									
DBCM	5.9	0.6			NA									
CHBr3	0.0	0.0			NA									
THM4	462.9	52.5	0.0	0.0	NA	0.0								
MCAA	5.5	0.1			NA									
DCAA	105.0	5.0			NA									
TCAA	96.5	13.5			NA									
MBAA	0.0	0.0			NA									
DBAA	1.6	0.2			NA									
BCAA	14.5	0.5			NA									
TBAA	0.0	NA			NA									
CDBAA	1.1	1.1			NA									
DCBAA	12.0	0.0			NA									
HAA5	208.5	18.7	0.0	0.0	NA	0.0								
HAA6	223.0	19.2	0.0	0.0	NA	0.0								
HAA9	215.8	NA	0.0	0.0	NA	0.0								
SDS Conditions														
WQP	Avg	SD	Count	Min - Max										
Res (mg/L) (0)	1.49	0.68	2	1.01 - 1.97										
Temp (°C)	25.0	0.0	2	25.0 - 25.0										
pH (unit)	8.9	0.1	2	8.8 - 9.0										
Time (hr)	24.0	0.0	2	24.0 - 24.0										
Design Parameters														
Active memb area: 0.167 ft ²														
Active width: 0.330 ft														
Norm Temp: 24.6 °C														
Feed TDS: 300.0 mg/L														
Manuf rep TDS rej: 50%														
Temp Norm MTC-w: 0.281 gfd/psi														
Comments:														


Water Quality Parameter Graphs



Water Quality Parameter Graphs (Continued)



Productivity Graphs



ICR Information

ID / ICR#: 4060167 / 294
ICR Contact: Mr. Jerry Baker
Phone No.: (954) 960-3061
Period: 12/8/98 - 12/10/98 (2 days)

Membrane Information


Manufacturer: Hydranautics Corp., San Diego, CA
Trade Name: NTR7450
MWCO: 1,000 Da Daltons
Mfr. Flux: 45.0 gfd
Mfr. NDP: 140.0 psi
Mfr. MTCw: 0.320 gfd/psi

Mfr. Temp: 25.0 °C
840 Element Area: 365.0 ft²
840 Purchase Price: \$800
840 Maximum Flow: 75.0 gpm
840 Minimum Flow: 25.0 gpm
840 Total Width: 64.4 ft
840 Feed Spacer Thickness: 0.0023 ft


Water Quality Summary

Source ->	Feed		Permeate				Concentrate				Mass Balance Closure Err (%)			
Recovery ->	Avg	Diff	0.00	0.50	0.72	0.00	0.00	0.50	0.72	0.00	WQP	Count	Avg	SD
pH	8.0	0.4		8.4	8.2			8.2	8.2		TDS	23	-9	13
Temp	23.5	0.5		23.0	25.0			23.0	25.0		Alk	2	-20	9
Alk	421	15		372	364			424	440		TDS	2	-4	2
TDS	280	2		262	264			292	300		TotHard	2	5	2
TotHard	217	3		204	206			236	264		CaHard	2	2	1
CaHard	205	1		174	192			240	246		Turb	2	-175	62
Turb	0.62	0.26		0.12	0.12			0.53	0.57		Amm	0	n/a	n/a
Amm	0.00	0.00		0.00	0.00			NA	NA		TOC	2	3	3
TOC	12.0	0.3		1.9	3.0			23.5	34.9		UV254	2	-12	4
UV254	0.570	0.043		0.050	0.081			1.008	1.574					
SUVA	4.74	0.24	#####	2.63	2.70	#VALUE!		4.29	4.51					
Bromide	140	0		140	140						Pretreatment Information			
TOX	1095	25		135	230						Process	Description	Scale	
CHCl3	405.0	45.0		21.0	49.0						Cartridge filtration	5 micron filter	bench	
BDCM	52.0	7.0		23.0	32.0									
DBCM	5.9	0.6		24.0	21.0									
CHBr3	0.0	0.0		9.4	4.5									
THM4	462.9	52.5	0.0	77.4	106.5	0.0								
MCAA	5.5	0.1		0.0	2.1									
DCAA	105.0	5.0		5.8	12.0									
TCAA	96.5	13.5		2.0	5.3									
MBAA	0.0	0.0		0.0	0.0									
DBAA	1.6	0.2		5.7	5.1									
BCAA	14.5	0.5		5.5	8.5									
TBAA	0.0	NA		NR	NA									
CDBAA	1.1	1.1		2.5	2.8									
DCBAA	12.0	0.0		2.7	4.4									
HAA5	208.5	18.7	0.0	13.5	24.5	0.0								
HAA6	223.0	19.2	0.0	19.0	33.0	0.0								
HAA9	215.8	NA	0.0	NR	NA	0.0								
SDS Conditions														
WQP	Avg	SD	Count	Min - Max										
Res (mg/L) (0)	1.24	0.51	4	0.82 - 1.97										
Temp (°C)	25.0	0.0	4	25.0 - 25.0										
pH (unit)	9.0	0.2	4	8.8 - 9.2										
Time (hr)	24.0	0.0	4	24.0 - 24.0										

Water Quality Parameter Graphs (Continued)



Productivity Graphs



ICR Information

ID / ICR#: 4060167 / 294
ICR Contact: Mr. Jerry Baker
Phone No.: (954) 960-3061
Period: 4/3/99 - 4/9/99 (6 days)


Membrane Information

Manufacturer: Hydranautics Corp., San Diego, CA
Trade Name: NTR7450
MWCO: 1,000 Da Daltons
Mfr. Flux: 45.0 gfd
Mfr. NDP: 140.0 psi
Mfr. MTCw: 0.320 gfd/psi
Mfr. Temp: 25.0 °C
840 Element Area: 365.0 ft²
840 Purchase Price: \$800
840 Maximum Flow: 75.0 gpm
840 Minimum Flow: 25.0 gpm
840 Total Width: 64.4 ft
840 Feed Spacer Thickness: 0.0023 ft


Water Quality Summary

Source ->	Feed		Permeate				Concentrate				Mass Balance Closure Err (%)			
Recovery ->	Avg	Diff	0.30	0.50	0.70	0.87	0.30	0.50	0.70	0.87	WQP	Count	Avg	SD
pH	8.1	0.2	8.0	7.9	8.0	8.1	8.1	8.1	8.0	8.2	TDS	60	-4	7
Temp	24.0	0.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	Alk	4	4	19
Alk	348	2	284	298	319	350	352	376	399	492	TDS	4	-3	8
TDS	293	0	271	270	279	293	287	295	303	321	TotHard	4	-3	17
TotHard	295	3	240	246	271	294	286	296	328	386	CaHard	4	-7	16
CaHard	270	2	212	218	233	268	276	278	295	336	Turb	4	-31	28
Turb	0.26	0.01	0.08	0.09	0.09	0.12	0.28	0.30	0.39	1.18	Amm	0	n/a	n/a
Amm	0.04	0.04	0.00	0.00	0.00	0.00	NA	NA	NA	NA	TOC	4	13	15
TOC	12.6	0.1	3.6	4.2	4.8	7.2	16.9	22.7	32.2	73.5	UV254	4	-10	9
UV254	0.588	0.001	0.106	0.118	0.122	0.203	0.729	0.958	1.360	3.050	Pretreatment Information			
SUVA	4.67	0.04	2.94	2.81	2.57	2.82	4.31	4.22	4.22	4.15				
Bromide	140	0	140	140	140	140	ProcessDescriptionScale							
TOX	1665	265	300	335	353	530								
CHCl3	475.0	45.0	75.0	81.0	94.5	150.0	Cartridge filtration5 micron filterbench							
BDCM	59.0	2.0	37.0	38.0	41.0	44.0								
DBCM	5.5	0.2	19.0	18.0	17.5	13.0								
CHBr3	0.0	0.0	2.0	1.5	1.5	0.0								
THM4	539.5	47.1	133.0	138.5	154.5	207.0								
MCAA	11.0	NA	3.1	2.7	3.3	4.0	Design Parameters							
DCAA	110.0	NA	18.0	21.0	24.0	37.0								
TCAA	140.0	NA	12.0	15.0	16.5	28.0								
MBAA	0.0	NA	0.0	0.0	0.0	0.0								
DBAA	1.4	NA	3.9	3.8	3.4	2.5								
BCAA	16.0	NA	10.0	11.0	11.0	12.0								
TBAA	0.0	NA	0.0	0.0	0.0	0.0								
CDBAA	2.6	NA	3.8	3.8	3.6	2.7								
DCBAA	19.0	NA	7.6	8.6	8.8	9.2								
HAA5	262.4	NA	37.0	42.5	47.2	71.5								
HAA6	278.4	NA	47.0	53.5	58.2	83.5								
HAA9	300.0	NA	58.4	65.9	70.5	95.4								
SDS Conditions							Active memb area: 0.167 ft²Active width: 0.330 ftNorm Temp: 24.6 °CFeed TDS: 300.0 mg/LManuf rep TDS rej: 50%Temp Norm MTC-w: 0.316 gfd/psi							
WQP	Avg	SD	Count	Min - Max										
Res (mg/L) (0)	0.89	0.25	6	0.55 - 1.20										
Temp (°C)	24.0	0.0	6	24.0 - 24.0										
pH (unit)	9.0	0.1	6	8.9 - 9.0										
Time (hr)	24.0	0.0	6	24.0 - 24.0		Comments:								


Water Quality Parameter Graphs



Water Quality Parameter Graphs (Continued)



Productivity Graphs



ICR Information

ID / ICR#: 4060167 / 294
ICR Contact: Mr. Jerry Baker
Phone No.: (954) 960-3061
Period: 4/29/98 - 5/5/98 (6 days)

Membrane Information


Manufacturer: Fluid Systems
Trade Name: TFC-SR
MWCO: 300 Daltons
Mfr. Flux: 24.0 gfd
Mfr. NDP: 100.0 psi
Mfr. MTCw: 0.240 gfd/psi


Mfr. Temp: 25.0 °C
840 Element Area: 330.0 ft²
840 Purchase Price: N.A.
840 Maximum Flow: 80.0 gpm
840 Minimum Flow: 20.0 gpm
840 Total Width: 58.2 ft
840 Feed Spacer Thickness: 0.0026 ft

Water Quality Summary


Water Quality Summary															Mass Balance Closure Err (%)			
Source ->	Feed		Permeate				Concentrate											
Recovery ->	Avg	Diff	0.29	0.50	0.70	0.82	0.29	0.50	0.70	0.82	WQP	Count	Avg	SD				
pH	8.3	0.2	8.4	8.3	8.2	8.2	8.5	8.5	8.4	8.6	TDS	15	-16	55				
Temp	24.0	0.0	23.0	23.0	24.0	24.0	23.0	23.0	24.0	24.0								
Alk	191	25	140	190	161	186	242	258	300	330	Alk	4	22	11				
TDS	297	3	204	247	225	260	317	337	389	429	TDS	4	-9	7				
TotHard	195	5	118	176	146	186	268	318	382	458	TotHard	4	29	15				
CaHard	161	3	106	156	133	158	232	234	348	420	CaHard	4	36	16				
Turb	0.96	0.01	0.07	0.07	0.09	0.08	1.18	1.33	1.48	1.80	Turb	4	-81	73				
Amm	0.00	NA	0.08	0.22	0.78	0.39	NA	NA	NA	NA	Amm	0	n/a	n/a				
TOC	14.4	NA	0.3	0.6	0.3	1.0	19.1	25.7	45.5	105.9	TOC	2	10	19				
UV254	0.523	0.048	0.010	0.017	0.005	0.028	0.809	1.132	1.748	3.934	UV254	3	16	12				
SUVA	#N/A	NA	4.00	2.83	1.80	2.80	4.24	4.40	3.84	3.71								
Bromide	140	NA	110	120	130	130	Pretreatment Information											
TOX	1300	NA	41	59	13	67												
ProcessDescriptionScale																		
Cartridge filtration5 micron filterbench																		
CHCl3	490.0	NA	2.9	5.3	2.9	7.9	Design Parameters											
BDCM	69.0	NA	5.8	9.4	1.8	9.3												
DBCM	7.1	NA	14.0	18.0	0.0	15.0	Active memb area: 0.167 ft²											
CHBr3	0.0	NA	16.0	17.0	0.0	16.0												
THM4	566.1	NA	38.7	49.7	4.6	48.2	Active width: 0.330 ft											
MCAA	8.6	NA	0.0	0.0	0.0	0.0												
DCAA	120.0	NA	1.0	2.2	1.9	3.2	Norm Temp: 24.6 °C											
TCAA	89.0	NA	0.0	1.0	0.0	1.6												
MBAA	1.0	NA	0.0	0.0	0.0	0.0	Feed TDS: 300.0 mg/L											
DBAA	1.3	NA	3.8	5.0	0.0	5.2												
BCAA	16.0	NA	1.8	3.1	0.0	3.0	Manuf rep TDS rej: 50%											
TBAA	0.0	NA	0.0	0.0	0.0	0.0												
CDBAA	0.0	NA	0.0	0.0	0.0	0.0	Temp Norm MTC-w: 0.237 gfd/psi											
DCBAA	12.0	NA	0.0	1.2	0.0	1.1												
HAA5	219.9	NA	4.8	8.2	1.9	10.0	ID#Recov (dec.)F _{W-des} (gfd)											
HAA6	235.9	NA	6.6	11.3	1.9	13.0												
HAA9	247.9	NA	6.6	12.5	1.9	14.1												
SDS Conditions																		
WQP	Avg	SD	Count	Min - Max														
Res (mg/L) (1)	0.79	0.53	6	0.08 - 1.23														
Temp (°C)	25.0	0.0	6	25.0 - 25.0														
pH (unit)	8.8	0.1	6	8.7 - 8.9														
Time (hr)	24.0	0.0	6	24.0 - 24.0														
Comments:																		

Water Quality Parameter Graphs



Water Quality Parameter Graphs (Continued)

Productivity Graphs



ICR Information

ID / ICR#: 4060167 / 294
ICR Contact: Mr. Jerry Baker
Phone No.: (954) 960-3061
Period: 7/8/98 - 7/14/98 (6 days)

Membrane Information


Manufacturer: Fluid Systems
Trade Name: TFC-SR
MWCO: 300 Daltons
Mfr. Flux: 24.0 gfd
Mfr. NDP: 100.0 psi
Mfr. MTCw: 0.240 gfd/psi

Mfr. Temp: 25.0 °C
840 Element Area: 330.0 ft²
840 Purchase Price: N.A.
840 Maximum Flow: 80.0 gpm
840 Minimum Flow: 20.0 gpm
840 Total Width: 58.2 ft
840 Feed Spacer Thickness: 0.0026 ft


Water Quality Summary

Source ->		Feed		Permeate				Concentrate				Mass Balance Closure Err (%)			
Recovery ->	Avg	Diff	0.30	0.51	0.69	0.91	0.30	0.51	0.69	0.91	WQP	Count	Avg	SD	
pH	7.9	0.3	7.7	7.7	7.8	7.7	7.7	8.3	8.1	8.3	TDS	54	-8	11	
Temp	24.0	0.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	Alk	4	-4	24	
Alk	205	2	157	175	193	188	238	245	270	265	TDS	4	-21	24	
TDS	317	2	223	246	238	273	333	352	453	486	TotHard	4	-18	14	
TotHard	299	9	162	182	210	270	286	332	508	484	CaHard	4	-18	33	
CaHard	256	4	146	158	180	206	280	324	478	462	Turb	4	-693	292	
Turb	1.26	0.14	0.05	0.05	0.05	0.05	0.35	0.38	0.48	1.13	Amm	0	n/a	n/a	
Amm	0.31	0.17	0.00	0.00	1.10	0.20	NA	NA	NA	NA	TOC	3	-6	21	
TOC	13.3	0.5	0.3	0.9	0.3	1.1	19.5	27.0	45.0	105.0	UV254	3	-35	46	
UV254	0.635	0.030	0.020	0.016	0.005	0.024	0.877	1.111	1.660	3.620					
SUVA	4.77	0.05	8.00	1.78	1.80	2.18	4.50	4.11	3.69	3.45					
Bromide	150	0	110	120	120	140									
TOX	1435	5	43	52	13	78									
CHCl3	480.0	0.0	5.1	6.0	3.0	8.2									
BDCM	53.5	5.5	8.0	9.5	0.0	14.0									
DBCM	5.4	0.0	12.0	15.0	0.0	22.0									
CHBr3	0.0	0.0	8.0	9.4	0.0	15.0									
THM4	538.9	5.5	33.1	39.9	3.0	59.2									
MCAA	10.4	0.6	0.0	0.0	0.0	0.0									
DCAA	130.0	0.0	2.5	2.4	3.8	3.4									
TCAA	103.0	7.0	0.0	0.0	0.0	1.1									
MBAA	0.0	0.0	0.0	0.0	0.0	0.0									
DBAA	1.5	0.0	3.0	3.6	0.0	5.3									
BCAA	16.0	1.0	1.2	1.9	0.0	3.5									
TBAA	0.0	0.0	0.0	0.0	0.0	0.0									
CDBAA	0.0	0.0	0.0	0.0	0.0	2.7									
DCBAA	12.5	1.5	1.1	1.4	0.0	1.9									
HAA5	244.9	6.4	5.5	6.0	3.8	9.8									
HAA6	260.9	7.4	6.7	7.9	3.8	13.3									
HAA9	273.4	8.9	7.8	9.3	3.8	17.9									
SDS Conditions															
WQP	Avg	SD	Count	Min - Max											
Res (mg/L) (0)	1.55	0.64	6	0.68 - 2.42											
Temp (°C)	25.0	0.0	6	25.0 - 25.0											
pH (unit)	9.2	0.3	6	8.9 - 9.5											
Time (hr)	24.0	0.0	6	24.0 - 24.0											


Water Quality Parameter Graphs



Water Quality Parameter Graphs (Continued)



Productivity Graphs



ICR Information

ID / ICR#: 4060167 / 294
ICR Contact: Mr. Jerry Baker
Phone No.: (954) 960-3061
Period: 11/10/98 - 11/16 (6 days)

Membrane Information


Manufacturer: Fluid Systems
Trade Name: TFC-SR
MWCO: 300 Daltons
Mfr. Flux: 24.0 gfd
Mfr. NDP: 100.0 psi
Mfr. MTCw: 0.240 gfd/psi

Mfr. Temp: 25.0 °C
840 Element Area: 330.0 ft²
840 Purchase Price: N.A.
840 Maximum Flow: 80.0 gpm
840 Minimum Flow: 20.0 gpm
840 Total Width: 58.2 ft
840 Feed Spacer Thickness: 0.0026 ft


Water Quality Summary

Source ->	Feed		Permeate				Concentrate				Mass Balance Closure Err (%)							
Recovery ->	Avg	Diff	0.30	0.54	0.71	0.90	0.30	0.54	0.71	0.90	WQP	Count	Avg	SD				
pH	8.0	0.4	7.7	7.7	7.7	7.8	8.1	7.6	7.8	8.5	TDS	45	-5	9				
Temp	23.5	0.5	23.0	23.0	23.0	23.0	23.0	23.0	23.0	23.0	Alk	4	-15	8				
Alk	421	15	312	330	321	384	400	506	581	612	TDS	4	2	5				
TDS	280	2	225	247	232	266	301	347	386	418	TotHard	4	5	7				
TotHard	217	3	150	172	158	196	240	308	364	456	CaHard	4	-12	16				
CaHard	205	1	142	152	135	164	234	254	345	424	Turb	4	-27	49				
Turb	0.62	0.26	0.08	0.07	0.09	0.10	1.11	1.15	1.00	4.25	Amm	0	n/a	n/a				
Amm	0.00	0.00	0.00	0.00	0.00	0.00	NA	NA	NA	NA	TOC	4	14	10				
TOC	12.0	0.3	0.8	1.0	0.9	1.8	17.6	34.2	42.9	122.3	UV254	4	0	12				
UV254	0.570	0.043	0.034	0.029	0.021	0.065	0.797	1.452	1.745	4.720	Pretreatment Information							
SUVA	4.74	0.24	4.25	2.90	2.41	3.61	4.53	4.25	4.07	3.86					Process	Description	Scale	
Bromide	140	0	130	130	130	140	Design Parameters				Cartridge filtration				5 micron filter	bench		
TOX	1095	25	72	85	62	140					Active memb area:				0.167 ft ²	ID#	Recov (dec.)	F _{W-des} (gfd)
CHCl3	405.0	45.0	8.7	12.0	4.9	29.0					Active width:				0.330 ft			
BDCM	52.0	7.0	11.0	15.0	7.6	25.0					Norm Temp:				24.6 °C	1	0.70	15.0
DBCM	5.9	0.6	16.0	21.0	15.5	24.0					Feed TDS:				300.0 mg/L	2	0.90	15.0
CHBr3	0.0	0.0	13.0	14.0	16.5	8.3					Manuf rep TDS rej:				50%	3	0.50	15.0
THM4	462.9	52.5	48.7	62.0	44.5	86.3	Temp Norm MTC-w:				0.237 gfd/psi	4	0.30	15.0				
MCAA	5.5	0.1	0.0	0.0	0.0	0.0	Comments:											
DCAA	105.0	5.0	3.1	3.8	1.9	7.0												
TCAA	96.5	13.5	0.0	0.0	0.0	1.9												
MBAA	0.0	0.0	0.0	0.0	0.0	0.0												
DBAA	1.6	0.2	3.6	4.8	4.2	6.1												
BCAA	14.5	0.5	2.4	2.7	1.7	6.0	SDS Conditions											
TBAA	0.0	NA	0.0	0.0	0.0	0.0												
CDBAA	1.1	1.1	0.0	0.0	0.0	2.2	WQP		Avg	SD	Count	Min - Max						
DCBAA	12.0	0.0	1.2	1.4	1.4	2.5	Res (mg/L) (0)	1.76	0.53	6	1.01 - 2.20							
HAA5	208.5	18.7	6.7	8.6	6.1	15.0	Temp (°C)	25.0	0.0	6	25.0 - 25.0							
HAA6	223.0	19.2	9.1	11.3	7.8	21.0	pH (unit)	8.8	0.2	6	8.4 - 9.0							
HAA9	215.8	NA	10.3	12.7	9.1	25.7	Time (hr)	24.0	0.0	6	24.0 - 24.0							


Water Quality Parameter Graphs



Water Quality Parameter Graphs (Continued)



Productivity Graphs



ICR Information

ID / ICR#: 4060167 / 294
ICR Contact: Mr. Jerry Baker
Phone No.: (954) 960-3061
Period: 3/26/99 - 4/1/99 (6 days)

Membrane Information


Manufacturer: Fluid Systems
Trade Name: TFC-SR
MWCO: 300 Daltons
Mfr. Flux: 24.0 gfd
Mfr. NDP: 100.0 psi
Mfr. MTCw: 0.240 gfd/psi

Mfr. Temp: 25.0 °C
840 Element Area: 330.0 ft²
840 Purchase Price: N.A.
840 Maximum Flow: 80.0 gpm
840 Minimum Flow: 20.0 gpm
840 Total Width: 58.2 ft
840 Feed Spacer Thickness: 0.0026 ft


Water Quality Summary

Source ->	Feed		Permeate				Concentrate				Mass Balance Closure Err (%)					
Recovery ->	Avg	Diff	0.31	0.51	0.71	0.90	0.31	0.51	0.71	0.90	WQP	Count	Avg	SD		
pH	8.1	0.2	8.0	7.9	8.0	7.9	8.0	8.1	8.1	8.2	TDS	57	-13	50		
Temp	24.0	0.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	24.0	Alk	4	-57	26		
Alk	348	2	136	144	155	292	356	360	435	534	TDS	4	-15	15		
TDS	293	0	184	198	204	259	339	375	420	443	TotHard	4	-26	20		
TotHard	295	3	134	140	156	224	352	378	508	602	CaHard	4	-33	22		
CaHard	270	2	102	116	126	196	318	334	480	566	Turb	4	-70	43		
Turb	0.26	0.01	0.07	0.08	0.09	0.11	0.29	0.30	0.32	0.80	Amm	0	n/a	n/a		
Amm	0.04	0.04	0.00	0.00	0.00	0.00	NA	NA	NA	NA	TOC	4	6	5		
TOC	12.6	0.1	0.7	1.0	0.8	1.6	17.9	27.9	45.5	114.4	UV254	4	-29	30		
UV254	0.588	0.001	0.014	0.018	0.020	0.045	0.717	1.099	1.727	3.094						
SUVA	4.67	0.04	2.00	1.80	2.67	2.81	4.01	3.94	3.80	2.70						
Bromide	140	0	83	96	100	130	Pretreatment Information									
TOX	1665	265	45	61	65	110										
							Process	Description		Scale						
CHCl3	475.0	45.0	4.9	5.7	4.3	15.0	Cartridge filtration	5 micron filter		bench						
BDCM	59.0	2.0	7.7	10.0	8.5	21.0	Design Parameters									
DBCM	5.5	0.2	13.0	17.0	15.5	26.0										
CHBr3	0.0	0.0	7.8	8.7	10.1	8.7										
THM4	539.5	47.1	33.4	41.4	38.3	70.7										
MCAA	11.0	NA	0.0	0.0	0.0	0.0										
DCAA	110.0	NA	1.2	2.4	1.8	4.0										
TCAA	140.0	NA	0.0	1.4	0.0	1.9										
MBAA	0.0	NA	0.0	0.0	0.0	0.0										
DBAA	1.4	NA	3.2	3.8	4.0	5.8										
BCAA	16.0	NA	1.9	2.7	2.2	5.2										
TBAA	0.0	NA	NR	NR	NA	NR										
CDBAA	2.6	NA	2.2	2.6	2.4	4.3										
DCBAA	19.0	NA	1.3	1.8	1.6	3.7										
HAA5	262.4	NA	4.4	7.6	5.8	11.7										
HAA6	278.4	NA	6.3	10.3	8.0	16.9										
HAA9	300.0	NA	NR	NR	NA	NR										
SDS Conditions							Active memb area: 0.167 ft ² Active width: 0.330 ft Norm Temp: 24.6 °C Feed TDS: 300.0 mg/L Manuf rep TDS rej: 50% Temp Norm MTC-w: 0.237 gfd/psi									
WQP	Avg	SD	Count	Min - Max		ID#									Recov (dec.)	F _{W-des} (gfd)
Res (mg/L) (0)	1.19	0.39	6	0.71 - 1.66		1									0.70	15.0
Temp (°C)	24.0	0.0	6	24.0 - 24.0		2									0.90	15.0
pH (unit)	8.9	0.1	6	8.8 - 9.0		3									0.50	15.0
Time (hr)	24.0	0.0	6	24.0 - 24.0		4	0.30	15.0								
Comments:																

Water Quality Parameter Graphs



Water Quality Parameter Graphs (Continued)



Productivity Graphs

