

# ICR TREATMENT STUDY ANALYSIS

## Base Analysis and Data Review Comments

<b>Treatment Study ID</b>	4111
<b>Study Protocol</b>	Two-Stage Pilot-Scale Membrane Study
<b>Plant ICR Number</b>	283
<b>PWS Name</b>	City of Melbourne Water System
<b>City, State, Zip</b>	Melbourne, FL 32934

### General Comments:

1. This study was grandfathered into the ICR, and therefore does not meet all of the specific requirements listed in the ICR and rule-by-reference manuals. This pilot-scale study (study ID 4111) was conducted in conjunction with a pilot-scale study (study ID 4011) and a single-element study (study ID 4211). This study was part of a larger study conducted by the University of Central Florida for the USEPA Risk Reduction Engineering Laboratory, published in a report entitled “*Reduction of Disinfection By-Product Precursors by Nanofiltration*” in April 1992 (EPA/600/SR-92/023).
2. The Osmonics Desal DK4040F (formerly known as the Desal DS5) was evaluated during this study, using a surface water source with an average TOC of 20 mg/L. Due to the nature of this raw water source, advanced membrane pretreatment was needed. The resulting integrated membrane system included the following pretreatments: coagulation, sedimentation, rapid sand filtration, pH reduction, and microfiltration. A schematic of this integrated membrane system, including the 4-2 staged array nanofiltration system, is shown in Figure 2 of the Summary Report (Part 2)
3. This system was operated from February through May 1991.
4. Section 1 of the Summary Report (Part 2) lists the significant conclusions and recommendations from this study.
5. Cost information is provided in Section 4 and Tables 15 and 16 of the Summary Report (Part 2).

### Water Quality Comments:

1. One water quality outlier was identified and removed prior to base analysis.

2. The reported target SDS conditions during this study were to dose and incubate the samples at 22°C, for 96 hours at a pH of 7.6, with a target residual of 0.2 mg/L. However, the chlorination procedure was more similar to a Formation Potential test, than a SDS test, since only a measurable residual (i.e., above 0.2 mg/L) after 96 hours was necessary for DBPs to be analyzed from that sample. No measured residuals were reported during this study – only the presence of a residual.
3. The following parameters were not measured during this study: ammonia, UV<sub>254</sub>, bromide, and BCAA (thus HAA6).

### **Productivity Comments:**

1. Three productivity outliers were identified and removed prior to base analysis.
2. This membrane system was operated between 10 and 15 gfd, at recoveries ranging from 45 to 65%. The experimental design for this study (denoted as the AC-DS5) is listed in Table 7 (Part 2).
3. The membrane system was cleaned every 2 to 4 weeks, as needed, with a phosphate detergent and NaOH solution.
4. During productivity analysis, the average slope and cleaning interval were calculated to be –  $2.33 \times 10^{-3}$  gfd/psi/day and 65 days, respectively. This slope is similar to the average slope and reported by the researchers:  $-1.72 \times 10^{-3}$  gfd/psi/day (the cleaning interval calculated from this slope is 73 days).

## ICR Information

ID / ICR#: FL3051447 / 283  
 ICR Contact: Mr. Ralph Sigman  
 Phone No.: (407) 255-4623  
 Period: 2/3/91 - 4/14/91 (70 days)

## Membrane Information

Manufacturer: Osmonics Desal  
 Trade Name: DS5  
 Membrane Model: DK4040F  
 MWCO: 150 - 300 Daltons  
 Element Size: 4" X 40"  
 Element Area: 90.0 ft<sup>2</sup>  
 Design Flux: 20.0 gfd  
 Mfr. NDP: 100.0 psi  
 Mfr. MTC<sub>w</sub>: 0.200 (gfd/psi)  
 Mfr. Temp: 25.0 °C  
 Maximum Flow: 12.0 gpm  
 Minimum Flow: 6.3 gpm  
 Total Width : 16.0 ft  
 Feed Spacer Thickness: 0.0028 ft  
 840 Element Area 350.0 ft<sup>2</sup>  
 840 Purchase Price: \$1,500

## Design Parameters

Norm Temp: 24.5 °C  
 Temp Norm MTC-w: 0.197 TavGC  
 Design Recovery: 0.65  
 Avg Sys Flux F<sub>w</sub>: 15.0 gfd  
 # of Elem in P.V.: 3  
 # Pres Ves in Stg 1: 2  
 # Pres Ves in Stg 2: 1  
 Pres Ves in Stg 3: NA  
 Design Flux: 15.0 gfd  
 Recycle Ratio: 0.00  
 Osmotic P Stage 1: 3.0 psi  
 Osmotic P Stage 2: 6.0 psi  
 Osmotic P Stage 3: NA

## Water Quality Summary

Water Quality Summary												
Summary	Feed (System)				Permeate (System)				Concentrate (System)			
	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max
pH	6.0	2.2	3	3.5 - 7.3	2.9	0.3	3	2.7 - 3.3	4.1	1.3	3	3.2 - 5.5
Temp	19.6	1.4	3	18.3 - 21.1	19.6	1.4	3	18.3 - 21.1	19.6	1.4	3	18.3 - 21.1
Alk	NA	NA	0	0 - 0	0	0	3	0 - 0	3	5	3	0 - 9
TDS	477	21	3	460 - 500	143	21	3	120 - 160	870	225	3	650 - 1100
TotHard	200	10	3	190 - 210	21	6	3	14 - 26	407	100	3	310 - 510
CaHard	147	6	3	140 - 150	13	3	3	9 - 15	323	75	3	250 - 400
Turb	0.33	0.2	3	0.20 - 0.60	0.00	0.0	3	0.00 - 0.00	15.13	25.9	3	0.20 - 45.00
Amm	NA	NA	0	NA	NA	NA	0	NA	NA	NA	0	0.0 - 0.0
TOC	7.6	1.8	3	6.2 - 9.7	0.4	0.3	3	0.3 - 0.8	15.0	5.2	3	12.0 - 21.0
UV254	NA	NA	0	0.000 - 0.000	NA	NA	0	0.000 - 0.000	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	0	NA	NA	NA	0	NA	NA	NA	0	NA
Bromide	NA	NA	0	0 - 0	NA	NA	0	0 - 0				
TOX	1250	328	3	950 - 1600	73	1	3	73 - 74				
CHCl3	156.7	45.1	3	110.0 - 200.0	4.0	0.0	3	4.0 - 4.0	Mass Balance			
BDCM	92.3	4.0	3	88.0 - 96.0	10.7	1.2	3	10.0 - 12.0	Closure Errors (%)			
DBCM	43.0	5.2	3	40.0 - 49.0	20.0	2.6	3	18.0 - 23.0	WQP	Count	Avg	SD/RD
CHBr3	14.0	2.6	3	11.0 - 16.0	14.0	1.0	3	13.0 - 15.0	Alk	0	n/a	n/a
THM4	306.0	37.0	3	270.0 - 344.0	48.7	4.6	3	46.0 - 54.0	TDS	3	-7	9
MCAA	15.3	5.0	3	10.0 - 20.0	7.7	5.0	3	3.0 - 13.0	TotHard	3	-7	6
DCAA	112.7	16.2	3	98.0 - 130.0	3.7	0.6	3	3.0 - 4.0	CaHard	3	0	5
TCAA	120.0	10.0	3	110.0 - 130.0	1.0	0.0	3	1.0 - 1.0	Turb	0	n/a	n/a
MBAA	4.3	1.5	3	3.0 - 6.0	0.7	0.6	3	0.0 - 1.0	Amm	0	n/a	n/a
DBAA	11.0	2.0	3	9.0 - 13.0	5.7	0.6	3	5.0 - 6.0	TOC	2	-8	10
BCAA	NA	NA	0	NA	NA	NA	0	NA	UV254	0	n/a	n/a
TBAA	NA	NA	0	NA	NA	NA	0	NA				
CDBAA	NA	NA	0	NA	NA	NA	0	NA				
DCBAA	NA	NA	0	NA	NA	NA	0	NA				
HAA5	263.3	26.3	3	243.0 - 293.0	18.7	5.0	3	14.0 - 24.0	TDS <sub>t</sub>	2	-6	14
HAA6	NA	NA	0	NA	NA	NA	0	NA	Comments:			
HAA9	NA	NA	0	NA	NA	NA	0	NA				
SDS Conditions					Pretreatment Information							
WQP	Avg	SD	Count	Min - Max	Process		Description			Scale		
Res (0)	0.20	0.00	6	0.20 - 0.20	Alum Coagulation		Aluminum sulfate dose: 151.4 mg/L			Full-scale		
Temp (°C)	22.0	0.0	6	22.0 - 22.0	Sedimentation		Circular clarifier			Full-scale		
pH (unit)	7.6	0.0	6	7.6 - 7.6	Dual Media Filtration		Sand/anthracite			Full-scale		
Time (hr)	96.0	0.0	6	96.0 - 96.0	Sulfuric Acid Feed		Approx. 85 mg/L to pH 3.5 to 4.5			Pilot-scale		
					Microfiltration		5um filter Filter Specialists Bag Filter			Pilot-scale		

## Mass Balance Errors

Pressure	RPD	SD	Flow	RPD	SD	TDS	RPD	SD
System Inf - Stg 1 Inf	0.0%	0.0%	System Inf - Stg 1 Inf	0.0%	0.0%	System Inf - Stg 1 Inf	0.0%	0.0%
Sys Conc - Stg 2 Conc	0.0%	0.0%	Sys Conc - Stg 2 Conc	0.0%	0.0%	Sys Conc - Stg 2 Conc	0.0%	0.0%
Stg 1 Conc - Stg 2 Inf	0.0%	0.0%	Stg 1 Conc - Stg 2 Inf	0.0%	0.0%	Stg 1 Conc - Stg 2 Inf	0.0%	0.0%
Sys Perm - Avg Stg Perm	5.6%	1.9%	Sys Perm - Sum Stg Per	0.0%	0.0%	Sys Perm - Avg Stg Perm	-17.5%	16.5%

## Stage Summary

	Stage 1 Influent						Stage 1 Permeate				
WQP	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			<b>0.35</b>	<b>0.07</b>	<b>3</b>	<b>0.27 - 0.41</b>					
pH	6.0	4.1	6.0	2.2	3	3.5 - 7.3	2.9	3.6	0.1	3	3.5 - 3.6
Temp	19.6	19.6	19.6	1.4	3	18.3 - 21.1	19.6	19.6	1.4	3	18.3 - 21.1
Alk	NA	3	NA	NA	0	0 - 0	0	0	0	3	0 - 0
<b>TDS</b>	<b>477</b>	<b>870</b>	477	<b>21</b>	<b>3</b>	<b>460 - 500</b>	<b>143</b>	<b>170</b>	<b>62</b>	<b>3</b>	<b>120 - 240</b>
TotHard	200	407	200	10	3	190 - 210	21	20	2	3	19 - 22
CaHard	147	323	147	6	3	140 - 150	13	14	2	3	12 - 16
Turb	0.33	15.13	0.33	0	3	0.20 - 0.60	0.00	0.00	0.00	3	0 - 0
<b>TOC</b>	<b>7.6</b>	<b>15.0</b>	7.6	<b>1.8</b>	<b>3</b>	<b>6.2 - 9.7</b>	<b>0.4</b>	<b>0.4</b>	<b>0.3</b>	<b>3</b>	<b>0.3 - 0.7</b>
UV254	NA	NA	NA	NA	0	0.000 - 0.000	NA	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	NA	NA	0	NA	NA	NA	NA	0	NA


	Stage 2 Influent						Stage 2 Permeate				
WQP	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			<b>0.30</b>	<b>0.09</b>	<b>3</b>	<b>0.19 - 0.35</b>					
pH	6.0	4.1	3.7	0.1	3	3.6 - 3.8	2.9	3.5	0.2	3	3.3 - 3.7
Temp	19.6	19.6	19.6	1.4	3	18.3 - 21.1	19.6	19.6	1.4	3	18.3 - 21.1
Alk	NA	3	<b>0</b>	0	3	0 - 0	0	0	0	3	0 - 0
<b>TDS</b>	<b>477</b>	<b>870</b>	647	<b>85</b>	<b>3</b>	<b>560 - 730</b>	<b>143</b>	<b>180</b>	<b>46</b>	<b>3</b>	<b>130 - 220</b>
TotHard	200	407	280	36	3	250 - 320	21	25	9	3	17 - 34
CaHard	147	323	220	26	3	200 - 250	13	15	5	3	<b>11 - 21</b>
Turb	0.33	15.13	2.57	4	3	0.00 - 7.60	0.00	0.00	0.00	3	0 - 0
<b>TOC</b>	<b>7.6</b>	<b>15.0</b>	12.0	<b>2.0</b>	<b>3</b>	<b>10.0 - 14.0</b>	<b>0.4</b>	<b>0.9</b>	<b>0.9</b>	<b>3</b>	<b>0.3 - 2.0</b>
UV254	NA	NA	NA	NA	0	0.000 - 0.000	NA	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	NA	NA	0.00	NA	NA	NA	NA	0.00	NA


	Stage 3 Influent						Stage 3 Permeate				
WQP	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery											
pH											
Temp											
Alk											
<b>TDS</b>											
TotHard											
CaHard											
Turb											
<b>TOC</b>											
UV254											
SUVA											

This was **only** a two stage study.


## Chart Legend:




## Water Quality Parameter Graphs



## Water Quality Graphs (Continued)



## Productivity Graphs



## ICR Information

ID / ICR#: FL3051447 / 283  
 ICR Contact: Mr. Ralph Sigman  
 Phone No.: (407) 255-4623  
 Period: 4/15/91 - 5/26/91 (41 days)

## Membrane Information

Manufacturer: Osmonics Desal  
 Trade Name: DS5  
 Membrane Model: DK4040F  
 MWCO: 150 - 300 Daltons  
 Element Size: 4" X 40"  
 Element Area: 90.0 ft<sup>2</sup>  
 Design Flux: 20.0 gfd  
 Mfr. NDP: 100.0 psi  
 Mfr. MTC<sub>w</sub>: 0.200 (gfd/psi)  
 Mfr. Temp: 25.0 °C  
 Maximum Flow: 12.0 gpm  
 Minimum Flow: 6.3 gpm  
 Total Width : 16.0 ft  
 Feed Spacer Thickness: 0.0028 ft  
 840 Element Area 350.0 ft<sup>2</sup>  
 840 Purchase Price: \$1,500

## Design Parameters

Norm Temp: 24.5 °C  
 Temp Norm MTC-w: 0.197 TavGC  
 Design Recovery: 0.65  
 Avg Sys Flux F<sub>w</sub>: 15.0 gfd  
 # of Elem in P.V.: 3  
 # Pres Ves in Stg 1: 2  
 # Pres Ves in Stg 2: 1  
 Pres Ves in Stg 3: NA  
 Design Flux: 15.0 gfd  
 Recycle Ratio: 0.00  
 Osmotic P Stage 1: 3.0 psi  
 Osmotic P Stage 2: 6.0 psi  
 Osmotic P Stage 3: NA

## Water Quality Summary

Feed (System)					Permeate (System)				Concentrate (System)			
Summary	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max	Mean	SD	Count	Min/Max
pH	7.3	NA	1	7.3 - 7.3	4.4	NA	1	4.4 - 4.4	4.4	NA	1	4.4 - 4.4
Temp	27.8	NA	1	27.8 - 27.8	27.8	NA	1	27.8 - 27.8	27.8	NA	1	27.8 - 27.8
Alk	NA	NA	0	0 - 0	0	NA	1	0 - 0	0	NA	1	0 - 0
TDS	410	NA	1	410 - 410	220	NA	1	220 - 220	590	NA	1	590 - 590
TotHard	180	NA	1	180 - 180	44	NA	1	44 - 44	280	NA	1	280 - 280
CaHard	130	NA	1	130 - 130	34	NA	1	34 - 34	210	NA	1	210 - 210
Turb	0.20	NA	1	0.20 - 0.20	0.00	NA	1	0.00 - 0.00	0.20	NA	1	0.20 - 0.20
Amm	NA	NA	0	NA	NA	NA	0	NA	NA	NA	0	0.0 - 0.0
TOC	9.0	NA	1	9.0 - 9.0	0.6	NA	1	0.6 - 0.6	15.0	NA	1	15.0 - 15.0
UV254	NA	NA	0	0.000 - 0.000	NA	NA	0	0.000 - 0.000	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	0	NA	NA	NA	0	NA	NA	NA	0	NA
Bromide	NA	NA	0	0 - 0	NA	NA	0	0 - 0				
TOX	1200	NA	1	1200 - 1200	77	NA	1	77 - 77				
CHCl3	210.0	NA	1	210.0 - 210.0	4.0	NA	1	4.0 - 4.0	Mass Balance Closure Errors (%)			
BDCM	77.0	NA	1	77.0 - 77.0	12.0	NA	1	12.0 - 12.0				
DBCM	26.0	NA	1	26.0 - 26.0	21.0	NA	1	21.0 - 21.0	WQP	Count	Avg	SD/RD
CHBr3	10.0	NA	1	10.0 - 10.0	12.0	NA	1	12.0 - 12.0	Alk	0	n/a	n/a
THM4	323.0	NA	1	323.0 - 323.0	49.0	NA	1	49.0 - 49.0	TDS	1	5	n/a
MCAA	8.0	NA	1	8.0 - 8.0	3.0	NA	1	3.0 - 3.0	TotHard	1	-2	n/a
DCAA	98.0	NA	1	98.0 - 98.0	5.0	NA	1	5.0 - 5.0	CaHard	1	2	n/a
TCAA	140.0	NA	1	140.0 - 140.0	1.0	NA	1	1.0 - 1.0	Turb	0	n/a	n/a
MBAA	3.0	NA	1	3.0 - 3.0	0.0	NA	1	0.0 - 0.0	Amm	0	n/a	n/a
DBAA	9.0	NA	1	9.0 - 9.0	8.0	NA	1	8.0 - 8.0	TOC	1	-4	n/a
BCAA	NA	NA	0	NA	NA	NA	0	NA	UV254	0	n/a	n/a
TBAA	NA	NA	0	NA	NA	NA	0	NA	TDS <sub>t</sub> 1 5 #DIV/0!			
CDBAA	NA	NA	0	NA	NA	NA	0	NA				
DCBAA	NA	NA	0	NA	NA	NA	0	NA	Comments:			
HAA5	258.0	NA	1	258.0 - 258.0	17.0	NA	1	17.0 - 17.0				
HAA6	NA	NA	0	NA	NA	NA	0	NA				
HAA9	NA	NA	0	NA	NA	NA	0	NA				
SDS Conditions					Pretreatment Information							
WQP	Avg	SD	Count	Min - Max	Process		Description		Scale			
Res (0)	0.20	0.00	2	0.20 - 0.20	Alum Coagulation		Aluminum sulfate dose: 151.4 mg/L		Full-scale			
Temp (°C)	22.0	0.0	2	22.0 - 22.0	Sedimentation		Circular clarifier		Full-scale			
pH (unit)	7.6	0.0	2	7.6 - 7.6	Dual Media Filtration		Sand/anthracite		Full-scale			
Time (hr)	96.0	0.0	2	96.0 - 96.0	Sulfuric Acid Feed		Approx. 85 mg/L to pH 3.5 to 4.5		Pilot-scale			
					Microfiltration		5um filter Filter Specialists Bag Filter		Pilot-scale			

## Mass Balance Errors

Pressure	RPD	SD	Flow	RPD	SD	TDS	RPD	SD
System Inf - Stg 1 Inf	0.1%	1.3%	System Inf - Stg 1 Inf	0.0%	0.0%	System Inf - Stg 1 Inf	0.0%	#DIV/0!
Sys Conc - Stg 2 Conc	0.0%	0.0%	Sys Conc - Stg 2 Conc	0.0%	0.0%	Sys Conc - Stg 2 Conc	0.0%	#DIV/0!
Stg 1 Conc - Stg 2 Inf	0.0%	0.0%	Stg 1 Conc - Stg 2 Inf	0.0%	0.0%	Stg 1 Conc - Stg 2 Inf	0.0%	#DIV/0!
Sys Perm - Avg Stg Perr	10.0%	3.4%	Sys Perm - Sum Stg Per	0.0%	0.0%	Sys Perm - Avg Stg Perm	-6.6%	#DIV/0!

## Stage Summary

WQP	Stage 1 Influent						Stage 1 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			0.30	NA	1	0.30 - 0.30					
pH	7.3	4.4	7.3	NA	1	7.3 - 7.3	4.4	4.5	NA	1	4.5 - 4.5
Temp	27.8	27.8	27.8	NA	1	27.8 - 27.8	27.8	27.8	NA	1	27.8 - 27.8
Alk	NA	0	NA	NA	0	0 - 0	0	0	NA	1	0 - 0
TDS	410	590	410	NA	1	410 - 410	220	200	NA	1	200 - 200
TotHard	180	280	180	NA	1	180 - 180	44	36	NA	1	36 - 36
CaHard	130	210	130	NA	1	130 - 130	34	29	NA	1	29 - 29
Turb	0.20	0.20	0.20	NA	1	0.20 - 0.20	0.00	0.00	NA	1	0 - 0
TOC	9.0	15.0	9.0	NA	1	9.0 - 9.0	0.6	0.5	NA	1	0.5 - 0.5
UV254	NA	NA	NA	NA	0	0.000 - 0.000	NA	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	NA	NA	0	NA	NA	NA	NA	0	NA

WQP	Stage 2 Influent						Stage 2 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery			0.21	NA	1	0.21 - 0.21					
pH	7.3	4.4	4.4	NA	1	4.4 - 4.4	4.4	4.7	NA	1	4.7 - 4.7
Temp	27.8	27.8	27.8	NA	1	27.8 - 27.8	27.8	27.8	NA	1	27.8 - 27.8
Alk	NA	0	0	NA	1	0 - 0	0	0	NA	1	0 - 0
TDS	410	590	520	NA	1	520 - 520	220	270	NA	1	270 - 270
TotHard	180	280	220	NA	1	220 - 220	44	61	NA	1	61 - 61
CaHard	130	210	170	NA	1	170 - 170	34	50	NA	1	50 - 50
Turb	0.20	0.20	0.30	NA	1	0.30 - 0.30	0.00	0.00	NA	1	0 - 0
TOC	9.0	15.0	12.0	NA	1	12.0 - 12.0	0.6	0.8	NA	1	0.8 - 0.8
UV254	NA	NA	NA	NA	0	0.000 - 0.000	NA	NA	NA	0	0.000 - 0.000
SUVA	NA	NA	NA	NA	0.00	NA	NA	NA	NA	0.00	NA


  

WQP	Stage 3 Influent						Stage 3 Permeate				
	Sys Feed	Sys Conc	Mean	SD	Count	Min/Max	Sys Perm	Mean	SD	Count	Min/Max
Recovery											
pH											
Temp											
Alk											
TDS											
TotHard											
CaHard											
Turb											
TOC											
UV254											
SUVA											

## Water Quality Parameter Graphs


## Chart Legend:

- Feed (System)
- ▲ Permeate (System)





## Water Quality Graphs (Continued)



## Productivity Graphs

