

ICR Treatment Study Summary Report

Evaluation of Pilot-Scale GAC Technology for Compliance with the Information Collection Rule

Conducted during the period of October 1998 through June 1999

Prepared by:
Saint Paul Water Utility
PWSID# 428
1900 Rice Street N
Saint Paul, MN 55113
Tel.: (651) 558-2116
Fax: (651) 558-2120

In August 1999

Attachments: 2 diskettes containing the Data Collection Spreadsheets

Evaluation of Pilot-Scale GAC Technology for Compliance with the Information Collection Rule

ICR Treatment Study Summary Report

I. Conclusions And Recommendations

The granular activated carbon pilot shown ability to reduce disinfection byproduct species by adsorbing the precursor total organic carbon. The carbon was quickly exhausted, however, due to the large concentrations of organic carbon in the influent waters. Typical run times (60% breakthrough) were on the order of 150 hours in warm water and about 1250 hours in cold water. The disinfection by products began forming in significant quantities at 100 to 200 hours in the 20 EBCT column in warm water and about 500 hours in cold water. The 10 minute EBCT columns showed earlier accumulation of disinfection byproducts in warm water, and significant number at the beginning of the run for total trihalomethanes (TTHM's). The consistency of the data is somewhat altered by the change of carbon type between the warm and cold water runs.

The prevalent forms of disinfection by products formed were chloroform and dibromochloromethane which are consistent with the TTHM data collected in our treatment plant effluent water for the past two decades. Dichloroacetic acid and trichloroacetic acid were the dominant forms found in the pilot effluent and are also consistent with the limited treatment plant effluent data collected in the past year.

It appears from the pilot data that granular activated carbon would not be a cost effective alternative for use in limiting disinfection byproduct formation at the Saint Paul Water Utility Treatment Plant. The cost for operating and maintaining a full scale process would greatly exceed initial capital costs due to the need for frequent regeneration of the carbon media..

II. Background Information

The Saint Paul Water Utility (SPWU) water treatment process consists of a lime softening and alum-ferric chloride coagulation/flocculation scheme followed by clarification and rapid sand filtration. Quick lime is added to the raw water entering the plant along with aluminum sulfate in a rapid mix resulting in an increase in pH to a range between 10.8 and 11.2 for the warm water and cold water seasons, respectively. Potassium permanganate is fed to the rapid mixing chamber in the event of a taste and odor incidence. The lime-alum solution is then flocculated in three consecutive

rectangular basins for approximately 15 to 30 minutes per reactor, depending on flow rates. The solids are separated by gravity settling in two radial and three rectangular clarifiers. The clear water overflows are collected and channeled into a rectangular recarbonation basin. The pH is lowered to an average of 8.7 with carbon dioxide and immediately followed by the disinfection processes.

The initial disinfection step occurs within the remainder of the recarbonation basin following pH reduction to 8.7. Free chlorine is added at either 26, 42.17, or 57.75 feet upstream of the basin effluent to provide ample time for virus inactivation. The different feed points are used in response to elevated THM levels that may occur, in which case the feed point would be moved closer to the exit of the basin to reduce the THM formation reaction time. Ammonia is fed at the effluent of the recarbonation basin to quench the chlorine and form monochloramines for the inactivation of *Giardia lamblia*; additional chlorine is fed along with the ammonia to boost the chloramine residual, (excess ammonia is added to accommodate a third chlorine dose). The water containing the chloramine residual flows into two, 3 million gallon secondary settling basins configured in a parallel flow arrangement. The water then passes to 12 dual media filters and 12 rapid sand filters arranged in four galleries of six filters each. The filtered water is collected in four small clearwells located immediately below each gallery. The water is again dosed with chlorine to raise the chloramine residual prior to entering the large 20 million gallon reservoir. Effluent water from the finished water reservoir is then dosed with sodium hydroxide to adjust the pH to 9.2 for corrosion control purposes. Finally, the water flows to the pumps where it is sent to the distribution system. Tables A.2 and A.3 from the ICR Database have been attached to this report with the details of the design plant parameters and the chemical parameters.

TREATMENT CHALLENGES FACING PLANT

Among the most pressing issues facing the St. Paul Water Utility, are the current rules and largely undefined future regulatory climate. These rules demand ever increasing water quality standards while providing little to no economic incentive or support. In addition, the various MCL's often create conflicting treatment strategies where optimized treatment for one contaminant is done at the expense of another. The most prevalent case is disinfection at the expense of disinfection byproducts.

Monitoring results from the ICR and the MN Department of Health suggest that we will easily meet the requirements of the Disinfectants and Disinfection Byproducts Rule. Our combined filter effluent turbidities indicate that we will also meet the requirements of the Interim Enhanced Surface Water Treatment Rule. We seem to be optimized given our current disinfection scheme and our influent TOC levels. However, meeting the future requirements of Stage 2 D/DBPs, (whatever they may be), may prove more difficult.

The Lead and Copper Rule is another regulation that has caused much concern and expense due to the single fact that we are directed to control contamination sources in household plumbing over which we have little control. The MCL's associated with this rule do not appear to be realistic in terms of public health concerns. The most effective control is phosphate addition, which creates and/or exacerbates further problems downstream at waste treatment facilities and natural aquatic systems. The cost vs. benefit of this strategy may not have been fully examined. Although we have reduced lead levels to very near the action level, currently, we are in a mandatory lead service line replacement program as a result of not meeting the "action level" for two consecutive

semesters. This is causing great expense with little evidence of significantly reducing the problem; tier-1 copper services are statistically the same as tier-1 lead services.

The most urgent concern for our utility is the threat of privatization. We are forced to do “more for less” to meet the ever stringent EPA regulations and be competitive at the same time. The net result, even if stressful, is very positive, however. We as a work group have been forced to reexamine our work loads, attitudes, and ethics. As a result we have become more efficient and effective as water and service provider. Our understanding of the treatment process and goals have been enhanced by the combination of increased regulations coupled with competitive forces.

One of the major complaints voiced during the past decade was the setting of regulatory based on health risk assessment and laboratory simulations of treatment effectiveness. The information collection rule along with the treat ability studies are viewed as an effort by the EPA to base the next set of regulations on additional real world factors such as cost, need, and effectiveness across the wide set of water quality scenarios existing throughout North America. This step has been received with confidence within our utility as a method of optimizing cost and benefit for human health protection.

Table 1 Tabular Summary of Source/Finished Water Quality

Full-Scale Water Quality Data						
Full-Scale Influent Water Quality Data						
Item	Units	Average	Std Dev	Min	Max	Count
Temperature	C	10.01	5.44	3	23	266
pH	Unit	8.15	0.23	7.7	8.9	269
Turbidity	ntu	1.33	0.8	0.35	3.6	269
Alkalinity	mg/L as CaCO ₃	168.98	18.62	130	220	269
Total Hardness	mg/L as CaCO ₃	181.7	18.41	140	234	269
Calcium Hardness	mg/L as CaCO ₃	129.13	19.37	82	198	269
TOC	mg/L	8.69	0.91	7.1	10.1	7
UV ₂₅₄	1/cm	0.19	0.01	0.172	0.207	7
Bromide	µg/L	<0.02				3
TSUVA*	L/(mg*m)	0.022	0.0025	0.0195	0.0255	7
*TSUVA = [UV ₂₅₄ (1/m)] / [TOC (mg/L)]. Summary information for TSUVA should only be calculated from TSUVA values with paired TOC and UV ₂₅₄ measurements						
Full-Scale Finished Water Quality Data						
Item	Units	Average	Std Dev	Min	Max	Count
Temperature	C	10.09	5.44	3	23	270
pH	unit	8.96	0.18	8.06	9.65	269
Turbidity	ntu	0.06	0.04	0.01	0.19	270
TOC	mg/L	4.3	0.57	3.2	5	7
UV ₂₅₄	1/cm	0.07	0.01	0.044	0.081	7
DS-THM4	µg/L	26.67	6.74	21.8	36.2	3
DS-HAA5	µg/L	27.4	1.53	25.4	29.1	3
DS-HAA6	µg/L	30.17	1.49	28.2	31.8	3

III. Materials And Methods

PRETREATMENT PROCESSES TO THE ADVANCED TREATMENT PROCESS

Table 2 Tabular Summary of Pretreatment Design Data

UNIT PROCESS	PROCESS DESCRIPTION
Rapid Mix (Full Scale)	Type of Mixer: ME Baffling Type: AV Liquid Volume (gal): 59,000 Mean Velocity Gradient (sec-1): 100.0
Flocculation (Full Scale)	Type of Mixer: ME Liquid Volume (gal): 2,926,000 Baffling Type: SP Stage Sequence Number: 1 Stage Mean Velocity Gradient (sec-1): 18 Stage Liquid Volume (gal): 981,000 Stage Sequence Number: 2 Stage Mean Velocity Gradient (sec-1): 18 Stage Liquid Volume (gal): 882,000 Stage Sequence Number: 3 Stage Mean Velocity Gradient (sec-1): 14 Stage Liquid Volume (gal): 1,063,000
Sedimentation (Full Scale)	Surface Area(ft ²): 83,150 Liquid Volume (gal): 13,390,000 Baffling Type: PR
PH Adjustment (Pilot Scale)	Chemical Type: Carbon Dioxide Adjusted pH: 7.0
Filtration (Pilot Scale)	Total Media Depth (in): 40 Media Type: DUAL Sand Depth (in): 4 Anthracite Depth (in): 36

ADVANCED TREATMENT PROCESS INFORMATION

List of equipment:

- 9-foot glass columns
- centrifugal pumps
- stainless steel tanks
- mixer with stainless steel rod
- pH meter
- solenoid valve
- pressure gages

- flow meter
- mass flow meter
- manual valves
- Teflon tubing
- Teflon gaskets

EXPERIMENTAL DESIGN

The SPWU historical database shows two distinctive seasonal periods based upon water temperature. The transitional periods are relatively short, therefore only two situations were evaluated: warm and cold water.

Table 3 Experimental Design Summary

SEASON	PRETREATMENT	EBCT, MIN
Warm Water	Recarbonation, Conventional Filtration	10 & 20
Cold Water	Recarbonation, Conventional Filtration	10 & 20

IV. Results And Discussion

PROBLEMS ENCOUNTERED

We had a difficult time starting up the columns. Due to breakage and replacement of the glass columns, we had to postpone our start-up date until September 1998. Then the breakthrough was occurring extremely fast, so we stopped and re-considered our possibilities. With the advice of Steve Allgeier, we adjusted the pH to an average of 7.0 before the GAC columns. The initial goal was to simulate the full-scale treatment pH of 8.5. Since the historical data suggested seasonality of the DBP formation and not of the influent TOC, we decided to incubate the SDS samples at 23°C to test the warm water conditions in the distribution system. October is typically a transition month in Minnesota and we couldn't keep the influent water temperature constant. We still had some trouble with the logistics of sending the samples on a timely manner to the laboratory due to the fast breakthrough. We failed to send 4 SDS samples from the first run.

Although we had performed isotherm analysis to select the best carbon for our water, the warm water run showed a poor performance and we decided to change carbon brand . The carbon types used in each run are documented in the data collection spreadsheets. The second run started in February 1999 and ended in June 1999. The performance improved to some degree, but it is difficult to tell if it was due to the temperature or the carbon type.

Table 4 GAC Warm Water Run – Summary of DBP Breakthrough Scenarios

Breakthrough Criterion	Value of Listed Parameter When Breakthrough Criterion is Met													
	Run Time (days)		Throughput (Bed Vol.)		TOC (mg/L)		SDS-THM4 (µg/L)		SDS-HAA5 (µg/L)		SDS-HAA6 (µg/L)		SDS-TOX (µg Cl ⁻ /L)	
EBCT (minutes)	10	20	10	20	10	20	10	20	10	20	10	20	10	20
SDS-THM4 = 90 µg/L	7	14	1011	1006	1.9	1.6	92.10	94.8	17.10	27.3	20.10	31.20	160	145
SDS-THM4 = 72 µg/L		12		866		1.3		61		17.3		20.6		110
SDS-THM4 = 54 µg/L	5	10	755	719	1.2	0.9	54.25	45	11.60	7.2	14.45	9.50	94	63
SDS-THM4 = 36 µg/L	1	8	144	577	0.9	0.8	39.50	34.9	8.20	6.0	10.30	8.10	63	52
SDS-HAA5 = 54 µg/L	8	19	1154	1371	2.2	2	145	147	32.90	48.9	37.10	53.4	230	250
SDS-HAA5 = 27 µg/L	7	14	1011	1006	1.9	1.6	92.10	94.8	17.10	27.3	20.10	31.2	160	145
SDS-HAA6 = 54 µg/L	8	19	1154	1371	2.2	2	145	147	32.90	48.9	37.10	53.4	230	250
SDS-HAA6 = 27 µg/L	7	14	1011	1006	1.9	1.6	92.10	94.8	17.10	27.3	20.10	31.2	160	145

Table 5 GAC Cold Water Run – Summary of DBP Breakthrough Scenarios

Breakthrough Criterion	Value of Listed Parameter When Breakthrough Criterion is Met													
	Run Time (days)		Throughput (Bed Vol.)		TOC (mg/L)		SDS-THM4 (µg/L)		SDS-HAA5 (µg/L)		SDS-HAA6 (µg/L)		SDS-TOX (µg Cl ⁻ /L)	
EBCT (minutes)	10	20	10	20	10	20	10	20	10	20	10	20	10	20
SDS-THM4 = 90 µg/L	53	104	7611	7476	2.2	4	77.7	72.6	21.4	23.3	25.3	27.7	165	185
SDS-THM4 = 72 µg/L	34	104	4902	7476	1.8	4	58.5	72.6	12.9	23.3	16.6	27.7	115	185
SDS-THM4 = 54 µg/L	25	77	3600	5535	0.9	1.3	33.9	38.7	8.5	11.0	11.2	14.0	66	73
SDS-THM4 = 36 µg/L	25	61	3600	4379	0.9	1.3	33.9	36	8.5	9.65	11.2	12.4	66	70
SDS-HAA5 = 54 µg/L	61	104	8766	7476	NA	4	174.3	72.6	52.6	23.3	58.5	27.7	330	185
SDS-HAA5 = 27 µg/L	55	104	7902	7476	2.4	4	73.7	72.6	21.3	23.3	25.5	27.7	175	185
SDS-HAA6 = 54 µg/L	61	104	8766	7476	NA	4	174.3	72.6	52.6	23.3	58.5	27.7	330	185
SDS-HAA6 = 27 µg/L	55	104	7902	7476	2.4	4	73.7	72.6	21.3	23.3	25.5	27.7	175	185

V. QA/QC Summary

A hard copy of the QA/QC spreadsheets have been added to the Appendix. The file Tssumrpt.xls is attached to this report.

Table of Contents

I. CONCLUSIONS AND RECOMMENDATIONS	2
II. BACKGROUND INFORMATION	2
Treatment challenges facing plant.....	3
III. MATERIALS AND METHODS	5
Pretreatment Processes to the Advanced Treatment Process	5
Advanced Treatment Process Information.....	5
Experimental Design.....	6
IV. RESULTS AND DISCUSSION	6
Problems Encountered	6
V. QA/QC SUMMARY.....	8

List of Tables

Table 1 Tabular Summary of Source/Finished Water Quality.....	4
Table 2 Tabular Summary of Pretreatment Design Data.....	5
Table 3 Experimental Design Summary	6
Table 4 GAC Warm Water Run – Summary of DBP Breakthrough Scenarios	7
Table 5 GAC Cold Water Run – Summary of DBP Breakthrough Scenarios	7

Appendix

TABLE A.2 DESIGN PLANT PARAMETERS FROM *ICR DATABASE*

TABLE A.3 DESIGN PLANT CHEMICAL PARAMETERS FROM *ICR DATABASE*

WATER QUALITY SUMMARY

SIMULATED DISTRIBUTION SYSTEM CONDITIONS

SDS- DISINFECTION BY-PRODUCT SUMMARY

TREATMENT PLANT SCHEMATIC

PRETREATMENT SYSTEM SCHEMATIC

GAC PILOT PLANT DIAGRAM

GAC PILOT PLANT SCHEMATIC

TOC BREAKTHROUGH CURVE, WARM WATER RUN

DBP CONCENTRATION CURVES, WARM WATER RUN

TOC BREAKTHROUGH CURVE, COLD WATER RUN

DBP CONCENTRATION CURVES, COLD WATER RUN

COST ANALYSIS

HARD COPIES OF FIELDS 1 THROUGH 6 FROM THE *ICR TREATMENT STUDY DATA COLLECTION SPREADSHEETS*

HARD COPIES OF SPREADSHEETS FROM THE *ICR TREATMENT STUDY SUMMARY REPORT*

A.2 -- Design Plant Parameters

Date: 08/30/99

PWS Name: Saint Paul Water Utility

PWS ID: MN1620026

WIDB:

ICR Contact Person: Ms. Justine Roe

Sampling Period: Design
Design Sampling Start Date: 07/29/97
Design Sampling End Date: 01/06/99

Treatment Plant Name: McCarron's Filtration Plant

ICR Treatment Plant ID: 428

Treatment Plant PWS ID:

Treatment Plant Category: CS/SOFT

State Approved Plant Capacity (MGD): 144.0
Historical Min. Water Temperature (deg C): 2.0
Installed Sludge Handling Capacity (DPD): 250,000.00
Blending Indicator: N

Water Resource Name: Vadnais Lake
Water Resource Type: Reservoir/lake
Average Residence Time (Days): 69
Intake Name: Vadnais Lake Gatehouse
Watershed Control: Y

Hydrologic Unit Code:
River Reach:

Latitude (degrees, minutes, seconds): +45°2'56.1"
Longitude (degrees, minutes, seconds): -93°5'40.74"
River Reach Miles:

Water Resource Name: Well B
Water Resource Type: Ground water
Intake Name: Well B
Wellhead Protection: N

Hydrologic Unit Code:

Latitude (degrees, minutes, seconds): +45°2'48.12"
Longitude (degrees, minutes, seconds): -93°5'50.64"

Water Resource Name: Well C
Water Resource Type: Ground water
Intake Name: Well C
Wellhead Protection: N

Hydrologic Unit Code:

Latitude (degrees, minutes, seconds): +45°2'56.1"
Longitude (degrees, minutes, seconds): -93°5'40.74"

Saint Paul Water Utility

Page 1

A.2 -- Design Plant Parameters 08/30/99

Water Resource Name: Well D
Water Resource Type: Ground water
Intake Name: Well D
Wellhead Protection: N

Hydrologic Unit Code:

Latitude (degrees, minutes, seconds): +45°2'50.34"
Longitude (degrees, minutes, seconds): -93°5'40.98"

Water Resource Name: Well E
Water Resource Type: Ground water
Intake Name: Well E
Wellhead Protection: N

Hydrologic Unit Code:

Latitude (degrees, minutes, seconds): +45°2'13.98"
Longitude (degrees, minutes, seconds): -93°6'5.58"

Seq. Sample No. Location Name	Sample Location Type	Sample Loc. No.
-------------------------------------	----------------------------	-----------------------

Influent	INF	1
----------	-----	---

Process Train Name: Main

Process Train Category: CS/SOFT

1	Rapid Mix	Rapid Mix
---	-----------	-----------

Type of Mixer: ME

Baffling Type: AV

Liquid Volume (gal): 59,000

Short Circuiting Factor:

Mean Velocity Gradient (sec-1): 100.0

2	Flocculator	Flocculation Basin
---	-------------	--------------------

Type of Mixer: ME

Liquid Volume (gal): 2,926,000

Short Circuiting Factor:

Baffling Type: SP

Seq. Sample
No. Location
Name

Sample
Location
Type

Sample
Loc.
No.

Stage Sequence Number: 1
Stage Mean Velocity Gradient (sec-1): 18
Stage Liquid Volume (gal): 981,000

Stage Sequence Number: 2
Stage Mean Velocity Gradient (sec-1): 18
Stage Liquid Volume (gal): 882,000

Stage Sequence Number: 3
Stage Mean Velocity Gradient (sec-1): 14
Stage Liquid Volume (gal): 1,063,000

3 Clarifier
Sedimentation
2
Surface Area (ft²): 83,150
Liquid Volume (gal): 13,390,000
Baffling Type: PR
Short Circuiting Factor:
Plate Settler Surface Area (ft²):
Plate Settler Brand Name:
Tube Settler Surface Area (ft²):
Tube Settler Brand Name:

4 Chlorine g/s
Disinfectant Addition
Chemical Code: CL2
Measurement Formula: CL2
Dose Rate (mg/L): 4.20

5 Anhydrous ammon
Disinfectant Addition
Chemical Code: NH3A

Saint Paul Water Utility

Page 3

A.2 -- Design Plant Parameters 08/30/99

Seq. Sample
No. Location
Name

Sample
Location
Type

Sample
Loc.
No.

Measurement Formula: NH3
Dose Rate (mg/L): 1.00

6 Recarb Chamber

Recarbonation Basin

3

Surface Area (ft2): 2,910
Liquid Volume (gal): 435,300
Baffling Type: PR
Short Circuiting Factor: 0.7

7 Second Settling

Sedimentation

4

Surface Area (ft2): 49,164
Liquid Volume (gal): 6,150,000
Baffling Type: AV
Short Circuiting Factor: 0.54
Plate Settler Surface Area (ft2):
Plate Settler Brand Name:
Tube Settler Surface Area (ft2):
Tube Settler Brand Name:

8 Filtration

Filtration

5

Surface Area (ft2): 33,264
Liquid Volume (gal): 1,389,192
Total Media Depth (in): 42
Depth of GAC (in):
Media Type: DUAL
Type of Activated Carbon:
Minimum Water Depth To Top of Media (ft): 3.0
Depth From Top of Media to Top of Backwash Trough (ft): 3.0

Seq. Sample No. Location Name	Sample Location Type	Sample Loc. No.	
9 Clearwell	Clearwell	6	Surface Area (ft2): 34,272 Liquid Volume (gal): 3,000,000 Minimum Liquid Volume (gal): 700,000 Baffling Type: PR Short Circuiting Factor: 0.42 Covered Indicator Code: Y Chemical Code: CL2 Measurement Formula: Cl2 Dose Rate (mg/L): 0.80
10 Chlorine gas	Disinfectant Addition		
11 Fin Water Res	Clearwell		Surface Area (ft2): 137,000 Liquid Volume (gal): 20,000,000 Minimum Liquid Volume (gal): 7,600,000 Baffling Type: PR Short Circuiting Factor: Covered Indicator Code: Y
12 Chemical Feed	Other Treatment Process		Surface Area (ft2): Liquid Volume (gal): Short Circuiting Factor:
Finished Water	FIN	7	

End of Report A.2 -Design Plant Parameters

A.3 -- Design Plant Chemical Parameters

Date: 08/30/99

PWS Name: Saint Paul Water Utility

PWS ID: MN1620026

WIDB:

ICR Contact Person: Ms. Justine Roe

Sampling Period: Design

Sampling Start Date: 07/29/97

Sampling End Date: 01/06/99

Sep. No.	Sample Location Name	Sample Location Type	Sample Location Number	Chemical Name	Measurement Formula	Dose (mg/L)
----------	----------------------	----------------------	------------------------	---------------	---------------------	-------------

Treatment Plant Name: McCarron's Filtration Plant

ICR Treatment Plant ID No: 428

Treatment Plant Category: CS/SOFT

Process Train Name: Main

Process Train Category: CS/SOFT

1	Rapid Mix	Rapid Mix		Calcium hydroxide Potassium permanganate Aluminum sulfate (Alum)	CaO KMnO4 Al2(SO4)3.18H2O	150.00 1.00 15.00
2	Flocculator	Flocculation Basin				
3	Clarifier	Sedimentation	2	Powdered activated carbon Ferric chloride	C FeCl3.6H2O	1.00 4.00
4	Chlorine gas	Disinfectant Addition		Chlorine gas	Cl2	4.20

Saint Paul Water Utility

Page 1

A.3 -- Design Plant Chemical Parameters 08/30/99

Sep. No.	Sample Location Name	Sample Location Type	Sample Location Number	Chemical Name	Measurement Formula	Dose (mg/L)
5	Anhydrous ammon	Disinfectant Addition				
6	Recarb Chamber	Recarbonation Basin	3	Anhydrous ammonia	NH3	1.00
7	Second Settling	Sedimentation	4	Hydrofluorosilic acid	F	1.00
8	Filtration	Filtration	5	Carbon dioxide	CO2	28.00
9	Clearwell	Clearwell	6	Ferric chloride	FeCl3.6H2O	0.25
10	Chlorine gas	Disinfectant Addition				
11	Fin Water Res	Clearwell		Chlorine gas	Cl2	0.80
12	Chemical Feed	Other Treatment Process		Sodium hydroxide	NaOH	5.00

End of Report A.3 -- Design Plant Chemical Parameters

Saint Paul Water Utility

GAC Pilot Study - Water Quality Summary

First Run: Warm Water

	pH	Turbidity	Alkalinity	Temp.	Total Hardness	Calcium Hardness	Ammonia	Bromide	TOC	UV254	SUVA
	---	ntu	mg/L as CaCO3	oC	mg/L as CaCO3	mg/L as CaCO3	mg NH3-N / L	mg/L	mg/L	cm-1	L/(mg*m)
Influent	Avg	6.84	65.95	19.11	85.68	60.55	0.10	BMRL *	4.26	0.077	1.81
	Std	0.17	14.87	2.78	2.70	4.94	0.00		0.38	0.02	0.40
	Count	19	19	19	11	11	9		19	19	19
	Min	6.51	58	11	81	53	0.1		3.7	0.01	0.27
	Max	7.27	128	22.5	91	69	0.1		4.92	0.096	2.34
10 min EBCT	Avg	6.94	Not Analyzed	19.53	Not Analyzed	Not Analyzed	0.11	Not Analyzed	2.81	0.045	1.55
	Std	0.16		2.92			0.03		0.98	0.02	0.18
	Count	19		19			11		19	19	19
	Min	6.71	0.06	11			0.1		0.9	0.01	1.11
	Max	7.36	0.14	24			0.2		4.08	0.07	1.92
20 min EBCT	Avg	6.98	Not Analyzed	19.45	Not Analyzed	Not Analyzed	0.10	Not Analyzed	2.14	0.037	1.83
	Std	0.47		2.79			0.00		0.85	0.01	1.54
	Count	19		19			6		17	15	15
	Min	6.61	0.06	11			0.1		0.6	0.017	1.24
	Max	8.85	0.22	23			0.1		3.3	0.068	7.56

Second Run: Cold Water

	pH	Turbidity	Alkalinity	Temp.	Total Hardness	Calcium Hardness	Ammonia	Bromide	TOC	UV254	SUVA
	--	ntu	mg/L as CaCO3	oC	mg/L as CaCO3	mg/L as CaCO3	mg NH3-N / L	mg/L	mg/L	cm-1	L/(mg*m)
Influent	Avg	7.31	53.53	11.18	89.62	57.76	0.21	0.00	3.54	0.061	1.74
	Std	0.90	5.60	2.57	22.25	23.01	0.16	0.00	0.37	0.01	0.16
	Count	17	17	17	17	17	14	2	17	17	17
	Min	6.48	43	9	72.5	44	0.1	0	2.9	0.05	1.48
	Max	10.83	65	18	175	148	0.5	0	4.1	0.075	2
10 min EBCT	Avg	7.18	Not Analyzed	12.26	Not Analyzed	Not Analyzed	0.20	Not Analyzed	1.96	0.028	1.19
	Std	0.40		1.62			0.20		1.16	0.02	0.26
	Count	19		19			14		16	13	13
	Min	5.98		10			0.1		0.6	0.009	0.75
	Max	8.31		16			0.8		5.5	0.081	1.6
20 min EBCT	Avg	7.26	Not Analyzed	13.18	Not Analyzed	Not Analyzed	0.16	Not Analyzed	1.38	0.026	1.34
	Std	0.70		2.18			0.08		0.99	0.02	0.52
	Count	17		17			10		9	5	5
	Min	5.95		11			0.1		0.5	0.013	1
	Max	9.67		18			0.3		4	0.054	2.33

* Below Minimum Reporting Level

Saint Paul Water Utility

GAC Pilot Study - Simulated Distribution System Conditions

First Run: Warm Water

	SDS mg/L	Free Cl2 dose mg/L	SDS mg/L	SDS mg/L	SDS mg/L	Chlorination temp. oC	SDS Chlorination pH	SDS Incubation time hours
Influent	Avg	10	0.74	8.83	23	23	9.04	233
	Std	2.07	0.94	1.56	0.00	0.00	0.11	93.37
	Count	13	13	13	13	13	13	13
	Min	7.12	0.05	5.72	23	23	8.83	168
	Max	15	3.6	11.4	23	23	9.21	432
10 min EBCT	Avg	5.29	0.30	4.99	23	23	8.99	245
	Std	1.83	0.19	1.91	0.00	0.00	0.17	100.38
	Count	15	15	15	15	15	15	15
	Min	3.05	0.1	2.25	23	23	8.71	168
	Max	6.8	0.8	6.7	23	23	9.2	456
20 min EBCT	Avg	3.60	0.63	2.97	23	23	9.05	224
	Std	1.39	0.56	1.17	0.00	0.00	0.11	72.62
	Count	15	15	15	15	15	15	15
	Min	2.54	0	1.44	23	23	8.83	168
	Max	8.47	2.2	6.27	23	23	9.2	384

Second Run: Cold Water

	SDS mg/L	Free Cl2 dose mg/L	SDS mg/L	SDS mg/L	SDS mg/L	Chlorination temp. oC	SDS Chlorination pH	SDS Incubation time hours
Influent	Avg	5.00	1.88	3.12	9.65	9.65	9.21	176.47
	Std	0.00	0.41	0.41	0.76	0.76	0.11	27.23
	Count	17	17	17	17	17	17	17
	Min	5	1.1	2.5	8	8	8.92	144
	Max	5	2.5	3.9	10	10	9.38	240
10 min EBCT	Avg	3.11	2.07	1.04	9.79	9.79	9.11	193.26
	Std	0.31	0.30	0.31	0.61	0.61	0.35	31.60
	Count	19	19	19	19	19	19	19
	Min	3	1.5	0.7	8	8	7.67	144
	Max	4	2.5	1.5	10	10	9.3	264
20 min EBCT	Avg	3.00	2.50	0.50	9.65	9.65	9.11	176.47
	Std	0.00	0.32	0.32	0.76	0.76	0.46	27.23
	Count	17	17	17	17	17	17	17
	Min	3	1.7	0.1	8	8	7.31	144
	Max	3	2.9	1.3	10	10	9.37	240

Saint Paul Water Utility

GAC Pilot Study - Simulated Distribution System - Disinfection By-Product Summary

First Run: Warm Water


		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS	
		TOX	CHCl3	BDCM	DBCM	CHBr3	THM4	MCAA*	DCAA*	TCAA*	MBAA*	DBAA*	BCAA*	TBAA	CDBAA	DCBAA	HAA5	HAA6													
		mg Cl- /L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L													
Influent	Avg	480	256	19	2	BMRL*	175	8	54	24	BMRL*	BMRL*	6	BMRL*	2	3	54	58													
	Std	77.36	43.33	1.21	0.17		138.04	2.02	14.55	5.24			0.73		0.00	0.84	44.45	47.12													
	Count	12	12	12	12		19	12	12	12			12		1	12	19	19													
	Min	315	169.5	16.5	1.5		0	4	31	13.05			4.4		2.4	2.1	0	0													
	Max	570	320	21	2.1		342.7	11	75.5	30			6.8		2.4	4.8	112.6	118.4													
10 min EBCT	Avg	258.77	135.90	13.93	2.18	BMRL*	120.01	4.98	31.05	10.64	BMRL*	1.00	4.35	BMRL*	2.10	1.70	35.84	39.28													
	Std	118.95	61.30	3.11	0.33		84.21	1.55	16.62	5.73		0.00	1.21		0.00	0.35	28.40	30.33													
	Count	15	15	15	15		19	11	15	15		1	15		1	14	19	19													
	Min	63	30	7.4	1.8		0	2.7	6.3	1.9		1	2.1		2.1	1	0	0													
	Max	405	190	17	3.25		209.3	7.7	50	17		1	6.2		2.1	2.25	70.6	75.7													
20 min EBCT	Avg	153.96	67.24	9.68	2.57	BMRL*	58.44	3.38	17.82	5.17	BMRL*	BMRL*	3.50	BMRL*	BMRL*	1.34	15.94	18.15													
	Std	73.78	43.52	3.82	0.48		53.46	1.02	9.62	2.98			0.97			0.15	16.43	18.16													
	Count	12	14	14	13		19	8	12	12			12			10	19	19													
	Min	37.5	4.3	1.7	1.8		0	2.3	2.6	1		1	1.6			1.1	0	0													
	Max	250	130	14	3.4		146.5	5.2	34	12			4.6			1.5	48.9	53.4													

Second Run: Cold Water

second run. cold water																													
		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS		SDS	
		TOX	CHCl3	BDCM	DBCM	CHBr3	THM4	MCAA*	DCAA*	TCAA*	MBAA*	DBAA*	BCAA*	TBAA	CDBAA	DCBAA	HAA5	HAA6											
		mg Cl- /L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L											
Influent	Avg	361	128	16	2	BMRL*	145	4	28	17	BMRL*	BMRL*	5	BMRL*	2	3	47	52											
	Std	148.09	25.44	1.90	0.39		26.73	0.62	3.09	2.36			0.61		0.20	0.53	5.74	6.09											
	Count	17	17	17	17		17	9	17	17					2	17	17	17											
	Min	77	84	12	1.5		97.5	2.4	22	14			4		2	2.15	36	40											
Max	670	165	19	2.8		185.15	4.5	35	23			5.9		2.4	4.4	55.5	60.9												
10 min EBCT	Avg	135.13	38.58	9.13	3.13	0.55	48.22	3.70	11.63	6.58	BMRL*	BMRL*	3.53	BMRL*	2.80	2.18	14.92	17.89											
	Std	78.27	36.31	4.72	1.19	0.05	41.37	0.10	7.33	3.54		0.40	1.21	0.10	0.71	12.77	14.33												
	Count	16	18	18	18	2	19	2	15	14		6	16	2	16	19	19	19											
	Min	35	0.8	0.6	0.5	0.5	0	3.6	2.4	2.4		1.2	1	2.7	1	0	0	0											
Max	330	150	21	5.2	0.6	174.3	3.8	33	16		2.4	5.9	2.9	3.7	52.6	58.5													
20 min EBCT	Avg	82.14	9.00	4.12	2.57	0.50	15.09	2.10	6.33	3.28	BMRL*	BMRL*	2.81	BMRL*	2.00	1.59	3.86	4.85											
	Std	42.43	14.15	3.54	1.49	0.00	18.37	0.00	4.52	1.82		0.13	0.85	0.00	0.31	6.23	7.61												
	Count	7	17	16	14	3	17	1	6	6		5	6	2	7	17	17	17											
	Min	54	0.6	0.5	0.6	0.5	1.1	2.1	1.6	2		1	1.5	2	2	1.2	0	0											
Max	185	58	12	5.2	0.5	72.6	2.1	16	7.3		1.3	4.4	2	2.2	23.3	27.7													


* Below Minimum Reporting Level


**Treatment Plant
Schematic**
PWSID MN1620026



Saint Paul Water Utility


Pretreatment System Schematic of GAC Study






Saint Paul Water Utility

GAC Pilot Plant Diagram




TOC Breakthrough Curve

Cold Water Pilot GAC Run




TOC Breakthrough Curve


Cold Water Pilot GAC Run




GAC Pilot Study Influent Water - Cold Water Run



GAC Pilot Study 10 minute EBCT - Cold Water Run




GAC Pilot Study 20 minute EBCT - Cold Water Run




TOC Breakthrough Curve

Warm Water Pilot GAC Run




TOC Breakthrough Curve


Warm Water Pilot GAC Run




GAC Pilot Study Influent Water - Warm Water Run



GAC Pilot Study 10 minute EBCT - Warm Water Run



GAC Pilot Study 20 minute EBCT - Warm Water Run



Saint Paul Water Utility

GAC Pilot Study - Cost Analysis

Alternative Number 2: Chloramine-GAC/Sand Filtration-Chloramine

Item No.	Description	Size	Units	Quantity (NO.)	Unit Cost (\$)	Total Cost (\$)
1	GAC Filter Media		tons	680	2,000	1,360,000
2	Flow Meter		each	3	25,000	75,000
3	Valves		each	3	30,000	90,000
4	Chlorine Feed System Modifications		LS	1	30,000	30,000
5	Ammonia Feed System Modifications		LS	1	30,000	30,000
	Sub-Total					1,585,000
	Design Contingency (30%)					475,500
	Overhead & Profit (12%)					190,200
	General Conditions (25%)					396,250
	Bonds & Insurance (2%)					31,700
	Sub-Total					2,678,650
	Final Design & Construction Management (15%)					401,798
	Total - 1996 Dollars					3,080,448
	Escalation 4%/yr, 2001 (22%)					677,698
	Total - 2001 Dollars					3,758,146

Cost Parameter	Parameter Value
Capital Recovery Interest Rate (%)	6%
Capital Recovery Period (years)	unknown
Overhead & Profit Factor (% of construction costs)	12%
Special Site Work Factor (% of construction costs)	15%
Construction Contingencies (% of construction costs)	15%
Engineering Fee Factor (% of construction costs)	10%-15%
1998 ENR Construction Cost Index (CCI base year 1913)	unknown
1998 Producers Price Index (PPI base year 1967 =100)	unknown
Labor Rate + Fringe (\$/work-hour)	\$22 + \$8
Labor Overhead Factor (% of labor)	15%
Electric Rate (\$/kW-h)	\$0.035
Fuel Oil Rate (\$/gal)	None
Natural Gas Rate (\$/ft3)	\$0.60
Current Process Water Rate (\$/1000 gallons)	\$2.00
Modifications to Existing Plant (% of construction costs)	100%