Vapor Recovery Unit Application

Glenwood Springs Producers Technology Transfer Workshop


Presenter: Bill Herrmann

Company: Williams Production RMT



Block Flow Diagram – Crawford Trail





Vapor Recovery Unit





Condensate Flash Tank





Specification Sheet



SPECIFICATION SHEET VAPOR RECOVERY SYSTEM PID NO.: 11/9/2006 WILLIAMS PRODUCTION RMT CO. MARK NO.: X-7701 DELIVERY REQ'D.: REVISION NO: A (for bid) SHIP TO: Crawford Trail Compressor St. P.U. NO.: Crawford Trail Compression & Dehydration Garfield Co., CO PROJECT: FURNISH: Sets / Date Reg'd Sets / Date Regid Preliminary approval dwgs. 2 / 4 wks ARO 4 wks ARO Operating Instructions. / Installation Instructions.

| SPECIFICATIONS FOR VAPOR RECOVERY SYSTEM Trail Ridge Compressor Station | |
|---|------------------------------------|
| SITE ELEVATION AMBIENT TEMPERATURE (Min/Max) | 8500 FT. -20/110 ⁰ F |
| GAS ANALYSIS (Mol%) | |
| Carbon Dioxide | 7.29 |
| Methane | 51.43 |
| Ethane | 18.83 |
| Propane | 11.34 |
| I-Butane | 3.10 |
| N-Butane | 3.25 |
| I-Pentane | 1.35 |
| N-Pentane | 0.97 |
| Hexane Plus | 2.44 |
| TOTAL | 100.00 |
| INLET PRESSURE | 14 PSIA |
| INLET TEMPERATURE | 49 ⁰ F |
| DISCHARGE PRESSURE | 212 PSIA |
| CAPACITY | 0.332 MMSCFD |
| GAS | SWEET NATURAL GAS |
| MOLECULAR WEIGHT | 29.76 |
| SPECIFIC HEAT RATIO (Cp/Cv) | 1.201 |
| COMPRESSIBILITY FACTOR (Z) | 0.9924 |
| DRIVER | ELECTRIC MOTOR |
| | 460 VOLT/ 3 PHASE/ 60 CYCLE |
| POWER | |
| POWER MOTOR ENCLOSURE | TEFC |

Underlying Regulation



- Regulation 7 of the Colorado Air Pollution Control Division (APCD)
- Revised 40 CFR, Subpart HH / O&G Area NESHAP
 - Rule effective on January 3, 2007
 - Subpart HH formerly addressed only major sources
 - Area source requirements now included in Subpart HH

Capital Cost Estimate



- VRU Skid: \$93,000 X 1.5 installation factor = \$139,500
- Condensate Flash Tank: \$40,000 X 2.5 installation factor = \$100,000
- Total Estimated Cost: ~\$240,000

Advantages of VRU over Flaring



- Conserves BTU's of the recycled stream (\$\$\$)
- Eliminates flare stack that may be visible to the public
- Controls CO2 emissions (greenhouse gasses)

Operational Challenges



- Designing for future expansion while maintaining operability at low flow rates
- Reliable power
- Operator understanding

Contact Information



Bill.Herrmann@williams.com

Office Phone: 303-629-8432