

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL RESOURCES
SOUTHCENTRAL TRITION + FIELD OPERATIONS
AIR TO AIR INITIAL PROGRAM

PLAN APPROVAL

STATE OF PENNSYLVANIA
PERMITTING DIVISION

Source & Air

PERMITS

Planning Unit Lead: Bethlehem Island Steam Electric

Source Name & Address

Name: Bethlehem Island Steam Electric Company

Station (See Attachment)

Address: 200 North Ninth Street

City/State/Zip: Hanover, PA 17101-1170

Contact Person: Mrs. Lynn Ratzell

Location:

Organization: Planning Environmental Management

East Hanover Township
York County

In accordance with provisions of the Air Pollution Control Act, the Act of January 8, 1950, P.L. 2119, as amended, and with Chapter 127 of the Rules and Regulations of the Department of Environmental Resources, the Department on DEC 22 1994 approved the NO_x and VOC Reasonably Available Control Technology (RACT) plan for the above source.

Permit Approving Agencies: May 31, 1995.

The plan is subject to the following conditions:

1. The Bethlehem Island SRA's NO_x and VOC RACT plan is to be implemented in accordance with the plans submitted with the application (as herein approved).
2. See attached.

Notify the person listed below when the installation is completed so that the source can be inspected for issuance of an OPERATING PERMIT.

TO: Mr. Richard D. Roller
Air Pollution Control Engineer
One Bharat Boulevard
Harrisburg, PA 17110
(717) 657-4587

Jeff Eason
Program Manager

Southcentral Region 67-2005
Funk District
Permits
EPA, Region III

APPENDIX A 67-0005PENNSYLVANIA POWER & LIGHT COMPANYEQUIPMENT AND CER

1. The following table lists the equipment and SES capabilities of the following sources:

<u>Source</u>	<u>Manufacturer</u>	<u>Control Devices</u>
Boiler Unit 1	Combustion Engineering	Low NO _x Concentric Firing System Level III Burners (ABB/Combustion Engineering)
Boiler Unit 2	Combustion Engineering	Low NO _x Concentric Firing System Level III Burners (ABB/Combustion Engineering)
Boiler Unit 3	Combustion Engineering	Low NO _x Concentric Firing System Level III Burners (ABB/Combustion Engineering)
Diesel Generator 1	General Motors	None
Diesel Generator 2	General Motors	None
Diesel Generator 3	General Motors	None

Conditions Cont'd.

- a. This Plan Approval authorizes temporary operation of the source(s) covered by this Plan Approval provided the following conditions are met:
- a. The Department must receive written notice from Pennsylvania Power & Light Company of the completion of construction and Pennsylvania Power & Light Company's intent to commence operation at least five (5) workdays prior to the completion of construction. The notice must state when construction will be completed and when Pennsylvania Power & Light Company expects to commence operation.
- b. Operation is authorized only to facilitate the start-up and shake-down of sources and air cleaning devices, to permit operations pending the issuance of an Operating Permit or to permit the evaluation of the source(s) for compliance with all applicable regulations and requirements.
- c. This condition authorizes temporary operation of the source(s) for a period of 180 days from the date of commencement of operation, provided the Department receives notice from Pennsylvania Power & Light Company pursuant to subpart 1a, above.

APPROVAL NO. 67-2003PENNSYLVANIA POWER & LIGHT COMPANYBRUNNER ISLAND SCSGENERAL INFORMATION

4. Pennsylvania Power & Light Company may request an extension of compliance with any applicable regulations and plan approval requirements if not been attained here. The extension request shall be submitted in writing at least 30 days prior to the end of this period of temporary operation and shall provide a description of the compliance status of the source, a detailed schedule for establishing compliance, and the reasons compliance has not been attained.
5. The notice submitted by Pennsylvania Power & Light Company pursuant to subpart 4, above, prior to the expiration of this plan approval, shall modify the plan approval expiration date. The new plan approval expiration date shall be 180 days from the date of the written notice.

The purpose of this Plan Approval is for the incorporation of the Department's NO_x and VOC Reasonably Available Control Technology (RACT) requirements for the Brunner Island SCS. This Plan Approval includes those sources and air pollution control devices previously covered under Plan Approval Nos. 67-376-001B, 67-300-023A, and 67-200-005A.

6. The implementation of the NO_x and VOC RACT strategy shall be as expeditious as possible, but no later than May 31, 1995.
7. The ten units 1, 2, and 3 are subject to an interim NO_x emission limit of 0.45 lb/MBtu. This interim limit shall be based on hourly continuous emission monitoring data averaged on a 20-day rolling basis. A final NO_x emission limit will be determined upon a review of one year's worth of emissions monitoring data after the installation of the low NO_x burner technology. The final NO_x emission limit will be incorporated into the Operating Permit upon its issuance [25 Pa. Code, §129.01(j)].
8. Diesel fuel usage in each of the three emergency generators (Diesel Generators 1, 2, and 3) shall be limited to 85,400 gallons during any consecutive 12-month period [25 Pa. Code, §129.93(c)(5)].
9. The Company shall maintain records in accordance with 25 Pa. Code, §129.95 requirements.
10. The NO_x continuous emission monitoring systems shall be operated and maintained in accordance with 25 Pa. Code, Chapters 123 and 179 and the Department's "Continuous Emission Monitoring Manual" (Revision No. 5 - March 1993), as well as in accordance with all other applicable requirements.

PP-PPV-001-67-2005PA. POWER & LIGHT COMPANYEDWARD ISLAND SFSAPPENDIX E

1. Within less than 180 days after the installation of the low NO_x burners, source tests shall be performed on Boiler Units 1, 2, and 3 as outlined below. The tests shall be conducted while the aforementioned sources are operating at their maximum rated capacity:
 - a. Units 1 and 2 - VOC testing only
 - b. Unit 3 - VOC, CO, and NO_x testing
2. At least 45 days prior to the actual testing, two copies of a test procedure and a sketch with dimensions including the location of the sampling ports and other data to insure the collection of representative samples shall be submitted to the Program Manager.
3. At least 140 weeks prior to the test programs, the Program Manager shall be informed of the anticipated time of the tests.
4. Within 45 days after completion of the test programs, two copies of the test reports, including all operating conditions, shall be submitted to the Program Manager.