COMMONWEALTH OF PENNSYLVANIA DEPARTMENT OF ENVIRONMENTAL PROTECTION SOUTHCENTRAL REGION - FIELD OPERATIONS AIR QUALITY PROGRAM

OPERATING PERMIT

In accordance with provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and after due consideration of an application received under Chapter 127 of the rules and regulations of the Department of Environmental Protection, the Department hereby issues this permit for the operation of the air contamination source described below.

		Source &	Air			
Permit No:	06-1034	Cleaning	Device: <u>Bechtelsville</u> Compressor Station			
Owner:	Texas Eastern Transmission Corporation	6	(See Attached)			
Address:	P.O. Box 1642					
	Houston, TX 77251					
Attention:	Mr. Charles Wait	Location:				
			Washington Township			
	Supervisor, Environmental Compliance		Berks County			
6. 	 a. operated in such a manner as not to cause air pollution; b. in compliance with the specifications and conditions of the Reasonably Available Control Technology (RACT) plan; c. operated and maintained in a manner consistent with good operating and maintenance practices. 					
2. Th	is permit-is valid only for the specific é	quipment, t	ocation and owner named above. ~			
	is operating permit is valid for a limit piration. Requests for an operating per- companied by a fee in the amount of \$600 per- can Air Fund. ^a The request should be ma newal of a Permit to Operate form and must mpleted Compliance History form (attached)	it renewat wable to th de on the be received	must be in writing and must be • "Commonwealth of Pennsylvania			

4. See attached.

Failure to comply with the conditions placed on this permit is a violation of Section 127.444. Violation of this or any other provision of Article III of the rules and regulations of the Department of Environmental Protection will result in suspension or revocation of this permit and/or prosecution under Section 9 of the Air Pollution Control Act.

Issued: January 31, 1997

Expires: January 31, 2002

Program Manager

Southcentral Region 06-1034 Lancaster District EPA, Region III

Permits

OPERATING PERMIT

PERMIT NO. 06-1034

TEXAS EASTERN TRANSMISSION CORPORATION

BECHTELSVILLE COMPRESSOR STATION

Sources, Continued

The Bechtelsville Compressor Station consists of the following sources:

Source	Company I.D.	Manufacturer/Model	Control Device
5000 Hp Gas Turbine	31902	Westinghouse/W-52	None
5000 Hp Gas Turbine	31903	Westinghouse/W-52	None
5000 Hp Gas Turbine	31904	Dresser Clark/DC 990	None
18,500 Hp Gas Turbine	31905	General Electric/Frame 5 MS 5001 LMD	None
445 Hp IC Engine	31935	Lero1/L 3460	None

Conditions, Continued

- 4. This operating permit is for the incorporation of the Department's NO_X Reasonably Available Control Technology (RACT) requirements (25 Pa. Code, §§129.91 through 129.95) for the Bechtelsville Compressor Station. This operating permit includes the source previously covered under Operating Permit No. 06-328-002.
- 5. The expiration date shown on this RACT operating permit is for State purposes. For Federal Enforcement purposes this operating permit shall remain in effect as part of the State Implementation Plan (SIP) until replaced and approved by the U.S. Environmental Protection Agency (EPA). The operating permit shall become enforceable by EPA upon its approval as a revision to the SIP.
- 6. The gas turbines are subject to the following NO_{χ} emission standards when operating at normal conditions. Normal operating conditions are defined as +/-10 percent of the nameplate horsepower rating of the turbine.
 - a. Westinghouse W-52 (31902 and 31903) 116 ppmdv corrected to 15 percent 0_2
 - b. Dresser Clark DC 990 (31904) 150 ppmdv corrected to 15 percent 02
 - c. General Electric Frame 5 MS 5001 LMD (31905) 120 ppmdv corrected to 15 percent 02
- 7. The emission limits listed in Condition No. 6 do not apply during the startup and shutdown of the gas turbines. Startup and shutdown periods are limited to a maximum of one hour each.

OPERATING PERMIT

PERMIT NO. 06-1034

TEXAS EASTERN TRANSMISSION CORPORATION

BECHTELSVILLE COMPRESSOR STATION

Conditions, Continued

- The Leroi L 3460 emergency standby engine shall be operated less than 500 hours during any consecutive 12-month period [25 Pa. Code, §129.93(c)(5)].
- 9. Verification of the NO_x emission standard listed in Condition No. 6 shall be conducted semiannually utilizing methodology outlined in 25 Pa. Code, Chapter 139 and the Department's Source Testing Manual or by other means approved by the Department. Based on the monthly records of fuel usage and operating hours, the Department reserves the right to decrease the verification frequency to an annual basis.
- At least two weeks prior to the test program, the Program Manager shall be informed of the date and time of the tests.
- 11. Within 60 days after completion of the test programs, two copies of the test reports, including all operating conditions, shall be submitted to the Program Manager. Test results shall be reported as follows:
 - a. ppmdv
 - b. ppmdv corrected to 15 percent 02
 - c. lb/hr
 - d. lb/mm Btu of heat input
- 12. Records shall be maintained in accordance with 25 Pa. Code, §129.95 requirements.
- 13. An annual report containing monthly records of fuel usage and operating hours for the sources listed in this operating permit shall be submitted to the Reading District Office. The report for January 1 through December 31 is due no later than March 1 of the following year for each operating year authorized by the operating permit or its renewal.
- 14. This Dresser Clark DG 990 ges turbine is subject to Subpart GG of the Standards of Performance for New Stationary Sources and shall comply with all applicable requirements of this Subpart. 40 CFR 960.4 requires submission of copies of all requests, reports, applications, submittals, and other communications to both EPA and the Department. The EPA copies shall be forwarded tor.

- Director-Air, Toxics and Radiation Division. U. S. EPA, Region III-841 Chestnut-Street Philadelphia, PA 19107 -