

## Attachment 3-1 NO<sub>x</sub> Rate Development in EPA Platform v6

The following questions (Q) and answers (A) are intended to provide further background on the four NO<sub>x</sub> rates found in the NEEDSv6 database.

Q1: Why are four NO<sub>x</sub> rates included in NEEDS?

A1: The four NO<sub>x</sub> rates in NEEDS represent a menu of all the NO<sub>x</sub> rates applicable to a specific electric generating unit given the current configuration of NO<sub>x</sub> combustion and post-combustion controls installed at the unit. The menu also reflects installation of state-of-the-art combustion controls under all conceivable operating conditions involving NO<sub>x</sub> controls that might be modeled in the future. By defining the menu of all the NO<sub>x</sub> rates applicable up front for every generating unit, an IPM model run can then select among the rates on the menu the appropriate rate(s) for the unit based on the particular policy scenario being modeled.

Q2: What operational states do the four NO<sub>x</sub> rates represent?

A2:

**Mode 1 and mode 2** reflect a unit's emission rates with its existing configuration of combustion and post-combustion (i.e., SCR or SNCR) controls.

- For a unit with an existing post-combustion control, mode 1 reflects the existing post-combustion control not operating and mode 2 the existing post-combustion control operating. However:
  - If a unit has operated its post-combustion control year round during 2017, 2016, 2015, 2014, 2011, 2009, and 2007 years then mode 1 = mode 2, which reflects that the control will likely continue to operate year round.
  - If a unit has not operated its post-combustion control during 2017, 2016, 2015, 2014, 2011, 2009, and 2007 years, mode 1 will be based on historic data and mode 2 will be calculated using the method described under Question 3.
  - If a unit has operated its post-combustion control seasonally in recent years (i.e., either only in the summer or winter, but not both), mode 1 will be based on historic data from when the control was not operating, and mode 2 will be based on historic data from when the SCR was operating.
- For a unit without an existing post-combustion control, mode 1 = mode 2 which reflects the unit's historic NO<sub>x</sub> rates from a recent year.

Please see Figure 3-4 in Section 3.9.2 for an explanation of how the model selects the appropriate NO<sub>x</sub> mode for each unit in the projection scenario.

Q3: How are emission rates calculated for each unit for each of the four NO<sub>x</sub> modes?

A3: The calculation uses the emission data reported to EPA for a specific year under Title IV of the Clean Air Act Amendments of 1990 (Acid Rain Program) and CSAPR. NO<sub>x</sub> rates are derived from the data for the summer and winter seasons.

The illustration here is for coal units only, and with the assumption that the data were complete and consistent with engineering principles. Otherwise, additional screening steps are applied.

The procedure uses the following hierarchy of NO<sub>x</sub> rate data sources:

1. 2017 ETS (referred to as 2017 NO<sub>x</sub> rates in the discussion below)
2. Comments on NO<sub>x</sub> rate
3. 2016/2015/2014/2011/2009/2007 ETS
4. 2015 EIA Form 860
5. National Emissions Inventory (NEI)<sup>1</sup>

---

<sup>1</sup> National Emissions Inventory (NEI) is a comprehensive and detailed estimate of air emissions of criteria pollutants, criteria precursors, and hazardous air pollutants from air emissions sources. The NEI is released every three years. The data is based primarily upon data provided by state, local, and tribal air agencies for sources in their jurisdictions.

6. California Air Resources Board (CARB) Database<sup>2</sup>  
7. Defaults

The existing coal steam boilers in US are categorized into three groups depending on the configuration of NO<sub>x</sub> combustion and post-combustion controls as summarized in NEEDS v6.

**Group 1 - Coal boilers without post-combustion NO<sub>x</sub> controls**

Mode 1 = 2017 ETS Annual Average NO<sub>x</sub> Rate

Mode 2 = Mode 1

Mode 3

Mode 3 calculation follows Steps 1-2:

Step 1: For units listed as having SOA combustion controls in NEEDS v6

Mode 3 = Mode 1

Step 2: For units listed as not having combustion controls in NEEDS v6

For non-wall fired dry bottom or tangential fired units.

Mode 3 = Mode 1

For wall fired dry bottom units<sup>3</sup>

If Mode 1  $\leq$  0.1549 lb/mmBtu then the unit has SOA control and

Mode 3 = Mode 1

If Mode 1  $>$  0.1549 lb/mmBtu, then

Mode 3 = 0.1549 lb/mmBtu

For tangential fired units

If Mode 1  $\leq$  0.139 lb/mmBtu then the unit has SOA control and

Mode 3 = Mode 1

If Mode 1  $>$  0.139 lb/mmBtu, then

Mode 3 = 0.139 lb/mmBtu

Mode 4

Mode 4 = Mode 3

**Group 2 - Coal boilers with SCR**

Pre-screen coal boilers with 2017 ETS NO<sub>x</sub> rates into the following four operating regimes. A coal boiler is assumed to be operating its SCR when the seasonal NO<sub>x</sub> rate is less than 0.2 lbs/MMBtu.

Group 2.1 SCR is not operating in both summer and winter seasons

Follow the NO<sub>x</sub> rate rules summarized for Group 1 boilers. No state of the art combustion controls are implemented.

Mode 1 = 2017 ETS Annual Average NO<sub>x</sub> Rate

---

It is further supplemented by data developed by the U.S. EPA. The current version of NEI NO<sub>x</sub> emission data is of the 2014 vintage (<https://www.epa.gov/air-emissions-inventories/2014-national-emissions-inventory-nei-data>).

<sup>2</sup> California Air Resources Board (CARB) hosts an online database of facility-level criteria and toxic plus risk data (<https://www.arb.ca.gov/app/emsinv/facinfo/facinfo.php>). The most current NO<sub>x</sub> emissions are of the 2016 vintage.

<sup>3</sup> For EPA Platform v6, EPA identified coal steam units with firing types – wall fired dry bottom and tangential fired that had state-of-the-art combustion controls (SOA CC). EPA estimated the average 2016 ozone season NO<sub>x</sub> emission rates for all such units by firing type. For dry bottom wall-fired coal boilers with “Low NO<sub>x</sub> Burner” and “Overfire”, there were 148 units averaging 0.1549 lb/mmBtu. For tangentially-fired coal boilers with “Low NO<sub>x</sub> Burner” and “Closed-coupled/Separated OFA”, there were 105 units averaging 0.1390 lb/mmBtu. For units that had a mode 1 rate less than these average rates, mode 3 = mode 1. If the mode 1 rate is greater than these average rates then mode 3 = average rates.

Mode 2 = maximum  $\{(1-0.9) * \text{Mode 1}, 0.07\}$   
Mode 3 = Mode 1  
Mode 4 = Mode 2

Group 2.2 SCR is operating in summer only

Mode 1 = 2017 ETS Winter NO<sub>x</sub> Rate  
Mode 2 = 2017 ETS Summer NO<sub>x</sub> Rate  
Mode 3 = Mode 1  
Mode 4 = Mode 2

Group 2.3 SCR is operating in winter only

Mode 1 = 2017 ETS Summer NO<sub>x</sub> Rate  
Mode 2 = 2017 ETS Winter NO<sub>x</sub> Rate  
Mode 3 = Mode 1  
Mode 4 = Mode 2

Group 2.4 SCR is operating year-round

Mode 1 = if (2016/2015/2014/2011/2009/2007 ETS Winter NO<sub>x</sub> Rate > 0.2, 2016/2015/2014/2011/2009/2007 ETS Winter NO<sub>x</sub> Rate, 2017 ETS Annual Average NO<sub>x</sub> Rate)<sup>4</sup>  
Mode 2 = 2017 ETS Annual Average NO<sub>x</sub> Rate  
Mode 3 = Mode 1  
Mode 4 = Mode 2

**Group 3 - Coal boilers with SNCR**

Step 1: Pre-screen coal boilers with 2017 ETS NO<sub>x</sub> rates to verify if they have not operated their SNCR in both summer and winter seasons. A coal boiler is assumed to be not operating its SNCR when the NO<sub>x</sub> rate is greater than 0.3 lbs/MMBtu in both summer and winter seasons.

Group 3.1 SNCR is not operating in both summer and winter seasons

Follow the NO<sub>x</sub> rate rules summarized for Group 1 boilers  
Mode 1 = 2017 ETS Annual Average NO<sub>x</sub> Rate  
Mode 2 = maximum  $\{(1-0.25^5) * \text{Mode 1}, 0.1\}$  for non FBC units  
Mode 2 = maximum  $\{(1-0.50) * \text{Mode 1}, 0.08\}$  for FBC units  
Mode 3 = same as Group 1 Mode 3  
Mode 4 = maximum  $\{(1-0.25) * \text{Mode 3}, 0.1\}$  for non FBC units  
Mode 4 = maximum  $\{(1-0.50) * \text{Mode 3}, 0.08\}$  for FBC units

Step 2: Pre-screen coal boilers with 2017 ETS NO<sub>x</sub> rates into the following three operating regimes. First estimate the implied removal for a coal boiler using the following equation:

$$\text{Implied Removal (\%)} = ((\text{Winter NO}_x \text{ Rate} - \text{Summer NO}_x \text{ Rate}) / \text{Winter NO}_x \text{ Rate}) * 100$$

Second, assign the coal boiler to a specific operating regime based on the following logic.  
If Implied Removal > 20% then SNCR is operating in summer season only,  
Else if Implied Removal < -20% then SNCR is operating in winter season only,  
Else SNCR is operating year-round

Second, assign the coal boiler to a specific operating regime based on the following logic.

---

<sup>4</sup> This equation implies that if a unit with a SCR operates year round in ETS 2017 and in winter in ETS 2016/2015/2014/2011/2009/2007, then Mode 1 NO<sub>x</sub> rate will reflect SCR operation.

<sup>5</sup> SNCR removal efficiency for FBC units is 50%; and for non FBC coal units is 25%, 20%, and 15% for units < 200 MW, 200-400 MW, and > 400 MW respectively.

Group 3.2 SNCR is operating in summer only

Mode 1 = 2017 ETS Winter NO<sub>x</sub> Rate

Mode 2 = 2017 ETS Summer NO<sub>x</sub> Rate

Mode 3 = same as Group 1 Mode 3

Mode 4 = maximum {(1-0.25) \* Mode 3, 0.1} for non FBC units

Mode 4 = maximum {(1-0.50) \* Mode 3, 0.08} for FBC units

Group 3.3 SNCR is operating in winter only

Mode 1 = 2017 ETS Summer NO<sub>x</sub> Rate

Mode 2 = 2017 ETS Winter NO<sub>x</sub> Rate

Mode 3 = same as Group 3.2 Mode 3

Mode 4 = same as Group 3.2 Mode 4

Group 3.4 SNCR is operating year-round

If (2016/2015/2014/2011/2009/2007 ETS Winter NO<sub>x</sub> Rate > 0.3) then

Mode 1 = 2016/2015/2014/2011/2009/2007 ETS Winter NO<sub>x</sub> Rate

Mode 2 = 2017 ETS Annual Average NO<sub>x</sub> Rate

Mode 3 = same as Group 3.2 Mode 3

Mode 4 = maximum {(1-0.25) \* Mode 3, 0.1} for non FBC units

Mode 4 = maximum {(1-0.50) \* Mode 3, 0.08} for FBC units

Else

Mode 1 = 2017 ETS Annual Average NO<sub>x</sub> Rate

Mode 2 = 2017 ETS Annual Average NO<sub>x</sub> Rate

Mode 3 = same as Group 3.2 Mode 3

Mode 4 = Mode 3

Other things worth noting are:

(a) In general, winter NO<sub>x</sub> rates reported in EPA's Emission Tracking System were used as proxies for assigning emission rates to Mode 1.

(b) **NO<sub>x</sub> Emission Rates for Units with Common Stacks** - The reported ETS NO<sub>x</sub> emissions and emissions rate data for units that share a common stack typically reflect an average of emissions and emission rates across all units that share the common stack. This can include instances where one or more units sharing a common stack are equipped with a SCR and one or more units are not. Because the emissions are measured at the stack, the emission rate for the SCR and non-SCR equipped units are typically reported as being similar, even if at the unit level they are not. This can create the appearance of SCRs being operated at reduced efficiencies, even if they are not. In instances where SCRs were retrofit on one of the units after 2017, the non-SCR equipped unit was represented with a NO<sub>x</sub> emissions rate equal to the 2017 emissions rate and the SCR equipped unit was represented with a 0.070 lbs/MMBtu emissions rate, matching IPM's assumption for emission rates achieved with recent SCR retrofits. This represents no change from how these units were previously represented in NEEDS.

For units with SCRs built in 2017 or earlier and share a common stack with a non-SCR equipped unit, there is no reliable data to determine the emission rates of the individual units. Therefore, EPA Platform v6 assumed that SCR-equipped units sharing a common stack with non-SCR equipped units would have emission rates equal to 0.075 lbs/MMBtu<sup>6</sup>. This is a conservatively low rate which implies that these units cannot achieve any additional reductions. The NO<sub>x</sub> emission rate for the non-SCR equipped unit are then recalculated such that the capacity weighted emissions rate of the units sharing the common stack would be equal to the capacity weighted emissions rate calculated from the ETS data.

---

<sup>6</sup> The exception here is the Gorgas unit 10, where the SCR NO<sub>x</sub> emission rate is set at 0.1 lbs/MMBTU based on utility comments.

(c) The NEI and CARB datasets were used to reduce the number of default NO<sub>x</sub> rates in instances where the 2017 ETS did not report any NO<sub>x</sub> rates.

The NEI dataset contained NO<sub>x</sub> emission and fuel use data presented at the facility ID, point ID, process ID, and source classification code (SCC) level. EPA matched NEI facility ID and point ID's with NEEDS units to create a crosswalk that was then used to map the NEI NO<sub>x</sub> emission and fuel use data to the NEEDS units that were without reported ETS NO<sub>x</sub> rates. Unit-level NO<sub>x</sub> emission rates were then calculated for the units. The procedure yielded NO<sub>x</sub> rates for 451 NEEDS units. The calculated unit-level NO<sub>x</sub> rates were further evaluated to remove outliers. Calculated unit-level NO<sub>x</sub> rates that were outside the rate range of the 2017 ETS NO<sub>x</sub> rates for the relevant plant type were not adopted.

Also, the NEI dataset is the primary data source for IC engine NO<sub>x</sub> rates. These NO<sub>x</sub> rates varied between 0.011 lbs/MMBtu and 28.11 lbs/MMBtu and have a median value of 3.12 lbs/MMBtu. The cut-off rate was assumed to be 4.80 lbs/MMBtu, which was the 85 percentile. For IC engines, if the NEI NO<sub>x</sub> rate was higher than 4.80 lbs/MMBtu, then the NEI rate was not adopted.

The CARB dataset contained NO<sub>x</sub> emissions information but no fuel use information. To obtain fuel use information, EPA mapped the CARB facilities to those in the 2016 EIA Form 923 data, and used the fuel use from the 2016 EIA Form 923 data, together with the NO<sub>x</sub> emissions from CARB, to calculate facility-level NO<sub>x</sub> emission rates. If a facility in NEEDS had only one plant type, the calculated facility-level NO<sub>x</sub> rate was adopted for all NEEDS units located at the facility. If a facility in NEEDS had multiple plant types, the calculated facility-level NO<sub>x</sub> rate was not adopted. The calculated facility-level NO<sub>x</sub> rates were further evaluated to remove outliers. If a NEEDS unit had a calculated facility-level NO<sub>x</sub> rate that was higher than the average NO<sub>x</sub> rate based on the 2017 ETS, the calculated facility-level NO<sub>x</sub> rate was not adopted.

(d) The state and national-level default NO<sub>x</sub> rates account for the units that were assigned NO<sub>x</sub> rates from the NEI and CARB described above. For units located in Connecticut, Pennsylvania, and New York, the revised state-level default NO<sub>x</sub> rates were further compared with RACT rates. If the revised state-level default NO<sub>x</sub> rates were higher than the RACT rates, the revised state-level default rates were not adopted, and the RACT rates used instead.