



**PERMIT**  
**Under the Environmental Conservation Law (ECL)**

**IDENTIFICATION INFORMATION**

Permit Type: Air Title V Facility  
Permit ID: 2-6304-00024/00035  
Mod 0 Effective Date: 12/06/2006 Expiration Date: 12/05/2011  
Mod 1 Effective Date: 01/13/2009 Expiration Date: 12/05/2011  
Mod 2 Effective Date: 04/06/2012 Expiration Date: 02/03/2015

Permit Issued To: TC RAVENSWOOD LLC  
110 TURNPIKE RD STE 203  
WESTBOROUGH, MA 01581

Contact: KEN YAGER  
RAVENSWOOD GENERATING STATION  
38-54 VERNON BLVD  
LONG ISLAND CITY, NY 11101  
(718) 706-2702

Facility: RAVENSWOOD GENERATING STATION  
38-54 VERNON BLVD  
QUEENS, NY 11101

Contact: KEN YAGER  
RAVENSWOOD GENERATING STATION  
38-54 VERNON BLVD  
LONG ISLAND CITY, NY 11101  
(718) 706-2702

Description:  
This facility consists of three (3) steam boiler turbine/generator sets and seventeen (17) simple cycle combustion turbines with a combined nominal rating of 2,288 mw and three (3) emergency generators. Natural gas is the primary fuel for all units, with low-sulfur #6 residual oil and/or distillate fuel used when gas is unavailable. The purpose of this modification is to include as required under Part 249 the New Best Available Retrofit Technology (BART 6 NYCRR Part 249) which will be submitted to the USEPA for approval as a revision to the State Implementation Plan (SIP).

New York State Department of Environmental Conservation  
Facility DEC ID: 2630400024



By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: JOHN F CRYAN  
NYSDEC  
47-40 21ST ST  
LONG ISLAND CITY, NY 11101-5407

Authorized Signature:

A handwritten signature in black ink, appearing to read "John F. Cryan", written over a horizontal line. Below the signature are two large, hand-drawn circles.

Date: 04/06/2012



PAGE LOCATION OF CONDITIONS

PAGE

FEDERALLY ENFORCEABLE CONDITIONS

Facility Level

14	<del>1-6 NYCRR 200.6: Acceptable Ambient Air Quality</del>
14	<del>2-1-6 NYCRR 201-6.5 (a) (7): Fees</del>
14	<del>2-6 NYCRR 201-6.5 (a) (7): Fees</del>
14	<del>3-6 NYCRR 201-6.5 (e): Recordkeeping and reporting of compliance monitoring</del>
15	<del>4-6 NYCRR 201-6.5 (e) (2): Monitoring, Related Recordkeeping, and Reporting Requirements.</del>
15	<del>5-6 NYCRR 201-6.5 (e) (3) (ii): Compliance Certification</del>
17	<del>6-6 NYCRR 201-6.5 (e): Compliance Certification</del>
18	<del>7-6 NYCRR 202-2.1: Compliance Certification</del>
19	<del>8-6 NYCRR 202-2.5: Recordkeeping requirements</del>
19	<del>9-6 NYCRR Part 215: Open Fires Prohibited at Industrial and Commercial Sites</del>
19	<del>2-2-6 NYCRR 215.2: Open Fires Prohibitions</del>
20	<del>10-6 NYCRR 200.7: Maintenance of Equipment</del>
21	<del>11-6 NYCRR 201-1.7: Recycling and Salvage</del>
21	<del>2-3-6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air</del>
21	<del>12-6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected Contaminants to the air</del>
21	<del>13-6 NYCRR 201-3.2 (a): Exempt Sources Proof of Eligibility</del>
21	<del>14-6 NYCRR 201-3.3 (a): Trivial Sources Proof of Eligibility</del>
22	<del>15-6 NYCRR 201-6.5 (a) (4): Standard Requirement Provide Information</del>
22	<del>16-6 NYCRR 201-6.5 (a) (8): General Condition Right to Inspect</del>
22	<del>17-6 NYCRR 201-6.5 (d) (5): Standard Requirements Progress Reports</del>
23	<del>18-6 NYCRR 201-6.5 (f) (6): Off Permit Changes</del>
23	<del>2-4-6 NYCRR 202-1.1: Required Emissions Tests</del>
23	<del>19-6 NYCRR 202-1.1: Required Emissions Tests</del>
24	<del>20-6 NYCRR 211.3: Visible Emissions Limited</del>
24	<del>21-40 CFR Part 68: Accidental release provisions.</del>
24	<del>22-40CFR 82, Subpart F: Recycling and Emissions Reduction</del>
25	<del>23-6 NYCRR Subpart 201-6: Emission Unit Definition</del>
32	<del>24-6 NYCRR 201-6.5 (e) (3): Compliance Certification</del>
33	<del>25-6 NYCRR 201-6.5 (g): Non Applicable requirements</del>
33	<del>26-6 NYCRR 204-1.6: Permit requirements.</del>
33	<del>27-6 NYCRR 204-2.1: Submissions to the Department.</del>
34	<del>28-6 NYCRR 204-4.1: Contents of reports and compliance certifications.</del>
34	<del>29-6 NYCRR 204-4.1: Discretionary report contents.</del>
35	<del>30-6 NYCRR 204-4.1: Compliance Certification</del>
35	<del>31-6 NYCRR 204-7.1: Submission of NOx allowance transfers.</del>
35	<del>32-6 NYCRR 204-8.1: General provisions.</del>
36	<del>33-6 NYCRR 204-8.1: Prohibitions.</del>
36	<del>34-6 NYCRR 204-8.1: Requirements for installation, certification, and data accounting.</del>
37	<del>35-6 NYCRR 204-8.2: Requirements for recertification of monitoring systems.</del>
37	<del>36-6 NYCRR 204-8.2: Compliance Certification</del>

New York State Department of Environmental Conservation

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024



- 37 ~~37-6 NYCRR 204.8.3: Out of control periods.~~
  - 38 ~~38-6 NYCRR 204.8.4: Compliance Certification~~
  - 39 ~~39-6 NYCRR 204.8.7: Compliance Certification~~
  - 39 ~~40-6 NYCRR Part 207: Submittal of Episode Action Plans~~
  - 40 ~~2-5-6 NYCRR 211.1: Air pollution prohibited~~
  - 40 ~~41-6 NYCRR 225.1.2 (a) (2): Compliance Certification~~
  - 40 ~~42-6 NYCRR 225.1.2 (a) (2): Compliance Certification~~
  - 41 ~~43-6 NYCRR 225.1.8: Compliance Certification~~
  - 41 ~~44-6 NYCRR 225.1.8 (d): Sampling, compositing, and analysis of fuel samples~~
  - 42 ~~45-6 NYCRR 225.2.3 (b): Compliance Certification~~
  - 42 ~~46-6 NYCRR 225.2.4 (b): Compliance Certification~~
  - 43 ~~47-6 NYCRR 225.2.4 (b): Compliance Certification~~
  - 43 ~~48-6 NYCRR 225.2.4 (b): Compliance Certification~~
  - 44 ~~49-6 NYCRR 225.2.4 (b): Compliance Certification~~
  - 44 ~~50-6 NYCRR 227.1.3 (a): Compliance Certification~~
  - 45 ~~51-6 NYCRR 227.2.5 (b): KeySpan Energy NOx RACT System Wide~~
- ~~Averaging Plan~~
- 45 2-6 6 NYCRR 249.3 (a): Compliance Certification
  - 46 2-7 6 NYCRR 249.3 (a): Compliance Certification
  - 47 2-8 6 NYCRR 249.3 (a): Compliance Certification
  - 48 2-9 6 NYCRR 249.3 (d): Compliance Certification
- Emission Unit Level**
- 48 ~~52-6 NYCRR Subpart 201-6: Emission Point Definition By Emission Unit~~
  - 53 ~~53-6 NYCRR Subpart 201-6: Process Definition By Emission Unit~~
  - 76 ~~54-6 NYCRR 201-7.2: Emission Unit Permissible Emissions~~
  - 80 ~~55-6 NYCRR 201-7.2: Process Permissible Emissions~~
- EU=U-00010**
- 88 ~~56-6 NYCRR 227.1.2 (a) (1): Compliance Certification~~
  - 89 ~~57-6 NYCRR 227.2.6 (a) (1): Testing, monitoring, and reporting requirements for very large boilers.~~
  - 89 2-10 6 NYCRR 249.3 (f): Compliance Certification
- EU=U-00010,EP=00010**
- 90 ~~58-6 NYCRR 227.1.4 (b): Compliance Certification~~
- EU=U-00020**
- 90 ~~59-6 NYCRR 227.1.2 (a) (1): Compliance Certification~~
  - 91 ~~60-6 NYCRR 227.2.6 (a) (1): Testing, monitoring, and reporting requirements for very large boilers.~~
  - 91 2-11 6 NYCRR 249.3 (f): Compliance Certification
- EU=U-00020,EP=00020**
- 92 ~~61-6 NYCRR 227.1.4 (b): Compliance Certification~~
- EU=U-00030**
- 93 ~~62-6 NYCRR 227.1.2 (a) (1): Compliance Certification~~
  - 93 ~~63-6 NYCRR 227.2.6 (a) (1): Testing, monitoring, and reporting requirements for very large boilers.~~
  - 94 2-12 6 NYCRR 249.3 (f): Compliance Certification

**New York State Department of Environmental Conservation**

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024



**Item 22.1:**

The permittee shall comply with all applicable provisions of 40 CFR Part 82.

**The following conditions are subject to annual compliance certification requirements for Title V permits only.**

**Condition 23: Emission Unit Definition**

**Effective between the dates of 12/06/2006 and 02/03/2015**

**Applicable Federal Requirement:6 NYCRR Subpart 201-6**

**Item 23.1(From Mod 2):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00010

Emission Unit Description:

THIS UNIT CONSISTS OF DUAL, TANGENTIALLY FIRED FURNACES COMPRISING A SINGLE BOILER. STEAM FROM THIS BOILER OPERATES A TANDEM TURBINE GENERATOR SET NOMINALLY RATED AT 390 MW. THE FURNACES OPERATE ON NATURAL GAS OR LOW SULFUR #6 RESIDUAL OIL. ON OCCASION, SMALL AMOUNTS OF WASTE FUEL A MAY BE FIRED IN CONJUNCTION WITH THE PRIMARY FUEL. ON AN INFREQUENT BASIS, NON-HAZARDOUS BOILER CLEANING SOLUTION MAY BE EVAPORATED IN THIS UNIT IN CONJUNCTION WITH THE PRIMARY FUEL.

CLOSE COUPLED OVER-FIRED AIR (CCOFA) COMPARTMENTS HAVE BEEN ADDED TO THE UPPER AND LOWER WINDBOX SECTIONS OF THIS EMISSION UNIT. CCOFA IS A PROVEN NO<sub>x</sub> REDUCTION TECHNOLOGY AND WAS INSTALLED AS PART OF KEYSpan'S PLAN TO MEET PHASE III OF THE NO<sub>x</sub> BUDGET REQUIREMENTS. INSTALLATION OCCURRED DURING THE FALL 2000 SCHEDULED OUTAGE.

Building(s): GEN STA

**Item 23.2(From Mod 2):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00020

Emission Unit Description:

THIS UNIT CONSISTS OF DUAL, TANGENTIALLY FIRED FURNACES COMPRISING A SINGLE BOILER. STEAM FROM THIS BOILER OPERATES A TANDEM TURBINE GENERATOR SET NOMINALLY RATED AT 390 MW. THIS BOILER IS EQUIPPED WITH A CLOSE-COUPLED-OVERFIRED-AIR (CCOFA) SYSTEM TO REDUCE THE FORMATION OF NITROGEN OXIDES. THE FURNACES OPERATE ON NATURAL GAS OR LOW SULFUR #6 RESIDUAL OIL. ON OCCASION, SMALL AMOUNTS OF WASTE FUEL A MAY BE FIRED IN CONJUNCTION WITH THE PRIMARY FUEL. ON AN INFREQUENT

New York State Department of Environmental Conservation

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024



BASIS, NON-HAZARDOUS BOILER CLEANING SOLUTIONS MAY BE EVAPORATED IN THIS UNIT IN CONJUNCTION WITH PRIMARY FUEL.

Building(s): GEN STA

**Item 23.3(From Mod 2):**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U-00030

Emission Unit Description:

THIS UNIT CONSISTS OF DUAL BOILERS, EACH HEATED BY DUAL, TANGENTIALLY FIRED FURNACES. STEAM FROM THESE BOILERS OPERATES A TANDEM TURBINE GENERATOR SET NOMINALLY RATED AT 972 MW. KEYSpan WILL BE INSTALLING A CLOSE-COUPLED-OVERFIRED-AIR (CCOFA) SYSTEM BY LATE 2001 TO FURTHER REDUCE THE FORMATION OF NITROGEN OXIDES. THE FURNACES OPERATE ON NATURAL GAS OR LOW SULFUR #6 RESIDUAL OIL. ON OCCASION, SMALL AMOUNTS OF WASTE FUEL A MAY BE FIRED IN CONJUNCTION WITH THE PRIMARY FUEL. ON AN INFREQUENT BASIS, NON-HAZARDOUS BOILER CLEANING SOLUTION MAY BE EVAPORATED IN THIS UNIT IN CONJUNCTION WITH THE PRIMARY FUEL.

Building(s): GEN STA

~~**Item 23.4(From Mod 0):**~~

~~The facility is authorized to perform regulated processes under this permit for:~~

~~Emission Unit: U-CT001~~

~~Emission Unit Description:~~

~~THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. THIS UNIT IS A "BLACK START" COMBUSTION TURBINE DESIGNED TO PROVIDE SUFFICIENT POWER TO BRING THE ENTIRE POWER STATION BACK ON LINE FOLLOWING A CATASTROPHIC SYSTEM COLLAPSE. A DIESEL ENGINE, EMISSION POINT GT0S1, EMISSION UNIT U-CT0S1 IS UTILIZED TO START THIS COMBUSTION TURBINE.~~

~~Building(s): GT1~~

~~**Item 23.5(From Mod 0):**~~

~~The facility is authorized to perform regulated processes under this permit for:~~

~~Emission Unit: U-CT004~~

~~Emission Unit Description:~~

~~THIS UNIT IS A COMBUSTION TURBINE USED TO SUPPLY PEAK GENERATION CAPACITY, AS REQUIRED TO SUPPORT THE NYC ELECTRIC DISTRIBUTION SYSTEM. A DIESEL ENGINE, EMISSION POINT GT0S4, EMISSION UNIT U-CT0S4 IS UTILIZED TO START THIS COMBUSTION TURBINE.~~

~~Building(s): CT4~~



New York State Department of Environmental Conservation

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024

~~sixty (60) days after the end of each calendar quarter (January – March, April – June, July – September, October – December). At least once per calendar year, Method 9 observations will be conducted on each combustion turbine by a qualified observer, and be reported semi-annually.~~

~~Parameter Monitored: OPACITY~~

~~Upper Permit Limit: 20 percent~~

~~Monitoring Frequency: AS REQUIRED – SEE PERMIT MONITORING DESCRIPTION~~

~~Averaging Method: 6 MINUTE AVERAGE (METHOD 9)~~

~~Reporting Requirements: AS REQUIRED – SEE MONITORING DESCRIPTION~~

~~**Condition 51: KeySpan Energy NOx RACT System Wide Averaging Plan Effective between the dates of 12/06/2006 and 02/03/2015**~~

~~**Applicable Federal Requirement:6 NYCRR 227.2.5 (b)**~~

~~**Item 51.1:**~~

~~KeySpan Energy's system wide averaging of NOx emissions from its Ravenswood Steam Plant and Ravenswood Generating Station must be performed in accordance with its NOx RACT System Wide Averaging Plan, dated December 28, 1993, approved by the Department, and modified on December 16, 1999, to include its Ravenswood Generating Station and Steam Plant in its system.~~

**Condition 2-6: Compliance Certification**

**Effective between the dates of 04/06/2012 and 02/03/2015**

**Applicable Federal Requirement:6 NYCRR 249.3 (a)**

**Item 2-6.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY075-00-0 PARTICULATES

**Item 2-6.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Particulate matter(PM) emissions of boilers in emission units U-00010, U-00020 and U-00030 are limited to 0.1 lbs/mmbtu. This condition is necessary to ensure compliance with BART requirements under EPA's Regional Haze Program.

The facility shall record the boiler consumption of natural gas and residual oil a daily basis. The compliance with the PM emission limit during oil firing shall be verified by performing stack test, using department approved methods, once during the permit term, and for natural gas, by using AP 42 emission factors.

The compliance deadline, with the emission limitation listed in this

**New York State Department of Environmental Conservation**

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024



condition is January 1, 2014. Compliance with the monitoring, record keeping, or reporting requirements listed in this condition begins on January 1, 2014.

Reference Test Method: EPA approved

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2012.

Subsequent reports are due every 6 calendar month(s).

**Condition 2-7: Compliance Certification**  
**Effective between the dates of 04/06/2012 and 02/03/2015**

**Applicable Federal Requirement:6 NYCRR 249.3 (a)**

**Item 2-7.1:**

The Compliance Certification activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 007446-09-5      SULFUR DIOXIDE

**Item 2-7.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

This condition applies to boilers under emission units U-00010, U-00020, and U-00030, firing residual oil and natural gas. This condition is necessary to ensure compliance with BART requirements under EPA's Regional Haze Program.

Sulfur content of residual oil used in these boilers shall not be greater 0.30 percent by weight. A log of the sulfur content in oil per delivery must be maintained on site.

Usage of natural gas ensures that the SO<sub>2</sub> emission rate will remain below the EPA's presumptive BART limit of 0.15 pounds per million btu.

Facility shall record the usage of natural gas and residual oil in these boilers . All records shall be kept at the facility for a minimum of five years, and must be available to NYSDEC upon request.

The compliance deadline, with the emission limitation listed in this condition is January 1, 2014. Compliance with the monitoring, record keeping, or reporting requirements listed in this condition begins on January 1, 2014.

Reference Test Method: EPA approved

Monitoring Frequency: AS REQUIRED - SEE PERMIT MONITORING DESCRIPTION



**New York State Department of Environmental Conservation**

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024

Averaging Method: MAXIMUM - NOT TO BE EXCEEDED AT ANY TIME  
(INSTANTANEOUS/DISCRETE OR GRAB)

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2012.

Subsequent reports are due every 6 calendar month(s).

**Condition 2-8: Compliance Certification**  
**Effective between the dates of 04/06/2012 and 02/03/2015**

**Applicable Federal Requirement: 6 NYCRR 249.3 (a)**

**Item 2-8.1:**

The Compliance Certification activity will be performed for the facility:

The Compliance Certification applies to:

Emission Unit: U-00010

Emission Unit: U-00020

Emission Unit: U-00030

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

**Item 2-8.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: CONTINUOUS EMISSION MONITORING (CEM)

Monitoring Description:

This condition applies to the emission units U-00010, U-00020, and U-00030, firing residual oil and natural gas. This condition is necessary to ensure compliance with BART requirements under EPA's Regional Haze Program.

The average NO<sub>x</sub> emission of boilers in U-00010, U-00020, and U-00030 shall not be greater than 0.15 lbs/mmbtu.

All the records shall be kept at the facility for a minimum of five years, and must be available to NYSDEC upon request.

The compliance deadline, with the emission limitation listed in this condition is January 1, 2014. Compliance with the monitoring, record keeping, or reporting requirements listed in this condition begins on January 1, 2014.

Manufacturer Name/Model Number: CEM

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 0.15 pounds per million Btus

Reference Test Method: EPA approved

Monitoring Frequency: CONTINUOUS

Averaging Method: 30 DAY ROLLING AVERAGE, ROLLED DAILY



**New York State Department of Environmental Conservation**

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 7/30/2012.  
Subsequent reports are due every 6 calendar month(s).

**Condition 2-9: Compliance Certification**  
**Effective between the dates of 04/06/2012 and 02/03/2015**

**Applicable Federal Requirement:6 NYCRR 249.3 (d)**

**Item 2-9.1:**  
The Compliance Certification activity will be performed for the Facility.

**Item 2-9.2:**  
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Control equipment or other emission reduction methods approved by the department as BART must be installed and operating no later than January 1, 2014.

Monitoring Frequency: SINGLE OCCURRENCE

Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE

~~\*\*\* Emission Unit Level \*\*\*~~

~~**Condition 52: Emission Point Definition By Emission Unit**~~  
~~**Effective between the dates of 12/06/2006 and 02/03/2015**~~

~~**Applicable Federal Requirement:6 NYCRR Subpart 201-6**~~

~~**Item 52.1(From Mod 0):**~~  
~~The following emission points are included in this permit for the cited Emission Unit:~~

~~Emission Unit: U-00010~~

~~Emission Point: 00010~~

~~Height (ft.): 499~~

~~Diameter (in.): 160~~

~~NYTMN (km.): 4512.564 NYTME (km.): 588.955 Building: GEN STA~~

~~**Item 52.2(From Mod 0):**~~  
~~The following emission points are included in this permit for the cited Emission Unit:~~

~~Emission Unit: U-00020~~

~~Emission Point: 00020~~

~~Height (ft.): 499~~

~~Diameter (in.): 162~~

~~NYTMN (km.): 4512.613 NYTME (km.): 588.961 Building: GEN STA~~



New York State Department of Environmental Conservation

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024

~~ducted through a common stack, which fire liquid fuels, and that have a heat capacity exceeding 250 mmBtu/hr.~~

~~Parameter Monitored: PARTICULATES~~

~~Upper Permit Limit: 0.1 pounds per million Btus~~

~~Reference Test Method: EPA REF METHOD 5~~

~~Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT~~

~~Averaging Method: 1 HOUR AVERAGE~~

~~Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE~~

~~**Condition 57: Testing, monitoring, and reporting requirements for very large boilers.**~~

~~Effective between the dates of 12/06/2006 and 02/03/2015~~

~~Applicable Federal Requirement: 6 NYCRR 227.2.6 (a) (1)~~

~~**Item 57.1:**~~

~~This Condition applies to Emission Unit: U-00010~~

~~**Item 57.2:**~~

~~The owner/operator shall measure NOx emissions with a continuous emissions monitoring system (CEMS) as described in 6 NYCRR 227.2.6(b).~~

**Condition 2-10: Compliance Certification**

**Effective between the dates of 04/06/2012 and 02/03/2015**

**Applicable Federal Requirement: 6 NYCRR 249.3 (f)**

**Item 2-10.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00010

**Item 2-10.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The emission limits in this permit for NOx, SO2, and/or PM10 established under Part 249 are based on New York's Best Available Retrofit Technology (BART) Rule (6 NYCRR Part 249), are effective on the date of this permit's issuance, and are state-enforceable. Federal enforceability of these facility-specific requirements is effective on the date on which these emission limits, as submitted to EPA as a revision to New York State's Implementation Plan for Regional Haze, are published in the Federal Register.

Monitoring Frequency: SEMI-ANNUALLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2012.



New York State Department of Environmental Conservation

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024

Subsequent reports are due every 6 calendar month(s).

**Condition 58:** ~~Compliance Certification~~  
~~Effective between the dates of 12/06/2006 and 02/03/2015~~

~~Applicable Federal Requirement: 6 NYCRR 227-1.4 (b)~~

**Item 58.1:**

~~The Compliance Certification activity will be performed for:~~

~~Emission Unit: U-00010~~

~~Emission Point: 00010~~

**Item 58.2:**

~~Compliance Certification shall include the following monitoring:~~

~~Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES~~

~~Monitoring Description:~~

~~The owner or operator of a stationary combustion installation which utilizes a continuous opacity monitoring system (COMS) shall include the following in their quarterly excess emission reports:~~

- ~~1) Magnitude, date, and time of each exceedence;~~
- ~~2) For each period of excess emissions, specific identification of the cause and corrective action taken;~~
- ~~3) Date, time, and duration of each period of COMS downtime, and the corrective action for each period of downtime;~~
- ~~4) Total time the COMS is required to record data during the reporting period;~~
- ~~5) The total number of exceedences and the duration of exceedences expressed as a percentage of the total time in which the COMS are required to record data; and~~
- ~~6) Such other requirements as the Department may deem necessary in order to enforce Article 19 of the Environmental Conservation Law (ECL).~~

~~The excess emission reports are due sixty (60) days after the end of each calendar quarter (January - March, April - June, July - September, October - December).~~

~~Monitoring Frequency: CONTINUOUS~~

~~Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION~~

**Condition 59:** ~~Compliance Certification~~  
~~Effective between the dates of 12/06/2006 and 02/03/2015~~

~~Applicable Federal Requirement: 6 NYCRR 227-1.2 (a) (1)~~



New York State Department of Environmental Conservation

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024

**Item 59.1:**

~~The Compliance Certification activity will be performed for:~~

~~Emission Unit: U-00020~~

~~Regulated Contaminant(s):~~

~~CAS No: 0NY075-00-0 PARTICULATES~~

**Item 59.2:**

~~Compliance Certification shall include the following monitoring:~~

~~Monitoring Type: INTERMITTENT EMISSION TESTING~~

~~Monitoring Description:~~

~~Particulate emission limit for singular boilers or multiple boilers ducted through a common stack, which fire liquid fuels, and that have a heat capacity exceeding 250 mmBtu/hr.~~

~~Parameter Monitored: PARTICULATES~~

~~Upper Permit Limit: 0.1 pounds per million Btus~~

~~Reference Test Method: EPA REF METHOD 5~~

~~Monitoring Frequency: ONCE DURING THE TERM OF THE PERMIT~~

~~Averaging Method: 1 HOUR AVERAGE~~

~~Reporting Requirements: ONCE / BATCH OR MONITORING OCCURRENCE~~

**Condition 60: Testing, monitoring, and reporting requirements for very large boilers.**

~~Effective between the dates of 12/06/2006 and 02/03/2015~~

~~Applicable Federal Requirement: 6 NYCRR 227-2.6 (a) (1)~~

**Item 60.1:**

~~This Condition applies to Emission Unit: U-00020~~

**Item 60.2:**

~~The owner/operator shall measure NO<sub>x</sub> emissions with a continuous emissions monitoring system (CEMS) as described in 6NYCRR 227-2.6(b).~~

**Condition 2-11: Compliance Certification**

**Effective between the dates of 04/06/2012 and 02/03/2015**

**Applicable Federal Requirement: 6 NYCRR 249.3 (f)**

**Item 2-11.1:**

The Compliance Certification activity will be performed for:

Emission Unit: U-00020

**Item 2-11.2:**

Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

New York State Department of Environmental Conservation

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024



Monitoring Description:

The emission limits in this permit for NO<sub>x</sub>, SO<sub>2</sub>, and/or PM<sub>10</sub> established under Part 249 are based on New York's Best Available Retrofit Technology (BART) Rule (6 NYCRR Part 249), are effective on the date of this permit's issuance, and are state-enforceable. Federal enforceability of these facility-specific requirements is effective on the date on which these emission limits, as submitted to EPA as a revision to New York State's Implementation Plan for Regional Haze, are published in the Federal Register.

Monitoring Frequency: SEMI-ANNUALLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

The initial report is due 7/30/2012.

Subsequent reports are due every 6 calendar month(s).

~~Condition 61: Compliance Certification  
Effective between the dates of 12/06/2006 and 02/03/2015~~

~~Applicable Federal Requirement: 6 NYCRR 227-1.4 (b)~~

~~Item 61.1:~~

~~The Compliance Certification activity will be performed for:~~

~~Emission Unit: U-00020~~

~~Emission Point: 00020~~

~~Item 61.2:~~

~~Compliance Certification shall include the following monitoring:~~

~~Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES~~

~~Monitoring Description:~~

~~The owner or operator of a stationary combustion installation which utilizes a continuous opacity monitoring system (COMS) shall include the following in their quarterly excess emission reports:~~

- ~~1) Magnitude, date, and time of each exceedence;~~
- ~~2) For each period of excess emissions, specific identification of the cause and corrective action taken;~~
- ~~3) Date, time, and duration of each period of COMS downtime, and the corrective action for each period of downtime;~~
- ~~4) Total time the COMS is required to record data during the reporting period;~~
- ~~5) The total number of exceedences and the duration of exceedences expressed as a percentage of the total time in which the COMS are required to record data; and~~
- ~~6) Such other requirements as the Department may deem necessary in order to enforce Article 19 of the Environmental Conservation Law~~



**New York State Department of Environmental Conservation**

Permit ID: 2-6304-00024/00035

Facility DEC ID: 2630400024

**Condition 2-12: Compliance Certification**  
Effective between the dates of 04/06/2012 and 02/03/2015

**Applicable Federal Requirement:6 NYCRR 249.3 (f)**

**Item 2-12.1:**  
The Compliance Certification activity will be performed for:

Emission Unit: U-00030

**Item 2-12.2:**  
Compliance Certification shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES  
Monitoring Description:

The emission limits in this permit for NOx, SO2, and/or PM10 established under Part 249 are based on New York's Best Available Retrofit Technology (BART) Rule (6 NYCRR Part 249), are effective on the date of this permit's issuance, and are state-enforceable. Federal enforceability of these facility-specific requirements is effective on the date on which these emission limits, as submitted to EPA as a revision to New York State's Implementation Plan for Regional Haze, are published in the Federal Register.

Monitoring Frequency: SEMI-ANNUALLY  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
The initial report is due 7/30/2012.  
Subsequent reports are due every 6 calendar month(s).

~~**Condition 64: Compliance Certification**~~  
~~Effective between the dates of 12/06/2006 and 02/03/2015~~

~~**Applicable Federal Requirement:6 NYCRR 227-1.4 (b)**~~

~~**Item 64.1:**~~  
~~The Compliance Certification activity will be performed for:~~

~~Emission Unit: U-00030                      Emission Point: 00030~~

~~**Item 64.2:**~~  
~~Compliance Certification shall include the following monitoring:~~

~~Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES~~  
~~Monitoring Description:~~

~~The owner or operator of a stationary combustion installation which utilizes a continuous opacity monitoring system (COMS) shall include the following in their quarterly excess emission reports:~~

- ~~1) Magnitude, date, and time of each exceedence;~~
- ~~2) For each period of excess emissions, specific identification of the~~