



Minnesota Pollution Control Agency

Compliance Report on Government Underground Storage Tanks

Noncompliant Federal - Government Underground Storage Tanks

| UST ID # | Owner Name | Site Name | Facility Address | City | County | State | Zip Code | Tank Size | Tank Product | Violation | Date of Last On-site Inspection | Actions to Ensure Compliance |
|----------|------------|-----------|------------------|------|--------|-------|----------|-----------|--------------|-----------|---------------------------------|------------------------------|
|----------|------------|-----------|------------------|------|--------|-------|----------|-----------|--------------|-----------|---------------------------------|------------------------------|

Noncompliant State - Government Underground Storage Tanks

| UST ID # | Owner Name | Site Name | Facility Address | City | County | State | Zip Code | Tank Size | Tank Product | Violation | Date of Last On-site Inspection | Actions to Ensure Compliance |
|----------|----------------------------------|-----------------------------------|------------------|----------------|--------|-------|----------|--------------|--------------|-----------|---------------------------------|------------------------------|
| 20876 | Minnesota Department of Correcti | Faribault Correctional Facility | 1101 Linden Road | Faribault | Rice | MN | 55021 | 10,000 Gas | | A | 7/5/2007 | Citation Warning |
| 4132 | Century College | Century College | 3300 Century Ave | White Bear Lak | Ramsey | MN | 55110 | 8,000 Diesel | | A | 6/2/2007 | Citation Warning |
| 3671 | University of Minnesota | Farms Ground Maintenance Building | 1866 Dudley Ave | Saint Paul | Ramsey | MN | 55108 | 4,000 Diesel | | A, H | | |
| | | | | | | | | 6,000 Diesel | | D | | |
| | | | | | | | | 6,000 Gas | | D | | |

Noncompliant County - Government Underground Storage Tanks

| UST ID # | Owner Name | Site Name | Facility Address | City | County | State | Zip Code | Tank Size | Tank Product | Violation | Date of Last On-site Inspection | Actions to Ensure Compliance |
|----------|------------------|-------------------------------------|-------------------|--------------|-----------|-------|----------|----------------------|--------------|------------|---------------------------------|------------------------------|
| 3968 | Ramsey County | Ramsey County Courthouse | 297 S Century Ave | Maplewood | Ramsey | MN | 55119 | 20,000 Fuel Oil | | S | 7/11/2007 | Citation Warning |
| 9774 | Wantonwan County | Wantonwan County Courthouse | 710 2nd Ave S | St. James | Wantonwar | MN | 56081 | 1,000 Diesel | | A,B,C,I | 6/18/2007 | Citation Warning |
| 8347 | Mower County | Mower County Highway Department | 1105 NE 8th Ave | Austin | Mower | MN | 55912 | 4,000 Gas | | D, H | 6/12/2007 | Citation Warning |
| | | | | | | | | 10,000 Diesel | | D, H | | |
| | | | | | | | | 10,000 Gas | | D, H | | |
| | | | | | | | | 1,000 Used/waste oil | | D, H | | |
| 14091 | Todd County | Todd County Annex | 212 2nd Ave | Long Prairie | Tocc | MN | 56347 | 1,000 Fuel Oil | | A, B | 7/12/2007 | Citation Warning |
| 8555 | Nobles County | Nobls County Governmental Facilites | 315 10th St | Worthington | Nobles | MN | 56187 | 6,000 Fuel Oil | | A, B, I, O | 7/18/2007 | |
| 124624 | Kandiyohi County | Kandiyohi County Park #1 | 14391 45th St SE | Lake Lillian | Kandiyohi | MN | 56253 | 500 Gas | | H, I, K, | | Elevated Enforcement** |

Noncompliant City - Government Underground Storage Tanks

| UST ID # | Owner Name | Site Name | Facility Address | City | County | State | Zip Code | Tank Size | Tank Product | Violation | Date of Last On-site Inspection | Actions to Ensure Compliance |
|----------|--------------------|---|-----------------------|------------|-----------|-------|----------|----------------------|--------------|---------------|---------------------------------|------------------------------|
| 6872 | City of Albert Lea | Albert Lea Municipal Airport | 231 E Clark St | Albert Lea | Freeborn | MN | 56007 | 6,000 Jet Fuel | | H | 7/16/2007 | Citation Warning |
| | | | | | | | | 6,000 Jet Fuel | | H | | |
| | | | | | | | | 10,000 Aviation Gas | | H | | |
| | | | | | | | | 10,000 Gas | | H | | |
| 9333 | City of Big Lake | Wastewater Treatment Plant | County Road 14 | Big Lake | Sherburne | MN | 55309 | 4,000 Fuel Oil | | O, B | 7/11/2007 | Citation Warning |
| 124586 | City of Burnsville | Burnsville City Hall | 100 Civic Center Pkwy | Burnsville | Dakota | MN | 55337 | 4,000 Diesel | | E, H, I K | 5/31/2007 | Citation Warning |
| 124587 | City of Burnsville | City of Burnsville Water Treatment Plant | 50 River Ridge Ct | Burnsville | Dakota | MN | 55337 | 7,000 Diesel | | A, B, H, I, K | 5/31/2007 | Citation Warning |
| 4031 | City of St. Paul | City of St. Paul Equipment Services | 1675 Energy Park Dr. | St. Paul | Ramsey | MN | 55108 | 6,000 Gas | | D | 6/15/2007 | Citation Warning |
| | | | | | | | | 6,000 Diesel | | D | | |
| | | | | | | | | 1,000 Used/waste oil | | D | | |
| 19469 | City of St. Paul | City of St. Paul Fire and Police Headquar | 100 E 10th St | St. Paul | Ramsey | MN | 55101 | 3,000 Gas | | A, B, C | 6/15/2007 | Citation Warning |
| | | | | | | | | 3,000 Diesel | | A, B, C | | |
| 4769 | City of Rochester | Water Reclamation Plant | 301 37th Ave NW | Rochester | Olmsted | MN | 55901 | 2,000 Gas | | A, B | 7/9/2007 | Citation Warning |
| | | | | | | | | 2,000 Gas | | A, B | | |
| | | | | | | | | 8,000 Diesel | | A, B | | |
| 3721 | City of Saint Paul | Ravoux Hi-rise (9m-1-16) | 280 Ravoux Street | Saint Paul | Ramsey | MN | 55103 | 15,000 Fuel Oil | | H, I | 6/14/2007 | Citation Warning |
| 3731 | City of Saint Paul | Valley Hi-rise (m-1-6) | 261 University Ave | Saint Paul | Ramsey | MN | 55101 | 1,000 Fuel Oil | | H, I | 6/14/2007 | Citation Warning |
| 12738 | City of Ortonville | Ortonville Wastewater Treatment Plant | Jackson Ave | Ortonville | Big Stone | MN | 56278 | 1,500 Fuel Oil | | A, H, I, O | 7/19/2007 | |

Noncompliant School/School Districts - Government Underground Storage Tanks

| UST ID # | Owner Name | Site Name | Facility Address | City | County | State | Zip Code | Tank Size | Tank Product | Violation | Date of Last On-site Inspection | Actions to Ensure Compliance |
|----------|-----------------------------------|--------------------------------------|-------------------|--------------|----------|-------|----------|----------------|--------------|-----------|---------------------------------|------------------------------|
| 12424 | Rosemont Ind. School District | Woodlawn Elementary School | 945 Wescott Rd | Eagan | Dakota | MN | 55123 | 5,000 Fuel Oil | | A, B, H | 5/21/2007 | Citation Warning |
| 18876 | Eden Prairie School District #272 | Eden Prairie Transportation Facility | 8055 Wallace Road | Eden Prairie | Hennepin | MN | 55344 | 2,500 Gas | | F, G, L | 5/10/2007 | |
| | | | | | | | | 15,000 Diesel | | F, G, L | | |

| | | | | | | | | | | | | |
|-------|----------------------------------|-------------------------------------|-----------------------|----------------|------------|----|-------|--------|----------------|---------------|-----------|------------------|
| 15097 | Foley Public School District #51 | Foley Elementary Schools and Bus | 757 Penn St | Foley | Benton | MN | 56329 | 10,000 | Diesel | D, H | 7/18/2007 | |
| | | | | | | | | 4,000 | Gas | D, H | | |
| 10162 | Holdingford School District # | Holdingford High School/Bus Garage | 900 5th St | Holdingford | Stearns | MN | 56340 | 4,000 | Gas | D, W | 6/25/2007 | Citation Warning |
| | | | | | | | | 10,000 | Diesel | D, W | | |
| 3007 | Hi Tech Excating | Hennepin Tech-Centers/ North Campus | 9000 Brooklyn Blvd | Brooklyn Park | Hennepin | MN | 55445 | 2,000 | Gas | E | 7/17/2007 | Citation Warning |
| | | | | | | | | 550 | Used/waste oil | E | | |
| 10168 | Ind. School District #748 | Sartell High School | 627 5th Ave N | Sartell | Stearns | MN | 56377 | 10,000 | Diesel | A, B, D, S | 6/26/2007 | Citation Warning |
| | | | | | | | | 10,000 | Diesel | A, B, D, S | | |
| | | | | | | | | 4,000 | Gas | A, B, D, S | | |
| 4527 | Ind. School District #16 | Ind. School District #16 | 8000 Highway 65 NE | Spring Lake Pa | Anoka | MN | 55432 | 1,000 | Gas | E | 6/8/2007 | Citation Warning |
| 1225 | Ind. School District #196 | Scott Highlands Middle School | 14011 Pilot Knob Road | Apple Valley | Dakota | MN | 55124 | 560 | Diesel | O, V | 5/21/2007 | Citation Warning |
| 9698 | Verndale Ind. School District | Verndale Public School | PO Box G | Verndale | Wadena | MN | 56481 | 1,000 | Diesel | A, D, H, P | 6/28/2007 | Citation Warning |
| 1348 | Rosemont Ind. School District | Deerwood Elementary School | 1480 Deerwood Dr | Eagan | Dakota | MN | 55122 | 560 | Diesel | A, H, O, V | 5/21/2007 | Citation Warning |
| | | | | | | | | 10,000 | Gas | A, B, F, G, J | | |
| | | | | | | | | 6,000 | Diesel | A, B, F, G, J | | |
| | | | | | | | | 560 | Used/waste oil | A | | |
| 549 | Mankato Public School District | East High School | 2600 Hoffman Road | Mankato | Blue Earth | MN | 56001 | 560 | Diesel | A, B | 5/24/2007 | Citation Warning |
| 15097 | Foley School District #51 | Foley Elementary School and Bus | 757 Penn Street | Foley | Benton | MN | 56329 | 10,000 | Diesel | D, H | 7/18/2007 | Citation Warning |
| | | | | | | | | 4,000 | Gas | D, H | | |
| 3852 | Saint Paul School District #625 | Saint Paul Technical Institute | 235 Marshall Ave | Saint Paul | Ramsey | MN | 55102 | 550 | Diesel | E, H, I, L | | |

*A Citation Warning consists of a nonmonetary penalty giving the Owner 60 days to return to compliance before a monetary penalty is assessed.

** The enforcement action has yet to be determined for the site but may consist of an elevated enforcement action with a monetary penalty.

| Violations | State or Federal | |
|------------|---|-------|
| A | Cathodic protection not tested every 3 years for the tank. | Both |
| B | Cathodic protection not tested every 3 years for the piping. | Both |
| C | No leak detection method for tank. | Both |
| D | Inadequate leak detection for the tank. | Both |
| E | Automatic tank gauge not put into test mode. | Both |
| F | Failure to conduct line tightness test. | Both |
| G | Failure to conduct mechanical line leak detector function test. | Both |
| H | Inadequate spill containment. | Both |
| I | Inadequate overfill protection. | Both |
| J | Shear valves not properly anchored. | Both |
| K | Failure to register tanks within 30 days of installation. | State |
| L | Failure to maintain leak detection records for 10 years. | Both |
| M | Leak at pump. | State |
| N | Leak at dispenser. | State |
| O | Vent pipe not 12 feet high or 2 feet above roof. | Both |
| P | Liquid in pump sump. | State |
| Q | Spill cover broken or missing. | State |
| R | 60 day rectifier check not conducted. | Both |
| S | Missing drop tube. | State |
| T | Missing caps on fill pipe. | State |
| U | Interstitial sensor not positioned to detect a release. | Both |
| V | Inadequate piping material. | State |
| W | Drop tube does not extend within 12" of tank bottom. | State |