

**State of New Jersey
Department of Environmental Protection
State Compliance Report on Government
Underground Storage Tanks (USTs)**

Last Refreshed: 08/08/2007 11:41 AM

County/Municipal

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
000202	GLEN ROCK BOROUGH DEPT OF PUBLIC WORKS	473 DOREMUS AVE Glen Rock NJ 07452	[N.J.A.C. 7:14B-2.4]	3/30/2005	Submit a completed Underground Storage Tank Facility Certification Questionnaire. within 15 days after receipt of this notice.
000202	GLEN ROCK BOROUGH DEPT OF PUBLIC WORKS	473 DOREMUS AVE Glen Rock NJ 07452	[N.J.A.C. 7:14B-5.1(d)]	3/30/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
000202	GLEN ROCK BOROUGH DEPT OF PUBLIC WORKS	473 DOREMUS AVE Glen Rock NJ 07452	[N.J.A.C. 7:14B-5.1(d)1]	3/30/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
000202	GLEN ROCK BOROUGH DEPT OF PUBLIC WORKS	473 DOREMUS AVE Glen Rock NJ 07452	[N.J.A.C. 7:14B-6.1]	3/30/2005	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
000202	GLEN ROCK BOROUGH DEPT OF PUBLIC WORKS	473 DOREMUS AVE Glen Rock NJ 07452	[N.J.A.C. 7:14B-6.2(a)1]	3/30/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
000202	GLEN ROCK BOROUGH DEPT OF PUBLIC WORKS	473 DOREMUS AVE Glen Rock NJ 07452	[N.J.A.C. 7:14B-6.6(a)1]	3/30/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
000319	MUNICIPAL BUILDING	70 MOONACHIE RD Moonachie NJ 07074	[N.J.A.C. 7:14B-2.4(a)]	6/13/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
000319	MUNICIPAL BUILDING	70 MOONACHIE RD Moonachie NJ 07074	[N.J.A.C. 7:14B-5.1(d)]	6/13/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps. spill buckets and catchment basins every thirty (30) days.
000319	MUNICIPAL BUILDING	70 MOONACHIE RD Moonachie NJ 07074	[N.J.A.C. 7:14B-5.8]	6/13/2007	Mark the fill ports in accordance with API Bulletin : within 15 days after receipt of this notice

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
000319	MUNICIPAL BUILDING	70 MOONACHIE RD Moonachie NJ 07074	[N.J.A.C. 7:14B-6.1(a)]	6/13/2007	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
000319	MUNICIPAL BUILDING	70 MOONACHIE RD Moonachie NJ 07074	[N.J.A.C. 7:14B-6.2(a)]	6/13/2007	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
000446	CAMDEN CNTY LINDENWOLD COMPLEX	2311 EGG HARBOR RD Lindenwold NJ 08021	[N.J.A.C. 7:14B-15.2(a)]	9/21/2006	Comply with rule/regulation: on the effective date of this document.
000446	CAMDEN CNTY LINDENWOLD COMPLEX	2311 EGG HARBOR RD Lindenwold NJ 08021	[N.J.A.C. 7:14B-1.8(b)]	9/21/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
000446	CAMDEN CNTY LINDENWOLD COMPLEX	2311 EGG HARBOR RD Lindenwold NJ 08021	[N.J.A.C. 7:14B-2.1(c)]	9/21/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
000446	CAMDEN CNTY LINDENWOLD COMPLEX	2311 EGG HARBOR RD Lindenwold NJ 08021	[N.J.A.C. 7:14B-2.4(a)]	9/21/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
000446	CAMDEN CNTY LINDENWOLD COMPLEX	2311 EGG HARBOR RD Lindenwold NJ 08021	[N.J.A.C. 7:14B-4.1(a)3ii]	9/21/2006	Comply with rule/regulation: on the effective date of this document.
000446	CAMDEN CNTY LINDENWOLD COMPLEX	2311 EGG HARBOR RD Lindenwold NJ 08021	[N.J.A.C. 7:14B-6.1(a)]	9/21/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
000446	CAMDEN CNTY LINDENWOLD COMPLEX	2311 EGG HARBOR RD Lindenwold NJ 08021	[N.J.A.C. 7:14B-6.1(a)2]	9/21/2006	Provide the Department with documentation of the performance claims of the Release Detection : within 15 days after receipt of this notice.
000446	CAMDEN CNTY LINDENWOLD COMPLEX	2311 EGG HARBOR RD Lindenwold NJ 08021	[N.J.A.C. 7:14B-6.2(a)]	9/21/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
000446	CAMDEN CNTY LINDENWOLD COMPLEX	2311 EGG HARBOR RD Lindenwold NJ 08021	[N.J.A.C. 7:14B-6.2(a)1]	9/21/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
000843	ATLANTIC CNTY DPW NORTHFIELD	DOLPHIN RD & RT 9 Northfield NJ 08225	[N.J.A.C. 7:14B-2.4(a)]	3/30/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
000843	ATLANTIC CNTY DPW NORTHFIELD	DOLPHIN RD & RT 9 Northfield NJ 08225	[N.J.A.C. 7:14B-5.8]	3/30/2006	Mark the fill ports in accordance with API Bulletin : within 15 days after receipt of this notice.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
000843	ATLANTIC CNTY DPW NORTHFIELD	DOLPHIN RD & RT 9 Northfield NJ 08225	[N.J.A.C. 7:14B-6.6(a)1]	3/30/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-15.2(a)]	6/6/2007	Comply with rule/regulation: on the effective date of this document Immediately obtain Financial Responsibility as required
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-2.1(a)]	6/6/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-2.1(c)]	6/6/2007	Comply with rule/regulation: on the effective date of this document Cease Use/Delivery Ban imposed
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-2.4(a)]	6/6/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-2.6(a)]	6/6/2007	Comply with rule/regulation: on the effective date of this document Make registration certificate available.
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-4.1(a)3]ii]	6/6/2007	Comply with rule/regulation on the effective date of this document Immediately provide overfill prevention for all tanks.
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-5.1(d)]	6/6/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-5.1(d)1]	6/6/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-5.9(b)]	6/6/2007	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-6.1(a)]	6/6/2007	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-6.1(a)2]	6/6/2007	Provide the Department with documentation of the performance claims of the Release Detection : within 15 days after receipt of this notice.
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-6.2(a)]	6/6/2007	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-6.2(a)1]	6/6/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide Interstitial test results.
002097	HAWORTH DPW	261 PARK ST Haworth NJ 07641	[N.J.A.C. 7:14B-6.7(f)]	6/6/2007	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately maintain required RDM records.
002586	CUMBERLAND CNTY COLLEGE	S ORCHARD RD & SHERMAN AVE Vineland NJ 083600517	[N.J.A.C. 7:14B-1.8(b)]	8/23/2005	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
002586	CUMBERLAND CNTY COLLEGE	S ORCHARD RD & SHERMAN AVE Vineland NJ 083600517	[N.J.A.C. 7:14B-4.1(a)3]ii]	8/23/2005	Comply with rule/regulation: on the effective date of this document.
002586	CUMBERLAND CNTY COLLEGE	S ORCHARD RD & SHERMAN AVE Vineland NJ 083600517	[N.J.A.C. 7:14B-6.1]	8/23/2005	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
003003	MOUNT LAUREL TWP	100 MOUNT LAUREL RD N Mount Laurel NJ 08054	[N.J.A.C. 7:14B-2.4(a)]	8/10/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
003003	MOUNT LAUREL TWP	100 MOUNT LAUREL RD N Mount Laurel NJ 08054	[N.J.A.C. 7:14B-4.1(a)3]ii]	8/10/2006	Comply with rule/regulation: on the effective date of this document Immediately provide overfill prevention for all tanks.
003003	MOUNT LAUREL TWP	100 MOUNT LAUREL RD N Mount Laurel NJ 08054	[N.J.A.C. 7:14B-6.1(a)2]	8/10/2006	Provide the Department with documentation of the performance claims of the Release Detection within 15 days after receipt of this notice
003003	MOUNT LAUREL TWP	100 MOUNT LAUREL RD N Mount Laurel NJ 08054	[N.J.A.C. 7:14B-6.2(a)1]	8/10/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide Interstitial test results.
003003	MOUNT LAUREL TWP	100 MOUNT LAUREL RD N Mount Laurel NJ 08054	[N.J.A.C. 7:14B-6.6(a)1]	8/10/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Provide documentation of yearly ALLD test.
003003	MOUNT LAUREL TWP	100 MOUNT LAUREL RD N Mount Laurel NJ 08054	[N.J.A.C. 7:14B-7.1(a)]	8/10/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately perform 7 day investigation.
003063	TOMS RIVER GARAGE	152 CHESTNUT ST Toms River NJ 08753	[N.J.A.C. 7:14B-2.1(a)]	3/28/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
003063	TOMS RIVER GARAGE	152 CHESTNUT ST Toms River NJ 08753	[N.J.A.C. 7:14B-5.8]	3/28/2007	Mark the fill ports in accordance with API Bulletin within 15 days after receipt of this notice

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
003063	TOMS RIVER GARAGE	152 CHESTNUT ST Toms River NJ 08753	[N.J.A.C. 7:14B-6.6(a)1]	3/28/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide an Automatic Line Leak Detector.
003604	ORADELL DEPARTMENT OF PUBLIC WORKS	MARGINAL RD & NEW MILFORD AVE Oradell NJ 07649	[N.J.A.C. 7:14B-4.1(a)3ii]	8/17/2005	Comply with rule/regulation: on the effective date of this document.
003604	ORADELL DEPARTMENT OF PUBLIC WORKS	MARGINAL RD & NEW MILFORD AVE Oradell NJ 07649	[N.J.A.C. 7:14B-5.1(d)1]	8/17/2005	Comply with rule/regulation within 15 days after receipt of this notice.
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-2.1(a)]	3/1/2005	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-2.1(c)]	3/1/2005	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-2.4(a)]	3/1/2005	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-4.1(a)1]	3/1/2005	Comply with rule/regulation: on the effective date of this document.
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-4.1(a)3j]	3/1/2005	Comply with rule/regulation. on the effective date of this document.
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-4.1(a)3ii]	3/1/2005	Comply with rule/regulation. on the effective date of this document.
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-5.1(d)1]	3/1/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-5.2(a)2j]	3/1/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-5.2(a)4]	3/1/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-5.5(b)]	3/1/2005	Comply with rule/regulation: on the effective date of this document.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-6.1(a)]	3/1/2005	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-6.1(a)2]	3/1/2005	Provide the Department with documentation of the performance claims of the Release Detection : within 15 days after receipt of this notice
004010	PUBLIC WORKS SERVICE CENTER-CAMDEN	1056 WRIGHT AVE Camden NJ 08103	[N.J.A.C. 7:14B-6.6(a)1]	3/1/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
004520	LIVINGSTON ROAD DEPARTMENT	235 LIVINGSTON AVE S Livingston NJ 07039	[N.J.A.C. 7:14B-2.1(a)]	10/21/2004	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
004520	LIVINGSTON ROAD DEPARTMENT	235 LIVINGSTON AVE S Livingston NJ 07039	[N.J.A.C. 7:14B-2.1(c)]	10/21/2004	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
004520	LIVINGSTON ROAD DEPARTMENT	235 LIVINGSTON AVE S Livingston NJ 07039	[N.J.A.C. 7:14B-5.1(d)]	10/21/2004	Comply with rule/regulation: within 15 days after receipt of this notice
004520	LIVINGSTON ROAD DEPARTMENT	235 LIVINGSTON AVE S Livingston NJ 07039	[N.J.A.C. 7:14B-5.1(d)1]	10/21/2004	Comply with rule/regulation: within 15 days after receipt of this notice.
004520	LIVINGSTON ROAD DEPARTMENT	235 LIVINGSTON AVE S Livingston NJ 07039	[N.J.A.C. 7:14B-5.1(d)2]	10/21/2004	Comply with rule/regulation: within 15 days after receipt of this notice
004520	LIVINGSTON ROAD DEPARTMENT	235 LIVINGSTON AVE S Livingston NJ 07039	[N.J.A.C. 7:14B-5.8]	10/21/2004	Mark the fill ports in accordance with API Bulletin : within 15 days after receipt of this notice.
004520	LIVINGSTON ROAD DEPARTMENT	235 LIVINGSTON AVE S Livingston NJ 07039	[N.J.A.C. 7:14B-6.6(a)1]	10/21/2004	Comply with rule/regulation: within 15 days after receipt of this notice
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-15.1(h)]	2/2/2005	Comply with rule/regulation: on the effective date of this document.
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-15.2(a)]	2/2/2005	Comply with rule/regulation: on the effective date of this document
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-2.1(a)]	2/2/2005	Submit a completed Underground Storage Tank Facility Certification Questionnaire : on the effective date of this document.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-4.1(a)3]ii]	2/2/2005	Comply with rule/regulation on the effective date of this document.
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-5.1(d)]	2/2/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-5.1(d)1]	2/2/2005	Comply with rule/regulation: within 15 days after receipt of this notice
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-5.1(d)2]	2/2/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-5.5(b)]	2/2/2005	Comply with rule/regulation: on the effective date of this document.
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-5.8]	2/2/2005	Mark the fill ports in accordance with API Bulletin within 15 days after receipt of this notice.
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-6.1]	2/2/2005	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-6.1(a)]	2/2/2005	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-6.1(a)2]	2/2/2005	Provide the Department with documentation of the performance claims of the Release Detection : within 15 days after receipt of this notice.
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-6.2(a)1]	2/2/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-6.5(a)1v]	2/2/2005	Comply with rule/regulation: within 15 days after receipt of this notice
004916	FLORHAM PK BORO	111 RIDGEDALE AVE Florham Park NJ 07932	[N.J.A.C. 7:14B-6.6(a)1]	2/2/2005	Comply with rule/regulation: within 15 days after receipt of this notice
005827	WARREN TWP STAGE V TREATMENT PLANT	184 LIBERTY CORNER RD Warren Twp NJ 07059	[N.J.A.C. 7:14B-6.1(a)]	6/13/2007	Provide an acceptable method of release detection monitoring and provide documentation : within 14 days after receipt of this notice. [N.J.A.C. 7:14B-6.1(a)]

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
005827	WARREN TWP STAGE V TREATMENT PLANT	184 LIBERTY CORNER RD Warren Twp NJ 07059	[N.J.A.C. 7:14B-6.1(a)2]	6/13/2007	Provide the Department with documentation of the performance claims of the Release Detection : within 14 days after receipt of this notice [N.J.A.C. 7:14B-6.1(a)2]
005827	WARREN TWP STAGE V TREATMENT PLANT	184 LIBERTY CORNER RD Warren Twp NJ 07059	[N.J.A.C. 7:14B-6.2(a)1]	6/13/2007	Comply with rule/regulation: within 14 days after receipt of this notice Provide 30 day Release Rate Test results. [N.J.A.C. 7:14A-6.2(a)1]
005827	WARREN TWP STAGE V TREATMENT PLANT	184 LIBERTY CORNER RD Warren Twp NJ 07059	[N.J.A.C. 7:14B-6.7(f)]	6/13/2007	Comply with rule/regulation upon occurrence of event. Immediately maintain required RDM records [N.J.A.C. 7:14B-6.7(f)]
005832	EDISON MUNICIPAL COMPLEX	100 MUNICIPAL BLVD Edison NJ 08817	[N.J.A.C. 7:14B-2.1(a)]	11/8/2004	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
007170	TOWNSHIP OF TOMS RIVER	1672 CHURCH RD & BAY AVE Toms River NJ 08753	[N.J.A.C. 7:14B-15.2(a)]	3/21/2007	Comply with rule/regulation: on the effective date of this document Immediately obtain Financial Responsibility as required.
007170	TOWNSHIP OF TOMS RIVER	1672 CHURCH RD & BAY AVE Toms River NJ 08753	[N.J.A.C. 7:14B-5.2(a)2]	3/21/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Provide corrosion protection system test results.
007514	OLD ADMINISTRATION OFFICES BUILDING	317 PENNSYLVANIA AVE Paterson NJ 07503	[N.J.A.C. 7:14B-5.1(d)]	10/25/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
007514	OLD ADMINISTRATION OFFICES BUILDING	317 PENNSYLVANIA AVE Paterson NJ 07503	[N.J.A.C. 7:14B-5.1(d)1]	10/25/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
007514	OLD ADMINISTRATION OFFICES BUILDING	317 PENNSYLVANIA AVE Paterson NJ 07503	[N.J.A.C. 7:14B-6.2(a)1]	10/25/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide 30 day Release Rate Test results.
007514	OLD ADMINISTRATION OFFICES BUILDING	317 PENNSYLVANIA AVE Paterson NJ 07503	[N.J.A.C. 7:14B-6.6(a)1]	10/25/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Provide documentation of yearly ALLD test.
007514	OLD ADMINISTRATION OFFICES BUILDING	317 PENNSYLVANIA AVE Paterson NJ 07503	[N.J.A.C. 7:14B-6.7(f)]	10/25/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately maintain required RDM records.
007518	COURT HOUSE COMPLEX	65 TO 77 HAMILTON ST Paterson NJ 07505	[N.J.A.C. 7:14B-1.8(b)]	1/3/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
007518	COURT HOUSE COMPLEX	65 TO 77 HAMILTON ST Paterson NJ 07505	[N.J.A.C. 7:14B-2.1(c)]	1/3/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
007518	COURT HOUSE COMPLE	65 TO 77 HAMILTON ST Paterson NJ 07505	[N.J.A.C. 7:14B-2.4(a)]	1/3/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
007518	COURT HOUSE COMPLE	65 TO 77 HAMILTON ST Paterson NJ 07505	[N.J.A.C. 7:14B-5.1(d)]	1/3/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
007518	COURT HOUSE COMPLE	65 TO 77 HAMILTON ST Paterson NJ 07505	[N.J.A.C. 7:14B-5.1(d)1]	1/3/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
007518	COURT HOUSE COMPLE	65 TO 77 HAMILTON ST Paterson NJ 07505	[N.J.A.C. 7:14B-6.1(a)]	1/3/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
007518	COURT HOUSE COMPLE	65 TO 77 HAMILTON ST Paterson NJ 07505	[N.J.A.C. 7:14B-6.2(a)]	1/3/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
007518	COURT HOUSE COMPLE	65 TO 77 HAMILTON ST Paterson NJ 07505	[N.J.A.C. 7:14B-6.2(a)1]	1/3/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
007518	COURT HOUSE COMPLE	65 TO 77 HAMILTON ST Paterson NJ 07505	[N.J.A.C. 7:14B-6.7(f)]	1/3/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
007521	PASSAIC CO DPW GARAGE	519 RINGWOOD AVE Pompton Lakes NJ 07442	[N.J.A.C. 7:14B-2.4]	4/21/2005	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
007521	PASSAIC CO DPW GARAGE	519 RINGWOOD AVE Pompton Lakes NJ 07442	[N.J.A.C. 7:14B-5.1(d)]	4/21/2005	Comply with rule/regulation within 15 days after receipt of this notice.
008233	BRANCH BROOK PARK MAINTENANCE GARAGE	30 HELLER PRKWAY Newark NJ 07102	[N.J.A.C. 7:14B-2.4(a)]	11/15/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
008233	BRANCH BROOK PARK MAINTENANCE GARAGE	30 HELLER PRKWAY Newark NJ 07102	[N.J.A.C. 7:14B-5.1(d)]	11/15/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
008233	BRANCH BROOK PARK MAINTENANCE GARAGE	30 HELLER PRKWAY Newark NJ 07102	[N.J.A.C. 7:14B-5.1(d)1]	11/15/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
008233	BRANCH BROOK PARK MAINTENANCE GARAGE	30 HELLER PRKWAY Newark NJ 07102	[N.J.A.C. 7:14B-5.8]	11/15/2006	Mark the fill ports in accordance with API Bulletin within 15 days after receipt of this notice.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
008237	SOUTH MOUNTAIN RESERVATION	S ORANGE AVE & BROOKSIDE DR Millburn NJ 07041	[N.J.A.C. 7:14B-1.8(a)]	11/15/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
008237	SOUTH MOUNTAIN RESERVATION	S ORANGE AVE & BROOKSIDE DR Millburn NJ 07041	[N.J.A.C. 7:14B-1.8(a)]	11/15/2006	Perform the required Site Investigation or Remedial Investigation: within 60 days of receipt of this document
008237	SOUTH MOUNTAIN RESERVATION	S ORANGE AVE & BROOKSIDE DR Millburn NJ 07041	[N.J.A.C. 7:14B-2.4(a)]	11/15/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
008237	SOUTH MOUNTAIN RESERVATION	S ORANGE AVE & BROOKSIDE DR Millburn NJ 07041	[N.J.A.C. 7:14B-2.6(a)]	11/15/2006	Comply with rule/regulation: on the effective date of this document Make registration certificate available.
008237	SOUTH MOUNTAIN RESERVATION	S ORANGE AVE & BROOKSIDE DR Millburn NJ 07041	[N.J.A.C. 7:14B-5.1(d)]	11/15/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
008237	SOUTH MOUNTAIN RESERVATION	S ORANGE AVE & BROOKSIDE DR Millburn NJ 07041	[N.J.A.C. 7:14B-5.1(d)1]	11/15/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
008237	SOUTH MOUNTAIN RESERVATION	S ORANGE AVE & BROOKSIDE DR Millburn NJ 07041	[N.J.A.C. 7:14B-5.8]	11/15/2006	Mark the fill ports in accordance with API Bulletin: within 15 days after receipt of this notice.
008237	SOUTH MOUNTAIN RESERVATION	S ORANGE AVE & BROOKSIDE DR Millburn NJ 07041	[N.J.A.C. 7:14B-7.1(a)]	11/15/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately perform 7 day investigation.
009237	WEST CALDWELL PUBLIC WORKS GARAGE	23 CLINTON RD West Caldwell NJ 07006	[N.J.A.C. 7:14B-5.1(d)]	4/10/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
009237	WEST CALDWELL PUBLIC WORKS GARAGE	23 CLINTON RD West Caldwell NJ 07006	[N.J.A.C. 7:14B-5.1(d)1]	4/10/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
009237	WEST CALDWELL PUBLIC WORKS GARAGE	23 CLINTON RD West Caldwell NJ 07006	[N.J.A.C. 7:14B-5.8]	4/10/2006	Mark the fill ports in accordance with API Bulletin: within 15 days after receipt of this notice.
009237	WEST CALDWELL PUBLIC WORKS GARAGE	23 CLINTON RD West Caldwell NJ 07006	[N.J.A.C. 7:14B-6.7(f)]	4/10/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-1.8(a)]	12/11/2006	Comply with rule/regulation: within 7 days after receipt of this notice.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-1.8(b)]	12/11/2006	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-2.1(c)]	12/11/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-2.4(a)]	12/11/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-4.1(a)3ii]	12/11/2006	Comply with rule/regulation: on the effective date of this document.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-4.1(a)3ii]	12/11/2006	Comply with rule/regulation: on the effective date of this document Immediately provide overflow prevention for all tanks.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.1(d)]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.1(d)]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.1(d)1]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.1(d)1]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.2(a)2]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.2(a)2]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Provide corrosion protection system test results.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.5(b)]	12/11/2006	Comply with rule/regulation: on the effective date of this document Make Release Response Plan available.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.8]	12/11/2006	Mark the fill ports in accordance with API Bulletin within 15 days after receipt of this notice

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-6.1(a)]	12/11/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-6.1(a)2]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-6.2(a)]	12/11/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-6.5(a)6viii]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-6.6(a)1]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide an Automatic Line Leak Detector.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-6.7(f)]	12/11/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-6.7(f)]	12/11/2006	Comply with rule/regulation within 7 days after receipt of this notice. Immediately maintain required RDM records.
010604	EAST ORANGE WATER RESERVE	300 PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-7.1(a)]	12/11/2006	Comply with rule/regulation within 7 days after receipt of this notice
013153	WEST WINDSOR TWP POLICE DEPT	20 MUNICIPAL DR West Windsor Twp NJ 08550	[N.J.A.C. 7:14B-8.2(a)1]	4/25/2007	Perform a Remedial Investigation and submit the report to the Department: within 120 days of receipt of this document. [N.J.A.C. 7:14B-8.2(a)1]
013153	WEST WINDSOR TWP POLICE DEPT	20 MUNICIPAL DR West Windsor Twp NJ 08550	[N.J.A.C. 7:26E-3.11(a)]	4/25/2007	Conduct a baseline ecological evaluation: within 60 days of the effective date of this document. [N.J.A.C. 7:26E-3.11(a)]
013153	WEST WINDSOR TWP POLICE DEPT	20 MUNICIPAL DR West Windsor Twp NJ 08550	[N.J.A.C. 7:26E-4.1(b)]	4/25/2007	Delineate the limits of contamination: within 90 days of the effective date of this document. [N.J.A.C. 7:26E-4.1(b)]
013153	WEST WINDSOR TWP POLICE DEPT	20 MUNICIPAL DR West Windsor Twp NJ 08550	[N.J.A.C. 7:26E-4.4(h)3]	4/25/2007	conduct a receptor evaluation: upon occurrence of event.. [N.J.A.C. 7:26E-4.4(h)3]

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
013153	WEST WINDSOR TWP POLICE DEPT	20 MUNICIPAL DR West Windsor Twp NJ 08550	[N.J.A.C. 7:26E-4.4(h)3]	4/25/2007	Delineate the limits of contamination: within 90 days of the effective date of this document including, but not limited to, the extent of free and/or residual product as determined pursuant to N.J.A.C. 7:26E-2.1(a)11. [N.J.A.C. 7:26E-4.4(h)3]
014865	DEPARTMENT OF PUBLIC WORKS	1 BROWERTOWN RD West Paterson NJ 07424	[N.J.A.C. 7:14B-5.8]	4/14/2005	Mark the fill ports in accordance with API Bulletin within 15 days after receipt of this notice
014865	DEPARTMENT OF PUBLIC WORKS	1 BROWERTOWN RD West Paterson NJ 07424	[N.J.A.C. 7:14B-6.2(a)1]	4/14/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
014865	DEPARTMENT OF PUBLIC WORKS	1 BROWERTOWN RD West Paterson NJ 07424	[N.J.A.C. 7:14B-6.7(f)]	4/14/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
016613	PASSAIC COUNTY GOLF COURSE	TOTOWA RD Wayne NJ 07470	[N.J.A.C. 7:14B-1.8(a)]	11/9/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
016613	PASSAIC COUNTY GOLF COURSE	TOTOWA RD Wayne NJ 07470	[N.J.A.C. 7:14B-1.8(a)]	11/9/2006	Perform the required Site Investigation or Remedial Investigation. within 60 days of receipt of this document.
016613	PASSAIC COUNTY GOLF COURSE	TOTOWA RD Wayne NJ 07470	[N.J.A.C. 7:14B-2.6(a)]	11/9/2006	Comply with rule/regulation: on the effective date of this document Make registration certificate available.
016613	PASSAIC COUNTY GOLF COURSE	TOTOWA RD Wayne NJ 07470	[N.J.A.C. 7:14B-4.1(a)3ii]	11/9/2006	Comply with rule/regulation on the effective date of this document Immediately provide overfill prevention for all tanks.
016613	PASSAIC COUNTY GOLF COURSE	TOTOWA RD Wayne NJ 07470	[N.J.A.C. 7:14B-5.1(d)]	11/9/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
016613	PASSAIC COUNTY GOLF COURSE	TOTOWA RD Wayne NJ 07470	[N.J.A.C. 7:14B-5.1(d)1]	11/9/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
016613	PASSAIC COUNTY GOLF COURSE	TOTOWA RD Wayne NJ 07470	[N.J.A.C. 7:14B-5.8]	11/9/2006	Mark the fill ports in accordance with API Bulletin within 15 days after receipt of this notice
016613	PASSAIC COUNTY GOLF COURSE	TOTOWA RD Wayne NJ 07470	[N.J.A.C. 7:14B-6.2(a)]	11/9/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
016613	PASSAIC COUNTY GOLF COURSE	TOTOWA RD Wayne NJ 07470	[N.J.A.C. 7:14B-6.2(a)1]	11/9/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide 30 day Release Rate Test results.
016613	PASSAIC COUNTY GOLF COURSE	TOTOWA RD Wayne NJ 07470	[N.J.A.C. 7:14B-6.2(a)1]	11/9/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide Interstitial test results.
016613	PASSAIC COUNTY GOLF COURSE	TOTOWA RD Wayne NJ 07470	[N.J.A.C. 7:14B-6.7(f)]	11/9/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately maintain required RDM records.
016781	PASSAIC VALLEY SEWERAGE COMMISSIONERS	600 WILSON AVE Newark NJ 07105	[N.J.A.C. 7:14B-1.8(a)]	11/14/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
016781	PASSAIC VALLEY SEWERAGE COMMISSIONERS	600 WILSON AVE Newark NJ 07105	[N.J.A.C. 7:14B-1.8(a)]	11/14/2006	Perform the required Site Investigation or Remedial Investigation: within 60 days of receipt of this document.
016781	PASSAIC VALLEY SEWERAGE COMMISSIONERS	600 WILSON AVE Newark NJ 07105	[N.J.A.C. 7:14B-2.4(a)]	11/14/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
016781	PASSAIC VALLEY SEWERAGE COMMISSIONERS	600 WILSON AVE Newark NJ 07105	[N.J.A.C. 7:14B-5.1(d)]	11/14/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
016781	PASSAIC VALLEY SEWERAGE COMMISSIONERS	600 WILSON AVE Newark NJ 07105	[N.J.A.C. 7:14B-5.1(d)1]	11/14/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
016781	PASSAIC VALLEY SEWERAGE COMMISSIONERS	600 WILSON AVE Newark NJ 07105	[N.J.A.C. 7:14B-5.8]	11/14/2006	Mark the fill ports in accordance with API Bulletin within 15 days after receipt of this notice.
016781	PASSAIC VALLEY SEWERAGE COMMISSIONERS	600 WILSON AVE Newark NJ 07105	[N.J.A.C. 7:14B-6.6(a)1]	11/14/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide an Automatic Line Leak Detector.
018845	WAYNE TWP DPW	201 DEY RD Wayne NJ 07470	[N.J.A.C. 7:14B-2.4(a)]	1/5/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
018845	WAYNE TWP DPW	201 DEY RD Wayne NJ 07470	[N.J.A.C. 7:14B-6.6(a)1]	1/5/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
018845	WAYNE TWP DPW	201 DEY RD Wayne NJ 07470	[N.J.A.C. 7:14B-6.7(f)]	1/5/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately maintain required RDM records.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
019655	HUDSON CNTY CORRECTIONAL FACILITY	30 HACKENSACK AVE Kearny NJ 07032	[N.J.A.C. 7:14B-2.4(a)]	10/30/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
019655	HUDSON CNTY CORRECTIONAL FACILITY	30 HACKENSACK AVE Kearny NJ 07032	[N.J.A.C. 7:14B-4.1(a)3(i)]	10/30/2006	Comply with rule/regulation: on the effective date of this document immediately provide overflow prevention for all tanks.
019655	HUDSON CNTY CORRECTIONAL FACILITY	30 HACKENSACK AVE Kearny NJ 07032	[N.J.A.C. 7:14B-5.1(d)1]	10/30/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
019980	HIGH BRIDGE BORO GARAGE	26 MAIN ST W High Bridge NJ 08829	[N.J.A.C. 7:14B-15.2(a)]	2/1/2007	Comply with rule/regulation: on the effective date of this document immediately obtain Financial Responsibility as required.
019980	HIGH BRIDGE BORO GARAGE	26 MAIN ST W High Bridge NJ 08829	[N.J.A.C. 7:14B-2.1(a)]	2/1/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
019980	HIGH BRIDGE BORO GARAGE	26 MAIN ST W High Bridge NJ 08829	[N.J.A.C. 7:14B-6.2(a)1]	2/1/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide interstitial test results.
019980	HIGH BRIDGE BORO GARAGE	26 MAIN ST W High Bridge NJ 08829	[N.J.A.C. 7:14B-6.7(f)]	2/1/2007	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately maintain required RDM records.
020665	GREENVILLE HOSPITAL	1825 JOHN F KENNEDY BLVD Jersey City NJ 07305	[N.J.A.C. 7:14B-1.8(a)]	8/23/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
020665	GREENVILLE HOSPITAL	1825 JOHN F KENNEDY BLVD Jersey City NJ 07305	[N.J.A.C. 7:14B-2.4(a)]	8/23/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
020665	GREENVILLE HOSPITAL	1825 JOHN F KENNEDY BLVD Jersey City NJ 07305	[N.J.A.C. 7:14B-2.6(a)]	8/23/2006	Comply with rule/regulation: on the effective date of this document.
020665	GREENVILLE HOSPITAL	1825 JOHN F KENNEDY BLVD Jersey City NJ 07305	[N.J.A.C. 7:14B-5.1(d)]	8/23/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
020665	GREENVILLE HOSPITAL	1825 JOHN F KENNEDY BLVD Jersey City NJ 07305	[N.J.A.C. 7:14B-5.1(d)1]	8/23/2006	Comply with rule/regulation: within 15 days after receipt of this notice
020665	GREENVILLE HOSPITAL	1825 JOHN F KENNEDY BLVD Jersey City NJ 07305	[N.J.A.C. 7:14B-6.2(a)]	8/23/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
020665	GREENVILLE HOSPITAL	1825 JOHN F KENNEDY BLVD Jersey City NJ 07305	[N.J.A.C. 7:14B-6.2(a)1]	8/23/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
020665	GREENVILLE HOSPITAL	1825 JOHN F KENNEDY BLVD Jersey City NJ 07305	[N.J.A.C. 7:14B-6.2(a)1]	8/23/2006	Provide an acceptable method of release detection monitoring and provide documentation: on the effective date of this document.
020665	GREENVILLE HOSPITAL	1825 JOHN F KENNEDY BLVD Jersey City NJ 07305	[N.J.A.C. 7:14B-6.2(b)2]	8/23/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
020665	GREENVILLE HOSPITAL	1825 JOHN F KENNEDY BLVD Jersey City NJ 07305	[N.J.A.C. 7:14B-6.7(f)]	8/23/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-2.4(a)]	11/9/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-2.6(a)]	11/9/2006	Comply with rule/regulation: on the effective date of this document.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-2.6(a)]	11/9/2006	Comply with rule/regulation: on the effective date of this document. Make registration certificate available.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-4.1(a)3ii]	11/9/2006	Comply with rule/regulation: on the effective date of this document.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-5.1(d)]	11/9/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-5.1(d)]	11/9/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-5.1(d)1]	11/9/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-5.1(d)1]	11/9/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-5.8]	11/9/2006	Mark the fill ports in accordance with API Bulletin: within 15 days after receipt of this notice.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-6.1(a)]	11/9/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-6.2(a)1]	11/9/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide 30 day Release Rate Test results.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-6.2(a)1]	11/9/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-6.2(b)2]	11/9/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-6.2(b)2]	11/9/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-6.6(a)1]	11/9/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Provide documentation of yearly ALLD test
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-6.7(f)]	11/9/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
020836	PASSAIC CNTY PARA TRANSIT	1310 RTE 23 N Wayne NJ 07470	[N.J.A.C. 7:14B-6.7(f)]	11/9/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately maintain required RDM records.
022255	KIRKPATRICK LANE PUMI STATION	KIRKPATRICK LN West Caldwell NJ 07006	[N.J.A.C. 7:14B-2.1(a)]	4/3/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
022255	KIRKPATRICK LANE PUMI STATION	KIRKPATRICK LN West Caldwell NJ 07006	[N.J.A.C. 7:14B-2.1(c)]	4/3/2007	Comply with rule/regulation: on the effective date of this document Cease Use/Delivery Ban imposed
022255	KIRKPATRICK LANE PUMI STATION	KIRKPATRICK LN West Caldwell NJ 07006	[N.J.A.C. 7:14B-4.1(a)3ii]	4/3/2007	Comply with rule/regulation: on the effective date of this document immediately provide overfill prevention for all tanks.
022255	KIRKPATRICK LANE PUMI STATION	KIRKPATRICK LN West Caldwell NJ 07006	[N.J.A.C. 7:14B-5.8]	4/3/2007	Mark the fill ports in accordance with API Bulletin within 15 days after receipt of this notice.
022255	KIRKPATRICK LANE PUMI STATION	KIRKPATRICK LN West Caldwell NJ 07006	[N.J.A.C. 7:14B-5.9(b)]	4/3/2007	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
023456	HILLCREST FIRE HOUSE	221 UNION AVE Paterson NJ 07505	[N.J.A.C. 7:14B-2.4(a)]	10/25/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
023456	HILLCREST FIRE HOUSE	221 UNION AVE Paterson NJ 07505	[N.J.A.C. 7:14B-5.1(d)]	10/25/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
023456	HILLCREST FIRE HOUSE	221 UNION AVE Paterson NJ 07505	[N.J.A.C. 7:14B-5.1(d)1]	10/25/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
023459	MADISON AVE FIREHOUSE	850 MADISON AVE Paterson NJ 07501	[N.J.A.C. 7:14B-2.4(a)]	10/17/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
023462	SOUTHSIDE FIREHOUSE	124 GETTY AVE Paterson NJ 07503	[N.J.A.C. 7:14B-2.4(a)]	10/20/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
023462	SOUTHSIDE FIREHOUSE	124 GETTY AVE Paterson NJ 07503	[N.J.A.C. 7:14B-5.1(d)1]	10/20/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
023640	STEPHEN R GREGG BAYONNE PARK	JOHN F KENNEDY BLVD Bayonne NJ 07002	[N.J.A.C. 7:14B-15.1(h)]	3/22/2005	Comply with rule/regulation: on the effective date of this document.
023640	STEPHEN R GREGG BAYONNE PARK	JOHN F KENNEDY BLVD Bayonne NJ 07002	[N.J.A.C. 7:14B-15.2(a)]	3/22/2005	Comply with rule/regulation: on the effective date of this document.
023640	STEPHEN R GREGG BAYONNE PARK	JOHN F KENNEDY BLVD Bayonne NJ 07002	[N.J.A.C. 7:14B-2.1(a)]	3/22/2005	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
023640	STEPHEN R GREGG BAYONNE PARK	JOHN F KENNEDY BLVD Bayonne NJ 07002	[N.J.A.C. 7:14B-5.1(d)1]	3/22/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
023640	STEPHEN R GREGG BAYONNE PARK	JOHN F KENNEDY BLVD Bayonne NJ 07002	[N.J.A.C. 7:14B-5.1(d)2]	3/22/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
023640	STEPHEN R GREGG BAYONNE PARK	JOHN F KENNEDY BLVD Bayonne NJ 07002	[N.J.A.C. 7:14B-5.5(b)]	3/22/2005	Comply with rule/regulation: on the effective date of this document.
023640	STEPHEN R GREGG BAYONNE PARK	JOHN F KENNEDY BLVD Bayonne NJ 07002	[N.J.A.C. 7:14B-5.8]	3/22/2005	Mark the fill ports in accordance with API Bulletin within 15 days after receipt of this notice

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
023640	STEPHEN R GREGG BAYONNE PARK	JOHN F KENNEDY BLVD Bayonne NJ 07002	[N.J.A.C. 7:14B-6.1]	3/22/2005	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
023640	STEPHEN R GREGG BAYONNE PARK	JOHN F KENNEDY BLVD Bayonne NJ 07002	[N.J.A.C. 7:14B-6.1(a)2]	3/22/2005	Provide the Department with documentation of the performance claims of the Release Detection : within 15 days after receipt of this notice
023640	STEPHEN R GREGG BAYONNE PARK	JOHN F KENNEDY BLVD Bayonne NJ 07002	[N.J.A.C. 7:14B-6.2(a)1]	3/22/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
023640	STEPHEN R GREGG BAYONNE PARK	JOHN F KENNEDY BLVD Bayonne NJ 07002	[N.J.A.C. 7:14B-6.5(a)1vi]	3/22/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
023811	PEMBERTON TWP MUNICIPAL COMPLEX	500 PEMBERTON-BROWNS MILLS RD Pemberton Twp NJ 08064	[N.J.A.C. 7:14B-2.4(a)]	8/18/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
023811	PEMBERTON TWP MUNICIPAL COMPLEX	500 PEMBERTON-BROWNS MILLS RD Pemberton Twp NJ 08064	[N.J.A.C. 7:14B-5.1(d)]	8/18/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
023811	PEMBERTON TWP MUNICIPAL COMPLEX	500 PEMBERTON-BROWNS MILLS RD Pemberton Twp NJ 08064	[N.J.A.C. 7:14B-6.1(a)]	8/18/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
023811	PEMBERTON TWP MUNICIPAL COMPLEX	500 PEMBERTON-BROWNS MILLS RD Pemberton Twp NJ 08064	[N.J.A.C. 7:14B-6.1(a)2]	8/18/2006	Provide the Department with documentation of the performance claims of the Release Detection : within 15 days after receipt of this notice.
023811	PEMBERTON TWP MUNICIPAL COMPLEX	500 PEMBERTON-BROWNS MILLS RD Pemberton Twp NJ 08064	[N.J.A.C. 7:14B-6.2(a)1]	8/18/2006	Comply with rule/regulation: within 15 days after receipt of this notice Immediately provide 30 day Release Rate Test results.
023811	PEMBERTON TWP MUNICIPAL COMPLEX	500 PEMBERTON-BROWNS MILLS RD Pemberton Twp NJ 08064	[N.J.A.C. 7:14B-6.2(a)1]	8/18/2006	Comply with rule/regulation within 15 days after receipt of this notice Immediately provide Interstitial test results.
023811	PEMBERTON TWP MUNICIPAL COMPLEX	500 PEMBERTON-BROWNS MILLS RD Pemberton Twp NJ 08064	[N.J.A.C. 7:14B-6.6(a)1]	8/18/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide an Automatic Line Leak Detector.
023811	PEMBERTON TWP MUNICIPAL COMPLEX	500 PEMBERTON-BROWNS MILLS RD Pemberton Twp NJ 08064	[N.J.A.C. 7:14B-6.6(a)1]	8/18/2006	Comply with rule/regulation within 15 days after receipt of this notice. Provide documentation of yearly ALLD test.
023811	PEMBERTON TWP MUNICIPAL COMPLEX	500 PEMBERTON-BROWNS MILLS RD Pemberton Twp NJ 08064	[N.J.A.C. 7:14B-6.7(f)]	8/18/2006	Comply with rule/regulation: within 7 days after receipt of this notice Immediately maintain required RDM records.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
023851	HOPATCONG MUNICIPAL BUILDING	111 RIVER STYX RD Hopatcong NJ 07843	[N.J.A.C. 7:14B-5.1(d)]	7/20/2006	Comply with rule/regulation. within 15 days after receipt of this notice.
023851	HOPATCONG MUNICIPAL BUILDING	111 RIVER STYX RD Hopatcong NJ 07843	[N.J.A.C. 7:14B-5.1(d)1]	7/20/2006	Comply with rule/regulation. within 15 days after receipt of this notice.
023851	HOPATCONG MUNICIPAL BUILDING	111 RIVER STYX RD Hopatcong NJ 07843	[N.J.A.C. 7:14B-5.8]	7/20/2006	Mark the fill ports in accordance with API Bulletin : within 15 days after receipt of this notice
023851	HOPATCONG MUNICIPAL BUILDING	111 RIVER STYX RD Hopatcong NJ 07843	[N.J.A.C. 7:14B-6.2(a)]	7/20/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
023851	HOPATCONG MUNICIPAL BUILDING	111 RIVER STYX RD Hopatcong NJ 07843	[N.J.A.C. 7:14B-6.2(a)1]	7/20/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
023851	HOPATCONG MUNICIPAL BUILDING	111 RIVER STYX RD Hopatcong NJ 07843	[N.J.A.C. 7:14B-6.2(a)1]	7/20/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
023851	HOPATCONG MUNICIPAL BUILDING	111 RIVER STYX RD Hopatcong NJ 07843	[N.J.A.C. 7:14B-6.2(b)2]	7/20/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
023851	HOPATCONG MUNICIPAL BUILDING	111 RIVER STYX RD Hopatcong NJ 07843	[N.J.A.C. 7:14B-6.7(f)]	7/20/2006	Comply with rule/regulation within 7 days after receipt of this notice.
023851	HOPATCONG MUNICIPAL BUILDING	111 RIVER STYX RD Hopatcong NJ 07843	[N.J.A.C. 7:14B-7.1(a)]	7/20/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
024155	EAST ORANGE WATER RES GOLF COURS	PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-1.8(b)]	12/11/2006	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed.
024155	EAST ORANGE WATER RES GOLF COURS	PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-2.4(a)]	12/11/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire. within 15 days after receipt of this notice.
024155	EAST ORANGE WATER RES GOLF COURS	PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-4.1(a)3ii]	12/11/2006	Comply with rule/regulation on the effective date of this document Immediately provide overflow prevention for all tanks.
024155	EAST ORANGE WATER RES GOLF COURS	PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.1(d)]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
024155	EAST ORANGE WATER RES GOLF COURSE	PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.1(d)1]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
024155	EAST ORANGE WATER RES GOLF COURSE	PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.2(a)2]	12/11/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Provide corrosion protection system test results.
024155	EAST ORANGE WATER RES GOLF COURSE	PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.5(b)]	12/11/2006	Comply with rule/regulation: on the effective date of this document Make Release Response Plan available.
024155	EAST ORANGE WATER RES GOLF COURSE	PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-5.8]	12/11/2006	Mark the fill ports in accordance with API Bulletin: within 15 days after receipt of this notice.
024155	EAST ORANGE WATER RES GOLF COURSE	PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-6.1(a)]	12/11/2006	Provide an acceptable method of release detection monitoring and provide documentation: on the effective date of this document
024155	EAST ORANGE WATER RES GOLF COURSE	PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-6.1(a)2]	12/11/2006	Provide the Department with documentation of the performance claims of the Release Detection: within 15 days after receipt of this notice.
024155	EAST ORANGE WATER RES GOLF COURSE	PARSONAGE HILL RD Millburn NJ 07078	[N.J.A.C. 7:14B-6.7(f)]	12/11/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately maintain required RDM records.
024488	HIGHWAY GARAGE	WAYNE & CLEMENTS RDS Pennsauken NJ 08110	[N.J.A.C. 7:14B-15.2(a)]	12/7/2006	Comply with rule/regulation: on the effective date of this document Immediately obtain Financial Responsibility as required.
024939	PREAKNESS HOSPITAL UNIT 1	VALLEY VIEW RD Haledon NJ 07508	[N.J.A.C. 7:14B-15.2(a)]	1/3/2007	Comply with rule/regulation: on the effective date of this document.
024939	PREAKNESS HOSPITAL UNIT 1	VALLEY VIEW RD Haledon NJ 07508	[N.J.A.C. 7:14B-1.8(a)]	1/3/2007	Comply with rule/regulation: within 7 days after receipt of this notice.
024939	PREAKNESS HOSPITAL UNIT 1	VALLEY VIEW RD Haledon NJ 07508	[N.J.A.C. 7:14B-2.4(e)]	1/3/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
024939	PREAKNESS HOSPITAL UNIT 1	VALLEY VIEW RD Haledon NJ 07508	[N.J.A.C. 7:14B-7.1(a)]	1/3/2007	Comply with rule/regulation: within 7 days after receipt of this notice.
024940	PREAKNESS HOSPITAL UNITS 2&3	OLDHAM RD Wayne NJ 07470	[N.J.A.C. 7:14B-15.2(a)]	1/3/2007	Comply with rule/regulation: on the effective date of this document.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
024940	PREAKNESS HOSPITAL UNITS 2&3	OLDHAM RD Wayne NJ 07470	[N.J.A.C. 7:14B-2.4(a)]	1/3/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
024940	PREAKNESS HOSPITAL UNITS 2&3	OLDHAM RD Wayne NJ 07470	[N.J.A.C. 7:14B-4.1(a)3]ii]	1/3/2007	Comply with rule/regulation: on the effective date of this document.
024940	PREAKNESS HOSPITAL UNITS 2&3	OLDHAM RD Wayne NJ 07470	[N.J.A.C. 7:14B-5.1(d)]	1/3/2007	Comply with rule/regulation: within 15 days after receipt of this notice.
024940	PREAKNESS HOSPITAL UNITS 2&3	OLDHAM RD Wayne NJ 07470	[N.J.A.C. 7:14B-5.1(d)1]	1/3/2007	Comply with rule/regulation: within 15 days after receipt of this notice.
024940	PREAKNESS HOSPITAL UNITS 2&3	OLDHAM RD Wayne NJ 07470	[N.J.A.C. 7:14B-6.7(f)]	1/3/2007	Comply with rule/regulation: within 7 days after receipt of this notice.
025060	TOWN GARAGE	111 SUSSEX ST Harrison NJ 07029	[N.J.A.C. 7:14B-2.4(a)]	12/18/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
025060	TOWN GARAGE	111 SUSSEX ST Harrison NJ 07029	[N.J.A.C. 7:14B-5.1(d)]	12/18/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
025060	TOWN GARAGE	111 SUSSEX ST Harrison NJ 07029	[N.J.A.C. 7:14B-5.1(d)1]	12/18/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
025060	TOWN GARAGE	111 SUSSEX ST Harrison NJ 07029	[N.J.A.C. 7:14B-5.8]	12/18/2006	Mark the fill ports in accordance with API Bulletin : within 15 days after receipt of this notice.
025060	TOWN GARAGE	111 SUSSEX ST Harrison NJ 07029	[N.J.A.C. 7:14B-6.6(a)1]	12/18/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Provide documentation of yearly ALLD test.
025982	ATLANTIC CNTY UTILITIES: AUTHORITY	DELILAH RD Egg Harbor Twp NJ 08234	[N.J.A.C. 7:14B-4.1(a)1]	10/26/2006	Comply with rule/regulation: on the effective date of this document immediately provide Corrosion Protection for the tanks.
025982	ATLANTIC CNTY UTILITIES: AUTHORITY	DELILAH RD Egg Harbor Twp NJ 08234	[N.J.A.C. 7:14B-5.2(a)2]	10/26/2006	Comply with rule/regulation: within 15 days after receipt of this notice Provide corrosion protection system test results.
025982	ATLANTIC CNTY UTILITIES: AUTHORITY	DELILAH RD Egg Harbor Twp NJ 08234	[N.J.A.C. 7:14B-5.8]	10/26/2006	Mark the fill ports in accordance with API Bulletin : within 15 days after receipt of this notice.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
025982	ATLANTIC CNTY UTILITIES AUTHORITY	DELILAH RD Egg Harbor Twp NJ 08234	[N.J.A.C. 7:14B-5.9(a)]	10/26/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
025982	ATLANTIC CNTY UTILITIES AUTHORITY	DELILAH RD Egg Harbor Twp NJ 08234	[N.J.A.C. 7:14B-5.9(b)]	10/26/2006	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed
025982	ATLANTIC CNTY UTILITIES AUTHORITY	DELILAH RD Egg Harbor Twp NJ 08234	[N.J.A.C. 7:14B-6.1(a)]	10/26/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
025982	ATLANTIC CNTY UTILITIES AUTHORITY	DELILAH RD Egg Harbor Twp NJ 08234	[N.J.A.C. 7:14B-6.2(a)1]	10/26/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide interstitial test results.
025982	ATLANTIC CNTY UTILITIES AUTHORITY	DELILAH RD Egg Harbor Twp NJ 08234	[N.J.A.C. 7:14B-7.1(a)]	10/26/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately perform 7 day investigation.
026286	SUNOCO 23 & MAIN INC	3 STEVENS AVE Little Falls NJ 07424	[N.J.A.C. 7:14B-15.1(h)]	8/23/2005	Comply with rule/regulation. on the effective date of this document.
026286	SUNOCO 23 & MAIN INC	3 STEVENS AVE Little Falls NJ 07424	[N.J.A.C. 7:14B-2.6(a)]	8/23/2005	Comply with rule/regulation: on the effective date of this document.
026286	SUNOCO 23 & MAIN INC	3 STEVENS AVE Little Falls NJ 07424	[N.J.A.C. 7:14B-5.1(d)]	8/23/2005	Comply with rule/regulation: within 15 days after receipt of this notice
026286	SUNOCO 23 & MAIN INC	3 STEVENS AVE Little Falls NJ 07424	[N.J.A.C. 7:14B-5.1(d)1]	8/23/2005	Comply with rule/regulation: within 15 days after receipt of this notice.
026286	SUNOCO 23 & MAIN INC	3 STEVENS AVE Little Falls NJ 07424	[N.J.A.C. 7:14B-5.5(b)]	8/23/2005	Comply with rule/regulation: on the effective date of this document.
026286	SUNOCO 23 & MAIN INC	3 STEVENS AVE Little Falls NJ 07424	[N.J.A.C. 7:14B-5.8]	8/23/2005	Mark the fill ports in accordance with API Bulletin : within 15 days after receipt of this notice.
030920	TWP OF CHERRY HILL POLICE DEPT	820 MERCER ST Cherry Hill NJ 08022	[N.J.A.C. 7:14B-15.2(a)]	2/21/2007	Comply with rule/regulation: on the effective date of this document Immediately obtain Financial Responsibility as required
030920	TWP OF CHERRY HILL POLICE DEPT	820 MERCER ST Cherry Hill NJ 08022	[N.J.A.C. 7:14B-2.4(a)]	2/21/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
030920	TWP OF CHERRY HILL POLICE DEPT	820 MERCER ST Cherry Hill NJ 08022	[N.J.A.C. 7:14B-4.1(a)3]ii]	2/21/2007	Comply with rule/regulation: on the effective date of this document Immediately provide overflow prevention for all tanks.
030920	TWP OF CHERRY HILL POLICE DEPT	820 MERCER ST Cherry Hill NJ 08022	[N.J.A.C. 7:14B-5.1(d)1]	2/21/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
030920	TWP OF CHERRY HILL POLICE DEPT	820 MERCER ST Cherry Hill NJ 08022	[N.J.A.C. 7:14B-5.2(a)2]	2/21/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Provide corrosion protection system test results.
030920	TWP OF CHERRY HILL POLICE DEPT	820 MERCER ST Cherry Hill NJ 08022	[N.J.A.C. 7:14B-6.2(a)]	2/21/2007	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
033080	ATLANTIC CITY MUA - OPERATIONS FACILITY	401 VIRGINIA AVE Atlantic City NJ 084040117	[N.J.A.C. 7:14B-4.1(a)3]ii]	11/3/2006	Comply with rule/regulation: on the effective date of this document Immediately provide overflow prevention for all tanks.
033080	ATLANTIC CITY MUA - OPERATIONS FACILITY	401 VIRGINIA AVE Atlantic City NJ 084040117	[N.J.A.C. 7:14B-5.9(b)]	11/3/2006	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed
033080	ATLANTIC CITY MUA - OPERATIONS FACILITY	401 VIRGINIA AVE Atlantic City NJ 084040117	[N.J.A.C. 7:14B-6.1(a)]	11/3/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
033080	ATLANTIC CITY MUA - OPERATIONS FACILITY	401 VIRGINIA AVE Atlantic City NJ 084040117	[N.J.A.C. 7:14B-6.1(a)2]	11/3/2006	Provide the Department with documentation of the performance claims of the Release Detection : within 15 days after receipt of this notice
033080	ATLANTIC CITY MUA - OPERATIONS FACILITY	401 VIRGINIA AVE Atlantic City NJ 084040117	[N.J.A.C. 7:14B-6.2(a)1]	11/3/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately provide Interstitial test results.
033080	ATLANTIC CITY MUA - OPERATIONS FACILITY	401 VIRGINIA AVE Atlantic City NJ 084040117	[N.J.A.C. 7:14B-6.6(a)1]	11/3/2006	Comply with rule/regulation: within 15 days after receipt of this notice Provide documentation of yearly ALLD test.
033126	HUDSON CNTY VOTECH SCHOOL	525 MONTGOMERY ST Jersey City NJ 07303	[N.J.A.C. 7:14B-5.1(d)]	11/30/2006	Comply with rule/regulation within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
033126	HUDSON CNTY VOTECH SCHOOL	525 MONTGOMERY ST Jersey City NJ 07303	[N.J.A.C. 7:14B-5.1(d)1]	11/30/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
033126	HUDSON CNTY VOTECH SCHOOL	525 MONTGOMERY ST Jersey City NJ 07303	[N.J.A.C. 7:14B-5.8]	11/30/2006	Mark the fill ports in accordance with API Bulletin : within 15 days after receipt of this notice

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
033126	HUDSON CNTY VOTECH SCHOOL	525 MONTGOMERY ST Jersey City NJ 07303	[N.J.A.C. 7:14B-6.2(a)]	11/30/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
033126	HUDSON CNTY VOTECH SCHOOL	525 MONTGOMERY ST Jersey City NJ 07303	[N.J.A.C. 7:14B-6.7(f)]	11/30/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately maintain required RDM records
033210	DEPT OF PUBLIC WORKS YARD	1600 RIVER RD Teaneck NJ 07666	[N.J.A.C. 7:14B-2.4(a)]	4/18/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
033210	DEPT OF PUBLIC WORKS YARD	1600 RIVER RD Teaneck NJ 07666	[N.J.A.C. 7:14B-5.8]	4/18/2007	Mark the fill ports in accordance with API Bulletin . within 15 days after receipt of this notice.
033750	CUMBERLAND CNTY	1728 W SHERMAN AVE Vineland NJ 08360	[N.J.A.C. 7:14B-2.6(a)]	3/8/2006	Comply with rule/regulation: on the effective date of this document.
033750	CUMBERLAND CNTY	1728 W SHERMAN AVE Vineland NJ 08360	[N.J.A.C. 7:14B-5.1(d)]	3/8/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
033750	CUMBERLAND CNTY	1728 W SHERMAN AVE Vineland NJ 08360	[N.J.A.C. 7:14B-6.1(a)]	3/8/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
033750	CUMBERLAND CNTY	1728 W SHERMAN AVE Vineland NJ 08360	[N.J.A.C. 7:14B-6.1(a)2]	3/8/2006	Provide the Department with documentation of the performance claims of the Release Detection within 15 days after receipt of this notice.
033750	CUMBERLAND CNTY	1728 W SHERMAN AVE Vineland NJ 08360	[N.J.A.C. 7:14B-6.2(a)1]	3/8/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
033750	CUMBERLAND CNTY	1728 W SHERMAN AVE Vineland NJ 08360	[N.J.A.C. 7:14B-6.6(a)1]	3/8/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
033750	CUMBERLAND CNTY	1728 W SHERMAN AVE Vineland NJ 08360	[N.J.A.C. 7:14B-6.7(f)]	3/8/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
033922	EASTSIDE PUBLIC WORKS GARAGE	800 BROADWAY EASTSIDE PK Paterson NJ 07505	[N.J.A.C. 7:14B-2.4(a)]	10/2/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice
033922	EASTSIDE PUBLIC WORKS GARAGE	800 BROADWAY EASTSIDE PK Paterson NJ 07505	[N.J.A.C. 7:14B-5.1(d)]	10/2/2006	Comply with rule/regulation: within 15 days after receipt of this notice Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
033922	EASTSIDE PUBLIC WORKS GARAGE	800 BROADWAY EASTSIDE PK Paterson NJ 07505	[N.J.A.C. 7:14B-5.1(d)1]	10/2/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-15.2(a)]	8/3/2006	Comply with rule/regulation: on the effective date of this document
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-15.2(a)]	8/3/2006	Comply with rule/regulation: on the effective date of this document. Immediately obtain Financial Responsibility as required.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-1.8(a)]	8/3/2006	Comply with rule/regulation: on the effective date of this document.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-1.8(a)]	8/3/2006	Comply with rule/regulation: on the effective date of this document. Delivery Ban Imposed
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-2.1(a)]	8/3/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-4.1(a)3]	8/3/2006	Comply with rule/regulation. on the effective date of this document.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-4.1(a)3]	8/3/2006	Comply with rule/regulation: on the effective date of this document. Immediately provide Spill Catchment Basins (Spill Buckets) at each fill pipe.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-4.1(a)3ii]	8/3/2006	Comply with rule/regulation: on the effective date of this document.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-4.1(a)3ii]	8/3/2006	Comply with rule/regulation: on the effective date of this document. Immediately provide overflow prevention for all tanks.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-5.1(d)]	8/3/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-5.1(d)]	8/3/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-5.5(b)]	8/3/2006	Comply with rule/regulation: on the effective date of this document.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-5.5(b)]	8/3/2006	Comply with rule/regulation: on the effective date of this document. Make Release Response Plan available.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-6.1(a)]	8/3/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-6.1(a)2]	8/3/2006	Provide the Department with documentation of the performance claims of the Release Detection : within 15 days after receipt of this notice
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-6.2(a)]	8/3/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-6.2(a)1]	8/3/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-6.7(f)]	8/3/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-6.7(f)]	8/3/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately maintain required RDM records.
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-7.1(a)]	8/3/2006	Comply with rule/regulation: within 7 days after receipt of this notice
213949	GLOUCESTER COUNTY COLLEGE	1400 TANYARD RD Deptford Twp NJ 08080	[N.J.A.C. 7:14B-7.1(a)]	8/3/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately perform 7 day investigation.
240562	RUTHERFORD DEPT OF PUBLIC WORKS	220 HIGHLAND CROSS Rutherford NJ 070702310	[N.J.A.C. 7:14B-2.4(a)]	6/12/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
240562	RUTHERFORD DEPT OF PUBLIC WORKS	220 HIGHLAND CROSS Rutherford NJ 070702310	[N.J.A.C. 7:14B-5.1(d)1]	6/12/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
240562	RUTHERFORD DEPT OF PUBLIC WORKS	220 HIGHLAND CROSS Rutherford NJ 070702310	[N.J.A.C. 7:14B-6.6(a)1]	6/12/2007	Comply with rule/regulation: within 15 days after receipt of this notice Provide documentation of yearly ALLD test.
53	UST Facilities		Total Violations		
			344		

Federal

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
007573	MILLVILLE POST OFFICE	302 HIGH ST N Millville NJ 083327090	[N.J.A.C. 7:14B-15.2(a)]	3/17/2006	Comply with rule/regulation. on the effective date of this document.
007573	MILLVILLE POST OFFICE	302 HIGH ST N Millville NJ 083327090	[N.J.A.C. 7:14B-1.8(a)]	3/17/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
007573	MILLVILLE POST OFFICE	302 HIGH ST N Millville NJ 083327090	[N.J.A.C. 7:14B-5.1(d)1]	3/17/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
007573	MILLVILLE POST OFFICE	302 HIGH ST N Millville NJ 083327090	[N.J.A.C. 7:14B-6.7(f)]	3/17/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
007578	CHERRY HILL POST OFFICE	1175 MARLKRESS RD Cherry Hill NJ 080349998	[N.J.A.C. 7:14B-15.2(a)]	3/1/2006	Comply with rule/regulation: on the effective date of this document.
007578	CHERRY HILL POST OFFICE	1175 MARLKRESS RD Cherry Hill NJ 080349998	[N.J.A.C. 7:14B-5.2(a)2]	3/1/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
007578	CHERRY HILL POST OFFICE	1175 MARLKRESS RD Cherry Hill NJ 080349998	[N.J.A.C. 7:14B-6.6(a)1]	3/1/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-2.4(a)]	7/2/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-2.4(a)]	7/12/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-4.1(a)3ii]	7/2/2007	Comply with rule/regulation. on the effective date of this document immediately provide overfill prevention for all tanks.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-4.1(a)3ii]	7/12/2007	Comply with rule/regulation on the effective date of this document immediately provide overfill prevention for all tanks.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-5.1(d)]	7/2/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-5.1(d)]	7/12/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately begin inspecting and cleaning all STP, dispenser and piping sumps, spill buckets and catchment basins every thirty (30) days.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-5.1(d)1]	7/2/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-5.1(d)1]	7/12/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-5.9(a)]	7/2/2007	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-5.9(a)]	7/2/2007	Comply with rule/regulation: within 7 days after receipt of this notice.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-5.9(a)]	7/12/2007	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-5.9(a)]	7/12/2007	Comply with rule/regulation: within 7 days after receipt of this notice.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-5.9(b)]	7/2/2007	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-5.9(b)]	7/12/2007	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-6.1(a)]	7/2/2007	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-6.1(a)]	7/12/2007	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-6.6(a)1]	7/2/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Provide documentation of yearly ALLD test.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
010658	DEPT VA NJ HEALTH SYSTEM	TREMONT AVE East Orange NJ 070181095	[N.J.A.C. 7:14B-6.6(a)1]	7/12/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Provide documentation of yearly ALLD test.
020131	UNITED PARCEL SERVICE	301 OAK AVE E Lawnside NJ 08045	[N.J.A.C. 7:14B-5.1(d)1]	10/30/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
020131	UNITED PARCEL SERVICE	301 OAK AVE E Lawnside NJ 08045	[N.J.A.C. 7:14B-5.9(a)]	10/30/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
020131	UNITED PARCEL SERVICE	301 OAK AVE E Lawnside NJ 08045	[N.J.A.C. 7:14B-6.6(a)1]	10/30/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Provide documentation of yearly ALLD test.
020131	UNITED PARCEL SERVICE	301 OAK AVE E Lawnside NJ 08045	[N.J.A.C. 7:14B-6.7(f)]	10/30/2006	Comply with rule/regulation: within 7 days after receipt of this notice. Immediately maintain required RDM records.
4	UST Facilities		Total Violations	29	

State

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
005885	NEW JERSEY AIR NATIONAL GUARD	400 LANGLEY RD Egg Harbor Twp NJ 082329500	[N.J.A.C. 7:14B-4.1(a)1]	7/12/2006	Comply with rule/regulation: on the effective date of this document immediately provide Corrosion Protection for the tanks.
005885	NEW JERSEY AIR NATIONAL GUARD	400 LANGLEY RD Egg Harbor Twp NJ 082329500	[N.J.A.C. 7:14B-4.1(a)3ii]	7/12/2006	Comply with rule/regulation: on the effective date of this document immediately provide overflow prevention for all tanks.
005885	NEW JERSEY AIR NATIONAL GUARD	400 LANGLEY RD Egg Harbor Twp NJ 082329500	[N.J.A.C. 7:14B-5.9(a)]	7/12/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
006950	RICHARD STOCKTON COLLEGE OF NJ	10 JIMMIE LEEDS RD Galloway Twp NJ 08240	[N.J.A.C. 7:14B-2.4(a)]	11/29/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
006950	RICHARD STOCKTON COLLEGE OF NJ	10 JIMMIE LEEDS RD Galloway Twp NJ 08240	[N.J.A.C. 7:14B-4.1(a)3ii]	11/29/2006	Comply with rule/regulation: on the effective date of this document immediately provide overflow prevention for all tanks.
006950	RICHARD STOCKTON COLLEGE OF NJ	10 JIMMIE LEEDS RD Galloway Twp NJ 08240	[N.J.A.C. 7:14B-5.9(b)]	11/29/2006	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed.
006950	RICHARD STOCKTON COLLEGE OF NJ	10 JIMMIE LEEDS RD Galloway Twp NJ 08240	[N.J.A.C. 7:14B-6.1(a)]	11/29/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
006950	RICHARD STOCKTON COLLEGE OF NJ	10 JIMMIE LEEDS RD Galloway Twp NJ 08240	[N.J.A.C. 7:14B-6.6(a)1]	11/29/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Provide documentation of yearly ALLD test.
009205	RUTGERS THE STATE UNIVERSITY OF NJ	5TH & PENN STS Camden NJ 08102	[N.J.A.C. 7:14B-2.1(a)]	6/21/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
009205	RUTGERS THE STATE UNIVERSITY OF NJ	5TH & PENN STS Camden NJ 08102	[N.J.A.C. 7:14B-6.1(a)]	6/21/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
012348	FERNWOOD MAINTENANCE COMPLEX	999 PARKWAY AVE Ewing Twp NJ 08625	[N.J.A.C. 7:14B-1 8(b)]	4/12/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
012348	FERNWOOD MAINTENANCE COMPLEX	999 PARKWAY AVE Ewing Twp NJ 08625	[N.J.A.C. 7:14B-2.1(a)]	4/12/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
012348	FERNWOOD MAINTENANCE COMPLEX	999 PARKWAY AVE Ewing Twp NJ 08625	[N.J.A.C. 7:14B-2.4(a)]	4/12/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
012348	FERNWOOD MAINTENANCE COMPLEX	999 PARKWAY AVE Ewing Twp NJ 08625	[N.J.A.C. 7:14B-6.2(a)1]	4/12/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document
012368	VINELAND MAINT YARD	RT 47 DELSEA DR Vineland NJ 08360	[N.J.A.C. 7:14B-1.8(b)]	3/8/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: on the effective date of this document.
012368	VINELAND MAINT YARD	RT 47 DELSEA DR Vineland NJ 08360	[N.J.A.C. 7:14B-2.4(a)]	3/8/2006	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
012368	VINELAND MAINT YARD	RT 47 DELSEA DR Vineland NJ 08360	[N.J.A.C. 7:14B-6.1(a)]	3/8/2006	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document.
012368	VINELAND MAINT YARD	RT 47 DELSEA DR Vineland NJ 08360	[N J.A.C. 7:14B-6.1(a)2]	3/8/2006	Provide the Department with documentation of the performance claims of the Release Detection : within 15 days after receipt of this notice
012368	VINELAND MAINT YARD	RT 47 DELSEA DR Vineland NJ 08360	[N.J.A.C. 7:14B-6.2(a)1]	3/8/2006	Comply with rule/regulation within 15 days after receipt of this notice.
012368	VINELAND MAINT YARD	RT 47 DELSEA DR Vineland NJ 08360	[N.J.A.C. 7:14B-6.7(f)]	3/8/2006	Comply with rule/regulation: within 7 days after receipt of this notice.
013186	NORTHERN DIVISION MAINTAINENCE AREA	NJ TPKE MM 104.7 Newark NJ 07102	[N.J.A.C. 7:14B-2.4(a)]	6/7/2007	Submit a completed Underground Storage Tank Facility Certification Questionnaire: within 15 days after receipt of this notice.
013186	NORTHERN DIVISION MAINTAINENCE AREA	NJ TPKE MM 104.7 Newark NJ 07102	[N.J.A.C. 7:14B-5.1(d)1]	6/7/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
013186	NORTHERN DIVISION MAINTAINENCE AREA	NJ TPKE MM 104.7 Newark NJ 07102	[N.J.A.C. 7:14B-5.8]	6/7/2007	Mark the fill ports in accordance with API Bulletin : within 15 days after receipt of this notice
013186	NORTHERN DIVISION MAINTAINENCE AREA	NJ TPKE MM 104.7 Newark NJ 07102	[N.J.A.C. 7:14B-6.1(a)]	6/7/2007	Provide an acceptable method of release detection monitoring and provide documentation : on the effective date of this document

UST ID	PI Name	Facility Address	Violation Citation	Date of Last Inspection	Corrective Action (UST)
013186	NORTHERN DIVISION MAINTAINANCE AREA	NJ TPKE MM 104.7 Newark NJ 07102	[N.J.A.C. 7:14B-6.6(a)1]	6/7/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Provide documentation of yearly ALLD test.
013308	JOHN FENWICK SERVICE AREA 1-N	NJ TPKE MM 5.4 Penns Grove NJ 08067	[N.J.A.C. 7:14B-5.1(d)]	2/22/2006	Comply with rule/regulation: within 15 days after receipt of this notice.
016119	MAINTENANCE DISTRICT #2	GS PKWY MP 1561 Clifton NJ 07015	[N.J.A.C. 7:14B-5.1(d)1]	8/18/2005	Comply with rule/regulation within 15 days after receipt of this notice.
021809	MANASQUAN WATER TREATMENT PLANT	HOSPITAL RD Wall Twp NJ 07719	[N.J.A.C. 7:14B-1.8(b)]	9/19/2006	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed.
021809	MANASQUAN WATER TREATMENT PLANT	HOSPITAL RD Wall Twp NJ 07719	[N.J.A.C. 7:14B-4.1(a)3ii]	9/19/2006	Comply with rule/regulation, on the effective date of this document Immediately provide overfill prevention for all tanks.
024450	D&R CANAL FIELD OFFICE	770 BEAR TAVERN RD Ewing NJ 08628	[N.J.A.C. 7:14B-15.2(a)]	8/15/2006	Comply with rule/regulation: on the effective date of this document Immediately obtain Financial Responsibility as required
024450	D&R CANAL FIELD OFFICE	770 BEAR TAVERN RD Ewing NJ 08628	[N.J.A.C. 7:14B-1.8(b)]	8/15/2006	Comply with rule/regulation: on the effective date of this document Delivery Ban Imposed
024450	D&R CANAL FIELD OFFICE	770 BEAR TAVERN RD Ewing NJ 08628	[N.J.A.C. 7:14B-4.1(a)3ii]	8/15/2006	Comply with rule/regulation: on the effective date of this document.
024450	D&R CANAL FIELD OFFICE	770 BEAR TAVERN RD Ewing NJ 08628	[N.J.A.C. 7:14B-5.1(d)1]	8/15/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Immediately clean the Spill Buckets.
024450	D&R CANAL FIELD OFFICE	770 BEAR TAVERN RD Ewing NJ 08628	[N.J.A.C. 7:14B-6.6(a)1]	8/15/2006	Comply with rule/regulation: within 15 days after receipt of this notice. Provide documentation of yearly ALLD test.
024461	DELAWARE RIVER PORT AUTH BETSY ROSS BRID	BETSY ROSS BRIDGE PLZA Pennsauken NJ 08110	[N.J.A.C. 7:14B-6.6(a)1]	1/30/2007	Comply with rule/regulation: within 15 days after receipt of this notice. Provide documentation of yearly ALLD test.
11	UST Facilities	Total Violations	35		