



# Spill Prevention Control and Countermeasure (SPCC) Plan


## Rectangular or Square Remote Impoundment Structure

### WORKSHEET

This worksheet can be used to calculate the containment volume of a rectangular or square remote impoundment<sup>1</sup> structure providing secondary containment for an aboveground tank storage facility.

#### Steps:

1. Determine the volume of the secondary containment impoundment,  $V_{SC}$
- 2a. Determine the volume of the largest tank when shell capacity is unknown,  $V_{Tank}$
- 2b. Determine the volume of the largest tank when shell capacity is known,  $V_{Tank}$
3. Determine the percentage of the secondary containment volume,  $V_{SC}$ , to the largest tank volume,  $V_{Tank}$
4. Determine whether the secondary containment impoundment can contain the entire tank shell capacity of the largest tank with additional capacity to contain rain.



Largest Tank Shell Capacity (gal) =

**a**

#### Information needed to use this worksheet:

- Tank shell capacity in gallons or tank diameter and length or height in feet of the largest tank
- Remote impoundment length, width, and height in feet
- If rain can collect in impoundment: amount of rain, inches or feet
- If rain can collect in drainage area with runoff in the area flowing into the impoundment, this amount must also be considered in the additional impoundment capacity to contain rain. The surface drainage area in square feet is required.

**Disclaimer:** Please note that these are simplified calculations for qualified facilities that assume: 1) the secondary containment is designed with a flat floor; 2) the wall height is equal for all four walls; and 3) the corners of the secondary containment system are 90 degrees. Additionally, the calculations do not include displacement for support structures or foundations. For Professional Engineer (PE) certified Plans, the PE may need to account for site-specific conditions associated with the secondary containment structure which may require modifications to these sample calculations to ensure good engineering practice.

<sup>1</sup> Remote impounding is an acceptable secondary containment method under NFPA 30 because the code primarily focuses on fire safety and emphasizes the importance of moving leaked or spilled flammable liquids away from the tank by adequate draining. A remote impoundment must be able to contain the contents of the largest tank. However, when this is not possible, partial impounding can be used in combination with diking to meet the largest-tank criterion.

For tank fields contained by diking, NFPA 30 requires that a slope of not less than one percent away from the tank shall be provided for at least 50 feet or to the dike base, whichever is less. This ensures that small spills will not accumulate against the wall of the tank. Also, if remote impounding is used, the drainage path to the impoundment should be designed so that if the drainage path is ignited, the flames will not pose serious risk to tanks or adjoining property.



# Spill Prevention Control and Countermeasure (SPCC) Plan

## Rectangular or Square Remote Impoundment Structure

### WORKSHEET

1. Determine the volume of the secondary containment impoundment,  $V_{SC}$

$$\begin{aligned} \text{Impoundment Containment Area, } A_{SC} &= \boxed{\phantom{000}} \times \boxed{\phantom{000}} \\ &\quad \text{Length (ft)} \quad \quad \quad \text{Width (ft)} \\ &= \boxed{\phantom{000}} \text{ ft}^2 \\ &\quad \quad \quad \mathbf{b} \\ V_{SC} \text{ (ft}^3\text{)} &= \boxed{\phantom{000}} \times \boxed{\phantom{000}} = \boxed{\phantom{000}} \text{ ft}^3 \\ &\quad \quad \quad \mathbf{b} \quad \quad \quad \text{Height (ft)} \quad \quad \quad \mathbf{c} \end{aligned}$$

2a. Determine the volume of the largest tank when the shell capacity is unknown,  $V_{Tank}$

$$\begin{aligned} \text{Tank radius (ft)} &= \boxed{\phantom{000}} \div 2 = \boxed{\phantom{000}} \text{ ft} \\ &\quad \quad \quad \text{Diameter (ft)} \\ V_{Tank} \text{ (ft}^3\text{)} &= 3.14 \times \boxed{\phantom{000}}^2 \times \boxed{\phantom{000}} = \boxed{\phantom{000}} \text{ ft}^3 \\ &\quad \quad \quad \text{Radius}^2 \quad \quad \quad \text{Tank Height (ft)} \quad \quad \quad \mathbf{d} \end{aligned}$$

2b. Determine the volume of the largest tank when shell capacity is known,  $V_{Tank}$

*a is the tank shell capacity from page 1.*

$$V_{Tank} \text{ (ft}^3\text{)} = \boxed{\phantom{000}} \times 0.1337 = \boxed{\phantom{000}} \text{ ft}^3$$

$\mathbf{a}$  (gal)                       $\mathbf{ft}^3/\text{gal}$                        $\mathbf{e}$



# Spill Prevention Control and Countermeasure (SPCC) Plan

## Rectangular or Square Remote Impoundment Structure

### WORKSHEET

**3. Determine the percentage of the secondary containment volume,  $V_{SC}$ , to the largest tank volume,  $V_{Tank}$** <sup>2</sup> (to determine whether the volume of the containment is sufficient to contain the largest tank's entire shell capacity).

**Note:** NaN = Not A Number. Once values **c** and **d/e** are inputted, NaN will be replaced with the correct value for **f**.

<p><math>V_{SC}/V_{Tank} = \frac{\boxed{\phantom{000}}}{\substack{c \\ (ft^3)}} \div \frac{\boxed{\phantom{000}}}{\substack{d \text{ or } e \\ (ft^3)}} = \frac{\boxed{\phantom{000}}}{f}</math></p> <p><i>c is the secondary containment volume calculated in Step 1.</i> <i>d / e is the tank volume calculated in Step 2.</i></p>	<p><math>\% = \frac{\boxed{\phantom{000}}}{f} \times 100 = \frac{\boxed{\phantom{000}}}{g}</math></p>
--	---

If the percentage, **g**, is 100% or greater, the capacity of the impoundment containment is sufficient to contain the shell capacity of the largest tank. If rain can collect in the impoundment, continue to step 4. If the percentage, **g**, is less than 100%, the capacity of the impoundment containment is not sufficient to contain the shell capacity of the largest tank.

#### 4. Determine whether the secondary containment impoundment can contain the entire tank shell capacity with additional capacity to contain rain.

If rain can collect in a remote impoundment structure, the SPCC rule requires that secondary containment for bulk storage containers have additional capacity to contain rainfall or freeboard. The rule does not specify a method to determine the additional capacity required to contain rain or the size of the rain event for designing secondary containment. However, industry practice often considers a rule of thumb of 110% of the tank capacity to account for rainfall. A dike with a 110% capacity of the tank may be acceptable depending on, the shell size of the tank, local precipitation patterns and frequency of containment inspections. In a different geographic area, a dike or berm designed to hold 110% for the same size tank may not have enough additional containment capacity to account for a typical rain event in that area. The 110% standard may also not suffice for larger storm events. If you want to determine a conservative capacity for a rain event, you may want to consider a 24-hour 25-year storm event. It is the responsibility of the owner or operator<sup>3</sup> to determine the additional containment capacity necessary to contain rain. A typical rain event may exceed the amount determined by using a 110% "rule of thumb" so it is important to consider the amount of a typical rain event when designing or assessing your secondary containment capacity.

Rainfall data may be available from various sources such as local water authorities, local airports, and the National Oceanic and Atmospheric Administration (NOAA).

<sup>2</sup> Steps 3 and 4 in the worksheet determines whether the volume of the impoundment containment is sufficient to contain the largest tank's entire shell capacity and rainfall (freeboard for precipitation) as required by the SPCC rule. Step 3 primarily determines whether the volume of the impoundment containment is sufficient to contain the entire shell capacity of the largest tank. Step 4 is necessary to determine whether the impoundment containment can also contain the expected volume of rainfall (both the volume of rain that falls into the impoundment plus the rain from the drainage area contributing runoff into the impoundment).

<sup>3</sup> The SPCC rule does not require you to show the secondary containment calculations in your Plan. However, you should maintain documentation of secondary containment calculations to demonstrate compliance to an EPA inspector.



# Spill Prevention Control and Countermeasure (SPCC) Plan

## Rectangular or Square Remote Impoundment Structure

### WORKSHEET

*Selected Rainfall Event:*

$$\text{Rainfall (in)} = \boxed{\phantom{000}} \text{ in}$$

**h**

$$\begin{aligned} \text{Rainfall (ft)} &= \boxed{\phantom{000}} \div 12 \\ &\text{h (in)} \quad \text{in/ft} \\ &= \boxed{\phantom{000}} \text{ ft} \\ &\quad \text{i} \end{aligned}$$

Volume of rain,  $V_{\text{RainImpound}}$ , that can fall directly into the impoundment:

$$V_{\text{RainImpound}} (\text{ft}^3) = \boxed{\phantom{000}} \times \boxed{\phantom{000}} = \boxed{\phantom{000}} \text{ ft}^3$$

*b is the area of secondary containment calculated in Step 1.*

**i (ft)          b (ft<sup>2</sup>)          j**

Volume of rain contributed from the Impoundment Drainage Area,  $V_{\text{DrainageArea}}$ , to the remote impoundment: (The drainage surface area,  $A_{\text{DrainageArea}}$ , contributing rain runoff into the remote dike impoundment in ft<sup>2</sup> is required to determine  $V_{\text{DrainageArea}}$ . This information can be obtained from the as-built plans for the design and construction of the impoundment).

$$\text{Area of Drainage, } A_{\text{DrainageArea}} (\text{ft}^2) = \boxed{\phantom{000}} \text{ ft}^2$$

**k**

$$V_{\text{DrainageArea}} (\text{ft}^3) = \boxed{\phantom{000}} \times \boxed{\phantom{000}} = \boxed{\phantom{000}} \text{ ft}^3$$

**i (ft)          k (ft<sup>2</sup>)          l**

Total Volume of Rain Collected in Impoundment,  $V_{\text{TotalRainImpound}}$ :

$$V_{\text{TotalRainImpound}} (\text{ft}^3) = \boxed{\phantom{000}} + \boxed{\phantom{000}} = \boxed{\phantom{000}} \text{ ft}^3$$

**j (ft<sup>3</sup>)          l (ft<sup>3</sup>)          m**

$$\begin{aligned} \text{Total Containment Capacity Required (ft}^3\text{)} &= \boxed{\phantom{000}} + \boxed{\phantom{000}} \\ &\text{e is the tank volume calculated in Step 2.} \\ &\quad \text{m (ft}^3\text{)} \quad \text{e (ft}^3\text{)} \\ &= \boxed{\phantom{000}} \text{ ft}^3 \\ &\quad \text{n} \end{aligned}$$

If the volume of the impoundment containment, **c**, is equal to or greater than the required containment capacity, **n**, the impoundment is sufficient to contain the shell capacity of the largest tank with sufficient additional capacity to contain a typical rainfall amount. If the volume of the impoundment containment, **c**, is less than the required containment capacity, **n**, the impoundment containment is not sufficient to contain the shell capacity of the largest tank and a typical rainfall amount.