



FORT GEORGE
BREWERY + PUBLIC HOUSE

ASTORIA, OREGON

2012-2013
OMEP, OSU, PPRC



OMEPP – Material and Labor



OSU – Energy Efficiency Center



PPRC – Supplemental P2



Good Environmental Practices (Already in Place)

- Heat exchanger
- Spent grain to feed
- Reuse pallets (not landfilled)
- Attempting to recycle stretch wrap
- Good housekeeping
- Restaurant grease recycle
- Enclosed room for boiler



Good Environmental Practices (Already in Place)

- Salvaged material



OMEF Projects: Labor & Material Focus

Canning and Keg Washing

Mark Biederback

Labor:

- Significant reduction in transfer of the product from process to cans and out the door
 - lifting, carrying, climbing ladders
 - picking up and tossing defect cans
- Keg cleaner functioning again

Material:

- Number of cans dropped before filled (~8' high palletized raw cans federal into feed chute)
- Enhanced some of the filling machine mechanics to decrease can and beer loss as a result of filling/canning.

OMEP Projects: Water Canning and Keg Washing Mark Biederback

Water conservation targeted but not resolved in can washing operation

Can flush water used inside then be used to clean the outside of the can?

OSU Energy Efficiency Center

Three Primary Analyses/Recommendations

Recommendation	Estimated payback (with local/state incentives)	Potential Savings
Lighting Retrofit	3.9 years	21,700 kwh
Insulate steam pipes	0.4 years	276 MMBtu/yr
Expansion Analysis (lighting)	0.2 years	~11,000 kwh (compared to installation of incandescents)

Wort Vapor Capture

Water Heater (On-Demand)


Heat Bridging (Warehouse metal I beams)

Canning Line Water Use

Refrigeration Controls

PPRC Walk-Through and Sampling of Recommendations

- Promote OMEP and OSU Recommendations
- Find outlets for 'energy waste sources' (Hop liquor and yeast)



PPRC Walk-Through


Work on increased recycling (tough in Astoria...)



PPRC Walk-Through and Sampling of Recommendations

- Keg collars
- Further minimize air flow from cold storage, with better curtains, seals, etc.
- Compressed air leak test
- Keg cleaning – standardize, NO HOT WATER for exterior, water reuse
- Dry/waterless cleaning techniques to extent possible
- Infrared camera assessment to identified


IR Assessment Hot Tank (Doors)






Cold Beer

Compression Tank & Adjacent






Note – temperature pointer/reading
not at hottest point on tank




Cold storage





Cold storage






Pub kitchen Cold storage/refrigeration




Steam / Condensate Lines – Throughout Facility




Steam / Condensate Line Insulation Options: Mineral Wool or Calcium Silica



Mineral wool pipe insulation from [IIG-LLC](#). They recommend a metal wrap around the outside of this product.




Mineral wool pipe insulation from [Isover](#).




Calcium silicate insulation
[Calsil](#)

See article comparing features / costs, of two different materials:
[Megha Insulations](#)



Pub tank door & steam? lines



Warehouse




Door closed
(purple area (beam
on left side, 65 dF
next to hand
image) maybe not
insulated well?)



Note air leaks at bottom of
door. Did not measure
temperature
at the 'draft' area

Warehouse - Door



Warehouse – Showing Areas of Lower Spray Insulation Efficacy

