

## Memo

**To:** File  
**From:** Bill Wentworth  
**CC:** Cathy Guynn, WVDEP  
**Date:** September 22, 2014  
**Re:** Long-Term Stewardship (LTS) Site Visit for the MPM Silicones Facility in Friendly, West Virginia.

---

EPA and WVDEP conducted a site visit/inspection of the MPM Silicones Facility in Friendly, West Virginia on September 11, 2014. The purpose of the visit was to confirm that specific requirements of the Corrective Action Final Determination for the facility are being complied with. The North and South inactive areas were visited to confirm that the earthen covers for these areas were in good condition and maintained. A visual inspection of these two areas revealed no erosional problems and both areas appeared to be in good condition.

The Waste Water Treatment System area was inspected for any signs of disrepair or problems. During the visit the one waste settling pond was being dredged and the solids were being filter pressed for disposal in the on-site landfill. The rest of the System appeared to be operating properly. The process sewer system is required to be inspected and cleaned in 1000 foot sections during plant wide electrical shut downs. Not only is the sewer system being cleaned, but they are being relined as part of the inspection process. The site representative provided a report detailing the portion of the sewer that was relined in August, 2013.

### **ACTION ITEMS**

None at this time

Attachment: Pipeline Assessment Certification Program Report (containing lining details)