

**PSD Permit No. NSR 4-4-11 and SE 87-01 for Desert View Power is amended to include the following conditions:**

**XI. Additional requirements for Hydrated Lime Delivery System Pursuant to 40 CFR 49.153(a)(2) – Minor NSR in Indian Country**

<b>Emission Unit</b>	<b>Description</b>
HLS-1	Hydrated Lime Storage Silo #1 (with fabric filter)
ACS-1	Ash Conditioning Storage #1 (with fabric filter)
ACS-2	Ash Conditioning Storage #2 (with fabric filter)
FUG-1	Hydrated Lime Truck Traffic

**a. Emissions Limitations and Work Practice Standards**

1. Vehicle miles traveled (VMT) for truck traffic associated with deliveries of hydrated lime – FUG-1 – to the permitted source shall not exceed 280 miles per 12-month period.
2. Annual delivery and usage of hydrated lime shall not exceed 2365 tons per 12-month period.

**b. Monitoring and Testing Requirements**

1. The Permittee shall monitor on a monthly basis each delivery of hydrated lime (in tons) and the VMT for each delivery.
2. At least once per calendar month, the permittee shall inspect the interior and exterior of the fabric filters for HLS-1, ACS-1, and ACS-2 for evidence of damage or leaks, and take appropriate corrective actions to restore filters to proper operation before resuming normal operations.

**c. Recordkeeping and Reporting Requirements**

1. The Permittee shall maintain records on a monthly basis of each delivery related to hydrated lime, including the tons of hydrated lime delivered and VMT for each delivery, and determine the 12-month rolling total for each.
2. The permittee shall maintain records of the dates and results of each filter inspection performed pursuant to condition XI.b.4 and any corrective actions taken as a result of the required inspections shall be recorded.