

University of Iowa Biomass Fuel Project Chicago Climate Exchange



Ferman Milster, P.E.

Associate Director – Utilities & Energy Management

May 19, 2009

UI Biomass Project

- › Co-fire oat hulls with coal in circulating fluidized bed (CFB) boiler.
- › Oat hull fuel displaces coal fuel.
- › Oat hulls are a byproduct of the cereal making process at Quaker Oats, Cedar Rapids Facility.

Why biomass combustion?

- › Renewable / Sustainable
- › Emissions Reductions
- › UI / Industry Partnership
- › Lowest Cost Energy Source
- › Educational Value

Major Challenges:

The feather-weight oat hulls required – without having a negative impact on the existing coal systems:

- › Special materials handling solutions,
- › Boiler control system modifications,
- › New procedures to make this fuel work
- › And ...

The Iowa DNR & US EPA

Business Aspects

- › Quaker Oats is a large production facility, employing ~1,200 lowans.
- › Oat hulls are purchased
 - › ~ ½ the cost of coal.
 - › Source of revenue for Quaker
 - › Purchased energy savings for UI
- › Stable fuel supply for UI.
- › Stable byproduct outlet for Quaker.


What did we do?

- › Converted a coal-fired boiler to burn a combination of coal and oat hulls.
- › Two years of effort to find out how to do it and obtain regulatory permits for operation.
- › Project operational since 2003.



Oat Hull & Coal Comparison

Fuel Ultimate Analysis
(as received)



Boiler Conversion

- › Circulating Fluidized Bed Boiler
 - › Pyroflow process
 - › 170,000 lbs/hr
 - › Washed bituminous coal (3.0 to 3.5% S)
 - › 90% SO₂ removal

SUB C

T STARTUP TRENDS

AIR AND GAS OVERVIEW

Main Steam 144 KLB/HR 735 DEG F
487 PSIG

SUB "L"
E. CHEM PPM
W. CHEM PPM



- Main Menu
- B11 Menu
- B11 Controls
- Limestone
- Secondary Air
- Primary Air
- Furnace Draft
- Bottom Ash
- Steam & Water
- B11 Trends
- PLANT MASTER TRANSMITTERS

Flow Control ON
FWH IN

1564 1581
1539 1575

0 IN H2O DRUM LEVEL 66 %
151 KLB/HR FEEDWATER

T CYCLONE TEMPS



- T Emissions
- T BTU Comp & Bias
- T Limestone System
- T Boiler Draft & Flue Gas
- T Primary Air
- T Baghouse Compartment DP
- T Baghouse Opacity Correlation


PV	SP	Descript.	CO	Auto/Man
475 PSIG	475	COAL PLT MST	60 %	AUTO
BM-BIAS	24	BLR MST	85 %	MAN
30 %	30	COAL MST	35 %	AUTO
54	55	BIO MST	50 %	AUTO
171 KLB/HR	167	AIR MST	77 %	AUTO
0 %	0	GAS FLOW	20 %	MAN
15 KLB/HR	7	SUB Air	0 %	AUTO
0.28 #/MBTU	0.23	SO ₂ TRIM	56 %	AUTO
2.7 KLB/HR	2.5	LIMESTN	27 %	AUTO
		Flow Ctrl ON/OFF		ON
144 KLB/HR	145	Blr 11 Flo Ctrl Mstr	85 %	AUTO

PV	SP	Descript.	CO	Auto/Man
30 IN H2O	30	SA Fan	47 %	AUTO
91 KLB/HR	91	PA Fan	23 %	AUTO
-1.28 IN H2O	-0.50	ID Fan	48 %	AUTO
20 KLB/HR	18	SA Nozzles	22 %	AUTO
4.5 %	4.3	O ₂ Trim	12 %	AUTO
0 KLB/HR		Air Master Bias		
-0.1 %		O ₂ Bias		
487 PSIG	530	VENT VLV	0 %	AUTO
		Total PA/SA Air Flow	155 KLB/HR	
0 IN H2O	0.00	DRUM LEVEL	66 %	AUTO

TIME REMAINING SH PROTEC TRIP 0

SOOT BLOWER ID FAN OVERRIDE C

LOOP SEAL UPS OFFLINE
LOOP SEAL UPS PWR LOSS



PyroPower / Foster Wheeler boiler conversion 1996


SECTIONAL SIDE VIEW
(LOOKING NORTH)

NO.	DATE	BY	CHKD.	DESCRIPTION
1	10-10-80	REVISED LINES COMMUNIQUE 1 FA QUENCH DUCT
2	11-11-80
3	12-11-80
4	1-24-81
5	2-24-81
6	3-27-81
7	4-16-81
8	5-27-81


DIM. 12'-2 1/4" WAS 14'-3 1/4" WAS 5' EL. 10' CON. G-23-9E
 12'-1 7/8" WAS EL. 12'-6" EL. 70'-0 1/4"
 WAS 14'-6 1/2" EL. 82'-0 1/4" WAS 77'-0" RPH
 WAS RPH ACCESS DOOR (HINGED) 18' X 24"
 WAS ACCESS DOOR. DWG. SHOWN AS BUILT

WIDE FLANGE BEAMS

THIS PRINT IS THE PROPERTY OF THE COMPANY AND IS NOT TO BE REPRODUCED OR COPIED IN ANY MANNER WITHOUT THE WRITTEN PERMISSION OF THE COMPANY.



Oat Hull Fuel Feeder
Nozzle



Oat Hull Fuel Feed System PID

Oat Hull Transport System



Auto Fuel Block
Valves

Air
Locks

Transport Air

Dust Recovery


Twin Screw
Feeder

Lean Phase
Transport

Emission (stack) Testing Results

	SO ₂ (lb/MMBtu)	NO _x (lb/MMBtu)	PM (lb/hr)	CO (lb/MMBtu)	VOC (lb/MMBtu)
Permit Limit	1.0	0.40	6.69	0.30	N/A
100% Coal	0.21	0.22	2.51	0.06	0.33
50% Oat Hulls	0.13	0.18	1.57	0.03	0.11
80% Oat Hulls	0.08	0.18	1.32	0.20	0.18

Flame Spray Layout



Spring 2007 Outage



Screen tubes in front of superheater, downstream of cyclone outlet

Spring 2007 Outage



Loop
seal

UI Biomass Fuel Project Results

Calendar Year	Tons of Coal Displaced	Avoided Emissions Tons CO2	Boiler Bio Heat Input	Avoided Fuel Cost
2003	11,511	28,385	18%	\$ 391,299
2004	16,636	41,024	24%	\$ 415,273
2005	24,290	59,899	36%	\$ 765,471
2006	27,424	67,627	41%	\$ 1,017,780
2007	23,324	57,518	43%	\$ 872,136
2008	17,929	44,213	41%	\$ 712,672
6-Yr Total	121,113	298,666		\$ 4,174,630

Avoided costs include fuel cost difference, lower limestone consumption, less ash disposal, and less coal system maintenance


Chicago Climate Exchange (CCX)

CCX is a cap and trade system whose Members make a legally binding emission reduction commitment.


Members are allocated annual emission allowances in accordance with their emissions Baseline and the CCX Emission Reduction Schedule.

Members who reduce beyond their targets have surplus allowances to sell or bank; those who do not meet the targets comply by purchasing CCX Carbon Financial Instrument® (CFI®) contracts.


CCX Required Reductions




CCX CO2 Cost History



Purchased Energy Type and Cost




Cost (\$)



Type (MMBtu basis)

UI Purchased Fuel CO2 Emissions



Questions / Discussion

<http://ui.media.uiowa.edu/btn/iowamag4.html>