

# SF6 Free HV GIS and Breakers

Thomas Rak Manager of Substation and T-Line Standards Engineering

January 2017



## Purpose

- Share status on replacement of SF6 with environmentally friendly insulating gas for high voltage GIS and breakers.
- SDG&E, SCE, SMUD, LADWP & PG&E
- EPRI
- ABB, GE, Hitachi & Siemens 3M
- Discussion on the Eco Gas replacement for SF6
- November 29, 30 2016
   What we learned





# Why SF6 Free GIS and Breakers? Environmental Stewardship

"Environmental stewardship is core to PG&E's culture and, in the supply chain context, that means finding ways to deliver energy with cleaner technology.

Procuring SF6 free technology is an imperative in this regard. Because the electric utility industry is responsible for 90% of the SF6 global market, we see eliminating this potent greenhouse gas from our value chain as a duty of care. Additionally, the move away from SF6 help us comply with SF6 leak rate legal requirements, as well as help eliminate the hazardous waste costs associated with the gas."

**Gun Shim** PG&E Vice President Supply Chain



## Why SF6 Free GIS and Breakers? Customer Requested

# "Timely Announcements by WalMart & Microsoft"

**Jess Brown** PG&E Director, Large Enterprise Accounts



### Why SF6 Free GIS and Breakers? Reporting Obligations

#### **USEPA**

- Report annually by March 31
- Resubmit report within 45 days (plus an additional 30 days if requested) of substantive errors being discovered [40 CFR Part 98.3(h)]
- Report calculated annual SF6 emissions (lbs) to include both hermitically and nonhermetically sealed gas insulated switchgear (GIS)

### CARB

- Report annually by June 1
- Resubmit report within 45 days (plus an additional 30 days if requested) of substantive errors being discovered [adopted 40 CFR Part 98.3(h) by reference]
- Report calculated annual SF6 emissions (lbs) and calculated SF6 emission rate for only non-hermetically sealed GIS (which uses average nameplate capacity of the GIS)

	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020 8 beyon
ARB allowable values	10%	9.0%	8.0%	7.0%	6.0%	5.0%	4.0%	3.0%	2.0%	1.0%

#### Maximum Allowable SF6 Emission Rate by Calendar Year



### **Because alternatives are available**

### ABB, GE, Hitachi and Siemens have alternatives to SF6

	Year non-SF6	Year non-SF6	Year non-SF6		
	Live Tank Breakers	Dead Tank Breakers	GIS		
	will be available	will be available	Will be available		
70kV	Available 2015	Available 2016	Available 2016		
115kV	Available 2017	Available 2017	Available 2016		
230kV	Available 2020	Available 2019	Available 2020		
500kV	Available 2020	Available 2019	Available 2022		

Please Note: For PG&E Asset Strategy planning purposes, I have included target availability dates above for our QSL suppliers for GIS and Breakers. These dates may change and will likely evolve as PG&E, SDG&E, SCE, SMUD and LADWP continue to work with our suppliers.



# Four Alternatives to SF6

### world class vendors

- 3M<sup>™</sup> Novec<sup>™</sup> Dielectric Fluids
  - GE
  - ABB

- Vacuum/clean air
  - Siemens
  - Hitachi



C5-Flourketone 5110



Flournitrile 4710







Vacuum



# Novec<sup>™</sup> 4710 vs. Novec<sup>™</sup> 5110

Dielectric Breakdown Voltage

Dielectric strength of pure Novec™ Dielectric Fluids exceeds SF6



### **Properties of different gases for GIS and breakers**

		F F F F				
		Sulfurhexaflouride	Clean-Air	Flournitrile 4710	C5-Flourketone 511	
es	Chemical formula	SF <sub>6</sub>	N <sub>2</sub> + O <sub>2</sub> (80% / 20%)	(CF <sub>3</sub> ) <sub>2</sub> CFCN	(CF <sub>3</sub> ) <sub>2</sub> CFC(O)CF <sub>3</sub>	
Gas	CO <sub>2</sub> -equivalent (GWP)	22.800	0	2.210	1	
Pure	Boiling point (Celsius)	-64°	< -183°	-5°	+27°	
	Dielectric strength	1*	0,43	2,2	1,7	
e	Carrier gas	None, N <sub>2</sub> or CF <sub>4</sub>		~ 95% CO <sub>2</sub>	~ 90% CO <sub>2</sub> w. N2 or O <sub>2</sub>	
lixtu	CO <sub>2</sub> -equivalent (GWP)	< 22.800	/	~ 380	<1	
Gas M	Boiling point (Celsius)	<-64°(variable)		~ -25°	+5°	
	Dielectric strength at same pressure	1*	0,43	0,870,92 <sup>2</sup>	0,7 <sup>3</sup>	
Arc Impact	Decomposition products	hydrofluoric acid, sulfur dioxide, sulfur compounds	Only if failure: ozone and nitrogen oxides	Incl. Carbon monoxide, carbon dioxide, hydrofluoric acid		

\* Relative dielectric strength, normalized to  $SF_6$  (=1)

<sup>2</sup> pressure 0,67MPa...0,77MPa, Source: Y. Kieffel, et al. "SF6 Alternative Development for High Voltage Switchgears," in Cigré Session, 2014.

<sup>3</sup> pressure 0,45 MPa Source: J. Mantilla, et al "Investigation of the Insulation Performance of a New Gas Mixture with Extremely Low GWP," in Electrical Insulation Conference, USA, 2014.





Relative scale compared to  $CO_2$ GasGWPDry Air (VCB)NONE $CO_2$  (Carbon dioxide)1 $SF_6$  (GCB)23,900

Pounds of SF<sub>6</sub> in GCB by 350
72.5 kV (VCB)
300
72.5 kV (GCB)
250
362 kV (GCB)
200
150
0
Lbs SF6





HITACHI Inspire the Next

# 145kV SF6 Free GIS

Switchgear type	8VN1
Rated voltage	145 kV
Rated power-frequency	275 kV
Rated lightning impulse (1.2 / 50 µs)	650 kV
Rated normal current	3150 A
Rated short-circuit breaking current	40 kA
Rated short-time current (up to 3 s)	40 kA
Leakage rate per year	< 0.1 %
Driving mechanism of circuit-breaker	Spring
Rated operating sequence	0-C0-15s-C0
Interrupter technology	Vacuum
Insulation medium	Clean air
Bay width common pole drive	3'4"
Bay height, depth (typical)	10'6" x 18'
Bay weight (typical)	5 t
Ambient temperature range	-58 °F up to +122 °F
Installation	indoor / outdoor
First major inspection	> 25 years
Expected lifetime	> 50 years



#### **Siemens Energy**

### **Technology Pilot for 145 kV**

### SF6 Free LTB & DCB

- Technology Pilot in 2010
  - Tested according to IEC 62271-100
  - Installed in March 2010
  - Daily switched capacitor bank application
  - Test installation works flawlessly





### World's first Non-SF6 GIS installation with AirPlus™

### UW Oerlikon, ewz, Switzerland

#### Energized in summer 2015

- 8 high-voltage GIS bays (top)
- 50 medium-voltage GIS bays (bottom)

GLK-14	ZX2
170 kV	24 kV
1250 A	2500 A
50 Hz	50 Hz
40 kA	25 kA
700 kPa abs	120 kPa abs
+5°C	-15°C
$\rm CO_2$ and $\rm O_2$	Tech. Air
	GLK-14         170 kV         1250 A         50 Hz         40 kA         700 kPa abs         +5°C         CO2 and O2





### **Products & First Available Applications**





First Application: Frankfurt North & Sottrum S/S for TenneT (Germany)

6 units produced FAT performed with TenneT. E&C @ site 2017 GE Gas-Insulated Lines 420 kV (-25°C)



First Application: Sellindge S/S for NG (UK)

Second Application: Kilmarnoch S/S for SPEN (Scotland)

Sellindge ready for energization

GE GIS 145 kV incl. CB (-25°C)



First Application: AXPO (CH)

Grimaud – RTE (France) End 2017?

# F35-145kV g<sup>3</sup> GIS



#### Same footprint with g<sup>3</sup> as SF<sub>6</sub> solution



Item			Value		
Rated Voltage			145		
Nominal Frequency			50 / 60		
Rated Nominal current			up to 2500		
Short duration pow frequency			5	315	kV
BIL			0	kV	
Chart circuit	Ith	40			kA
Short circuit	duration	3			S
Short circuit current peak		108			kA
Mechanical class for CB and			10,000 (M2)		
Cap. Switching performance			C2 (LC/CC/BC)		
Pressure Design			6.5	7	bar
(lockout/Warning/Filling)		87	94	102	psi
Medium for insulation / interruption		6%vol <mark>8</mark> 3			

 $SF_6 = 60 \text{ kg Equiv } 1'400 \text{ t } CO_2$ 

Equiv 27 t CO<sub>2</sub>





# Synergy

- PG&E
  - Purchased/Installed 6 72 kV SF6 free HV breakers from Hitachi (Pilot)
  - Writing specification for 115kV single bay SF6 free GIS (Pilot)
  - Livermore Training center Non SF6 GIS installation 2017 (Pilot)
  - PG&E will pilot Non SF6 technology for 2018 acceptance.
  - Planning 115kV multi bay SF6 free HV GIS for bid in 2018
  - Team with other CA utilities
- PG&E will work with other CA Utilities
  - To avoid duplication
  - Reduce cost
  - Standardize on replacement gas
  - Multi SME
  - IEEE standard
  - Utility specification





# Thank you



*Pacific Gas and Electric Company*<sup>®</sup>

lir

SD

#### ELECTRIC POWER RESEARCH INSTITUTE



An EDISON INTERNATIONAL® Company



