

DRAFT NPDES PERMIT NO. PR0000418

AUTHORIZATION TO DISCHARGE UNDER THE
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Clean Water Act, as amended, 33 U.S.C. ' 1251 et. seq. (the "Act"),

Peñuelas Technology Park, LLC
Firm Delivery
683 State Road No. 337
Peñuelas, Puerto Rico 00624

hereinafter referred to as "the permittee" is authorized to discharge from a facility named "Peñuelas Technology Park – Peñuelas Facility" located at:

State Road No 337, Km. 1.1
Tallaboa Ward
Peñuelas, Puerto Rico 00624

to receiving waters named:

Outfall 001: Guayanilla Bay

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts I and II hereof. All references to Title 40 of the Code of Federal Regulations are to regulations that are in effect on the effective date of this permit, including all amendments thereto published in the Federal Register. Unless otherwise specified herein, all terms are defined as provided in the applicable regulations under Title 40 of the Code of Federal Regulations.

This permit shall become effective on Effective Date of Permit (EDP).

This permit and the authorization to discharge shall expire at midnight, EDP + 5 years.

Signed this day of

José C. Font
Acting Director
Caribbean Environmental Protection Division
U.S. Environmental Protection Agency
Region II

TABLE A-1 EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning on EDP and lasting through the permit expiration date, the permittee is authorized to discharge from outfall serial number 001 wastewater coming from the recovery of the groundwater control system at the facility’s industrial landfill and the wastewater treatment plant areas and sanitary wastewaters, treated in a wastewater treatment system prior to be discharged. Such shall be limited and monitored by the permittee as specified below:

Receiving Water Name and Classification: Guayanilla, SC

| Effluent Characteristics | Gross Discharge Limitations | | Monitoring Requirements | |
|---|--|----------------|-------------------------|-------------|
| | Units (specified) | | Measurement Frequency | Sample Type |
| | Monthly Average | Daily Maximum | | |
| 2,4,6-Trichlorophenol (µg/l) ^{2,3} | ---- | 24 | φ | Grab |
| Benzo(a)Anthracene (µg/l) ^{2,3} | ---- | 0.18 | Monthly | Grab |
| Benzo(k)Fluoranthene (µg/l) ^{2,3} | ---- | 0.18 | Monthly | Grab |
| Chrysene (µg/l) ^{2,3} | ---- | 0.18 | Monthly | Grab |
| BOD ₅ (mg/l) ^{1,2,3} | 30.0 | ---- | Monthly | Composite |
| Color (Pt-Co Units) ^{2,3} | Shall not be altered except by natural causes. | | Monthly | Grab |
| Cyanide Free (CN) (µg/l) ^{2,3} φ | ---- | ---- | α | Grab |
| Dissolved Oxygen (mg/l) ^{1,2,3} | Shall not be less than 4.0. | | Daily | Grab |
| Enterococci (colonies/100 ml) ^{1,2,3,6} | The enterococci density in terms of geometric mean of at least five representative samples of the waters taken sequentially in a given instance. | | β | Grab |
| Flow m ³ /day (MGD) ^{1,3,4} γ | ---- | 237.67 (0.062) | Continuous Recording | |
| Lead (Pb) (µg/l) ^{2,3} | ---- | 8.52 | Quarterly | Grab |
| Pentachlorophenol (µg/l) ^{2,3} | ---- | 7.9 | φ | Grab |
| pH (SU) ^{2,3} | Shall always lie between 7.3 and 8.5. | | Daily | Grab |
| Silver (Ag) (µg/l) ^{2,3,4} | ---- | 2.24 | Monthly | Grab |

TABLE A-1 EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

| <u>Effluent Characteristics</u> | <u>Gross Discharge Limitations</u> | | <u>Monitoring Requirements</u> | |
|---|--|----------------------|--------------------------------|--------------------|
| | Units (specified) | | <u>Measurement Frequency</u> | <u>Sample Type</u> |
| | <u>Monthly Average</u> | <u>Daily Maximum</u> | | |
| Solids and Other Matter ^{2,3} | The waters of Puerto Rico shall not contain floating debris, scum or other floating materials attributable to the discharge in amounts sufficient to be unsightly or deleterious to the existing or designated uses of the water body. | | ---- | ---- |
| Suspended, Colloidal or Settleable Solids (ml/l) ^{1,2,3} @ | Solids from wastewater source shall not cause deposition in or be deleterious to the existing or designated uses of the water body. | | Daily | Grab |
| Taste and Odor-producing Substances ^{2,3} | Shall contain none in amounts that will render any undesirable taste or odor to edible aquatic life. | | ---- | ---- |
| Temperature °F (°C) ^{2,3} | Except by natural causes, no heat may be added to the waters of Puerto Rico, which would cause the temperature of any site to exceed 90 °F (32.2 °C). | | Daily | Grab |
| Special Conditions | See special conditions below that constitute part of this permit. | | | |

Notes:

To comply with the monitoring requirements specified above, samples shall be taken at the outfall of discharge serial number 001.

All flow measurements shall achieve accuracy within the range of plus or minus (±) 10%.

γ See Special Conditions 1. φ See Special Conditions 8. β See Special Condition 4.

@ The permittee shall perform sampling for Settleable Solids.

| <u>Effluent Characteristics</u> | <u>Gross Discharge Limitations</u> | | <u>Monitoring Requirements</u> | |
|---------------------------------|------------------------------------|----------------------|--------------------------------|--------------------|
| | Units (specified) | | <u>Measurement Frequency</u> | <u>Sample Type</u> |
| | <u>Monthly Average</u> | <u>Daily Maximum</u> | | |

φ The permittee shall implement a monitoring program using the analytical method approved by U.S. Environmental Protection Agency (EPA) with the lowest possible detection level, in accordance with Rule 1306.2(c) of the Puerto Rico Water Quality Standard Regulation (PRWQSR), as amended following the next schedule:

| Monitoring Period | Monitoring Frequency |
|--|---|
| 1. Beginning on EDP, until the start-up of the new contaminated groundwater treatment system (CGTS). | Annual |
| 2. Beginning immediately after the start-up of the new CGTS, until EDP + 5 years. | Monthly for one (1) year period, after which they will be conducted annually. |

The monitoring program shall commence no later than thirty (30) days after the Puerto Rico Environmental Quality Board's (EQB's) written approval of the Quality Assurance Project Plan (QAPP). The QAPP must be submitted for evaluation and approval of EQB no later than thirty (30) days after the EDP. The results of the monitoring program shall be submitted to EQB and EPA-Region 2 no later than sixty (60) days of completion of the one year monitoring program. Based on the evaluation of the results obtained, EQB will determine if more frequent monitoring is necessary for this parameter. In such case, the WQC will be reopened to revise the monitoring frequency.

α The permittee shall implement a monitoring program using the analytical method approved by EPA with the lowest possible detection level, in accordance with Rule 1306.2(c) of the PRWQSR, as amended following the next schedule:

| Effluent Characteristics | Gross Discharge Limitations | | Monitoring Requirements | |
|---|-----------------------------|---|-------------------------|-------------|
| | Units (specified) | | Measurement Frequency | Sample Type |
| | Monthly Average | Daily Maximum | | |
| Monitoring Period | | Monitoring Frequency | | |
| 1. Beginning on EDP, until the start-up of the new CGTS. | | Annual | | |
| 2. Beginning immediately after the start-up of the new CGTS, until EDP + 5 years. | | Monthly for one (1) year period, after which they will be conducted annually. | | |

The monitoring program shall commence no later than thirty (30) days after the EQB’s written approval of the QAPP. The QAPP must be submitted for evaluation and approval of EQB no later than thirty (30) days after the EDP. The results of the monitoring program shall be submitted to EQB and EPA-Region 2 no later than sixty (60) days of completion of the one year monitoring program. Based on the evaluation of the results obtained, EQB will determine if an effluent limitation is necessary for this parameter. In such case the WQC will be reopened to include the applicable effluent limitation.

β The permittee shall implement a monitoring program using the analytical method approved by EPA with the lowest possible detection level, in accordance with Rule 1306.2(c) of the Puerto Rico Water Quality Standard Regulation (PRWQSR), as amended, for one (1) year period, after which they will be conducted annually. The monitoring program shall commence no later than thirty (30) days after the EQB’s written approval of the QAPP. The QAPP must be submitted for evaluation and approval of EQB no later than thirty (30) days after the EDP. The results of the monitoring program shall be submitted to EQB and EPA-Region 2 no later than sixty (60) days of completion of the one year monitoring program. Based on the evaluation of the results obtained, EQB will determine if an effluent limitation is necessary for this parameter. In such case the WQC will be reopened to include the applicable effluent limitation.

Notes 1, 2, 3, 4, 5 and 6 see page 13 of Special Conditions.

TABLE A-2 EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

PART I
 Page 6 of 31 Pages
 Permit No. PR0000418

During the period beginning on EDP and lasting through EDP + 36 months, the permittee is authorized to discharge from outfall serial number 001 wastewater coming from the recovery of the groundwater control system at the facility’s industrial landfill and the wastewater treatment plant areas and sanitary wastewaters, treated in a wastewater treatment system prior to be discharged. Such shall be limited and monitored by the permittee as specified below:

Receiving Water Name and Classification: Guayanilla, SC

| Effluent Characteristics | Gross Discharge Limitations | | Monitoring Requirements | |
|---|-----------------------------|---------------|-------------------------|-------------|
| | Units (specified) | | Measurement Frequency | Sample Type |
| | Monthly Average | Daily Maximum | | |
| Bis(2-Ethylhexyl)Phthalate ^x (µg/l) ^{2,3} | ---- | 59 | Monthly | Grab |
| Copper (Cu) (µg/l) ^{2,3} | ---- | 5.8 | Monthly | Grab |
| Mercury (Hg) (µg/l) ^{2,3,5} φ | ---- | 0.49 | Monthly | Grab |
| Nickel (Ni) (µg/l) ^{2,3} | ---- | 11.20 | Monthly | Grab |
| Oil and Grease (mg/l) ^{2,3} | ---- | 10.0 | Twice per Month | Grab |

Notes:

To comply with the monitoring requirements specified above, samples shall be taken at the outfall of discharge serial number 001.

All flow measurements shall achieve accuracy within the range of plus or minus (±) 10%.

φ See Special Conditions 8.

Notes 2, 3, and 5 see page 13 of Special Conditions.

During the period beginning on EDP + 36 months + 1 day and lasting through EDP + 5 years months, the permittee is authorized to discharge from outfall serial number 001 wastewater coming from the recovery of the groundwater control system at the facility's industrial landfill and the wastewater treatment plant areas and sanitary wastewaters, treated in a wastewater treatment system prior to be discharged. Such shall be limited and monitored by the permittee as specified below:

Receiving Water Name and Classification: Guayanilla, SC

| Effluent Characteristics | Gross Discharge Limitations | | Monitoring Requirements | |
|---|--|---------------|-------------------------|-------------|
| | Units (specified) | | Measurement Frequency | Sample Type |
| | Monthly Average | Daily Maximum | | |
| Bis(2-Ethylhexyl)Phthalate ^x (µg/l) ^{2,3} | ---- | 22 | Monthly | Grab |
| Copper (Cu) (µg/l) ^{2,3} | ---- | 3.73 | Monthly | Grab |
| Mercury (Hg) (µg/l) ^{2,3,5} φ | ---- | 0.025 | Monthly | Grab |
| Nickel (Ni) (µg/l) ^{2,3} | ---- | 8.28 | Monthly | Grab |
| Oil and Grease (mg/l) ^{2,3} | The water of Puerto Rico shall be substantially free from floating non-petroleum oils and greases as well as petroleum derived oils and greases. | | Twice per Month | Grab |

Notes:

To comply with the monitoring requirements specified above, samples shall be taken at the outfall of discharge serial number 001.

All flow measurements shall achieve accuracy within the range of plus or minus (±) 10%.

φ See Special Conditions 8.

Notes 2, 3, and 5 see page 13 of Special Conditions.

A. SPECIAL CONDITIONS

PART I

Page 8 of 31 Pages

Permit No. PR0000418

These special conditions are an integral part of the permit:

1. The flow of discharge 001 shall not exceed the limitation:
 - 234.67 m³/day (0.062 MGD) as daily maximum flow until the new CGTS is constructed and approved by EQB, according to the Compliance Plan (CP) established in Special Condition 16.
 - Once the new CGTS is constructed and approved by EQB, the flow discharge 001 must not exceed the design capacity of such CGTS.

No increase in flow of discharge 001 shall be authorized without a recertification from the EQB. ^{1,4}

2. Prior to the construction of any additional treatment system or the modification of the existing one, the permittee shall obtain the approval from EQB of the engineering report, plans and specifications from EQB. ⁴
3. The permittee shall install, maintain and operate all water pollution control equipment in such manner as to be in compliance with the applicable Rules and Regulations. ^{2,3}
4. No toxic substances shall be discharged, in toxic concentrations, other than those allowed as specified in the NPDES permit. Those toxic substances included in the Permit Renewal Application, but not regulated by the permit, shall not exceed those concentrations as specified in the applicable regulatory limitations. ^{1,2}
5. The waters of Puerto Rico shall not contain any substance, attributable to discharge 001, at such concentration which, either alone or as result of synergistic effects with other substances, is toxic or produces undesirable physiological responses in humans, fish or other fauna or flora. ²
6. The discharge 001 shall not cause the presence of oil sheen in the receiving water body. ²
7. All sample collection, preservation, and analysis shall be carried out in accordance with the 40 CFR Part 136. A licensed chemist authorized to practice the profession in Puerto Rico shall certify all chemical analyses. A licensed microbiologist or a medical technician authorized to practice the profession in Puerto Rico shall certify all bacteriological tests. ^{1,3}
8. The samples taken for the analysis of Cyanide and Mercury shall be analyzed using the analytic method approved by the EPA with the lowest possible detection level, in accordance with Rule 1306.8 of the Puerto Rico Water Quality Standards Regulation (PRWQSR), as amended. ^{1,3}

A. SPECIAL CONDITIONS

PART I

Page 9 of 31 Pages

Permit No. PR0000418

9. The flow- measuring device for the discharge 001 shall be periodically calibrated and properly maintained. Calibration and maintenance records must be kept in compliance with the applicable Rules and Regulations.^{3,4}
10. The sampling point for discharge 001 shall be located immediately after the primary flow measuring device of the effluent of the treatment system. If any standard or prohibition to the sanitary sludge disposal is promulgated and said prohibition or standard is more stringent than any condition, restriction, prohibition or standard contained in the NPDES permit, such permit shall be modified accordingly or revoked and reissued to be adjusted with regard to such prohibition or standard.⁵
11. The sampling point for discharge 001 shall be labeled with a 18 inches X 12 inches (minimum dimension) sign that reads as follows:

"Punto de Muestreo para la Descarga 001"
12. All water or wastewaters treatment facilities, whether publicly or privately owned, must be operated by a person licensed by the Potable Water and Wastewaters Treatment Plants Operators Examining Board of the Commonwealth of Puerto Rico.²
13. This special condition shall not become in effect until EQB has determined the applicability to the respective facility and has notified the permittee and the EPA, in writing, of the necessity to comply with this special condition.

Not later than one hundred eighty (180) days after the effective date of the permit condition (EDPC), the permittee shall conduct quarterly acute toxicity tests for a period of one (1) year, after which the tests shall be performed annually, of its wastewaters discharge through Outfall Serial Number 001, in accordance with the following:³

- a. The test species should be silverside (Menidia beryllina) and mysid (Mysidopsis bahia). The test should be static renewal type.
- b. The toxicity tests shall be conducted in accordance with the EPA publication, EPA 821-R-02-012 Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms (Fifth Edition), October 2002, or the most recent edition of this publication, if such edition is available.
- c. The tests shall provide a measure of the acute toxicity as determined by the wastewaters concentration, which cause 50 percent mortality of the organisms over a 48-hour period. The test results shall be expressed in terms of Lethal Concentration (LC) and reported as 48 hour LC50.

A. SPECIAL CONDITIONS

PART I

Page 10 of 31 Pages

Permit No. PR0000418

- d. A procedure report shall be submitted to EPA Region II and EQB ninety (90) days after EDP. The following information shall be included in the procedure report:
1. An identification of the organizations responsible for conducting the tests and the species to be tested.
 2. A detailed description of the methodology to be utilized in the conduct of the tests, including equipment, sample collection, dilution water and source of test organisms.
 3. A schematic diagram, which depicts the effluent sampling location. The diagram shall indicate the location of effluent sampling in relation to wastewater treatment facility and discharge monitoring point.
- e. The results of the tests conducted shall be submitted to EPA Region II and EQB within thirty (30) days of completion of each test. Based on a review of the test results, EPA or EQB may require additional toxicity tests, including chronic analyses. In addition to submitting the procedures report and test results to the addresses listed in Part I.B of this permit, results shall be submitted to:

CHIEF, CLEAN WATER REGULATORY BRANCH
U.S. ENVIRONMENTAL PROTECTION AGENCY, REGION II
290 BROADWAY – 24th FLOOR
NEW YORK, NEW YORK 10007-1866

- f. Reopener Clause for Toxicity Requirements
This permit may be reopened by EPA to include toxicity/treatability studies, and/or effluent limitations for toxicity and toxicity/treatability studies, and may impose toxicity limitations.
14. The sludge produced within the facility due to the operation of the treatment system shall be analyzed and all constituents shall be identified as required by “Resources Conservation and Recovery Act” (RCRA) and by “Toxic Substances Control Act” (TSCA). The permittee shall obtain appropriate federal and state permits prior to the final disposal of such wastes. The sludge shall be disposed properly in such manner that water pollution or other adverse effects to surface waters or to underground water do not occur. The pertinent permit form EQB’s Solid Wastes Program must be obtained.^{3,4}
15. Within thirty (30) days after the EDP, the permittee shall submit to the EQB a copy of the Emergency Plan (EP), in accordance with Rule 1306.5 of the PRWQSR to prevent and control spills. The EP shall be signed and certified by a professional licensed engineer authorized to practice the profession in Puerto Rico.³

16. COMPLIANCE PLAN AND INTERM LIMITS ³

- a. The permittee shall comply with the following interim and final effluent limits at discharge 001 for the following parameters:

| <u>Parameters</u> | <u>Interim Limits</u> | <u>Final Limits</u> |
|--|-----------------------|---------------------|
| Bis(2-Ethylhexyl)Phthalate ^x (µg/L) | 59 | 22 |
| Copper (Cu) (µg/L) | 5.8 | 3.73 |
| Mercury (Hg) (µg/L) | 0.49 | 0.025 |
| Nickel (Ni) (µg/L) | 11.20 | 8.28 |
| Oil and Grease (mg/L) | 10.0 | * |

*The water of Puerto Rico shall be substantially free from floating non-petroleum oils and greases as well as petroleum derived oils and greases.

- b. The interim effluent limits will be effective during the period beginning on the EDP and lasting through EDP + 36 months. At EDP + 36 months + 1 day, the effluent limits will become effective.
- c. The schedule (activity/compliance deadline) of the Compliance Plan is as follows:
1. Peñuelas Technology Park LLC (PTPLLC) prepares and submits to EQB and EPA a Progress Report informing the activities performed by the facility to complete the conceptual design, the corresponding environmental document proceeding, and the Consolidated General Permit Application for the new facility’s CGTS.
 EDP + 7 months
 2. PTPLLC prepares and submits to EQB and EPA a Progress Report informing the activities performed by the facility to transact the corresponding environmental document and the Consolidated General Permit.
 EDP + 12 months
 3. PTPLLC submits to EQB for evaluation and approval the Engineering Report, Plans and Specifications of the final design of the new facility’s CGTS.
 EDP + 18 months
 4. PTPLLC starts the construction of the new facility’s CGTS.
 EDP + 26 months
 5. PTPLLC completes the construction and start-up of the new facility’s CGTS.
 EDP + 36 months

A. SPECIAL CONDITIONS

PART I
Page 12 of 31 Pages
Permit No. PR0000418

6. Final permit limits become effective.

EDP + 36 months + 1 day

1, 2, 3, 4, 5 and 6 see next page.

A. REFERENCES OF SPECIAL CONDITIONS

PART I

Page 13 of 31 Pages

Permit No. PR0000418

1. According to Rule 1301 of the Puerto Rico Water Quality Standards Regulation, as amended.
2. According to Rule 1303 of the Puerto Rico Water Quality Standards Regulation, as amended.
3. According to Rule 1306 of the Puerto Rico Water Quality Standards Regulation, as amended.
4. According to the Environmental Public Policy Act of September 22, 2004, Act No. 416, as amended.
5. According to the Code of Federal Regulation Number 40 (40 CFR), Part 131.36, as amended (Federal Register/Volume 57, No. 246/Tuesday, December 22, 1992).
6. According to the Code of Federal Regulation Number 40 (40 CFR), Part 131.40, as amended (Federal Register/Volume 69, No. 16/Monday, January 26, 2004).

B. MONITORING AND REPORTING REQUIREMENTS

PART I

Page 14 of 31 Pages

Permit No. PR0000418

1. Monitoring and records. See Part II.B.10.

2. Discharge monitoring reports.

a. See Part II.B.12.d.

b. Monitoring results obtained during the previous month shall be summarized and reported on a Discharge Monitoring Report Form (EPA No. 3320-1), postmarked no later than the 28th day of the month following the completed reporting period. The first report is due on EDP + 1 MONTH + 28 DAYS. Duplicate signed copies of these, and all other reports required herein, shall be submitted to the Regional Administrator and State Director at the following addresses:

COMPLIANCE ASSISTANCE
PROGRAM SUPPORT BRANCH
US EPA REGION II
REGION II
U.S. ENVIRONMENTAL PROTECTION
AGENCY
290 BROADWAY - 21ST FLOOR
NEW YORK, NEW YORK 10007-1866

MULTIMEDIA PERMITS AND
COMPLIANCE BRANCH
CARIBBEAN ENVIRONMENTAL
PROTECTION DIVISION
CITY VIEW PLAZA II – SUITE 7000
48 ROAD 165 KM. 1.2
GUAYNABO, PUERTO RICO 00968-8069

ENVIRONMENTAL QUALITY BOARD OF PUERTO RICO
P.O. BOX 11488
SANTURCE, PUERTO RICO 00910
ATTN: WATER QUALITY BUREAU

3. Twenty-four hour reporting.

a. Pollutants for which the permittee must report violations of maximum daily discharge limitations under paragraph 12.f of Part II.B (40 CFR §122.41(1)(6)(ii)(C)) (24 hour reporting) shall be listed in the permit as follows: **Not Applicable**

4. Additional reporting requirements. *Existing manufacturing, commercial, mining, and silvicultural dischargers.* In addition to the reporting requirements under 40 C.F.R. §122.41(1), all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Director as soon as they know or have reason to believe:

a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":

B. MONITORING AND REPORTING REQUIREMENTS

PART I

Page 15 of 31 Pages

Permit No. PR0000418

- (1) One hundred micrograms per liter (100 ug/l);
- (2) Two hundred micrograms per liter (200 ug/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/l) for 2, 4-dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;
- (3) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 C.F.R. §122.21(g)(7); or
- (4) The level established as follows by the Director in accordance with 40 C.F.R. §122.44(f): **Not Applicable**

b. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":

- (1) Five hundred micrograms per liter (500 ug/l);
- (2) One milligram per liter (1 mg/l) for antimony;
- (3) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 C.F.R. §122.21(g)(7); or
- (4) The level established as follows by the Director in accordance with 40 C.F.R. §122.44(f): **Not Applicable**

1. "Average monthly discharge limitation" means the highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.
2. "Average weekly discharge limitation" means the highest allowable average of "daily discharges" over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.
3. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility.
4. "Composite" means a combination of individual (or continuously taken) samples obtained at regular intervals over the entire discharge day. The volume of each sample shall be proportional to the discharge flow rate. For a continuous discharge, a minimum of 24 individual grab samples (at hourly intervals) shall be collected and combined to constitute a 24-hour composite sample. For intermittent discharges of more than four (4) hours duration, grab samples shall be taken at a minimum of 30 minute intervals.
5. "Daily discharge" means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharge over the day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of pollutant over the day. For purposes of sampling, "daily" means an operating day or 24-hour period.
6. "Director" means the "Regional Administrator" or the "State Director", as the context requires, or an authorized representative. Until the State has an approved State program authorized by EPA under 40 C.F.R. Part 123, "Director" means the Regional Administrator. When there is an approved State program, "Director" normally means the State Director. Even in such circumstances, EPA may retain authority to take certain action (see, for example, 40 C.F.R. 123.1(d), 45 Federal Register 14178, April 1, 1983, on the retention of jurisdiction over permits EPA issued before program approval). If any condition of this permit requires the reporting of information or other actions to both the Regional Administrator and the State Director, regardless of who has permit-issuing authority, the terms "Regional Administrator" and "State Director" will be used in place of "Director".
7. "Discharge Monitoring Report" or "DMR" means the EPA uniform national form, including any subsequent additions, revisions, or modifications, for the reporting of self-monitoring results by permittees.
8. "Grab" means an individual sample collected in less than 15 minutes.

A. DEFINITIONS

PART II

Page 17 of 31 Pages

Permit No. PR0000418

9. "Gross" means the weight or the concentration contained in the discharge. (Unless a limitation is specified as a net limitation, the limitation contained in this permit is a gross limitation).
10. "Maximum daily discharge limitation" means the highest allowable "daily discharge".
11. "Monthly" means one day each month (the same day each month) and a normal operating day (e.g., the 2nd Tuesday of each month).
12. "Net" means the amount of a pollutant contained in the discharge measured in appropriate units as specified herein, less the amount of a pollutant contained in the surface water body intake source, measured in the same units, over the same period of time, provided:
 - a. The intake water source must be drawn for the same body of water into which the discharge is made; and
 - b. In cases where the surface water body intake source is pretreated for the removal of pollutants, the intake level of a pollutant to be used in calculating the net is that level contained after the pretreatment steps.
13. "Regional Administrator" means the Regional Administrator of Region II of EPA or the authorized representative of the Regional Administrator.
14. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
15. "State Director" means the chief administrative officer of the State water pollution control agency, or the authorized representative of the State Director.
16. "Toxic pollutant" means any of the pollutants listed in 40 C.F.R. §401.15 (45 F.R. 44503, July 30, 1979) and any modification to that list in accordance with Section 307 (a)(1) of the Clean Water Act.
17. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

A. DEFINITIONS

PART II

Page 18 of 31 Pages

Permit No. PR0000418

18. "Weekly" means every seventh day (the same day of each week) and a normal operating day.

TABLE OF REGULATORY REFERENCES FOR GENERAL CONDITIONS

Note: General Condition language in Part II, Sections B.1 through B.14, and B.17 is based on the July 1, 2011 Code of Federal Regulations (C.F.R.). Reference to language in the U.S.C. (United States Code) is based on the date of permit issuance.

| <u>Section</u> | <u>Section Title</u> | <u>Reference</u> |
|-----------------------|--|-------------------------|
| B.1. | Duty to Comply | 40 C.F.R. §122.41(a) |
| B.2. | Duty to Reapply | 40 C.F.R. §122.41(b) |
| B.3. | Need to Halt or Reduce not a Defense | 40 C.F.R. §122.41(c) |
| B.4. | Duty to Mitigate | 40 C.F.R. §122.41(d) |
| B.5. | Proper operation and maintenance | 40 C.F.R. §122.41(e) |
| B.6. | Permit actions | 40 C.F.R. §122.41(f) |
| B.7. | Property rights | 40 C.F.R. §122.41(g) |
| B.8. | Duty to provide information | 40 C.F.R. §122.41(h) |
| B.9. | Inspection and Entry | 40 C.F.R. §122.41(i) |
| B.10. | Monitoring and records | 40 C.F.R. §122.41(j) |
| B.11. | Signatory requirements | 40 C.F.R. §122.41(k) |
| B.12. | Reporting Requirements | 40 C.F.R. §122.41(l) |
| B.13. | Bypass | 40 C.F.R. §122.41(m) |
| B.14. | Upset | 40 C.F.R. §122.41(n) |
| B.15. | Removed substances | 33 U.S.C. §1311 |
| B.16. | Oil and hazardous substance liability | 33 U.S.C. §1321 |
| B.17. | Reopener clause for toxic effluent limitations | 40 C.F.R. §122.44(b)(1) |
| B.18. | State laws | 33 U.S.C. §1370 |
| B.19. | Availability of information | 33 U.S.C. §1318 |
| B.20. | Severability | - |

1. Duty to Comply.

a. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

b. The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.

c. The Clean Water Act provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Clean Water Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Clean Water Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation (as adjusted by 40 C.F.R. Part 19).

d. The Clean Water Act provides that any person who negligently violates Sections 301, 302, 306, 307, 308, 318, or 405 of the Clean Water Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402 of the Clean Water Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Clean Water Act, is subject to criminal penalties of not less than \$2,500 nor more than \$25,000 per day of violation, or imprisonment of not more than 1 year, or both. In the case of a second or subsequent conviction for a negligent violation of the Clean Water Act, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than 2 years, or both.

e. The Clean Water Act provides that any person who knowingly violates Sections 301, 302, 306, 307, 308, 318, or 405 of the Clean Water Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Clean Water Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Clean Water Act, is subject to criminal penalties of not less than \$5,000 nor more than \$50,000 per day of violation, or imprisonment for not more than 3 years, or both. In the case of a second or subsequent conviction for a knowing violation of the Clean Water Act, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.

f. Any person who knowingly violates Sections 301, 302, 303, 306, 307, 308, 318 or 405 of the Clean Water Act, or any permit condition or limitation implementing any of such

sections in a permit issued under section 402 of the Clean Water Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. A person which is an organization, as defined at 33 U.S.C. 309(c)(3)(B)(iii), shall, upon conviction be subject to a fine of not more than \$1,000,000. In the case of a second or subsequent conviction for a knowing endangerment violation of the Clean Water Act, the maximum punishment shall be doubled with respect to both fine and imprisonment.

g. Any person who knowingly makes any false material statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under the Clean Water Act or who knowingly falsifies, tampers with, or renders inaccurate any monitoring device or method required to be maintained under this chapter, shall upon conviction, be punished by a fine of not more than \$10,000, or imprisonment for not more than 2 years, or both. In the case of a second or subsequent conviction, under this paragraph, punishment shall be by a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both.

h. Any person may be assessed an administrative penalty by the Administrator for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation (as adjusted by 40 C.F.R. Part 19), with the maximum amount of any Class I penalty assessed not to exceed \$25,000 (as adjusted by 40 C.F.R. Part 19). Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues (as adjusted by 40 C.F.R. Part 19), with the maximum amount of any Class II penalty not to exceed \$125,000 (as adjusted by 40 C.F.R. Part 19).

2. Duty to Reapply. This permit and the authorization to discharge shall terminate on the expiration date indicated on the first page. In order to receive authorization to discharge after the expiration date of this permit, the permittee must apply for and obtain a new permit. If the permit issuing authority remains EPA, the permittee shall complete, sign, and submit an application to the Regional Administrator no later than 180 days before the expiration date.

3. Need to Halt or Reduce not a Defense. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

4. Duty to Mitigate. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

5. Proper operation and maintenance. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

6. Permit actions.

a. This permit may be modified, revoked and reissued, or terminated during its term pursuant to 40 C.F.R. Part 122, Subpart D. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

7. Property rights. This permit does not convey any property rights of any sort, or any exclusive privileges.

8. Duty to provide information. The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit; or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

9. Inspection and Entry. The permittee shall allow the Director, or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon presentation of credentials and other documents as may be required by law, to:

a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;

b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;

c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and

d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

10. Monitoring and records.

a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.

b. Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 C.F.R. part 503), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement report or application. This period may be extended by request of the Director at any time.

c. Records of monitoring information shall include:

- (1) The date, exact place, and time of sampling or measurements;
- (2) The individual(s) who performed the sampling or measurements;
- (3) The date(s) analyses were performed;
- (4) The individual(s) who performed the analyses;
- (5) The analytical techniques or methods used; and
- (6) The results of such analyses.

d. Monitoring must be conducted according to test procedures approved under 40 C.F.R. Part 136 and any subsequent changes to the methods contained therein unless another method is required under 40 C.F.R. subchapters N or O.

e. The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both. (See U.S.C. §1319(c)(4)).

11. Signatory requirements. All applications, reports, or information submitted to the Director shall be signed and certified. (See 40 C.F.R. §122.22)

a. Applications. All permit applications shall be signed as follows:

(1) For a corporation. By a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

Note: EPA does not require specific assignments or delegations of authority to responsible corporate officers identified in 40 C.F.R. §122.22(a)(1)(i). The Agency will presume that these responsible corporate officers have the requisite authority to sign permit applications unless the corporation has notified the Director to the contrary. Corporate procedures governing authority to sign permit applications may provide for assignment or delegation to applicable corporate positions under 40 C.F.R. §122.22(a)(1)(ii) rather than to specific individuals.

(2) For a partnership or sole proprietorship. By a general partner or the proprietor, respectively; or

(3) For a municipality, State, Federal, or other public agency. By either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes: (i) The chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of EPA).

b. All reports required by permits, and other information requested by the Director shall be signed by a person described in paragraph 11.a of Part II.B, or by a duly authorized representative of that person. A person is a duly authorized representative only if:

- (1) The authorization is made in writing by a person described in paragraph 11.a of Part II.B;
 - (2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company, (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) and,
 - (3) The written authorization is submitted to the Regional Administrator, U.S. Environmental Protection Agency, Region II, 290 Broadway, New York, New York, 10007-1866, Attention: Compliance Assistance Program Support Branch, and to the State Director.
- c. Changes to authorization. If an authorization under paragraph 11.b of Part II.B is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph 11.b of Part II.B must be submitted to the Director prior to or together with any reports, information, or applications to be signed by an authorized representative.
- d. Certification. Any person signing a document under paragraph 11.a or 11.b of Part II.B shall make the following certification:
- I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.
- e. The Clean Water Act provides that any person who knowingly makes any false material statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by imprisonment for not more than 6 months per violation, or by both. If a conviction is for a violation committed after a first conviction of such person under this paragraph, punishment shall be by a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both. (See section 309.c.4 of the Clean Water Act).

12. Reporting Requirements.

a. Planned changes. The permittee shall give notice to the Director as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:

(1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 C.F.R. §122.29(b);

(2) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under paragraph 4.a of Part I.B (40 C.F.R. §122.42(a)(1)); or

(3) The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.

b. Anticipated noncompliance. The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

c. Transfers. This permit is not transferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Clean Water Act. (See 40 C.F.R. §122.61; in some cases, modification or revocation and reissuance is mandatory.)

d. Monitoring reports. Monitoring results shall be reported at the intervals specified in Part I of this permit.

(1) Monitoring results shall be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Director for reporting results of monitoring of sludge use or disposal practices.

(2) If the permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 C.F.R. 136, or another method required for an industry-specific waste stream under 40 C.F.R. subchapters N or O,

the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Director.

(3) Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Director in the permit.

e. Compliance Schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.

f. Twenty-four hour reporting.

(1) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances to the Regional Administrator at (732) 548-8730 and State Director. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

(2) The following shall be included as information which must be reported within 24 hours under this paragraph.

- (a) Any unanticipated bypass (see 13 below) which exceeds any effluent limitation in the permit. (See 40 C.F.R. §122.41(g)).
- (b) Any upset (see 14 below) which exceeds any effluent limitation in the permit.
- (c) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in the permit to be reported within 24 hours. (See 40 C.F.R. §122.44(g)).

(3) The Director may waive the written report on a case-by-case basis for reports under paragraph 12.f.(2) of Part II.B if the oral report has been received within 24 hours.

g. Other noncompliance. The permittee shall report all instances of noncompliance not reported under paragraphs 12.d, e, and f of Part II.B, at the time the monitoring reports are submitted. The reports shall contain the information listed in paragraph 12.f of Part II.B.

h. Other information. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

13. Bypass

a. Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 13.b. and 13.c of Part II.B.

b. Notice.

(1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.

(2) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in paragraph 12.f of Part II.B (24-hour notice).

c. Prohibition of bypass.

(1) Bypass is prohibited, and the Director may take enforcement action against a permittee for bypass, unless:

(a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;

(b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and

(c) The permittee submitted notices as required under paragraph 13.b of Part II.B.

(2) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 13.b.(1) of Part II.B.

14. Upset.

a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of paragraph 14.(b) of Part II.B are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.

b. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
- (2) The permitted facility was at the time being properly operated;
- (3) The permittee submitted notice of the upset as required in paragraph 12.f.(2)(b) of Part II.B (24 hour notice); and
- (4) The permittee complied with any remedial measures required under paragraph 4 of Part II.B (duty to mitigate).

c. Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.

15. Removed substances. Pursuant to section 301 of the Clean Water Act, solids, sludges, filter backwash or other pollutants removed in the course of treatment or control of wastewaters and/or the treatment of intake waters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering navigable waters. The following data shall be reported together with the monitoring data required in paragraph 2 of Part I.B:

- a. The sources of the materials to be disposed of;
- b. The approximate volumes and weights;
- c. The method by which they were removed and transported; and
- d. Their final disposal locations.

16. Oil and hazardous substance liability. The imposition of responsibilities upon, or the institution of any legal action against the permittee under Section 311 of the Clean Water Act

shall be in conformance with regulations promulgated pursuant to Section 311 to discharges from facilities with NPDES permits.

17. Reopener clause for toxic effluent limitations. Other effluent limitations and standards under sections 301, 302, 303, 307, 318 and 405 of the Clean Water Act. If any applicable toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under Section 307(a) of the Clean Water Act for a toxic pollutant and that standard or prohibition is more stringent than any limitation on the pollutant in the permit, the Director shall institute proceedings under these regulations to modify or revoke and reissue the permit to conform to the toxic effluent standard or prohibition. See also 40 C.F.R. §122.41(a).

18. State laws. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law or regulation under authority preserved by Section 510 of the Clean Water Act. The issuance of this permit does not preempt any duty to obtain State or local assent required by law for the discharge.

19. Availability of information. (Section 308 of the Clean Water Act)

a. NPDES permits, effluent data, and information required by NPDES application forms provided by the Director under 40 C.F.R. §122.21 (including information submitted on the forms themselves and any attachments used to supply information required by the forms) shall be available for public inspection at the offices of the Regional Administrator and State Director.

b. In addition to the information set forth in subsection a., any other information submitted to EPA in accordance with the conditions of this permit shall be made available to the public without further notice unless a claim of business confidentiality is asserted at the time of submission in accordance with the procedures in 40 C.F.R. Part 2 (Public Information).

c. If a claim of confidentiality is made for information other than that enumerated in subsection a., that information shall be treated in accordance with the procedures in 40 C.F.R. Part 2. Only information determined to be confidential under those procedures shall not be made available by EPA for public inspection.

20. Severability. The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

C. EFFECTIVENESS OF PERMIT

PART II

Page 31 of 31 Pages

Permit No. PR0000418

1. This permit shall become effective in its entirety on the date indicated on the first page of this permit unless a petition has been filed with the Environmental Appeals Board to review any condition of the permit decision pursuant to the provisions of 40 C.F.R. Part 124.19. All contested conditions and any uncontested condition(s) that are inseverable from the contested conditions shall be stayed. All other conditions shall become effective thirty (30) days after the date of the notification specified in 40 C.F.R. §124.16(a)(2)(ii).

2. For purposes of judicial review under Section 509(b) of the Clean Water Act, final agency action on a permit does not occur unless and until a party has exhausted its administrative remedies under 40 C.F.R. 124. Any party which neglects or fails to seek review under 40 C.F.R. §124.19, thereby waives its opportunity to exhaust available agency administrative remedies.