



FACT SHEET

Public Comment Period:

Technical Contacts:

Kathleen Collins (206-553-2108) collins.kathleen@epa.gov
Susan Poulson (206-553-6258) poulson.susan@epa.gov
(1-800-424-4372 - within EPA Region 10)

**The United States Environmental Protection Agency (EPA)
Plans To Reissue A National Pollutant Discharge Elimination System (NPDES) Permit to
each of the following facilities:**

Ahsahka Water and Sewer District
Slate Creek Ranger Station
Fenn Ranger Station
City of Cascade
Clarkia Water and Sewer District
City of Fairfield
City of Glenns Ferry
City of Grace
City of Horseshoe Bend
City of Orofino
City of Riggins
City of Ririe
City of Worley

EPA Proposes To Reissue NPDES Permit

EPA proposes to reissue the NPDES permits to the facilities referenced above. The draft permits place conditions on the discharge of pollutants from each wastewater treatment plant to waters of the United States. In order to ensure protection of water quality and human health, the permits place limits on the types and amounts of pollutants that can be discharged from each facility.

This Fact Sheet includes:

- information on public comment, public hearing, and appeal procedures
- a listing of proposed effluent limitations, and other conditions for each facility
- a map and description of the discharge locations
- technical material supporting the conditions in each permit

The State of Idaho Proposes Certification

EPA is requesting that the Idaho Department of Environmental Quality certify the NPDES permits for those facilities that discharge to state waters, under section 401 of the Clean Water Act.

Public Comment

Persons wishing to comment on, or request a Public Hearing for the draft permit for any of these facilities may do so in writing by the expiration date of the Public Comment period. A request for a Public Hearing must state the nature of the issues to be raised as well as the requester's name, address and telephone number. All comments and requests for Public Hearings must be in writing and should be submitted to EPA as described in the Public Comments Section of the attached Public Notice.

After the Public Notice expires, and all comments have been considered, EPA's regional Director for the Office of Water will make a final decision regarding permit reissuance. If no substantive comments are received, the tentative conditions in the draft permit will become final, and the permit will become effective upon issuance. If comments are received, EPA will address the comments and issue the permit. The permit will become effective 30 days after the issuance date, unless an appeal is submitted to the Environmental Appeals Board within 30 days.

Documents are Available for Review.

The draft NPDES permits and related documents can be reviewed or obtained by visiting or contacting EPA's Regional Office in Seattle between 8:30 a.m. and 4:00 p.m., Monday through Friday (see address below). The draft permits, fact sheet, and other information can also be found by visiting the Region 10 website at "www.epa.gov/r10earth/water.htm."

United States Environmental Protection Agency
Region 10
1200 Sixth Avenue, OW-130
Seattle, Washington 98101
(206) 553-2108 or
1-800-424-4372 (within Alaska, Idaho, Oregon and Washington)

The fact sheet and draft permits are also available at:

EPA Idaho Operations Office
1435 North Orchard Street
Boise, Idaho 83706
(208) 378-5746

TABLE OF CONTENTS

ACRONYMS	5
I. APPLICANTS	7
II. FACILITY INFORMATION	7
III. RECEIVING WATER	7
A. Water Quality Standards	8
B. Water Quality Limited	8
IV. EFFLUENT LIMITATIONS	9
A. Basis for Permit Effluent Limits	9
B. Proposed Effluent Limitations	9
V. MONITORING REQUIREMENTS	10
A. Basis for Effluent and Surface Water Monitoring	10
B. Effluent Monitoring	10
C. Surface Water Monitoring	15
VI. SLUDGE (BIOSOLIDS) REQUIREMENTS	15
VII. OTHER PERMIT CONDITIONS	16
A. Quality Assurance Plan	16
B. Operation and Maintenance Plan	16
C. Additional Permit Provisions	16
VIII. OTHER LEGAL REQUIREMENTS	16
A. Endangered Species Act	16
B. Essential Fish Habitat	17
C. State/Tribal Certification	17
D. Permit Expiration	17
Appendix A - Facility Information	A-1
Appendix B - Basis for Effluent Limitations	B-1
Appendix C - Location of Facilities	C-1

LIST OF TABLES

Table 1: Monthly, Weekly and Instantaneous Maximum Effluent Limitations	10
Table 2a: Effluent Monitoring Requirements (>0.5 - 1.0 mgd Design Flow)	12
Table 2b: Effluent Monitoring Requirements (>0.1 - 0.5 mgd Design Flow)	13
Table 2c: Effluent Monitoring Requirements (up to 0.1 mgd Design Flow)	14
Table 3: Surface Water Monitoring Requirements	15

ACRONYMS

1Q10	1 day, 10 year low flow
7Q10	7 day, 10 year low flow
AML	Average Monthly Limit
BOD ₅	Biochemical oxygen demand, five-day
BE	Biological evaluation
°C	Degrees Celsius
cfs	Cubic feet per second
CFR	Code of Federal Regulations
CV	Coefficient of Variation
CWA	Clean Water Act
DMR	Discharge Monitoring Report
DO	Dissolved oxygen
EFH	Essential Fish Habitat
EPA	U.S. Environmental Protection Agency
ESA	Endangered Species Act
I/I	Inflow and Infiltration
lbs/day	Pounds per day
LTA	Long Term Average
mg/L	Milligrams per liter
ml	milliliters
ML	Minimum Level
µg/L	Micrograms per liter
mgd	Million gallons per day
MDL	Maximum Daily Limit
MPN	Most Probable Number
N	Nitrogen
NMFS	National Marine Fisheries Service
NPDES	National Pollutant Discharge Elimination System
OW	Office of Water
O&M	Operations and maintenance
POTW	Publicly owned treatment works
QAP	Quality assurance plan
RP	Reasonable Potential
RPM	Reasonable Potential Multiplier
s.u.	Standard Units
TMDL	Total Maximum Daily Load
TRE	Toxicity Reduction Evaluation
TSD	Technical Support document (EPA, 1991)
TSS	Total suspended solids
USFWS	U.S. Fish and Wildlife Service
USGS	United States Geological Services
UV	Ultraviolet radiation
WLA	Wasteload allocation

WQBEL Water quality-based effluent limit
WWTP Wastewater treatment plant

I. APPLICANTS

This fact sheet provides information on the draft permits for the following facilities:

<u>Facility</u>	<u>NPDES Permit Number</u>
Ahsahka Water and Sewer District	ID 002522-4
Slate Creek Ranger Station	ID 002073-7
Fenn Ranger Station	ID 002071-1
City of Cascade	ID 002316-7
Clarkia Water and Sewer District	ID 002507-1
City of Fairfield	ID 002438-4
City of Glens Ferry	ID 002200-4
City of Grace	ID 002382-5
City of Horseshoe Bend	ID 002102-4
City of Orofino	ID 002015-0
City of Riggins	ID 002093-1
City of Ririe	ID 002617-4
City of Worley	ID 002271-3

II. FACILITY INFORMATION

These draft permits are for the discharge of effluent from municipal wastewater treatment plants. These facilities treat primarily residential and commercial wastewater.

The facilities provide secondary treatment through either activated sludge systems or wastewater stabilization ponds (lagoons). Disinfection may be provided using either chlorination or ultraviolet (UV) radiation. Information specific for each of the treatment facilities is provided in Appendix A.

III. RECEIVING WATER

Specific receiving water information available for each of the facilities is provided in Appendix A. The information includes:

- Receiving water body
- Subbasin
- Low flow conditions - including the 1 day, 10 year low flow (1Q10), and the 7 day, 10 year low flow (7Q10)
- Beneficial uses of the water body
- Identification of water quality limited segments

A. Water Quality Standards

An NPDES permit must ensure that the discharge from the facility complies with the State/Tribe's water quality standards. A State/Tribe's water quality standards¹ are composed of use classifications, numeric and/or narrative water quality criteria, and an anti-degradation policy. The use classification system designates the beneficial uses (such as cold water biota, contact recreation, etc.) that each water body is expected to achieve. The numeric and/or narrative water quality criteria are the criteria deemed necessary, by the State/Tribe, to support the beneficial use classification of each water body. The anti-degradation policy represents a three tiered approach to maintain and protect various levels of water quality and uses.

Some of the facilities discharge to Tribal waters for which the Tribe has not yet adopted water quality standards. In this case, EPA's practice is to apply adjacent or downstream standards to the water body for the purpose of developing permit limitations and conditions. Therefore, the State of Idaho water quality standards were applied to these permits.

Because the effluent limits in the draft permits are based on current water quality criteria or technology-based limits that have been shown to not cause or contribute to an exceedence of water quality standards the discharges as authorized in the draft permits will not result in degradation of the receiving water.

B. Water Quality Limited

Any waterbody for which the water quality does not, and/or is not expected to meet, applicable water quality standards is defined as a "water quality limited segment."

Section 303(d) of the Clean Water Act (CWA) requires states to develop a Total Maximum Daily Load (TMDL) management plan for water bodies determined to be water quality limited segments. The TMDL documents the amount of a pollutant a waterbody can assimilate without violating a state's water quality standards and allocates that load to known point sources and nonpoint sources. The allocations for point sources are then incorporated into the NPDES permit.

¹ Idaho's water quality standards are contained in *Water Quality Standards and Wastewater Treatment Requirements* (IDAPA 58.01.02.)

IV. EFFLUENT LIMITATIONS

A. Basis for Permit Effluent Limits

In general, the CWA requires that the limits for a particular pollutant be the more stringent of either technology-based effluent limits or water quality-based limits. Technology-based limits are set according to the level of treatment that is achievable using available technology. A water quality-based effluent limit is designed to ensure that the water quality standards of a waterbody are being met and they may be more stringent than technology-based effluent limits. The basis for the proposed effluent limits in the draft permit are provided in Appendix B.

B. Proposed Effluent Limitations

The following summarizes the proposed effluent limitations that are in the draft permits.

1. The pH range must be between 6.5 to 9.0 standard units.
2. The monthly average effluent concentration of five-day Biochemical Oxygen Demand (BOD₅) shall not exceed 15 percent of the monthly average influent concentration of BOD₅.
3. The monthly average effluent concentration of Total Suspended Solids (TSS) shall not exceed 15 percent of the monthly average influent concentration of TSS.
4. There must be no discharge of any floating solids, visible foam in other than trace amounts, or oily wastes that produce a sheen on the surface of the receiving water.
5. Table 1, below presents the proposed average monthly, average weekly, and instantaneous maximum effluent limits for BOD₅, TSS, and escherichia coli (E. Coli), and chlorine (if applicable).

Table 1: Monthly, Weekly and Instantaneous Maximum Effluent Limitations				
Parameters	Units	Average Monthly Limit	Average Weekly Limit	Instantaneous Maximum Limit
BOD ₅	mg/L	30	45	---
	lbs/day	Facility Specific ¹	Facility Specific ¹	---
TSS	mg/L	30	45	---
	lbs/day	Facility Specific ¹	Facility Specific ¹	---
E. coli Bacteria ²	colonies/100 ml	126 ³	---	406
E. coli Bacteria ⁴	colonies/100 ml	126 ³	---	576
Chlorine ⁵	mg/L	0.5	0.75	---
	lbs/day	Facility Specific ¹	Facility Specific ¹	---
Notes: 1 Loading (in lbs/day) is calculated for each facility as: concentration (in mg/L) * design flow (in mgd) * conversion factor of 8.34 2 Applies to facilities that discharge to receiving waters that are protected for primary contact recreation 3 Based on the geometric mean of all samples taken during the month. 4 Applies to facilities that discharge to receiving waters that are protected for secondary contact recreation 5 Applies only to those facilities that chlorinate.				

V. MONITORING REQUIREMENTS

A. Basis for Effluent and Surface Water Monitoring

Section 308 of the CWA and federal regulation 40 CFR 122.44(i) require monitoring in permits to determine compliance with effluent limitations. Monitoring may also be required to gather effluent and surface water data to determine if additional effluent limitations are required and/or to monitor effluent impacts on receiving water quality. The permittee is responsible for conducting the monitoring and for reporting results on Discharge Monitoring Reports (DMRs) to U.S. Environmental Protection Agency (EPA).

B. Effluent Monitoring

Monitoring frequencies are based on the nature and effect of the pollutant, as well as a determination of the minimum sampling necessary to adequately monitor the

facility's performance. Permittees have the option of taking more frequent samples than are required under the permit. These samples can be used for averaging if they are conducted using EPA approved test methods (generally found in 40 CFR 136) and if the Method Detection Levels (MDLs) are less than the effluent limits.

Facilities described in this fact sheet range in size from a discharge of a few thousand gallons per day up to potentially 1 million gallons per day (mgd). Given this wide range in discharge volume, the draft permits require monitoring frequency and sample type which are reflective of the facility size as specified by design flow. Facilities with higher design flows are required to monitor more frequently than facilities with lower design flows. In addition, facilities with higher design flows are required to take 8-hour composite samples for BOD₅, TSS, and ammonia, whereas, smaller facilities are required to take grab samples for these parameters.

Tables 2a through 2c present the monitoring requirements for the permittees in the draft permits. The sampling location must be after the last treatment unit and prior to discharge to the receiving water. The monitoring samples must not be influenced by combination with other effluent. If no discharge occurs during the reporting period, "no discharge" shall be reported on the DMR.

Table 2a: Effluent Monitoring Requirements (>0.5 - 1.0 mgd Design Flow)				
Parameter	Unit	Sample Location	Sample Frequency	Sample Type
Flow	mgd	Effluent	continuous	recording
BOD ₅	mg/L	Influent and Effluent	1/month	8-hour composite
	lbs/day	Influent and Effluent	1/month	calculation ¹
	% Removal	--	–	calculation ²
TSS	mg/L	Influent and Effluent	1/month	8-hour composite
	lbs/day	Influent and Effluent	1/month	calculation ¹
	% Removal	--	–	calculation ²
pH	standard units	Effluent	5/week	grab
E. coli Bacteria	colonies/100 ml	Effluent	5/month	grab
Temperature ^{3, 4}	°C	Effluent	5/week	grab
Chlorine ⁵	mg/L	Effluent	5/week	grab
Total Ammonia as N ³	mg/L	Effluent	1/month	8-hour composite
Total Phosphorus as P ^{3,4}	mg/L	Effluent	1/month	8-hour composite
Dissolved Oxygen ^{3,4}	mg/L	Effluent	5/month	grab
<p>Notes:</p> <ol style="list-style-type: none"> 1 Maximum daily loading is calculated by multiplying the concentration in mg/L by the average daily flow in mgd and a conversion factor of 8.34. 2 Percent removal is calculated using the following equation: (influent - effluent) ÷ influent. 3 Monitoring is required for one year of permit of only. 4 Monitoring is required only if the receiving water is water quality limited for the parameter. 5 Applies only to those facilities that chlorinate. 				

Table 2b: Effluent Monitoring Requirements (>0.1 - 0.5 mgd Design Flow)				
Parameter	Unit	Sample Location	Sample Frequency	Sample Type
Flow	mgd	Effluent	1/week ¹	measure ¹
BOD ₅	mg/L	Influent and Effluent	1/month	8-hour composite
	lbs/day	Influent and Effluent	1/month	calculation ²
	% Removal	--	–	calculation ³
TSS	mg/L	Influent and Effluent	1/month	8-hour composite
	lbs/day	Influent and Effluent	1/month	calculation ²
	% Removal	--	–	calculation ³
pH	standard units	Effluent	1/week	grab
E. coli Bacteria	colonies/100 ml	Effluent	5/month	grab
Temperature ^{4, 5}	°C	Effluent	5/month	grab
Chlorine ⁶	mg/L	Effluent	1/ week	grab
Total Ammonia as N ⁴	mg/L	Effluent	1/month	8-hour composite
Total Phosphorus as P ^{4,5}	mg/L	Effluent	1/month	8-hour composite
Dissolved Oxygen ^{4,5}	mg/L	Effluent	5/month	grab
<p>Notes:</p> <ol style="list-style-type: none"> 1 If the current permit for a facility requires that the permittee monitor flow using a continuous recording, or requires a different monitoring frequency this permit provision is retained in the draft permit. 2 Maximum daily loading is calculated by multiplying the concentration in mg/L by the average daily flow and a conversion factor of 8.34. 3 Percent removal is calculated using the following equation: (influent - effluent) ÷ influent. 4 Monitoring is required for one year of permit of only. 5 Monitoring is required only if the receiving water is water quality limited for the parameter. 6 Applies only to those facilities that chlorinate. 				

Table 2c: Effluent Monitoring Requirements (up to 0.1 mgd Design Flow)				
Parameter	Unit	Sample Location	Sample Frequency	Sample Type
Flow	mgd	Effluent	1/week ¹	measure ¹
BOD ₅	mg/L	Influent and Effluent	1/month	grab
	lbs/day	Influent and Effluent	1/month	calculation ²
	% Removal	--	--	calculation ³
TSS	mg/L	Influent and Effluent	1/month	grab
	lbs/day	Influent and Effluent	1/month	calculation ²
	% Removal	--	--	calculation ³
pH	standard units	Effluent	1/week	grab
E. coli Bacteria	colonies/100 ml	Effluent	5/month	grab
Temperature ^{4,5}	°C	Effluent	1/week	grab
Chlorine ⁶	mg/L	Effluent	1/week	grab
Total Ammonia as N ⁴	mg/L	Effluent	1/month	grab
Total Phosphorus as P ^{4,5}	mg/L	Effluent	1/month	grab
Dissolved Oxygen ^{4,5}	mg/L	Effluent	5/month	grab
<p>Notes:</p> <ol style="list-style-type: none"> 1 If the current permit for a facility requires that the permittee monitor flow using a continuous recording, or requires a different monitoring frequency, this permit provision is retained in the draft permit. 2 Maximum daily loading is calculated by multiplying the concentration in mg/L by the average daily flow and a conversion factor of 8.34. 3 Percent removal is calculated using the following equation: (influent - effluent) ÷ influent. 4 Monitoring is required for one year of permit of only. 5 Monitoring is required only if the receiving water is water quality limited for the parameter. 6 Applies only to those facilities that chlorinate. 				

C. Surface Water Monitoring

Table 3 presents the proposed surface water monitoring requirements for the draft permits. The permittees should work with the IDEQ Regional Office to establish the appropriate upstream monitoring location.

Table 3: Surface Water Monitoring Requirements			
Parameter	Sample Location	Sample Frequency²	Sample Type
Ammonia, mg/L	Upstream of treatment plant outfall	1/ quarter	grab
pH, standard units	Upstream of treatment plant outfall	1/quarter	grab
Temperature, °C	Upstream of treatment plant outfall	1/quarter	grab
Total Phosphorus as P ¹	Upstream of treatment plant outfall	1/quarter	grab
Dissolved Oxygen ¹	Upstream of treatment plant outfall	1/quarter	grab
Notes: 1 Monitoring is required only if the receiving water is water quality limited for the parameter. 2 The sampling frequency may be adjusted in the draft permit if the facility discharges intermittently.			

VI. SLUDGE (BIOSOLIDS) REQUIREMENTS

EPA Region 10 separates wastewater and sludge permitting. Under the CWA, EPA has the authority to issue separate sludge-only permits for the purposes of regulating biosolids. EPA may issue a sludge-only permit to each facility at a later date, as appropriate.

Until future issuance of a sludge-only permit, sludge management and disposal activities at each facility continue to be subject to the national sewage sludge standards at 40 CFR Part 503 and any requirements of the State's biosolids program. The Part 503 regulations are self-implementing, which means that permittees must comply with them whether or not a permit has been issued.

VII. OTHER PERMIT CONDITIONS

A. Quality Assurance Plan

The federal regulation at 40 CFR 122.41(e) requires the permittee to develop procedures to ensure that the monitoring data submitted is accurate and to explain data anomalies if they occur. The permittees are required to develop and implement a Quality Assurance Plan within 180 days of the effective date of the final permit. The Quality Assurance Plan shall consist of standard operating procedures the permittee must follow for collecting, handling, storing and shipping samples, laboratory analysis, and data reporting.

B. Operation and Maintenance Plan

The permits require the Permittee to properly operate and maintain all facilities and systems of treatment and control. Proper operation and maintenance is essential to meeting discharge limits, monitoring requirements, and all other permit requirements at all times. Each Permittee is required to develop and implement an operation and maintenance plan for their facility within 180 days of the effective date of the final permit. The plan shall be retained on site and made available to EPA and IDEQ upon request.

C. Additional Permit Provisions

Sections II, III, and IV of the draft permits contain standard regulatory language that must be included in all NPDES permits. Because they are regulations, they cannot be challenged in the context of an NPDES permit action. The standard regulatory language covers requirements such as monitoring, recording, reporting requirements, compliance responsibilities, and other general requirements.

VIII. OTHER LEGAL REQUIREMENTS

A. Endangered Species Act

The Endangered Species Act requires federal agencies to consult with the National Marine Fisheries Service (NMFS) and the U.S. Fish and Wildlife Service (USFWS) if their actions could beneficially or adversely affect any threatened or endangered species. Biological evaluations (BEs) analyzing the effects of the discharge from the treatment facilities on listed endangered and threatened species in the vicinity of the facilities were prepared. The BEs are available upon request. The BEs determined that issuance of these permits will not affect any of the threatened or endangered species in the vicinity of the discharges.

B. Essential Fish Habitat

Essential fish habitat (EFH) is the waters and substrate (sediments, etc.) necessary for fish to spawn, breed, feed, or grow to maturity. The Magnuson-Stevens Fishery Conservation and Management Act (January 21, 1999) requires EPA to consult with the National Marine Fisheries Service (NMFS) when a proposed discharge has the potential to adversely affect (reduce quality and/or quantity of) EFH. The EPA has tentatively determined that the issuance of these permits will not affect any EFH species in the vicinity of the discharges, therefore consultation is not required for this action.

C. State/Tribal Certification

Section 401 of the CWA requires EPA to seek State/Tribal certification before issuing a final permit. As a result of the certification, the State/Tribe may require more stringent permit conditions or additional monitoring requirements to ensure that the permit complies with water quality standards.

Some of the facilities discharge to Tribal waters for which the Tribe has not yet adopted water quality standards. In this case, the provisions of Section 401 of the CWA requiring State/Tribe certification of the permit do not apply. The EPA will conduct the 401 certification of these permits.

D. Permit Expiration

The permits will expire five years from the effective date of the permits.

Appendix A - Facility Information

Slate Creek Ranger Station

NPDES ID Number: ID 002073-7

Facility Location: U.S. Highway 95, mile marker 214
Slate Creek, Idaho

Mailing Address: H C01, Box 70
White Bird, Idaho 83554

Facility Background: The facility is owned and operated by the U.S. Forest Service. The facility's existing permit became effective February 15, 1974. The current permit application was received on August 27, 2001.

Collection System Information

Service Area: The Slate Creek Ranger Station is an administrative site for district personnel year-around, and a summer camp for forest fire fighters.

Service Area Population: Varies 50 - 150

Collection System Type: 100% separated sanitary sewer

Facility Information

Treatment Train: Lagoon and chlorination

Design Flow: 0.012 mgd

Existing Flow: 400 gpd (average daily)

Outfall Location: latitude 45° 38' 14" N; longitude 116° 16' 59" W

Receiving Water Information

Receiving Water: Salmon River near confluence with Slate Creek

Beneficial Uses: cold water communities, primary contact recreation, special resource water, drinking water supply

Water Quality Limited Segment: Not listed

Low Receiving Water Flow: 1,894 cfs 1Q10
2,311 cfs 7Q10

Additional Notes

Basis for BOD₅/TSS Limits: Monitoring data show facility can meet secondary treatment concentration limits. No data exist for BOD₅ and TSS percent removal.

Fenn Ranger Station	
NPDES ID Number:	ID 002071-1
Facility Location:	Moose Creek Ranger District HC 75 Box 91 Kooskia, ID 83539
Mailing Address:	Star Route Kooskia, Idaho 83539
Facility Background:	The facility is owned and operated by the U.S. Forest Service. The facility's existing permit became effective February 15, 1974. The current permit application was received on August 23, 2001.
<u>Collection System Information</u>	
Service Area:	Forest Service trailer court.
Service Area Population:	50
Collection System Type:	90% separated sanitary sewer; 10% storm sewer
<u>Facility Information</u>	
Treatment Train:	Oxidation ditch, clarifier and chlorination
Design Flow:	0.02 mgd
Existing Flow:	0.006 mgd (average daily)
Outfall Location:	latitude 46° 5' 41" N; longitude 115° 32' 27" W
<u>Receiving Water Information</u>	
Receiving Water:	Selway River
Beneficial Uses:	cold water communities, salmonid spawning, primary contact recreation, special resource water, drinking water supply
Water Quality Limited Segment:	Not listed
Low Receiving Water Flow:	120 cfs 1Q10 169 cfs 7Q10
<u>Additional Notes</u>	
Basis for BOD ₅ /TSS Limits:	Principal treatment process is not a trickling filter or waste stabilization pond, therefore secondary treatment limits required.

Ahsahka Water and Sewer District

NPDES ID Number: ID 002522-4
Facility Location: East Portion of Dworshak National Fish Hatchery
Located within the Nez Perce Indian Reservation
Mailing Address: P.O. Box 37
Ahsahka, ID 83520
Permit Background: The District's existing permit became effective September 5, 1989. The current permit application was received on June 18, 2001.

Collection System Information

Service Area: Residents of Ahsahka, the Dworshak National Fish Hatchery, and the powerhouse and visitor's center at Dworshak Dam
Service Area Population: 150
Collection System Type: 100% separated sanitary sewer

Facility Information

Treatment Train: Imhoff Tank, Oxidation ditch, clarifier, and chlorination
Design Flow: 0.075 mgd
Existing Flow: 0.012 mgd (average daily)
0.026 (maximum daily)
Outfall Location: latitude 46° 30' 3" N; longitude 116° 19' 11" W

Receiving Water Information

Receiving Water: Clearwater River at river mile 40.4, just upstream of confluence with North Fork of Clearwater River
Subbasin: Clearwater Subbasin (HUC 1706306)
Beneficial Uses: cold water communities, salmonid spawning, primary contact recreation, special resource water, drinking water supply
Water Quality Limited Segment: Clearwater River (from North Fork to Washington State line) is listed for total dissolved gas
Low Receiving Water Flow: 478 cfs 1Q10
555 cfs 7Q10

Additional Notes

Discharge Location: The facility discharges to tribal waters
Basis for BOD₅/TSS Limits: Principal treatment process is not a trickling filter or waste stabilization pond, therefore secondary treatment limits required.

City of Cascade

NPDES ID Number: ID 002316-7
Facility Location: 880 South Main
Cascade, ID 83611
Mailing Address: P.O. Box 649
Cascade, ID 83611
Facility Background: The facility is owned and operated by the City of Cascade.
The facility's existing permit became effective March 24, 1986.
The current permit application was received on June 25, 2001.

Collection System Information

Service Area: City of Cascade
Service Area Population: 1000
Collection System Type: 100% separated sanitary sewer

Facility Information

Treatment Train: Lagoon and disinfection through soil column
Design Flow: 0.72 mgd
Existing Flow: 0.119 mgd (average daily)
Outfall Location: latitude 44° 28' 40" N; longitude 116° 00' 58" W
Land Application: The facility land applies its effluent. It has discharged to the North Fork Payette River only once in the last five years

Receiving Water Information

Receiving Water: North Fork Payette River (river mile 38)
Beneficial Uses: cold water communities, primary contact recreation, special resource water, drinking water supply, salmonid spawning
Water Quality Limited Segment: This segment is not listed, however, approximately 4 miles downstream the river is listed for nutrients, sediment, temperature, flow, and habitat alteration

Additional Notes

Basis for BOD₅/TSS Limits: Secondary treatment limits required since no existing data were available to evaluate existing treatment plant efficiency.

Clarkia Water and Sewer District

NPDES ID Number: ID 002507-1
Mailing Address: P.O. Box 1096
Clarkia, Idaho 83812
Facility Background: The facility's existing permit became effective September 28, 1989. The current permit application was received on August 10, 2001.

Collection System Information

Service Area: City of Clarkia
Service Area Population: 75
Collection System Type: 100% separated sanitary sewer

Facility Information

Treatment Train: The effluent from individual septic tanks is sent to the treatment plant. The treatment plant includes sand filtration and chlorination
Design Flow: 0.018 mgd
Existing Flow: 0.016 mgd (average daily)
0.029 mgd (maximum daily)
Outfall Location: latitude 47° 0' 16" N; longitude 116° 15' 28" W

Receiving Water Information

Receiving Water: St. Maries River
Subbasin: St. Joe Subbasin (HUC 17010304)
Beneficial Uses: cold water aquatic life and primary contact
Water Quality Limited Segment: St. Maries (from Clarkia to Mashburn) is listed as water quality limited but no specific chemical parameters have been identified.
Low Receiving Water Flow: 29 cfs 1Q10
33 cfs 7Q10

Additional Notes

Basis for BOD₅/TSS Limits: Monitoring data show facility can meet secondary treatment concentration limits. Because the influent to the treatment plant is the effluent from individual septic tanks, most of BOD₅ and TSS reduction in the wastestream occurs prior to reaching the treatment plant. Therefore, the draft permit does not require 85% BOD₅ and TSS removal.

City of Fairfield

NPDES ID Number: ID 002438-4
Mailing Address: P.O. Box 336
Fairfield, Idaho 83327
Facility Address: 407 Soldier Road
Fairfield, Idaho 83327
Facility Background: The facility's existing permit for discharge became effective September 30, 1987. The current permit application was received January 29, 2002.

Collection System Information

Service Area: City of Fairfield
Service Area Population: 395
Collection System Type: 100% separated sanitary sewer

Facility Information

Treatment Train: Lagoons and rapid infiltration basin
Design Flow: 0.165 mgd
Months in which discharge occurs: March - May
Outfall Location: latitude 43° 15' 00" N; longitude 114° 45' 00" W

Receiving Water Information

Receiving Water: Unknown drainage ditch which joins Soldier Creek approximately 2 miles downstream. Before 1988, flow from the drainage ditch reached Soldier Creek. Since 1988, the ditch dries up before reaching Soldier Creek.
Basin: Upper Snake River Basin (HUC 17040220)
Beneficial Uses: cold water communities, salmonid spawning, primary contact recreation
Water Quality Limited Segment: Soldier Creek is listed for bacteria, dissolved oxygen, flow, nutrients, and sediment.

Additional Notes

Discharge Requirements: The draft permit requires monitoring during each month that the facility is discharging and water in the drainage ditch is expected to reach Soldier Creek. At a minimum, the facility must month each year during the month of April.
Basis for BOD₅/TSS Limits: Secondary treatment limits required since no existing data were available to evaluate existing treatment plant efficiency.

City of Glens Ferry	
NPDES ID Number:	ID 002200-4
Mailing Address:	P.O. Box 910 Glens Ferry, Idaho 83623
Facility Address:	901 South Martell Drive Glens Ferry, Idaho 83623
Facility Background:	The facility's existing permit for discharge became effective May 21, 1986. The current permit application was received June 27, 2001.
<u>Collection System Information</u>	
Service Area:	City of Glens Ferry
Service Area Population:	1600
Collection System Type:	100% separated sanitary sewer
<u>Facility Information</u>	
Treatment Train:	Lagoons and rapid infiltration basin
Design Flow:	0.5 mgd
Existing flow:	0.35 mgd (annual average) 0.56 mgd (maximum daily)
Months in which discharge occurs:	year round
Outfall Location:	latitude 42° 56' 38" N; longitude 115° 18' 28" W
<u>Receiving Water Information</u>	
Receiving Water:	Snake River
Beneficial Uses:	cold water communities, primary contact recreation, drinking water, special resource water
Water Quality Limited Segment:	This segment of the Snake River is listed for sediment.
<u>Additional Notes</u>	
Basis for BOD ₅ /TSS Limits:	Monitoring data show facility can meet secondary treatment concentration limits and 85% BOD ₅ removal. No data exist for TSS percent removal.

City of Grace

Facility: City of Grace WWTP
NPDES ID Number: ID 002382-5
Facility Location: 385 North 5th Street
Grace, ID 83241
Mailing Address: P.O. Box 288
Grace, ID 83241
Background: The City's existing permit was issued on September 28, 1989.
The current permit application was received on June 28, 2001.

Collection System Information

Service Area Population: 990
Collection System Type: 100% separated sanitary sewer

Facility Information

Treatment Train: Oxidation ditch, chlorination, treated effluent is pumped to Bear Creek Reservoir.
Design Flow: 0.435 mgd
Existing Flow: 0.05 mgd (max daily)
Outfall Location: Not available

Receiving Water Information

Receiving Water: Grace Dam Impoundment on Bear River Reservoir
Beneficial Uses: cold water biota, primary contact recreation
Water Quality Limited Segment: The reservoir is listed as water quality limited segment for nutrients and sediment.
Low Receiving Water Flow: 200 cfs 1Q10 and 7Q10
(Based on lowest flow to Grace Dam Impoundment)

Additional Notes

Basis for BOD₅/TSS Limits: Principal treatment process is not a trickling filter or waste stabilization pond, therefore secondary treatment limits required.

City of Horseshoe Bend

NPDES ID Number: ID 002102-4

Mailing Address: P.O. Box 246
Horseshoe Bend, Idaho 83629

Facility Address: 112 Ada Street
Horseshoe Bend, Idaho 83629

Facility Background: The effluent from the existing facility is currently discharged to a sand filtration area adjacent to the Payette River. Because of permit violations and operational problems, the City is in the process of upgrading the treatment plant. The upgraded facility, scheduled to be on-line in 2004, will resume discharge to the Payette River.

Collection System Information

Service Area: City of Horseshoe Bend

Service Area Population: 702

Collection System Type: 100% separated sanitary sewer

Facility Information - Upgraded Facility - Scheduled to be On-Line in 2004

Treatment Train: Screens, Lagoons and UV Disinfection

Design Flow: 0.2 mgd (average daily); 0.5 mgd (maximum daily)

Existing Flow: 0.07 mgd (average daily); 0.09 mgd (maximum daily)

Outfall Location: latitude 43° 54' 49" N; longitude 116° 11' 44" W

Receiving Water Information

Receiving Water: Payette River

Subbasin: Payette Subbasin (HUC 17050122)

Beneficial Uses: cold water communities, salmonid spawning, primary contact recreation, special resource water, drinking water supply

Water Quality Limited Segment: Black Canyon reservoir, a few miles downstream of Horseshoe Bend, is listed for bacteria, nutrients, and turbidity. The segment to which the treatment plant discharges is not listed.

Low Receiving Water Flow: 468 cfs 1Q10; 571 cfs 7Q10

Additional Notes

Basis for BOD₅/TSS Limits: Secondary treatment limits required since no data available on upgraded treatment facility to evaluate treatment plant efficiency.

City of Orofino

Facility: City of Orofino Wastewater Treatment Plant
NPDES ID Number: ID 002015-0
Facility Location: 10200 Highway 12
Orofino, ID 83544-312
Mailing Address: P.O. Box 312
Orofino, ID 83544-312
Background: The City's existing permit became effective on January 31, 1992. The current permit application was received on June 4, 2001.

Collection System Information

Service Area: City of Orofino and Orofino/Whiskey Creek District
Service Area Population: 2,885
Collection System Type: 100% separated sanitary sewer

Facility Information

Treatment Train: coarse screening, grit removal, oxidation ditch, clarifiers, gas chlorination
Design Flow: 0.88 mgd
Existing Flow: 0.5 mgd (average daily)
1.4 mgd (maximum daily)
Outfall Location: latitude 46° 29' 14" N; longitude 116° 15' 59" W

Receiving Water Information

Receiving Water: Clearwater River just upstream of the confluence with the North Fork of the Clearwater River
Subbasin: Clearwater Subbasin (HUC 17060306)
Beneficial Uses: cold water communities, salmonid spawning, primary contact recreation, special resource water, drinking water supply
Water Quality Limited Segment: Downstream of discharge, Clear Water River (North Fork to Washington State line) is listed for total dissolved gas.
Low Receiving Water Flow: 717 cfs 1Q10; 874 cfs 7Q10

Additional Notes

Discharge Location: The facility discharges to tribal waters
Basis for BOD₅/TSS Limits: Principal treatment process is not a trickling filter or waste stabilization pond, therefore secondary treatment limits required.

City of Riggins

Facility: City of Riggins Wastewater Treatment Plant
NPDES ID Number: ID 002093-1
Facility Location: P.O. Box 249
Riggins, ID 83549
Mailing Address: 1210 N
Riggins, ID 83549
Background: The City's existing permit became effective on June 27, 1985. The current permit application was received on December 3, 2001.

Collection System Information

Service Area: City of Riggins
Service Area Population: 435
Collection System Type: 100% separated sanitary sewer

Facility Information

Treatment Train: activated sludge, secondary clarification, and chlorination
Design Flow: 0.105 mgd
Existing Flow: 0.04 mgd (average daily)
0.09 mgd (maximum daily)
Outfall Location: latitude 45° 25' 58" N; longitude 116° 18' 41" W

Receiving Water Information

Receiving Water: Salmon River downstream of the confluence to the Little Salmon River
Subbasin: Salmon Subbasin (HUC 17060209)
Beneficial Uses: cold water communities, primary contact recreation, special resource water, drinking water supply
Water Quality Limited Segment: Not listed
Low Receiving Water Flow: 1,894 cfs 1Q10
2,311 cfs 7Q10

Additional Notes

Basis for BOD₅/TSS Limits: Monitoring data show facility can meet secondary treatment concentration and percent removal limits. Principal treatment process is not a trickling filter or waste stabilization pond, therefore secondary treatment limits required.

City of Ririe	
NPDES ID Number:	ID 002617-4
Facility Location:	300 Ririe Street Ririe, Idaho 83443
Mailing Address:	P.O. Box 68 Ririe, Idaho 83443
Facility Background:	The facility is owned and operated by the City of Ririe. The facility's existing permit became effective September 24, 1987. The current permit application was received on July 9, 2001.
<u>Collection System Information</u>	
Service Area:	City of Ririe
Service Area Population:	560
Collection System Type:	combined sewer system
<u>Facility Information</u>	
Treatment Train:	Lagoon and UV disinfection
Design Flow:	0.1 mgd
Existing Flow:	currently not discharging
Outfall Location:	unknown
<u>Receiving Water Information</u>	
Receiving Water:	Dry Bed Canal/Enterprise Canal
Beneficial Uses:	cold water communities, primary contact recreation
Water Quality Limited Segment:	this segment is not listed
<u>Additional Notes</u>	
Discharge Requirements:	The current permit includes the following requirements: <ul style="list-style-type: none"> • discharge to Dry Bed Canal from November 1 through April 30, • discharge to Enterprise Canal from May 1 through October 31. • A discharge to the canal is allowed only when there is a minimum flow of 10 cfs in the canal. These requirements have been retained in the proposed permit.
Basis for BOD ₅ /TSS Limits:	Secondary treatment limits required since no existing data were available to evaluate existing treatment plant efficiency.

City of Worley	
NPDES ID Number:	ID 002271-3

Facility Location: S 29401 B. Street
Worley, Idaho 83876

Mailing Address: P.O. Box 219
Worley, Idaho 83876

Facility Background: The facility's existing permit became effective September 28, 1987. The current permit application was received on August 24, 2001

Collection System Information

Service Area: City of Worley

Service Area Population: 500

Collection System Type: 100% separated sanitary sewer

Facility Information

Treatment Train: Aerated lagoon system and chlorination.

Design Flow: 0.57 mgd

Existing Flow: 0.047 (average daily)

Months when discharge occurs: January through April

Outfall Location: unknown

Receiving Water Information

Receiving Water: Rock Creek

Subbasin: Hangman (HUC 17010306)

Beneficial Uses: secondary contact recreation

Water Quality Limited Segment: This creek is not listed as water quality limited

Additional Notes

Discharge requirements: The current permit does not allow a discharge when the dilution ratio is less than 10:1. This condition has been retained in the proposed permit. The proposed permit only allows a discharge January through April.

Discharge Location: The facility discharges to tribal waters

Basis for BOD₅/TSS Limits: Draft permit retains secondary treatment requirements from existing permit. Monitoring data show facility can meet secondary treatment concentration limits. No data exist for TSS percent removal.

Appendix B - Basis for Effluent Limitations

The Clean Water Act (CWA) requires Publicly Owned Treatment Works (POTW) to meet effluent limits based on available wastewater treatment technology. These types of effluent limits are called secondary treatment effluent limits. EPA may find, by analyzing the effect of an effluent discharge on the receiving water, that secondary treatment effluent limits are not sufficiently stringent to meet water quality standards. In such cases, EPA is required to develop more stringent water quality-based effluent limits which are designed to ensure that the water quality standards of the receiving water are met.

Secondary treatment effluent limits may not limit every parameter that is in an effluent. For example, secondary treatment effluent limits for POTWs have only been developed for five-day biochemical oxygen demand (BOD₅), total suspended solids (TSS), and pH, yet effluent from a POTW may contain other pollutants such as bacteria, chlorine, ammonia, or metals depending on the type of treatment system used and the service area of the POTW (i.e., industrial facilities as well as residential areas discharge into the POTW). When technology based effluent limits do not exist for a particular pollutant expected to be in the effluent, EPA must determine if the pollutant may cause or contribute to an exceedance of the water quality standards for the water body. If a pollutant causes or contributes to an exceedance of a water quality standard, water quality-based effluent limits for the pollutant must be incorporated into the permit.

The following discussion explains in more detail the derivation of technology based effluent limits, and water quality based effluent limits. Part A discusses technology based effluent limits, Part B discusses water quality based effluent limits, and Part C discusses facility specific limits.

A. Technology Based Effluent Limits

1. BOD₅, TSS and pH

Secondary Treatment

The CWA requires POTWs to meet performance-based requirements based on available wastewater treatment technology. Section 301 of the CWA established a required performance level, referred to as “secondary treatment,” that all POTWs were required to meet by July 1, 1977. EPA developed “secondary treatment” regulations which are specified in the 40 CFR 133. These technology-based effluent limits apply to all municipal wastewater treatment plants, and identify the minimum level of effluent quality attainable by secondary treatment in terms of BOD₅, TSS, and pH. The secondary treatment effluent limits are listed in Table B-1.

Table B-1: Secondary Treatment Effluent Limits			
Parameter	Average Monthly Limit	Average Weekly Limit	Range
BOD ₅	30 mg/L	45 mg/L	---
TSS	30 mg/L	45 mg/L	---
Removal Rates for BOD ₅ and TSS	85%	---	---
pH	---	---	6.0 - 9.0 s.u.

Treatment Equivalent to Secondary

The regulations include special considerations, referred to as “treatment equivalent to secondary”, for waste stabilization ponds and trickling filters. The regulations allow alternative limits for BOD₅ and TSS for facilities using trickling filters or waste stabilization ponds provided the following requirements are met (40 CFR 133.101(g), and 40 CFR 133.105(d)):

- The BOD₅ and TSS effluent concentrations consistently achievable through proper operation and maintenance of the treatment works exceed the minimum level of the effluent quality described above (Secondary Treatment Effluent Limits).
- A trickling filter or waste stabilization pond is used as the principal treatment process.
- The treatment works provide significant biological treatment of municipal wastewater (i.e., a minimum of 65% reduction of BOD₅ is consistently attained).

Reduced Percent Removal Requirements for Less Concentrated Influent Wastewater

In accordance with 40 CFR § 133.103 (d), treatment works that receive less concentrated wastes from separate sewer systems can qualify to have their percent removal limits reduced provided that all of the following conditions are met:

- The facility can consistently meet its permit effluent concentration limits but cannot meet its percent removal limits because of less concentrated influent water
- The facility would have been required to meet significantly more stringent limitations than would otherwise be required by the concentration-based standards and
- The less concentrated effluent is not the result of excessive inflow/infiltration (I/I).

Draft Permit Limits

The past five years of monitoring data for each of the facilities were examined to determine if any considerations were necessary in designating effluent limits for BOD₅ and TSS (such as treatment equivalent to secondary limits or reduced percent removal requirements).

All of the permits require secondary treatment effluent limits for BOD₅ and TSS. In most cases, the data review revealed that the facility could consistently achieve secondary treatment limits, and therefore no considerations for “treatment equivalent to secondary” or “less concentrated influent wastewater” were necessary.

In some cases, there were no existing data available to assess the efficiency of the wastewater treatment plant, this was particularly the case for TSS percent removal. With no data to evaluate, the permit requires secondary treatment limits.

2. Chlorine

A technology-based average monthly chlorine effluent limitation of 0.5 mg/L for wastewater treatment plants is derived from standard operating practices. The Water Pollution Control Federation's Chlorination of Wastewater (1976) states that a properly designed and maintained wastewater treatment plant can achieve adequate disinfection if a 0.5 mg/L chlorine residual is maintained after 15 minutes of contact time. A treatment plant that provides adequate chlorination contact time can meet the 0.5 mg/L limit on a monthly average basis. In addition to average monthly limits (AMLs), NPDES regulations require effluent limits for POTWs to be expressed as average weekly limits (AWLs) unless impracticable. The AWL is derived as 1.5 times the AML, resulting in an AWL for chlorine of 0.75 mg/L.

3. Mass-based Limits

The federal regulation at 40 CFR § 122.45 (f) require BOD₅, TSS, and chlorine limitations to be expressed as mass based limits using the design flow of the facility. The mass based limits are expressed in lbs/day and are calculated as follows:

Mass based limit (lbs/day) = concentration limit (mg/L) x design flow (mgd) x 8.34

B. Water Quality-Based Effluent Limits

The following discussion is divided into four sections. Section 1 discusses the statutory basis for including water quality based effluent limits in NPDES permits, section 2 discusses the procedures used to determine if water quality based effluent limits are needed in an NPDES permit, section 3 discusses the procedures used to develop water quality based effluent limits, and section 4 discusses the specific water quality based limits.

1. Statutory Basis for Water Quality-Based Limits

Section 301(b)(1)(C) of the CWA requires the development of limitations in permits necessary to meet water quality standards by July 1, 1977. Discharges to state/tribal waters must also comply with limitations imposed by the state/tribe as part of its certification of NPDES permits under section 401 of the CWA.

The NPDES regulation (40 CFR 122.44(d)(1)) implementing section 301 (b)(1)(C) of the CWA requires that permits include limits for all pollutants or parameters which are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any state/tribal water quality standard, including state/tribal narrative criteria for water quality.

The regulations require that this evaluation be made using procedures which account for existing controls on point and nonpoint sources of pollution, the variability of the pollutant in the effluent, species sensitivity (for toxicity), and where appropriate, dilution in the receiving water. The limits must be stringent enough to ensure that water quality standards are met, and must be consistent with any available wasteload allocation.

2. Reasonable Potential Analysis

When evaluating the effluent to determine if water quality-based effluent limits are needed based on chemical specific numeric criteria, a projection of the receiving water concentration (downstream of where the effluent enters the receiving water) for each pollutant of concern is made. The chemical specific concentration of the effluent and receiving water and, if appropriate, the dilution available from the receiving water are factors used to project the receiving water concentration. If the projected concentration of the receiving water exceeds the numeric criterion for a specific chemical, then there is a reasonable potential that the discharge may cause or contribute to an excursion above the applicable water quality standard, and a water quality-based effluent limit is required.

Sometimes it is appropriate to allow a small area of receiving water to provide dilution of the effluent, these areas are called mixing zones. Mixing zone allowances will increase the mass loadings of the pollutant to the water body, and

decrease treatment requirements. Mixing zones can be used only when there is adequate receiving water flow volume and the receiving water is below the chemical specific numeric criterion necessary to protect the designated uses of the water body. Mixing zones must be authorized by the Idaho Department of Environmental Quality.

3. Procedure for Deriving Water Quality-Based Effluent Limits

The first step in developing a water quality based permit limit is to develop a wasteload allocation (WLA) for the pollutant. A wasteload allocation is the concentration or loading of a pollutant that the permittee may discharge without causing or contributing to an exceedance of water quality standards in the receiving water.

In cases where a mixing zone is not authorized, either because the receiving water already exceeds the criterion, the receiving water flow is too low to provide dilution, or the state/tribe does not authorize one, the criterion becomes the WLA. Establishing the criterion as the wasteload allocation ensures that the permittee will not contribute to an exceedance of the criterion. The wasteload allocations have been determined for pH and E. coli bacteria in this way because the state/tribe does not generally authorize mixing zones for these pollutants. For these particular parameters, the wasteload allocation translates directly into the effluent limit without any statistical conversion.

4. Specific Water Quality-Based Effluent Limits

(a) Toxic Substances

The Idaho Water Quality Standards require surface waters of the state to be free from toxic substances in concentrations that impair designated uses. Because there are no significant industrial discharges to the facilities, and concentrations of priority pollutants from cities without a significant industrial component are low, it is anticipated that toxicity will not be a problem in the facility discharges. Therefore, water quality-based effluent limits have not been proposed for the draft permits.

(b) Floating, Suspended or Submerged Matter/Oil and Grease

The Idaho Water Quality Standards require surface waters of the state to be free from floating, suspended, or submerged matter of any kind in concentrations causing nuisance or objectionable conditions that may impair designated beneficial uses. A narrative condition is proposed for the draft permits that states there must be no discharge of floating solids or visible foam or oil and grease other than trace amounts.

(c) Excess Nutrients/Phosphorus

The Idaho Water Quality Standards require surface waters of the state be free from excess nutrients that can cause visible slime growths or other nuisance aquatic growths impairing designated beneficial uses.

If a facility discharges to a receiving water listed as water quality limited for nutrients, and a TMDL has not been developed, the draft permit requires effluent and receiving water monitoring for phosphorus. However, if a nutrient wasteload allocation from an EPA approved TMDL is available then it is incorporated into the draft permit.

(d) Sediment/Total Suspended Solids (TSS)

The draft permits include technology-based limits for TSS. If a facility discharges to a receiving water listed as water quality limited for sediment, the sediment wasteload allocation from the TMDL (if approved by the EPA) is incorporated into the draft permit limits.

(e) pH

The Idaho Water Quality Standards require surface waters of the state to have a pH value within the range of 6.5 - 9.5 standard units. It is anticipated that mixing zones will not be authorized for the water quality-based criterion for pH. Therefore, this criterion must be met before the effluent is discharged to the receiving water. The technology-based effluent limits for pH are 6.0 - 9.0 standard units. These limits must be met before the effluent is discharged to the receiving water. To ensure that both water quality-based requirements and technology-based requirements are met, the draft permits incorporate the lower range of the water quality standards (6.5 standard units) and the upper range of the technology-based limits (9.0 standard units).

(f) Dissolved Oxygen (DO)

The Idaho Water Quality Standards require the level of DO to exceed 6 mg/L at all times for water bodies that are protected for aquatic life use. Further, during salmonid spawning and incubation periods, the one day minimum intergravel DO must exceed 5 mg/L and the seven day average intergravel DO must exceed 6 mg/L.

If a facility discharges to a receiving water listed as water quality limited for DO, and a TMDL has not been developed, the draft permit requires effluent and receiving water monitoring for DO. However, if a DO wasteload allocation from an EPA approved TMDL is available then it is

incorporated into the draft permit.

(g) Temperature

The Idaho Water Quality Standards require ambient water temperatures of 22°C or less with a maximum daily average of no greater than 19°C for cold water biota protection. Further, water temperatures of 13°C or less with a maximum daily average not greater than 9°C are required for salmonid spawning use during the spawning and incubation periods.

If a facility discharges to a receiving water listed as water quality limited for temperature, and a TMDL has not been developed, the draft permit requires effluent and receiving water monitoring for temperature. However, if a temperature wasteload allocation from an EPA approved TMDL is available then it is incorporated into the draft permit.

(h) Ammonia

The Idaho Water Quality Standards contain water quality criteria to protect aquatic life, including salmonids, against short term and long term adverse impacts from ammonia. Currently, there are no ammonia data for the facilities to determine if ammonia may cause or contribute to a water quality standard violation. Since the data are not available to determine if water quality-based effluent limits are required for ammonia, the draft permits do not propose effluent limits for ammonia. However, the draft permits require monthly sampling for ammonia during one year of the permit. These data will be used to determine if an ammonia limit is needed for the discharge for the next permit.

(i) Escherichia Coli (E. Coli) Bacteria

According to the Idaho Water Quality Standards, waters designated for primary contact recreation are not to contain E. coli bacteria significant to the public health in concentrations exceeding:

- a. A single sample of four hundred and six E. coli organisms per one hundred ml; or
- b. A geometric mean of one hundred and twenty six E. coli organisms per one hundred ml based on a minimum of five samples taken, every three to five days, over a thirty day period.

Waters that are designated for secondary contact recreation are not to contain E. coli bacteria significant to the public health in concentrations exceeding:

- a. A single sample of five hundred and seventy six E. coli organisms per one hundred ml; or
- b. A geometric mean of one hundred and twenty six E. coli organisms per one hundred ml based on a minimum of five samples taken, every three to five days, over a thirty day period.

It is anticipated that mixing zones will not be authorized for bacteria, therefore, the criteria must be met before the effluent is discharged to the receiving water. The proposed water quality-based effluent limits in the draft permits include an instantaneous maximum limit of 406 organisms/100 ml, and an average monthly limit of 126 organisms/100 ml.

(j) Total Residual Chlorine

The Idaho Water Quality Standards contain water quality criteria to protect aquatic life against short term and long term adverse impacts from chlorine. Several of the facilities use chlorine disinfection. A reasonable potential analysis was conducted for each facility to determine if the discharge has the potential to exceed Idaho Water Quality Standards. The results indicated that the facilities would not have the potential to exceed water quality criterion. Therefore, the draft permits include technology-based chlorine limits. For facilities that do not chlorinate, chlorine is not expected to be present in the discharge and therefore no total residual chlorine limits have been included in those draft permits.

Appendix C - Location of Facilities

To be added.