

United States Environmental Protection Agency
 Region 10
 1200 Sixth Avenue Suite 155
 Seattle, Washington 98101-3123

**Authorization to Discharge under the
 National Pollutant Discharge Elimination System**

In compliance with the provisions of the Clean Water Act, 33 U.S.C. §1251 *et seq.*, as amended by the Water Quality Act of 1987, P.L. 100-4, the “Act,”

Henggeler Packing Company, Inc.

is authorized to discharge from a fruit packing facility located in Fruitland, Idaho, at the following location(s):

Outfall	Receiving Water	Latitude	Longitude
001	Drain S-14	43.988881 north	116.890244 west

in accordance with discharge point(s), effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective

This permit and the authorization to discharge shall expire at midnight

The permittee shall reapply for a permit reissuance on or before insert date, 180 days before the expiration of this permit if the permittee intends to continue operations and discharges at the facility beyond the term of this permit.

Signed this day of

Draft Permit

Daniel D. Opalski, Director
 Office of Water and Watersheds

Draft permit. This document does not authorize a discharge.

Schedule of Submissions

The following is a summary of some of the items the permittee must complete and/or submit to EPA during the term of this permit:

Item	Due Date
1. Discharge Monitoring Reports (DMR)	DMRs are due monthly and must be submitted on or before the 20th day of the month following the monitoring month.
2. Quality Assurance Plan (QAP)	The permittee must provide EPA and IDEQ with written notification that the Plan has been developed and implemented within 1 year after the effective date of the final permit (see I.C.). The Plan must be kept on site and made available to EPA and IDEQ upon request.
3. Best Management Practices (BMP) Plan	The permittee must provide EPA and IDEQ with written notification that the Plan has been developed and implemented within 1 year after the effective date of the final permit (see II.C.). The Plan must be kept on site and made available to EPA and IDEQ upon request.
4. NPDES Application Renewal	The application must be submitted at least 180 days before the expiration date of the permit (see V.B).
5. Surface Water Monitoring Report	The Report must be submitted annually by January 31st and with the application for renewal of the permit (see I.C).
6. Compliance Schedule	Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit must be submitted no later than 14 days following each schedule date (see III.J).
7. Twenty-Four Hour Notice of Noncompliance Reporting	The permittee must report certain occurrences of noncompliance by telephone within 24 hours from the time the permittee becomes aware of the circumstances. (See I.B.2 and III.G).

Table of Contents

Schedule of Submissions.....	2
I. Limitations and Monitoring Requirements.....	5
A. Discharge Authorization.....	5
B. Effluent Limitations and Monitoring.....	5
C. Surface Water Monitoring.....	8
II. Special Conditions.....	9
A. Quality Assurance Plan (QAP).....	9
B. Selenium Schedule of Compliance.....	10
C. Best Management Practices Plan.....	11
III. General Monitoring, Recording and Reporting Requirements.....	14
A. Representative Sampling (Routine and Non-Routine Discharges).....	14
B. Reporting of Monitoring Results.....	14
C. Monitoring Procedures.....	15
D. Additional Monitoring by Permittee.....	15
E. Records Contents.....	15
F. Retention of Records.....	15
G. Twenty-four Hour Notice of Noncompliance Reporting.....	15
H. Other Noncompliance Reporting.....	16
I. Changes in Discharge of Toxic Pollutants.....	16
J. Compliance Schedules.....	17
IV. Compliance Responsibilities.....	17
A. Duty to Comply.....	17
B. Penalties for Violations of Permit Conditions.....	17
C. Need To Halt or Reduce Activity not a Defense.....	19
D. Duty to Mitigate.....	19
E. Proper Operation and Maintenance.....	19
F. Bypass of Treatment Facilities.....	19
G. Upset Conditions.....	20
H. Toxic Pollutants.....	21
I. Planned Changes.....	21
J. Anticipated Noncompliance.....	21
V. General Provisions.....	21
A. Permit Actions.....	21
B. Duty to Reapply.....	21
C. Duty to Provide Information.....	22
D. Other Information.....	22
E. Signatory Requirements.....	22
F. Availability of Reports.....	23
G. Inspection and Entry.....	23

Draft permit. This document does not authorize a discharge.

H. Property Rights 24

I. Transfers 24

J. State Laws 24

VI. Definitions..... 24

Appendix A 27

I. Limitations and Monitoring Requirements

A. Discharge Authorization

During the effective period of this permit, the permittee is authorized to discharge pollutants from the outfall(s) specified herein to Drain S-14, within the limits and subject to the conditions set forth herein. This permit authorizes the discharge of only those pollutants resulting from facility processes, waste streams, and operations that have been clearly identified in the permit application process.

B. Effluent Limitations and Monitoring

- The permittee must limit and monitor discharges from outfall 001 as specified in Table 1, below. All figures represent maximum effluent limits unless otherwise indicated. The permittee must comply with the effluent limits in the tables at all times unless otherwise indicated, regardless of the frequency of monitoring or reporting required by other provisions of this permit.

Table 1: Effluent Limitations and Monitoring Requirements for Outfall 001

Parameter	Units	Effluent Limitations			Monitoring Requirements	
		Average Monthly Limit	Maximum Daily Limit	Instantaneous Maximum Limit	Sample Frequency	Sample Type
Flow	mgd	Report	Report	—	Daily	Measurement
Five-day biochemical oxygen demand (BOD ₅)	mg/L	30	60	—	1/month	Grab
Total suspended solids (TSS)	mg/L	30	60	—	1/month	Grab
pH	s.u.	Within the range of 6.5 – 9.0			1/week	Grab
Chlorine, total residual (August 1 – November 30 and monthly average effluent flow > 0.062 mgd) ¹	µg/L	64	129 ²	—	1/week ⁶	Grab
Chlorine, total residual (August 1 – November 30 and monthly average effluent flow ≤ 0.062 mgd) ¹	µg/L	105	210 ²	—	1/week ⁶	Grab
Chlorine, total residual (December 1 – July 31 and monthly average effluent flow > 0.062 mgd) ^{1,7}	µg/L	25	49 ²	—	1/week ⁶	Grab
Chlorine, total residual (December 1 – July 31 and monthly average effluent flow ≤ 0.062 mgd) ^{1,7}	µg/L	36	72 ²	—	1/week ⁶	Grab
Selenium (August 1 – November 30 and monthly average effluent flow > 0.062 mgd) ¹	µg/L	37	75 ²	—	1/month	Grab
Selenium (August 1 – November 30 and monthly average effluent flow ≤ 0.062 mgd) ¹	µg/L	62	124 ²	—	1/month	Grab
Selenium (December 1 – July 31 and monthly average effluent flow > 0.062 mgd) ¹	µg/L	13	25 ²	—	1/month	Grab
Selenium (December 1 – July 31 and monthly average effluent flow ≤ 0.062 mgd) ¹	µg/L	19	38 ²	—	1/month	Grab

Draft permit. This document does not authorize a discharge.

Parameter	Units	Effluent Limitations			Monitoring Requirements	
		Average Monthly Limit	Maximum Daily Limit	Instantaneous Maximum Limit	Sample Frequency	Sample Type
Total phosphorus as P (May 1 – September 30) ¹	µg/L	70	Report	—	1/month	Grab
Floating, suspended or submerged matter	—	See Part I.B.3.			1/month	Visual observation
Temperature (year-round until 1 year after the effective date of the final permit)	°C	Report	Report	—	1/week	Grab
Temperature (year-round from 1 year after the effective date of the final permit until 7 years after the effective date of the final permit)	°C	See Notes 3 and 4.			Continuous ³	Recording ⁴
Temperature (July 16 – October 14 and monthly average effluent flow > 0.062 mgd after 7 years after the effective date of the final permit) ¹	°C	Report	21.4	—	Continuous ³	Recording ⁴
Temperature (July 16 – October 14 and monthly average effluent flow ≤ 0.062 mgd after 7 years after the effective date of the final permit) ¹	°C	Report	23.2	—	Continuous ³	Recording ⁴
Temperature (October 15 – July 15, after 7 years after the effective date of the final permit) ¹	°C	Report	9	13	Continuous ³	Recording ⁴
Nitrate + nitrite as N	mg/L	—	Report		4/year ⁵	Grab
Total ammonia as N	mg/L	—	Report		4/year ⁵	Grab
Total Kjeldahl nitrogen	mg/L	—	Report		4/year ⁵	Grab
4,4'-DDD	ng/L		Report		1/year ⁸	Grab
4,4'-DDE	ng/L		Report		1/year ⁸	Grab
4,4'-DDT	ng/L		Report		1/year ⁸	Grab
Dieldrin	ng/L		Report		1/year ⁸	Grab
Heptachlor	ng/L		Report		1/year ⁸	Grab
Heptachlor epoxide	ng/L		Report		1/year ⁸	Grab

Notes:

1. These effluent limits are subject to a compliance schedule. See II.B.
2. Reporting is required within 24 hours of a maximum daily limit violation. See Parts I.B.2. and III.G.
3. Temperature data must be recorded using micro-recording temperature devices known as thermistors. Set the recording device to record at one-hour intervals. Report the following temperature monitoring data on the DMR: monthly instantaneous maximum, maximum daily average, seven-day running average of the daily instantaneous maximum.
4. Use the temperature device manufacturer's software to generate (export) a Microsoft Excel or ASCII text file. The file must be submitted annually to the EPA and IDEQ by January 31 for the previous monitoring year along with the placement log. The placement logs should include the following information for both thermistor deployment and retrieval: date, time, temperature device manufacturer ID, location, depth, whether it measured air or water temperature, and any other details that may explain data anomalies. The permittee may submit the file as an electronic attachment to NetDMR. The file name of the electronic attachment must be as follows: YYYY_MM_DD_ID0027901_temperature_43599, where YYYY_MM_DD is the date that the permittee submits the file.
5. Two samples must be taken when packing is occurring and two samples must be taken when packing is not occurring.
6. The permittee must monitor the effluent for chlorine when chemicals containing chlorine are added to the process and cooling water or well water overflow discharges.
7. See I.B.8.
8. The annual sample must be taken when packing is occurring.

2. The permittee must report within 24 hours any violation of the maximum daily limits for selenium. Violations of all other effluent limits are to be reported at the time that discharge monitoring reports are submitted (see III.G and III.H).

Draft permit. This document does not authorize a discharge.

3. Narrative limitations for floating, suspended or submerged matter:
 - a) The permittee must not discharge floating, suspended, or submerged matter of any kind in concentrations causing nuisance or objectionable conditions or that may impair designated beneficial uses.
 - b) The permittee must observe the surface of the receiving water in the vicinity of where the effluent enters the surface water. The permittee must maintain a written log of the observation which includes the date, time, observer, and whether there is presence of floating, suspended or submerged matter. The log must be retained and made available to EPA or insert state or tribe upon request.
4. The permittee must collect effluent samples from the effluent stream after the last treatment unit prior to discharge into the receiving waters.
5. For all effluent monitoring, the permittee must use sufficiently sensitive analytical methods which meet the following:
 - a) Parameters with an effluent limit. The method must achieve a minimum level (ML) less than the effluent limitation unless otherwise specified in Table 1.
 - b) Parameters that do not have effluent limitations.
 - (i) The permittee must use a method that detects and quantifies the level of the pollutant, or
 - (ii) The permittee must use a method that can achieve a maximum ML less than or equal to those specified in Appendix A.
 - c) For parameters that do not have an effluent limit, the permittee may request different MLs. The request must be in writing and must be approved by EPA.
 - d) See also Part III.C, "Monitoring Procedures."
6. For purposes of reporting on the DMR for a single sample, if a value is less than the MDL, the permittee must report "less than {numeric value of the MDL}" and if a value is less than the ML, the permittee must report "less than {numeric value of the ML}."
7. For purposes of calculating monthly averages, zero may be assigned for values less than the MDL and the numeric value of the MDL may be assigned for values between the MDL and the ML. If the average value is less than the MDL, the permittee must report "less than {numeric value of the MDL}" and if the average value is less than the ML, the permittee must report "less than {numeric value of the ML}." If a value is equal to or greater than the ML, the permittee must report and use the actual value. The resulting average value must be compared to the compliance level, the ML, in assessing compliance.
8. Some of the effluent limits for total residual chlorine are not quantifiable using EPA approved analytical methods. EPA will use 50 µg/L (the Minimum Level) as the compliance evaluation level for this parameter.

Draft permit. This document does not authorize a discharge.

9. The permittee must not use pesticides or fungicides in the process and cooling water discharge or in the overflow well water discharge or on any product or material that comes into direct contact with those discharges.

C. Surface Water Monitoring

The permittee must conduct surface water monitoring. Surface water monitoring must start within 180 days after the effective date of the permit and continue for as long as the permit remains in effect. The program must meet the following requirements:

1. A monitoring station must be established in Drain S-14 above the influence of the facility's discharge.
2. To the extent practicable, surface water sample collection must occur on the same day as effluent sample collection.
3. Samples must be analyzed for the parameters listed in Table 2, and must achieve method detection limits (MDLs) that are equivalent to or less than those listed in Appendix A. The permittee may request different MDLs. The request must be in writing and must be approved by EPA.

Table 2: Surface Water Monitoring

Parameter	Units	Frequency	Sample Type
Dissolved Oxygen	mg/L	4/year	Grab
Dissolved Oxygen (beginning 1 year after the effective date of the final permit)	% Saturation	4/year	Calculation
Nitrate + nitrite	mg/L	4/year	Grab
pH	standard units	4/year	Grab
Selenium	µg/L	4/year	Grab
Temperature (beginning 1 year after the effective date of the final permit)	°C	Continuous	Recording
Total ammonia as N	mg/L	4/year	Grab
Total Kjeldahl nitrogen	mg/L	4/year	Grab
Total phosphorus	µg/L	4/year	Grab

4. Quality assurance/quality control plans for all the monitoring must be documented in the Quality Assurance Plan required under Part II.A., "Quality Assurance Plan."
5. Submission of SW Monitoring
 - a) The permittee must submit all surface water monitoring results for the previous calendar year for all parameters in an annual report to EPA and IDEQ by January 31st of the following year and with the application (see Part V.B of this permit, Duty to Reapply). The file must be in the format of one analytical result per row and include the following information: name and contact information of laboratory, sample identification number, sample location in latitude and longitude (decimal degrees format), method of

Draft permit. This document does not authorize a discharge.

location determination (i.e., GPS, survey etc.), date and time of sample collection, water quality parameter (or characteristic being measured), analysis result, result units, detection limit and definition (i.e., MDL etc.), analytical method, date completed, and any applicable notes.

- b) The permittee may submit the surface water monitoring report as an attachment to the DMR. The file name of the electronic attachment must be as follows: YYYY_MM_DD_ID0027901_SWMRP, where YYYY_MM_DD is the date that the permittee submits the report.

II. Special Conditions

A. Quality Assurance Plan (QAP)

The permittee must develop a quality assurance plan (QAP) for all monitoring required by this permit. Any existing QAPs may be modified for compliance with this section.

Within one year of the effective date of this permit, the permittee must submit written notice to EPA and IDEQ that the QAP has been developed and implemented. The permittee may submit written notification as an electronic attachment to the DMR.

The file name of the electronic attachment must be as follows:

YYYY_MM_DD_ID0027901_QAP_55099, where YYYY_MM_DD is the date that the permittee submits the written notification. The plan must be retained on site and made available to EPA and/or IDEQ upon request.

1. The QAP must be designed to assist in planning for the collection and analysis of effluent and receiving water samples in support of the permit and in explaining data anomalies when they occur.
2. Throughout all sample collection and analysis activities, the permittee must use the EPA-approved QA/QC and chain-of-custody procedures described in *EPA Requirements for Quality Assurance Project Plans (EPA/QA/R-5)* and *Guidance for Quality Assurance Project Plans (EPA/QA/G-5)*. The QAP must be prepared in the format that is specified in these documents.
3. At a minimum, the QAP must include the following:
 - a) Details on the number of samples, type of sample containers, preservation of samples, holding times, analytical methods, analytical detection and quantitation limits for each target compound, type and number of quality assurance field samples, precision and accuracy requirements, sample preparation requirements, sample shipping methods, and laboratory data delivery requirements.
 - b) Map(s) indicating the location of each sampling point.
 - c) Qualification and training of personnel.
 - d) Name(s), address(es) and telephone number(s) of the laboratories used by or proposed to be used by the permittee.

Draft permit. This document does not authorize a discharge.

4. The permittee must amend the QAP whenever there is a modification in sample collection, sample analysis, or other procedure addressed by the QAP.
5. Copies of the QAP must be kept on site and made available to EPA and/or IDEQ upon request.

B. Schedule of Compliance

1. A schedule of compliance is authorized for the effluent limitations for phosphorus, selenium, and temperature.
2. The permittee may continue to discharge and comply with the effluent limitations for phosphorus, selenium, and temperature, or the permittee may terminate its discharges of pollutants to waters of the United States.
 - a) The permittee must make a final decision on whether to terminate its discharges of pollutants to waters of the United States by 1 year after the effective date of the final permit.
 - b) The permittee's decision to terminate the discharge to waters of the United States or continue to discharge and comply with effluent limitations must be evidenced by a firm public commitment satisfactory to the Director of the Office of Water and Watersheds.
3. If the permittee decides to continue its discharge of pollutants to waters of the United States, the permittee must achieve compliance with the final effluent limitations for phosphorus, selenium, and temperature within 7 years of the effective date of the final permit.
 - a) The permittee must submit an Annual Report of Progress which outlines the progress made towards reaching the compliance date for the phosphorus, selenium and temperature effluent limitations. The annual Report of Progress must be submitted by insert date one year after effective date of permit of each year. The first report is due one year after the effective date of the final permit and annually thereafter, until compliance with the phosphorus, selenium, and temperature effluent limits is achieved. The permittee may submit the annual report as an attachment to the DMR. The file name of the electronic attachment must be as follows:
YYYY_MM_DD_ID0027901_Progress_CS010, where YYYY_MM_DD is the date that the permittee submits the Report of Progress. See also Part III.J., "Compliance Schedules." At a minimum, the annual report must include:
 - (i) An assessment of the previous year of phosphorus, selenium and temperature effluent data and comparison to the effluent limitations.
 - (ii) A report on progress made towards meeting the effluent limitations.
 - (iii) Further actions and milestones targeted for the upcoming year.
4. If the permittee decides to terminate its discharge of pollutants to waters of the United States, the permittee must terminate the discharge within 7 years of the effective date of the final permit.

Draft permit. This document does not authorize a discharge.

- a) The permittee must submit an Annual Report of Progress which outlines the progress made towards terminating discharges of pollutants to waters of the United States. The annual Report of Progress must be submitted by insert date one year after effective date of permit of each year. The first report is due one year after the effective date of the final permit and annually thereafter, until the discharge of pollutants to waters of the United States is terminated. The permittee may submit the annual report as an attachment to the DMR. The file name of the electronic attachment must be as follows: YYYY_MM_DD_ID0027901_Progress_CS010, where YYYY_MM_DD is the date that the permittee submits the Report of Progress. See also Part III.J., “Compliance Schedules.” At a minimum, the annual report must include:
- (i) A report on progress made towards terminating the discharges of pollutants to waters of the United States.
 - (ii) Further actions and milestones targeted for the upcoming year.

C. Best Management Practices Plan

1. Purpose

Through implementation of the best management practices (BMP) plan the permittee must prevent or minimize the generation and the potential for the release of pollutants from the facility to the waters of the United States through normal and ancillary activities.

2. Development and Implementation Schedule

The permittee must develop and implement a BMP Plan which achieves the objectives and the specific requirements listed below. The permittee must submit written notice to EPA and IDEQ that the Plan has been developed and implemented within 1 year of the effective date of the permit. The permittee may submit written notification as an electronic attachment to the DMR. The file name of the electronic attachment must be as follows: YYYY_MM_DD_ID0027901_BMP_05899, where YYYY_MM_DD is the date that the permittee submits the written notification. Any existing BMP plans may be modified for compliance with this section. The plan must be retained on site and made available to EPA and/or IDEQ upon request. The permittee must implement the provisions of the plan as conditions of this permit within 1 year of the effective date of this permit.

3. Objectives

The permittee must develop and amend the BMP Plan consistent with the following objectives for the control of pollutants.

- a) The number and quantity of pollutants and the toxicity of effluent generated, discharged or potentially discharged at the facility must be minimized by the permittee to the extent feasible by managing each waste stream in the most appropriate manner.
- b) Under the BMP Plan and any Standard Operating Procedures included in the BMP Plan, the permittee must ensure proper operation and maintenance of

Draft permit. This document does not authorize a discharge.

water management and wastewater treatment systems. BMP Plan elements must be developed in accordance with good engineering practices.

- c) Each facility component or system must be examined for its waste minimization opportunities and its potential for causing a release of significant amounts of pollutants to waters of the United States due to equipment failure, improper operation, natural phenomena such as rain or snowfall, etc. The examination must include all normal operations and ancillary activities including material storage areas, storm water, in-plant transfer, material handling and process handling areas, loading or unloading operations, spillage or leaks, sludge and waste disposal, or drainage from raw material storage.

4. Elements of the BMP Plan

The BMP Plan must be consistent with the objectives above and the general guidance contained in *Guidance Manual for Developing Best Management Practices* (EPA 833-B-93-004, October 1993) and *Storm Water Management for Industrial Activities, Developing Pollution Prevention Plans and Best Management Practices* (EPA 832-R-92-006, September 1992) or any subsequent revision to these guidance documents. The BMP Plan must include, at a minimum, the following items:

- a) Plan Components.
 - (i) Statement of BMP policy. The BMP Plan must include a statement of management commitment to provide the necessary financial, staff, equipment, and training resources to develop and implement the BMP Plan on a continuing basis.
 - (ii) Structure, functions, and procedures of the BMP Committee. The BMP Plan must establish a BMP Committee responsible for developing, implementing, and maintaining the BMP Plan.
 - (iii) Description of potential pollutant sources.
 - (iv) Risk identification and assessment.
 - (v) Standard operating procedures to achieve the above objectives and specific best management practices (see below).
 - (vi) Reporting of BMP incidents. The reports must include a description of the circumstances leading to the incident, corrective actions taken and recommended changes to operating and maintenance practices to prevent recurrence.
 - (vii) Materials compatibility.
 - (viii) Good housekeeping.
 - (ix) Inspections.
 - (x) Preventative maintenance and repair.
 - (xi) Security.
 - (xii) Employee training.

Draft permit. This document does not authorize a discharge.

- (xiii) Recordkeeping and reporting.
 - (xiv) Prior evaluation of any planned modifications to the facility to ensure that the requirements of the BMP plan are considered as part of the modifications.
 - (xv) Final constructed site plans, drawings and maps (including detailed storm water outfall/culvert configurations).
- b) Specific Best Management Practices. The BMP Plan must establish specific BMPs or other measures to achieve the objectives under part II.C. and which ensure that the following specific requirements are met:
- (i) Solids, sludges, or other pollutants removed in the course of treatment or control of water and wastewaters must be disposed of in a manner such as to prevent any pollutant from such materials from entering navigable waters.
 - (ii) Ensure proper management of solid and hazardous waste in accordance with regulations promulgated under the Resource Conservation and Recovery Act (RCRA). Management practices required under RCRA regulations must be referenced in the BMP Plan.
 - (iii) Any cleaning products, coatings, or other chemicals used in fruit packing must be used in accordance with the product label and must be used in a manner that minimizes their presence in the effluent.

5. Review and Certification.

The BMP Plan must be reviewed and certified as follows:

- a) Annual review by the plant manager and BMP Committee.
- b) Certified statement that the above reviews have been completed and that the BMP Plan fulfills the requirements set forth in this permit. The statement must be certified by the dated signatures of each BMP Committee member. The statement must be submitted to EPA on or before insert date of each year of operation under this permit after the initial BMP submittal (the initial statement must be submitted to EPA six months after completion of the BMP Plan).

6. Documentation

The permittee must maintain a copy of the BMP Plan at the facility and make it available to EPA or an authorized representative upon request.

7. BMP Plan Modification

- a) The permittee must amend the BMP Plan whenever there is a change in the facility or in the operation of the facility which materially increases the generation of pollutants or their release or potential release to surface waters.
- b) The permittee must amend the BMP Plan whenever it is found to be ineffective in achieving the general objective of preventing and minimizing

Draft permit. This document does not authorize a discharge.

the generation and the potential for the release of pollutants from the facility to the waters of the United States and/or the specific requirements above.

- c) Any changes to the BMP Plan must be consistent with the objectives and specific requirements listed above. All changes in the BMP Plan must be reported to EPA with the annual certification required under Part D.3, above.

III. General Monitoring, Recording and Reporting Requirements

A. Representative Sampling (Routine and Non-Routine Discharges)

Samples and measurements taken for the purpose of monitoring must be representative of the monitored activity.

In order to ensure that the effluent limits set forth in this permit are not violated at times other than when routine samples are taken, the permittee must collect additional samples at the appropriate outfall whenever any discharge occurs that may reasonably be expected to cause or contribute to a violation that is unlikely to be detected by a routine sample. The permittee must analyze the additional samples for those parameters limited in Part I.B of this permit that are likely to be affected by the discharge.

The permittee must collect such additional samples as soon as the spill, discharge, or bypassed effluent reaches the outfall. The samples must be analyzed in accordance with paragraph III.C (“Monitoring Procedures”). The permittee must report all additional monitoring in accordance with paragraph III.D (“Additional Monitoring by Permittee”).

B. Reporting of Monitoring Results

The permittee must submit monitoring data and other reports electronically using NetDMR.

1. Monitoring data must be submitted electronically to EPA no later than the 20th of the month following the completed reporting period.
2. The permittee must sign and certify all DMRs, and all other reports, in accordance with the requirements of Part V.E, of this permit, “Signatory Requirements.”
3. The permittee must submit copies of the DMRs and other reports to IDEQ.
4. Submittal of Reports as NetDMR Attachments. Unless otherwise specified in this permit, the permittee may submit all reports to EPA and IDEQ as NetDMR attachments rather than as hard copies. The file name of the electronic attachment must be as follows: YYYY_MM_DD_ID0027901_Report Type Name_Identifying Code, where YYYY_MM_DD is the date that the permittee submits the attachment.
5. The permittee may use NetDMR after requesting and receiving permission from US EPA Region 10. NetDMR is accessed from: <https://netdmr.epa.gov>.

Draft permit. This document does not authorize a discharge.

C. Monitoring Procedures

Monitoring must be conducted according to test procedures approved under 40 CFR 136, unless another method is required under 40 CFR subchapters N or O, or other test procedures have been specified in this permit or approved by EPA as an alternate test procedure under 40 CFR 136.5.

D. Additional Monitoring by Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR 136 or as specified in this permit, the permittee must include the results of this monitoring in the calculation and reporting of the data submitted in the DMR.

Upon request by EPA, the permittee must submit results of any other sampling, regardless of the test method used.

E. Records Contents

Records of monitoring information must include:

1. the date, exact place, and time of sampling or measurements;
2. the name(s) of the individual(s) who performed the sampling or measurements;
3. the date(s) analyses were performed;
4. the names of the individual(s) who performed the analyses;
5. the analytical techniques or methods used; and
6. the results of such analyses.

F. Retention of Records

The permittee must retain records of all monitoring information, including, all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, copies of DMRs, a copy of the NPDES permit, and records of all data used to complete the application for this permit, for a period of at least five years from the date of the sample, measurement, report or application. This period may be extended by request of EPA or IDEQ at any time.

G. Twenty-four Hour Notice of Noncompliance Reporting

1. The permittee must report the following occurrences of noncompliance by telephone within 24 hours from the time the permittee becomes aware of the circumstances:
 - a) any noncompliance that may endanger health or the environment;
 - b) any unanticipated bypass that exceeds any effluent limitation in the permit (See Part IV.F., "Bypass of Treatment Facilities");

Draft permit. This document does not authorize a discharge.

- c) any upset that exceeds any effluent limitation in the permit (See Part IV.G., “Upset Conditions”); or
 - d) any violation of a maximum daily discharge limitation for applicable pollutants identified by Part I.B.2.
2. The permittee must also provide a written submission within five days of the time that the permittee becomes aware of any event required to be reported under subpart 1 above. The written submission must contain:
 - a) a description of the noncompliance and its cause;
 - b) the period of noncompliance, including exact dates and times;
 - c) the estimated time noncompliance is expected to continue if it has not been corrected; and
 - d) steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
 3. The Director of the Office of Compliance and Enforcement may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the NPDES Compliance Hotline in Seattle, Washington, by telephone, (206) 553-1846.
 4. Reports must be submitted to the addresses in Part III.B (“Reporting of Monitoring Results”).

H. Other Noncompliance Reporting

The permittee must report all instances of noncompliance, not required to be reported within 24 hours, at the time that monitoring reports for Part III.B (“Reporting of Monitoring Results”) are submitted. The reports must contain the information listed in Part III.G.2 of this permit (“Twenty-four Hour Notice of Noncompliance Reporting”).

I. Changes in Discharge of Toxic Pollutants

The permittee must notify the Director of the Office of Water and Watersheds and IDEQ as soon as it knows, or has reason to believe:

1. That any activity has occurred or will occur that would result in the discharge, on a **routine or frequent** basis, of any toxic pollutant that is not limited in the permit, if that discharge may reasonably be expected to exceed the highest of the following “notification levels”:
 - a) One hundred micrograms per liter (100 ug/l);
 - b) Two hundred micrograms per liter (200 ug/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/l) for 2,4-dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;
 - c) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21(g)(7); or

Draft permit. This document does not authorize a discharge.

- d) The level established by EPA in accordance with 40 CFR 122.44(f).
2. That any activity has occurred or will occur that would result in any discharge, on a **non-routine or infrequent** basis, of any toxic pollutant that is not limited in the permit, if that discharge may reasonably be expected to exceed the highest of the following “notification levels”:
 - a) Five hundred micrograms per liter (500 ug/l);
 - b) One milligram per liter (1 mg/l) for antimony;
 - c) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21(g)(7); or
 - d) The level established by EPA in accordance with 40 CFR 122.44(f).
3. The permittee must submit the notification to Office of Water and Watersheds at the following address:

US EPA Region 10
Attn: NPDES Permits Unit Manager
1200 Sixth Avenue
Suite 155 OWW-191
Seattle, Washington 98101-3123

J. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit must be submitted no later than 14 days following each schedule date.

IV. Compliance Responsibilities

A. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification, or for denial of a permit renewal application.

B. Penalties for Violations of Permit Conditions

1. Civil and Administrative Penalties. Pursuant to 40 CFR Part 19 and the Act, any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed the maximum amounts authorized by Section 309(d) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$53,484 per day for each violation).

Draft permit. This document does not authorize a discharge.

2. **Administrative Penalties.** Any person may be assessed an administrative penalty by the Administrator for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Pursuant to 40 CFR 19 and the Act, administrative penalties for Class I violations are not to exceed the maximum amounts authorized by Section 309(g)(2)(A) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$21,393 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$53,484). Pursuant to 40 CFR 19 and the Act, penalties for Class II violations are not to exceed the maximum amounts authorized by Section 309(g)(2)(B) of the Act and the Federal Civil Penalties Inflation Adjustment Act (28 U.S.C. § 2461 note) as amended by the Debt Collection Improvement Act (31 U.S.C. § 3701 note) (currently \$21,393 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$267,415).
3. **Criminal Penalties:**
 - a) **Negligent Violations.** The Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than 1 year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than 2 years, or both.
 - b) **Knowing Violations.** Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than 3 years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.
 - c) **Knowing Endangerment.** Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the Act, shall, upon conviction of violating the imminent danger provision, be

Draft permit. This document does not authorize a discharge.

subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.

- d) **False Statements.** The Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both. The Act further provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

C. Need To Halt or Reduce Activity not a Defense

It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with this permit.

D. Duty to Mitigate

The permittee must take all reasonable steps to minimize or prevent any discharge in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment.

E. Proper Operation and Maintenance

The permittee must at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by the permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

F. Bypass of Treatment Facilities

1. **Bypass not exceeding limitations.** The permittee may allow any bypass to occur that does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 2 and 3 of this Part.
2. **Notice.**

Draft permit. This document does not authorize a discharge.

- a) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it must submit prior written notice, if possible at least 10 days before the date of the bypass.
 - b) Unanticipated bypass. The permittee must submit notice of an unanticipated bypass as required under Part III.G (“Twenty-four Hour Notice of Noncompliance Reporting”).
3. Prohibition of bypass.
- a) Bypass is prohibited, and the Director of the Office of Compliance and Enforcement may take enforcement action against the permittee for a bypass, unless:
 - (i) The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (ii) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance; and
 - (iii) The permittee submitted notices as required under paragraph 2 of this Part.
 - b) The Director of the Office of Compliance and Enforcement may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 3.a. of this Part.

G. Upset Conditions

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the permittee meets the requirements of paragraph 2 of this Part. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
2. Conditions necessary for a demonstration of upset. To establish the affirmative defense of upset, the permittee must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - a) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - b) The permitted facility was at the time being properly operated;
 - c) The permittee submitted notice of the upset as required under Part III.G, “Twenty-four Hour Notice of Noncompliance Reporting;” and

Draft permit. This document does not authorize a discharge.

- d) The permittee complied with any remedial measures required under Part IV.D, “Duty to Mitigate.”
3. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

H. Toxic Pollutants

The permittee must comply with effluent standards or prohibitions established under Section 307(a) of the Act for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the Act within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

I. Planned Changes

The permittee must give written notice to the Director of the Office of Water and Watersheds as specified in part III.I.3. and IDEQ as soon as possible of any planned physical alterations or additions to the permitted facility whenever:

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source as determined in 40 CFR 122.29(b); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in the permit, nor to notification requirements under Part III.I (“Changes in Discharge of Toxic Substances”).

J. Anticipated Noncompliance

The permittee must give written advance notice to the Director of the Office of Compliance and Enforcement and IDEQ of any planned changes in the permitted facility or activity that may result in noncompliance with this permit.

V. General Provisions

A. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause as specified in 40 CFR 122.62, 122.64, or 124.5. The filing of a request by the permittee for a permit modification, revocation and reissuance, termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

B. Duty to Reapply

If the permittee intends to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. In accordance with 40 CFR 122.21(d), and unless permission for the application to be submitted at a later date has been granted by the Regional Administrator, the

Draft permit. This document does not authorize a discharge.

permittee must submit a new application at least 180 days before the expiration date of this permit.

C. Duty to Provide Information

The permittee must furnish to EPA and IDEQ, within the time specified in the request, any information that EPA or IDEQ may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee must also furnish to EPA or IDEQ, upon request, copies of records required to be kept by this permit.

D. Other Information

When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or that it submitted incorrect information in a permit application or any report to EPA or IDEQ, it must promptly submit the omitted facts or corrected information in writing.

E. Signatory Requirements

All applications, reports or information submitted to EPA and IDEQ must be signed and certified as follows.

1. All permit applications must be signed as follows:
 - a) For a corporation: by a responsible corporate officer.
 - b) For a partnership or sole proprietorship: by a general partner or the proprietor, respectively.
 - c) For a municipality, state, federal, Indian tribe, or other public agency: by either a principal executive officer or ranking elected official.
2. All reports required by the permit and other information requested by EPA or IDEQ must be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a) The authorization is made in writing by a person described above;
 - b) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company; and
 - c) The written authorization is submitted to the Director of the Office of Compliance and Enforcement and IDEQ.
3. Changes to authorization. If an authorization under Part V.E.2 is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Part V.E.2. must be submitted to the Director of the Office of Compliance and

Draft permit. This document does not authorize a discharge.

Enforcement and IDEQ prior to or together with any reports, information, or applications to be signed by an authorized representative.

4. Certification. Any person signing a document under this Part must make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

F. Availability of Reports

In accordance with 40 CFR 2, information submitted to EPA pursuant to this permit may be claimed as confidential by the permittee. In accordance with the Act, permit applications, permits and effluent data are not considered confidential. Any confidentiality claim must be asserted at the time of submission by stamping the words “confidential business information” on each page containing such information. If no claim is made at the time of submission, EPA may make the information available to the public without further notice to the permittee. If a claim is asserted, the information will be treated in accordance with the procedures in 40 CFR 2, Subpart B (Public Information) and 41 Fed. Reg. 36902 through 36924 (September 1, 1976), as amended.

G. Inspection and Entry

The permittee must allow the Director of the Office of Compliance and Enforcement, EPA Region 10; IDEQ; or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon the presentation of credentials and other documents as may be required by law, to:

1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
4. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by the Act, any substances or parameters at any location.

Draft permit. This document does not authorize a discharge.

H. Property Rights

The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any injury to persons or property or invasion of other private rights, nor any infringement of federal, tribal, state or local laws or regulations.

I. Transfers

This permit is not transferable to any person except after written notice to the Director of the Office of Water and Watersheds as specified in part III.I.3. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act. (See 40 CFR 122.61; in some cases, modification or revocation and reissuance is mandatory).

J. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Act.

VI. Definitions

1. “Act” means the Clean Water Act.
2. “Administrator” means the Administrator of the EPA, or an authorized representative.
3. “Average monthly discharge limitation” means the highest allowable average of “daily discharges” over a calendar month, calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month.
4. “Best Management Practices” (BMPs) means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the United States. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage areas.
5. “Bypass” means the intentional diversion of waste streams from any portion of a treatment facility.
6. “Daily discharge” means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the “daily discharge” is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of

Draft permit. This document does not authorize a discharge.

measurement, the “daily discharge” is calculated as the average measurement of the pollutant over the day.

7. “Director of the Office of Compliance and Enforcement” means the Director of the Office of Compliance and Enforcement, EPA Region 10, or an authorized representative.
8. “Director of the Office of Water and Watersheds” means the Director of the Office of Water and Watersheds, EPA Region 10, or an authorized representative.
9. “DMR” means discharge monitoring report.
10. “EPA” means the United States Environmental Protection Agency.
11. “Geometric Mean” means the n^{th} root of a product of n factors, or the antilogarithm of the arithmetic mean of the logarithms of the individual sample values.
12. “Grab” sample is an individual sample collected over a period of time not exceeding 15 minutes.
13. “IDEQ” means the Idaho Department of Environmental Quality.
14. “Maximum daily discharge limitation” means the highest allowable “daily discharge.”
15. “Method Detection Limit (MDL)” means the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results.
16. “Minimum Level (ML)” means either the sample concentration equivalent to the lowest calibration point in a method or a multiple of the method detection limit (MDL). Minimum levels may be obtained in several ways: They may be published in a method; they may be sample concentrations equivalent to the lowest acceptable calibration point used by a laboratory; or they may be calculated by multiplying the MDL in a method, or the MDL determined by a lab, by a factor.
17. “NPDES” means National Pollutant Discharge Elimination System, the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits . . . under sections 307, 402, 318, and 405 of the CWA.
18. “QA/QC” means quality assurance/quality control.
19. “Regional Administrator” means the Regional Administrator of Region 10 of the EPA, or the authorized representative of the Regional Administrator.
20. “Severe property damage” means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
21. “Upset” means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations

Draft permit. This document does not authorize a discharge.

because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

Appendix A

Minimum Levels

The Table below lists the maximum Minimum Level (ML) for pollutants that may have monitoring requirements in the permit. The permittee may request different MLs. The request must be in writing and must be approved by EPA. If the Permittee is unable to obtain the required ML in its effluent due to matrix effects, the Permittee must submit a matrix-specific detection limit (MDL) and a ML to EPA with appropriate laboratory documentation.

CONVENTIONAL PARAMETERS

Pollutant & CAS No. (if available)	Minimum Level (ML) µg/L unless specified
Biochemical Oxygen Demand	2 mg/L
Total Suspended Solids	5 mg/L
Dissolved oxygen	+/- 0.2 mg/L
Temperature	+/- 0.2° C
pH	N/A

NONCONVENTIONAL PARAMETERS

Pollutant & CAS No. (if available)	Minimum Level (ML) µg/L unless specified
Total Ammonia (as N)	50
Chlorine, Total Residual	50
Nitrate + Nitrite Nitrogen (as N)	100
Nitrogen, Total Kjeldahl (as N)	300
Phosphorus, Total (as P)	10

PRIORITY POLLUTANTS

Pollutant & CAS No. (if available)	Minimum Level (ML) µg/L unless specified
Selenium, Total (7782-49-2)	1.0
4,4'-DDD	8.4 ng/L
4,4'-DDE	16.8 ng/L
4,4'-DDT	14.1 ng/L
Dieldrin	7.5 ng/L
Heptachlor	5.7 ng/L
Heptachlor Epoxide	6.6 ng/L

Draft permit. This document does not authorize a discharge.