N.Y.S. DEPARTMENT OF ENVIRONMENTAL CONSERVATION DIVISION OF AIR

SECNC NO: 8-C-0152 RUM DATE: 04/01/96

C 261400 1357 00003 W C

LOCATION FAC EP

CERTIFICATE TO OPERATE AN AIR CONTAMINATION SOURCE STATIONARY COMBUSTION INSTALLATION UNIT

0 N N (1) ROCHES (2) PO BOX (3) ROCHES (5) 14642	STER UNIV CENT UTIL (640 STER (4) NY	F A C I L I T Y (6) UNIVERSITY OF R (7) ELMMOOD AVENUE (8) ROCHESTER 10) REP: W. NICHOLS		(11) CONFIDENTIAL STATUS NON-CO (12) APPLICATION STATUS IN COM- DATE OF LAST CHANGE 03/2 PRIGR CO ISSUE DATE PRIOR CO EXPIRATION DATE	
00003 POINT POINT	(41)UTH-E: 286.1 KM. (42)S (46)UTH-N: 777.0 KM. (47)H	STACK HEIGHT: 137 FT. HT ABV STRUC: 69 FT. STK DIAM: 48 IN.	POINT EMIS-CLASS / PGM-CODE: (43)EXIT VELOCITY: 32.98 FT/SEC (40)EXIT FLOH: 24856.00 ACFM (53)EXIT TEMP: 337 DEGR F	(44)SIC: 8999 (45)AGENCY-CODE-1: (49)CO FEE: (50)AGENCY-CODE-2: N	
UNIT C	(57)TYPE: COL PACKAGE BOILER	(58 MFG: BABCO	CK & HILCOX STERLING : 1 OUTSIDE AIR INTAKE	(59)HEAT IMPUT: S9.80 MILLIONS BTU/NR (61)SOURCE CODE: 7310 SPACE HEATING-SC	orio
BURNER DATA	(64)TYPE: 052 STEAM ATOMIZED (67)TYPE: 036 NO 6 OIL - VIRSIN (71)FUEL SUPPLIER: ALLIED OIL - (86)TYPE: 099 NONE 1. SHOULD RESULT IN ESTABLISH THE EXPIR	(65)NFG: COEN FUEL QUANTIT GOETZ OIL SIGNIFICANT NEW SCIENTIF: A DECISION BY DEC THAT LE	IES: (68)AVG/HR: 323.7 (69 (72)HOURS/DAY: 24.0 (73 GENERAL CONDITIONS IC EVIDENCE FROM A RECOGNIZED INSTI DHER AMBIENT POLLUTION LEVELS MUST O REDUCE EMISSIONS FROM THIS SOURCE	(66)NO. OF BURNERS: 2 DHAX/HR: 850.0 (70)TOTAL/YSAR: DDAYS/YEAR: 23 (74)% OP BY SEASON: 25 TUTION BE	179627
SPECIAL CONDITIONS	(148)CONDITION 1. SEE ATTA 2. DATED 03	CHED SPECIAL CONDITIONS -19-96, RELATING TO 6NYCRI NOX RACT REQUIREMENTS.			
2. LAST INTERNAL 62284 3. NEH BRICK WORK ON UNIT 3 4. 4.		NTS (19)8Y (20)D	(21)INSPECTION STATUS (22)DATE OF NEXT ACTION / (23)ISSUE DATE 10/0 (24)EXPIRATION DATE 10/0	5	

FIRM REP'S SIGNATURE: DATE: ISSUING OFFICER

ISSUING OFFICER'S SIGNATURE: DATE:

APR 25 B

SPECIAL PERMIT CONDITIONS Article 19, Air Pollution Control

Facility Name:

University of Rochester

DEC Permit No.:

8-2614-00548/00006-0

Air Program ID No.:

261400 1357

Emission Point No.: 00003

1. As a result of the May 24, 1995 NO_x RACT determination, an alternative emission limit of 0.425 pounds of nitrogen oxides per one million BTU heat input is established for this source. This emission limit constitutes a variance from the emissions limit contained in 6NYCRR part 227-2. This emission limit will be achieved by burner tuning and oxygen trim.

Issue Date: March 19, 1996

- Compliance with this emission limit shall be determined with a one-hour average in accordance with 6NYCRR part 227-2.6(c).
- To insure continuing compliance with condition #1, this boiler will be operated according to the operating plan submitted to The Department on September 29, 1995.
- 4. This source is limited to combusting 1,000,000 gallons of fuel oil per year (#2 and #6 combined).
- 5. Deviations from the operating conditions set forth in the operating plan will be reported to the NYSDEC Region 8 office annually. This annual report is due 30 days after the end of each calendar year. This report will also include annual fuel use for this boiler. A study detailing the feasibility of nitrogen oxide reduction by process modification or abatement technology will also be included.
- 6. The Department reserves the right to require the source owner to evaluate and implement innovative control technology within a time frame established by the commissioner's representative per 621.14(a)(4).
- 7. Any increase in fuel use from that specified in condition #3 shall be grounds for The Department to revoke this variance.