

**Region 8 Permit Limits for constituents without MCLs.**

<b>Constituent</b>	<b>Concentration</b>
Copper	1.3 mg/L
Fluoride	4 mg/L
Iron	5 mg/L
Manganese	0.8 mg/L
Silver	0.1 mg/L
Zinc	2 mg/L