

CALCULATIONS OF NEW MEXICO WATER QUALITY-BASED EFFLUENT LIMITATIONS

NMAC 20.6.4. **NMWQS as of January 14, 2011**

(EPA approved site-specific criteria for aluminum, cadmium, and zinc on April 30, 2012)

Calculations Specifications:

Excel **Revised as of May 1, 2012**

Prepared By:

Isaac Chen 21-Dec-20

STEP 1: REFERENCE IMPLEMENTATION PROCEDURES
INPUT FACILITY AND RECEIVING STREAM DATA
LIST SOURCE OF DATA INPUT

APPENDIX A of FACT SHEET

IMPLEMENTATION PROCEDURES

The State of New Mexico Standards for Interstate and Intrastate Surface Waters are implemented in this spread sheet by using procedures established in the "Procedures for Implementing NPDES Permits in New Mexico" amended May 2011

FACILITY	DATA INPUT	
Permittee	LANL	
NPDES Permit No.	NM0028355	
Outfall No.(s)	03A113	
Plant Effluent Flow (MGD)	0.0016	For industrial and federal facility, use the highest monthly average flow for the past 24 months. For POTWs, use the design flow.
Plant Effluent Flow (cfs)	0.00248	
RECEIVING STREAM	DATA INPUT	
Receiving Stream Name	Sandia Canton	
Basin Name	Rio Grande	
Waterbody Segment Code No.	20.6.4.128	
Is a publicly owned lake or reservoir (enter "1" if it's a lake, "0" if not)	0	
Are acute aquatic life criteria considered (1= yes, 0= no) (MUST enter "1" for 2005 Standards)	1	
Are chronic aquatic life criteria considered (1= yes, 0=no)	0	
Are domestic water supply criteria considered (1= yes, 0=no)	0	
Are irrigation water supply criteria considered (1= yes, 0=no)	0	
Livestock watering and wildlife habitat criteria applied to all streams		
USGS Flow Station	USGS	
WQ Monitoring Station No.	SJR	
Receiving Stream TSS (mg/l)	1.8	For intermittent stream, enter effluent TSS
Receiving Stream Hardness (mg/l as CaCO ₃)	96	For intermittent stream, enter effluent Hardness (If no data, 20 mg/l is used)
Receiving Stream Critical Low Flow (4Q3) (cfs)	0	Enter "0" for intermittent stream and lake.
Receiving Stream Harmonic Mean Flow (cfs)	0.00155	Enter harmonic mean or modified harmonic mean flow data
Avg. Water Temperature (C Max)	21.8	
pH (Max)	8.5	
Fraction of stream allowed for mixing (F)	1	Enter 1, if stream morphology data is not available or for intermittent streams.
Fraction of Critical Low Flow	0	

STEP 2: INPUT AMBIENT AND EFFLUENT DATA**CALCULATE IN-STREAM WASTE CONCENTRATIONS****DATA INPUT**

Input pollutant geometric mean concentration as micro-gram per liter (ug/l or ppb)

unless other unit is specified for the parameter.

Effluent value reported as "< detection level" (DL) but the DL is greater than MQL, input "1/2 DL" for calculation.

Effluent value reported as "< detection level" (DL) and the DL is smaller than MQL, no data is inputted.

If a less than MQL value is reported, input either the reported value or "0" for calculation.

The following formula is used to calculate the Instream Waste Concentration (Cd)

See "Procedures for Implementing NPDES Permits in New Mexico" amended July 2009

$$Cd = [(F \cdot Qa \cdot Ca) + (Qe \cdot 2.13 \cdot Ce)] / (F \cdot Qa + Qe)$$

Where:

Cd = Instream Waste Concentration

F = Fraction of stream allowed for mixing (see "Procedures for Implementing NPDES Permits in New Mexico")

Ce = Reported concentration in effluent

Ca = Ambient stream concentration upstream of discharge

Qe = Plant effluent flow

Qa = Critical low flow of stream at discharge point expressed as the 4Q3 or harmonic mean flow for human health criteria

The following formula convert metals reported in total form to dissolved form if criteria are in dissolved form

See "Procedures for Implementing NPDES Permits in New Mexico" amended July 2009

$$Kp = Kpo \cdot (TSS^{**a})$$

Kp = Linear partition coefficient; Kpo and a can be found in table below

$$C/Ct = 1 / (1 + Kp \cdot TSS \cdot 10^{-6})$$

TSS = Total suspended solids concentration found in receiving stream (or in effluent for intermittent stream)

$$\text{Total Metal Criteria (Ct)} = Cr / (C/Ct)$$

C/Ct = Fraction of metal dissolved; and Cr = Dissolved criteria value

Total Metals	Total Value	Stream Linear Partition Coefficient					Lake Linear Partition Coefficient				
		Kpo	alpha (a)	Kp	C/Ct	Dissolved Value in Stream	Kpo	alpha (a)	Kp	C/Ct	Dissolved Value in Lake
Arsenic	2	480000	-0.73	312530.4294	0.639977566	1.279955132	480000	-0.73	312530.4294	0.639977566	1.27995513
Chromium III	7.87	3360000	-0.93	1945072.742	0.222166388	1.748449471	2170000	-0.27	1851553.04	0.230797878	1.8163793
Copper	10.4	1040000	-0.74	673180.7453	0.452135707	4.702211348	2850000	-0.9	1679189.096	0.248599121	2.58543086
Lead	0.518	2800000	-0.8	1749605.065	0.241005139	0.124840662	2040000	-0.53	1493948.889	0.271068236	0.14041335
Nickel	0.6	490000	-0.57	350502.2031	0.613156888	0.367894133	2210000	-0.76	1413790.86	0.282101489	0.16926089
Silver	0	2390000	-1.03	1304569.5	0.298665702	0	2390000	-1.03	1304569.5	0.298665702	0
Zinc	0	1250000	-0.7	828360.267	0.40143739	0	3340000	-0.68	2239552.065	0.198759987	0

The following formula is used to calculate hardness dependent criteria

(Please refer to State Water Quality Standards for details)

Dissolved

WQC (ug/l)

Aluminum (T)	Acute	$e(1.3695[\ln(\text{hardness})]+1.8308)$	3234.646244	If Stream pH < 6.5, enter 750 in cell O113
	Chronic	$e(1.3695[\ln(\text{hardness})]+0.9161)$	1295.918317	If Stream pH < 6.5, enter 87 in cell P113
Cadmium (D)	Acute	$e(0.8968[\ln(\text{hardness})]-3.5699) \cdot CF1$	1.596137868	$CF1 = 1.136672 - 0.041838 \cdot \ln(\text{hardness})$
	Chronic	$e(0.7647[\ln(\text{hardness})]-4.2180) \cdot CF2$	0.439914443	$CF2 = 1.101672 - 0.041838 \cdot \ln(\text{hardness})$

			Dissolved WQC (ug/l)	
Chromium III (D)	Acute		$0.316 e(0.819[\ln(\text{hardness})]+3.7256)$	551.0293659
	Chronic		$0.860 e(0.819[\ln(\text{hardness})]+0.6848)$	71.67759951
Copper (D)	Acute		$0.960 e(0.9422[\ln(\text{hardness})]-1.700)$	12.93202601
	Chronic		$0.960 e(0.8545[\ln(\text{hardness})]-1.702)$	8.648739044
Lead (D)	Acute		$e(1.273[\ln(\text{hardness})]-1.46)*CF3$	61.77208289
	Chronic		$e(1.273[\ln(\text{hardness})]-4.705)*CF4$	2.407169388
Manganese (D)	Acute		$e(0.3331[\ln(\text{hardness})]+6.4676)$	2945.354265
	Chronic		$e(0.3331[\ln(\text{hardness})]+5.8743)$	1627.311235
Nickel (D)	Acute		$0.998 e(0.846[\ln(\text{hardness})]+2.255)$	452.3411118
	Chronic		$0.997 e(0.846[\ln(\text{hardness})]+0.0584)$	50.24113236
Silver (D)	Acute		$0.85 e(1.72[\ln(\text{hardness})]-6.59)$	2.99864332
Zinc (D)	Acute		$0.978 e(0.9094[\ln(\text{hardness})]+0.9095)$	154.1725819
	Chronic		$0.986 e(0.90947[\ln(\text{hardness})]+0.6235)$	116.8088485

CF3 = 1.46203 - 0.145712*ln(hardness)

CF4 = 1.46203 - 0.145712*ln(hardness)

POLLUTANTS	CAS No.	MQL	Instream Waste Concentration								Livestock&	Acute	Chronic	Human	Need
			Ambient	Effluent	Acute	Domestic	Chronic	Human	Domestic	Irrigation	Wildlife	Aquatic	Aquatic	Health	TMDL
			Conc.	Conc.	Aquatic	Supply	Aquatic	Health	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria
			Ca (ug/l)	Ce (ug/l)	2.13*Ce	Cd,dom (ug/l)	Cd (ug/l)	Cd,hh (ug/l)	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l
Radioactivity, Nutrients, and Chlorine															
Aluminum, total	7429-90-5	2.5	19.3	41.109	41.109	41.109	25.2978462	1E+100	5000	1E+100	3234.646244	1295.91832	1E+100	N/A	
Barium, dissolved	7440-39-3	100	60.3	128.439	128.439	128.439	79.0393846	2000	1E+100	1E+100	1E+100	1E+100	1E+100	N/A	
Boron, dissolved	7440-42-8	100	49.3	105.009	105.009	105.009	64.6209231	1E+100	750	5000	1E+100	1E+100	1E+100	N/A	
Cobalt, dissolved	7440-48-4	50	0	0	0	0	0	1E+100	50	1000	1E+100	1E+100	1E+100	N/A	
Uranium, dissolved	7440-61-1	0.1	0	0	0	0	0	30	1E+100	1E+100	1E+100	1E+100	1E+100	N/A	
Vanadium, dissolved	7440-62-2	50	0	0	0	0	0	1E+100	100	100	1E+100	1E+100	1E+100	N/A	
Ra-226 and Ra-228 (pCi/l)			0.0833	0.177429	0.177429	0.177429	0.10918708	5	1E+100	30	1E+100	1E+100	1E+100	N/A	
Strontium (pCi/l)			0	0	0	0	0	8	1E+100	1E+100	1E+100	1E+100	1E+100	N/A	
Tritium (pCi/l)			0	0	0	0	0	20000	1E+100	20000	1E+100	1E+100	1E+100	N/A	
Gross Alpha (pCi/l)			2.95	6.2835	6.2835	6.2835	3.86676923	15	1E+100	15	1E+100	1E+100	1E+100	N/A	
Asbestos (fibers/l)			0	0	0	0	0	7000000	1E+100	1E+100	1E+100	1E+100	1E+100	N/A	
Total Residual Chlorine	7782-50-5	33	0	0	0	0	0	1E+100	1E+100	11	19	11	1E+100	N/A	
Nitrate as N (mg/l)			0	0	0	0	0	10	1E+100	1E+100	1E+100	1E+100	1E+100	N/A	
Nitrite + Nitrate (mg/l)			0.779	1.65927	1.65927	1.65927	1.02108923	1E+100	1E+100	132	1E+100	1E+100	1E+100	N/A	
METALS AND CYANIDE															
Antimony, dissolved (P)	7440-36-0	60	0	0	0	0	0	6	1E+100	1E+100	1E+100	1E+100	640	N/A	
Arsenic, dissolved (P)	7440-38-2	0.5	1.279955132	2.72630443	2.72630443	2.72630443	1.6777258	10	100	200	340	150	9	N/A	
Beryllium, dissolved	7440-41-7	0.5	0	0	0	0	0	4	1E+100	1E+100	1E+100	1E+100	1E+100	N/A	
Cadmium, dissolved	7440-43-9	1	0	0	0	0	0	5	10	50	1.596137868	0.43991444	1E+100	N/A	
Chromium (III), dissolved	16065-83-1	10	1.748449471	3.724197372	3.724197372	3.72419737	2.29181377	1E+100	1E+100	1E+100	551.0293659	71.6775995	1E+100	N/A	
Chromium (VI), dissolved	18540-29-9	10	7.87	16.7631	16.7631	16.7631	10.3157538	1E+100	1E+100	1E+100	16	11	1E+100	N/A	

Chromium, dissolved	7440-47-3		7.87	16.7631	16.7631	16.7631	10.3157538	100	100	1000	1E+100	1E+100	1E+100	N/A
Copper, dissolved	7440-50-8	0.5	4.702211348	10.01571017	10.01571017	10.0157102	6.16351395	1300	200	500	12.93202601	8.64873904	1E+100	N/A
Lead, dissolved	7439-92-1	0.5	0.124840662	0.26591061	0.26591061	0.26591061	0.1636373	15	5000	100	61.77208289	2.40716939	1E+100	N/A
Manganese, dissolved	7439-96-5		2.4	5.112	5.112	5.112	3.14584615	1E+100	1E+100	1E+100	2945.354265	1627.31123	1E+100	N/A

POLLUTANTS	CAS No.	MQL	Instream Waste Concentration							Livestock&	Acute	Chronic	Human	Need	Health	TMDL
			Ambient	Effluent	Acute	Domestic	Chronic	Human	Domestic	Irrigation	Wildlife	Aquatic	Aquatic			
			Conc	Conc.	Aquatic	Supply	Aquatic	Health	Criteria	Criteria	Criteria	Criteria	Criteria			
		Ca (ug/l)	Ce (ug/l)	2.13*Ce	Cd.dom (ug/l)	Cd (ug/l)	Cd,hh (ug/l)	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l			
Mercury, dissolved	7439-97-6	0.005		0.011	0.02343	0.02343	0.02343	0.01441846	1E+100	1E+100	1E+100	1.4	0.77	1E+100	N/A	
Mercury, total	7439-97-6	0.005		0.011	0.02343	0.02343	0.02343	0.01441846	2	1E+100	0.77	1E+100	1E+100	1E+100	N/A	
Molybdenum, dissolved	7439-98-7			2.02	4.3026	4.3026	4.3026	2.64775385	1E+100	1000	1E+100	1E+100	1E+100	1E+100	N/A	
Molybdenum, total recoverable	7439-98-7			2.02	4.3026	4.3026	4.3026	2.64775385	1E+100	1E+100	1E+100	7920	1895	1E+100	N/A	
Nickel, dissolved (P)	7440-02-0	0.5		0.367894133	0.783614503	0.783614503	0.7836145	0.48222431	700	1E+100	1E+100	452.3411118	50.2411324	4600	N/A	
Selenium, dissolved (P)	7782-49-2	5		0	0	0	0	0	50	130	50	1E+100	1E+100	4200	N/A	
Selenium, dis (SO4 >500 mg/l)		5			0	0	0	0	50	250	50	1E+100	1E+100	4200	N/A	
Selenium, total recoverable	7782-49-2	5		0	0	0	0	0	1E+100	1E+100	5	20	5	1E+100	N/A	
Silver, dissolved	7440-22-4	0.5		0	0	0	0	0	1E+100	1E+100	1E+100	2.99864332	1E+100	1E+100	N/A	
Thallium, dissolved (P)	7440-28-0	0.5		0.261	0.55593	0.55593	0.55593	0.34211077	2	1E+100	1E+100	1E+100	1E+100	0.47	N/A	
Zinc, dissolved	7440-66-6	20		3.3	7.029	7.029	7.029	4.32553846	10500	2000	25000	154.1725819	116.808849	26000	N/A	
Cyanide, total recoverable	57-12-5	10		0	0	0	0	0	200	1E+100	5.2	22	5.2	140	N/A	
Dioxin	1764-01-6	0.00001		0	0	0	0	0	3.00E-05	1E+100	1E+100	1E+100	1E+100	5.1E-08	N/A	
VOLATILE COMPOUNDS																
Acrolein	107-02-8	50			0	0	0	0	18	1E+100	1E+100	1E+100	1E+100	9	N/A	
Acrylonitrile	107-13-0	20			0	0	0	0	0.65	1E+100	1E+100	1E+100	1E+100	2.5	N/A	
Benzene	71-43-2	10			0	0	0	0	5	1E+100	1E+100	1E+100	1E+100	510	N/A	
Bromoform	75-25-2	10			0	0	0	0	44	1E+100	1E+100	1E+100	1E+100	1400	N/A	
Carbon Tetrachloride	56-23-5	2			0	0	0	0	5	1E+100	1E+100	1E+100	1E+100	16	N/A	
Chlorobenzene	108-90-7	10			0	0	0	0	100	1E+100	1E+100	1E+100	1E+100	1600	N/A	
Clorodibromomethane	124-48-1	10			0	0	0	0	4.2	1E+100	1E+100	1E+100	1E+100	130	N/A	
Chloroform	67-66-3	50			0	0	0	0	57	1E+100	1E+100	1E+100	1E+100	4700	N/A	
Dichlorobromomethane	75-27-4	10			0	0	0	0	5.6	1E+100	1E+100	1E+100	1E+100	170	N/A	
1,2-Dichloroethane	107-06-2	10			0	0	0	0	5	1E+100	1E+100	1E+100	1E+100	370	N/A	
1,1-Dichloroethylene	75-35-4	10			0	0	0	0	7	1E+100	1E+100	1E+100	1E+100	7100	N/A	
1,2-Dichloropropane	78-87-5	10			0	0	0	0	5	1E+100	1E+100	1E+100	1E+100	150	N/A	
1,3-Dichloropropylene	542-75-6	10			0	0	0	0	3.5	1E+100	1E+100	1E+100	1E+100	210	N/A	
Ethylbenzene	100-41-4	10			0	0	0	0	700	1E+100	1E+100	1E+100	1E+100	2100	N/A	
Methyl Bromide	74-83-9	50			0	0	0	0	49	1E+100	1E+100	1E+100	1E+100	1500	N/A	
Methylene Chloride	75-09-2	20		1.67	3.5571	3.5571	3.5571	2.18898462	5	1E+100	1E+100	1E+100	1E+100	5900	N/A	
1,1,2,2-Tetrachloroethane	79-34-5	10			0	0	0	0	1.8	1E+100	1E+100	1E+100	1E+100	40	N/A	
Tetrachloroethylene	127-18-4	10			0	0	0	0	5	1E+100	1E+100	1E+100	1E+100	33	N/A	
Toluene	108-88-3	10			0	0	0	0	1000	1E+100	1E+100	1E+100	1E+100	15000	N/A	
1,2-trans-Dichloroethylene	156-60-5	10			0	0	0	0	100	1E+100	1E+100	1E+100	1E+100	10000	N/A	
1,1,1-Trichloroethane	71-55-6				0	0	0	0	200	1E+100	1E+100	1E+100	1E+100	1E+100	N/A	
1,1,2-Trichloroethane	79-00-5	10			0	0	0	0	5	1E+100	1E+100	1E+100	1E+100	160	N/A	
Trichloroethylene	79-01-6	10			0	0	0	0	5	1E+100	1E+100	1E+100	1E+100	300	N/A	
Vinyl Chloride	75-01-4	10			0	0	0	0	2	1E+100	1E+100	1E+100	1E+100	24	N/A	
ACID COMPOUNDS																
2-Chlorophenol	95-57-8	10			0	0	0	0	175	1E+100	1E+100	1E+100	1E+100	150	N/A	

2,4-Dichlorophenol	120-83-2	10		0	0	0	0	105	1E+100	1E+100	1E+100	1E+100	290	N/A
2,4-Dimethylphenol	105-67-9	10		0	0	0	0	700	1E+100	1E+100	1E+100	1E+100	850	N/A
4,6-Dinitro-o-Cresol	534-52-1	50		0	0	0	0	14	1E+100	1E+100	1E+100	1E+100	280	N/A

POLLUTANTS	CAS No.	MQL	Instream Waste Concentration								Livestock&	Acute	Chronic	Human	Need
			Ambient	Effluent	Acute	Domestic	Chronic	Human	Domestic	Irrigation	Wildlife	Aquatic	Aquatic	Health	TMDL
			Conc	Conc.	Aquatic	Supply	Aquatic	Health	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria
2,4-Dinitrophenol	51-28-5	50			0	0	0	0	70	1E+100	1E+100	1E+100	1E+100	5300	N/A
Pentachlorophenol	87-86-5	50			0	0	0	0	1	1E+100	1E+100	19	15	30	N/A
Phenol	108-95-2	10			0	0	0	0	10500	1E+100	1E+100	1E+100	1E+100	860000	N/A
2,4,6-Trichlorophenol	88-06-2	10			0	0	0	0	32	1E+100	1E+100	1E+100	1E+100	24	N/A
BASE/NEUTRAL															
Acenaphthene	83-32-9	10			0	0	0	0	2100	1E+100	1E+100	1E+100	1E+100	990	N/A
Anthracene	120-12-7	10			0	0	0	0	10500	1E+100	1E+100	1E+100	1E+100	40000	N/A
Benzidine	92-87-5	50			0	0	0	0	0.0015	1E+100	1E+100	1E+100	1E+100	0.002	N/A
Benzo(a)anthracene	56-55-3	5			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	0.18	N/A
Benzo(a)pyrene	50-32-8	5			0	0	0	0	0.2	1E+100	1E+100	1E+100	1E+100	0.18	N/A
3,4-Benzofluoranthene	205-99-2	10			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	0.18	N/A
Benzo(k)fluoranthene	207-08-9	5			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	0.18	N/A
Bis(2-chloroethyl)Ether	111-44-4	10			0	0	0	0	0.3	1E+100	1E+100	1E+100	1E+100	5.3	N/A
Bis(2-chloroisopropyl)Ether	108-60-1	10			0	0	0	0	1400	1E+100	1E+100	1E+100	1E+100	65000	N/A
Bis(2-ethylhexyl)Phthalate	117-81-7	10			0	0	0	0	6	1E+100	1E+100	1E+100	1E+100	22	N/A
Butyl Benzyl Phthalate	85-68-7	10			0	0	0	0	7000	1E+100	1E+100	1E+100	1E+100	1900	N/A
2-Chloronaphthalene	91-58-7	10			0	0	0	0	2800	1E+100	1E+100	1E+100	1E+100	1600	N/A
Chrysene	218-01-9	5			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	0.18	N/A
Dibenzo(a,h)anthracene	53-70-3	5			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	0.18	N/A
1,2-Dichlorobenzene	95-50-1	10			0	0	0	0	600	1E+100	1E+100	1E+100	1E+100	1300	N/A
1,3-Dichlorobenzene	541-73-1	10			0	0	0	0	469	1E+100	1E+100	1E+100	1E+100	960	N/A
1,4-Dichlorobenzene	106-46-7	10			0	0	0	0	75	1E+100	1E+100	1E+100	1E+100	190	N/A
3,3'-Dichlorobenzidine	91-94-1	5			0	0	0	0	0.78	1E+100	1E+100	1E+100	1E+100	0.28	N/A
Diethyl Phthalate	84-66-2	10			0	0	0	0	28000	1E+100	1E+100	1E+100	1E+100	44000	N/A
Dimethyl Phthalate	131-11-3	10			0	0	0	0	350000	1E+100	1E+100	1E+100	1E+100	1100000	N/A
Di-n-Butyl Phthalate	84-74-2	10			0	0	0	0	3500	1E+100	1E+100	1E+100	1E+100	4500	N/A
2,4-Dinitrotoluene	121-14-2	10			0	0	0	0	1.1	1E+100	1E+100	1E+100	1E+100	34	N/A
1,2-Diphenylhydrazine	122-66-7	20			0	0	0	0	0.44	1E+100	1E+100	1E+100	1E+100	2	N/A
Fluoranthene	206-44-0	10			0	0	0	0	1400	1E+100	1E+100	1E+100	1E+100	140	N/A
Fluorene	86-73-7	10			0	0	0	0	1400	1E+100	1E+100	1E+100	1E+100	5300	N/A
Hexachlorobenzene	118-74-1	5			0	0	0	0	1	1E+100	1E+100	1E+100	1E+100	0.0029	N/A
Hexachlorobutadiene	87-68-3	10			0	0	0	0	4.5	1E+100	1E+100	1E+100	1E+100	180	N/A
Hexachlorocyclopentadiene	77-47-4	10			0	0	0	0	50	1E+100	1E+100	1E+100	1E+100	1100	N/A
Hexachloroethane	67-72-1	20			0	0	0	0	25	1E+100	1E+100	1E+100	1E+100	33	N/A
Indeno(1,2,3-cd)Pyrene	193-39-5	5			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	0.18	N/A
Isophorone	78-59-1	10			0	0	0	0	368	1E+100	1E+100	1E+100	1E+100	9600	N/A
Nitrobenzene	98-95-3	10			0	0	0	0	18	1E+100	1E+100	1E+100	1E+100	690	N/A
n-Nitrosodimethylamine	62-75-9	50			0	0	0	0	0.0069	1E+100	1E+100	1E+100	1E+100	30	N/A
n-Nitrosodi-n-Propylamine	621-64-7	20			0	0	0	0	0.05	1E+100	1E+100	1E+100	1E+100	5.1	N/A
n-Nitrosodiphenylamine	86-30-6	20			0	0	0	0	71	1E+100	1E+100	1E+100	1E+100	60	N/A
Pyrene	129-00-0	10			0	0	0	0	1050	1E+100	1E+100	1E+100	1E+100	4000	N/A

1,2,4-Trichlorobenzene	120-82-1	10		0	0	0	0	70	1E+100	1E+100	1E+100	1E+100	70	N/A
------------------------	----------	----	--	---	---	---	---	----	--------	--------	--------	--------	----	-----

POLLUTANTS	CAS No.	MQL	Instream Waste Concentration								Livestock&	Acute	Chronic	Human	Need
			Ambient	Effluent	Acute	Domestic	Chronic	Human	Domestic	Irrigation	Wildlife	Aquatic	Aquatic	Health	TMDL
			Conc	Conc.	Aquatic	Supply	Aquatic	Health	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria
			Ca (ug/l)	Ce (ug/l)	2.13*Ce	Cd,dom (ug/l)	Cd (ug/l)	Cd,hh (ug/l)	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	
PESTICIDES AND PCBS															
Aldrin	309-00-2	0.01			0	0	0	0	0.021	1E+100	1E+100	3	1E+100	0.0005	N/A
Alpha-BHC	319-84-6	0.05			0	0	0	0	0.056	1E+100	1E+100	1E+100	1E+100	0.049	N/A
Beta-BHC	319-85-7	0.05			0	0	0	0	0.091	1E+100	1E+100	1E+100	1E+100	0.17	N/A
Gamma-BHC	58-89-9	0.05			0	0	0	0	0.2	1E+100	1E+100	0.95	1E+100	1.8	N/A
Chlordane	57-74-9	0.2			0	0	0	0	2	1E+100	1E+100	2.4	0.0043	0.0081	N/A
4,4'-DDT and derivatives	50-29-3	0.02			0	0	0	0	1	1E+100	0.001	1.1	0.001	0.0022	N/A
Dieldrin	60-57-1	0.02			0	0	0	0	0.022	1E+100	1E+100	0.24	0.056	0.00054	N/A
Diazinon	333-41-5				0	0	0	0	1E+100	1E+100	1E+100	0.17	0.17	1E+100	N/A
Alpha-Endosulfan	959-98-8	0.01			0	0	0	0	62	1E+100	1E+100	0.22	0.056	89	N/A
Beta-Endosulfan	33213-65-9	0.02			0	0	0	0	62	1E+100	1E+100	0.22	0.056	89	N/A
Endosulfan sulfate	1031-7-8	0.1			0	0	0	0	62	1E+100	1E+100	1E+100	1E+100	89	N/A
Endrin	72-20-8	0.02			0	0	0	0	2	1E+100	1E+100	0.086	0.036	0.06	N/A
Endrin Aldehyde	7421-93-4	0.1			0	0	0	0	10.5	1E+100	1E+100	1E+100	1E+100	0.3	N/A
Heptachlor	76-44-8	0.01			0	0	0	0	0.4	1E+100	1E+100	0.52	0.0038	0.00079	N/A
Heptachlor Epoixde	1024-57-3	0.01			0	0	0	0	0.2	1E+100	1E+100	0.52	0.0038	0.00039	N/A
PCBs	1336-36-3	0.2		0	0	0	0	0	0.5	1E+100	0.014	2	0.014	0.00064	N/A
Toxaphene	8001-35-2	0.3			0	0	0	0	3	1E+100	1E+100	0.73	0.0002	0.0028	N/A

Note: SCORET CODE for reference only. Codes for total form are used except for parameters which have criteria in both total and dissolved forms.

STEP 3: SCAN POTENTIAL INSTREAM WASTE CONCENTRATIONS AGAINST WATER QUALITY CRITERIA AND ESTABLISH EFFLUENT LIMITATIONS FOR ALL APPLICABLE PARAMETERS

No limits are established if the receiving stream is not designated for the particular uses.

No limits are established if the potential instream waste concentrations are less than the chronic water quality criteria.

The most applicable stringent criteria are used to establish effluent limitations for a given parameter.

Water quality criteria apply at the end-of-pipe for acute aquatic life criteria and discharges to public lakes.

If background concentration exceeds the water quality criteria, water quality criteria apply. And "Need TMDL" shown to the next column of Avg. Mass

Monthly avg concentration = daily max. / 1.5.

APPLICABLE WATER QUALITY-BASED LIMITS

The following formula is used to calculate the allowable daily maximum effluent concentration

See "Procedures for Implementing NPDES Permits in New Mexico" amended July 2009

Daily Max. Conc. = $C_s + (C_s - C_a)(F \cdot Q_a / Q_e)$

Monthly Avg. Conc. = Daily Max. Conc. / 1.5

Where: C_s = Applicable water quality standard

C_a = Ambient stream concentration

F = Fraction of stream allowed for mixing (1.0 is assigned to domestic water supply and human health uses)

Q_e = Plant effluent flow

Q_a = Criteria Low flow (4Q3) or Harmonic Mean flow for Human Health Criteria

