



UNITED STATES ENVIRONMENTAL PROTECTION
AGENCY
WASHINGTON, D.C. 20460

OFFICE OF WATER

DECISION MEMORANDUM

SUBJECT: Project Waiver of American Iron and Steel Requirements to the West Basin Municipal Water District in Carson, California for 12-Inch Globe Valves

FROM: Andrew Sawyers, Director
Office of Wastewater Management

Decision: The U.S. Environmental Protection Agency (EPA) is hereby granting a project waiver pursuant to the “American Iron and Steel” (AIS) requirements of the Clean Water Act Section 608 under the authority of Section 608(c)(2) to Carson, California (Applicant) for 12-inch globe valves. This waiver permits the use of globe valves, manufactured outside of the United States, in Carson, California’s Juanita Millender McDonald Carson Regional Water Recycling Plant Phase II Expansion Project, because no domestic manufacturers produce alternatives that meet the project’s technical specifications.

This waiver applies only to the proposed project funded by the Clean Water State Revolving Fund (CWSRF). Any other jurisdiction with projects funded by either the CWSRF, the Drinking Water State Revolving Fund, or the Water Infrastructure Finance and Innovation Act that wishes to use the same products must apply for a separate waiver.

Rationale: Section 608 of the Clean Water Act requires CWSRF assistance recipients for treatment works projects to use specific iron and steel products that are produced in the United States. EPA has the authority to determine whether it is necessary to waive this requirement based on certain circumstances set forth in Section 608(c) of the Clean Water Act. The provision states that, “[the requirements] shall not apply in any case or category of cases in which the Administrator [of EPA] finds that – . . . (2) iron and steel products are not produced in the United States in sufficient and reasonably available quantities and of a satisfactory quality.”

Background of Waiver Request: The Applicant provided information to EPA asserting that there are no domestic manufacturers producing 12-inch globe valves in sufficient and reasonably available quantities and of a satisfactory quality. These globe valves are necessary to connect the main infrastructure to the new custom engineered microfiltration system in Carson, California.

Assessment of Waiver Request: EPA conducted market research and a public comment period on the

supply and availability of these 12-inch globe valves. The basis of evaluation included thorough review of the waiver request submission, examination of domestic manufacturer catalogs or other technical data and marketing materials, personal communication with domestic manufacturers, inquiries of state staff, and outreach to contractors and engineers with expertise and familiarity with the project. During market research, EPA contacted fourteen (14) manufacturers and suppliers of these globe valves. None responded indicating they had potential domestic alternatives. EPA received no (zero) public comments to the waiver request. Therefore, EPA agrees with the assessment that no domestic manufacturers produce available products meeting the project's specifications.

Finding: Since the Applicant established a proper basis to specify the products required for this project, and because EPA substantiated the Applicant's claim through market research that these products are not available from a manufacturer in the United States, Carson, California is hereby granted a waiver from the AIS requirements. This waiver permits the purchase of 12-inch globe valves, as documented in the State of California Water Resources Control Board's waiver request submittal on behalf of the Applicant dated March 21, 2022.

If you have any questions concerning the contents of this memorandum, please contact Timothy Connor, Chemical Engineer, Water Infrastructure Division, at connor.timothy@epa.gov or (202) 566-1059.