AIM System Inspection and Testing Checklist: Category 1 or 2								
UST Facility			Person Completing Checklist					
Facility Name		Facility ID #	Name					
Physical Address			Company					
City	County	State	City		State			
UST Owner			Signature		Date Completed			
	scription	Line 1	Line 2	Line 3	Line 4			
Type of AIM Sys		□ 1 □ 2	□ 1 □ 2	□ 1 □ 2	□ 1 □ 2			
			rm for detailed systen	n description.				
Annual	Wa	alkthrough Insp	ections [280.36]					
Visually check containment sumps at endpoints for damage and leaks to the containment area or releases to the environment. Remove water and								
 debris. For double-walled sumps with interstitial monitoring, check for a leak in the interstitial area. 								
Every 30 Days								
Check that system is operating with no alarms or unusual operating conditions.								
Ensure records of system component testing listed below are reviewed and current		☐ Pass ☐ Fail	☐ Pass ☐ Fail	□ Pass □ Fail	□ Pass □ Fail			
Note: The items below are not required to be performed every 30-days as part of the walkthrough inspection. Most items must be performed annually, unless otherwise noted. Use this checklist to verify that each step has been performed within one year (i.e., 365 days) of the previous test, unless otherwise noted. If <i>No</i> is checked for any of the steps, the AIM system fails. Provide copies of all relevant test forms upon request to the UST implementing agency.								
Testing (Required Annually - Unless Otherwise Noted)								
	sole 280.40(a)(3)(i)	☐ Yes ☐ No	☐ Yes ☐ No					
	n configuration.			☐ Yes ☐ No	☐ Yes ☐ No			
Test alarm		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No			
Test battery b	packup	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No			
Date Last Test								
	Test Results	☐ Pass☐ Fail	☐ Pass☐ Fail	☐ Pass☐ Fail	□ Pass □ Fail			
Sensors 280.40(a)(3)(ii)								
Test alarm of communicati controller/mo		☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No			

AIM System Inspection and Testing Checklist: Category 1 or 2 Testing (Continued)							
Inspect for residual buildup.	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No			
Date Last Test							
Test Results	☐ Pass☐ Fail	□ Pass □ Fail	□ Pass □ Fail	□ Pass □ Fail			
ALLD 280.40(a)(3)(iii)		1					
DW piping. Verify integrity of interstitial space by air testing piping. Ensure vacuum pumps and pressure gauges are operating within manufacturer's specifications.	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No			
Monitoring reservoir. Note: Testing of this component covered below. Listed to show as part of ALLD.	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No			
• Containment sumps at end points. Note: Verification of integrity could be by testing of the sump or if the sump is DW, proving that the interstitial space of the containment sump has integrity. Annual integrity testing of containment sumps at endpoints that varies from that in 280.35(a)(1)(ii) may be used to test full area of sumps(s) or area of sump(s) to the point of each sensor's activation threshold, if equipped with liquid detecting sensor(s).	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No			
Date Last Test							
Test Results	☐ Pass ☐ Fail	□ Pass □ Fail	☐ Pass☐ Fail	□ Pass □ Fail			
Monitoring Points 280.40(a)(3)(iv)							
Monitoring Reservoir (P / V / Liquid)							
✓ Ensure proper communication of vacuum pumps and pressure gauges with sensors and controllers, as applicable. Verify that the pressure, vacuum, or liquid detecting sensor triggers the alarm at the appropriate threshold and communicates that to the monitoring console.	☐ Yes ☐ No	□ Yes □ No	☐ Yes ☐ No	☐ Yes ☐ No			
✓ P / V System Calibrated Per Manufacturer's Instructions. 280.40(a)(2)	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No			
Describe calibration completed and frequence							

AIM System Inspection and Testing Checklist: Category 1 or 2									
Testing (Continued)									
Description	Line 1	Line 2	Line 3	Line 4					
Containment Sumps at End Points 280.35(a)(1)(ii) – Required Once Every Three Years									
Test containment sumps used for piping interstitial monitoring to ensure liquid tight by using vacuum, pressure, or liquid testing.	☐ Yes ☐ No								
Notes: If DW containment sump with periodic monitoring of both walls of the sump, sump testing to comply with 280.35(a)(1)(ii) is not required.									
Owners and operators testing annually using a recognized low-level sump testing procedure would meet the regulatory requirement. If the owner and operator use an annual test that varies from what is allowed under 280.35 (a)(1)(ii), then a test that complies with 280.35(a)(1)(ii) must be completed every three years									
Date Last Test		_		_					
Test Results	☐ Pass☐ Fail	☐ Pass☐ Fail	☐ Pass☐ Fail	☐ Pass☐ Fail					
Comments									