U.S. EPA

Technical Systems Audit Checklist for the Teledyne T640 or T640x PM Continuous Monitors

1. Introduction and Overview:

This checklist is intended to support auditors and managers in conducting a Technical Systems Audit of the Teledyne T640 or T640x PM continuous monitor.

2. Summary of method and description:

The Teledyne API Model T640 and T640x are real-time, continuous particulate matter (PM) mass monitors that use scattered light spectrometry for measurement; specifically, they employ broadband spectroscopy using 90° white-light scattering with a polychromatic light-emitting diode (LED).

There are two designated methods of the T640 instrumentation. The model T640 with 640x option (T640x) is an approved Federal Equivalent Method (FEM) for PM_{2.5} [EQPM-0516-238], PM₁₀ [EQPM-0516-239], and PM_{10-2.5} [EQPM-0516-240]. The T640x operates at a total flow rate of 16.7 lpm with 5.0 lpm entering the measurement cell and the remaining 11.7 lpm discarded as bypass flow. The model T640 is an approved FEM for PM_{2.5} [EQPM-0516-236]. The T640 also measures PM₁₀ and PM_{10-2.5}, but only the PM_{2.5} fraction meets FEM requirements. The non-FEM channels of the T640 may be reported for AQI or other non-regulatory purposes of the data. The T640 operates with a single flow rate at 5.0 lpm.

3. Teledyne T640/T640x Set-up:


With two models (T640 or T640x) and two options for the location of the monitor (installed in an outdoor shelter or in a walk-in shelter), there are four basic set-ups of the method. While the available firmware and measurement principle are identical for each method and set-up, there are some differences in how the methods are configured. The key points and differences are noted in Table 1 below. Questions in the checklist are noted if they only apply to one method or one of the set-ups.


Table 1 – Models and Installation Set-Ups.

Installation set- up/Method	T640	T640x
Either Installation	 Inlet is essentially just protecting against precipitation as there is no well in the design. Operates with one air pump, which is located inside the unit. This flow is identified as the "sample flow" with a nominal flow rate of 5 lpm. With only one flow there is only one sample filter, located inside the front panel display of the monitor. 	 Inlet is a PM10 omni-directional sampling head designed to operate at 16.67 lpm. There is no second stage impactor (VSCC or WINS). Operates with two air pumps: The same sample flow (5 lpm) that works with a T640, and An external pump designed to provide the bypass flow so that the PM10 head operates at a total flowrate of 16.7 lpm. Thus, the bypass flow operates at 11.7 lpm. A second sample filter is connected to the bypass port located on the back of the T640x monitor.

Walk-in shelter installation	 Preferred installation location when there is space available inside a walk-in shelter. Downtube should be configured with a "Slip Coupler" so that sample flow (5 lpm) and SpanDust verification or calibration can be conducted inside the shelter while viewing the front panel display on the monitor. Optional - recommend insulating downtube inside the shelter so that Aerosol Sample Conditioner (ASC) does not need to work as hard and sample air relative humidity is more likely to stay in control (i.e., ≤ 35% relative humidity).
Outdoor shelter installation	 Alternate location for installation. Note: while outdoor set-ups are permitted with the method; care should be taken to avoid extreme heat inside the T640 chassis. This can be tracked with "box temperature".

Sample Flow Block Diagrams for each Method:





4. On-site Technical Systems Audit of Teledyne T640 or T640x

Table 2 – Technical System Audit General Information:

Date:	Standard Time:	
Auditor:	Auditor Organization:	
Site Name:	AQS Site ID:	
Monitoring Agency Staff:	Monitoring Agency:	

Conducting an on-site audit of the Teledyne T640 or T640x involves evaluating several aspects of the set-up, operation, maintenance, and reporting of the monitor. For this checklist we have grouped the questions into four areas:

- a. Items to review at the monitor
- b. Items to review in the firmware and data logger
- c. Items to review at the inlet.
- d. Maintenance and QC records to review

Table 3 – Audit Questions for the Teledyne T640 or T640x PM Continuous Federal Equivalent Method:

Date:			
Question #	Item	Response	Comments
Items to rev	iew at the Monitor:		
1	Confirm the model and location of	□ T640	☐ Walk-in Shelter
1	the PM _{2.5} continuous monitor?	□ T640x	☐ Outdoor Shelter
	Does this method match what is	Annual Plan:	Reported to AQS:
2	identified in the annual plan and	□ Yes	□ Yes
	reported to AQS?	□ No	□ No
3	Is there an FEM sticker on the PM _{2.5} continuous Monitor?	□ Yes	T640 = Automated Equivalent Method: EQPM-0516-236 T640x = all of the following: • Automated Equivalent Method: EQPM-0516-238 • Automated Equivalent Method: EQPM-0516-239
			Automated Equivalent Method: EQPM-0516-240

Date:				
Question #	Item	Response	Comm	ents
			EQPM-0516-236 US EPA Continuous PM _{2.5} FEM Ambient Particulate Monitor *Federal Equivalency Method (FEM) designations are in accordance with 40 CFR Part 53. The unit must be equipped with the designated accessories and operated in accordance with the operations manual.	EQPM-0516-238 US EPA Continuous PM _{2.5} FEM Ambient Particulate Monitor EQPM-0516-239 US EPA Continuous PM ₁₀ FEM Ambient Particulate Monitor EQPM-0516-240 US EPA Continuous PM _{10-2.5} FEM Ambient Particulate Monitor *Federal Equivalency Method (FEM) designations are in accordance with 40 CFR Part 53. The unit must be equipped with the designated accessories and operated in accordance with the operations manual.
4	What is the serial number and year of manufacture? These can be found on the back of the monitor. Serial number is identified as "S/N"	S/N: Year:	Example from back panel of the remarks of the remar	monitor.
5	Are there any concerns about the location of the monitor inside the walk-in shelter or small modular shelter?	□ Yes □ No	This is largely professional judger include substantial vibration whe blowing directly on down-tube w or poor access to monitor.	ere monitor is set-up; AC
6	Is an instrument manual for the PM _{2.5} continuous monitor available at the station (hardcopy or digital)? If so, what is the date on the manual?	☐ Yes☐ No Date:	The latest instrument manual ver Please check the manufacturer's Note: one manual covers both th	website for latest version.

Date:			
Question #	Item	Response	Comments
7	Is an SOP for the method available at the station? If so, identify approval date.	☐ Yes☐ No Approval Date:	If available, look for approval before trip.
8	T640x only - How far is the external sample pump placed away from the monitor? Is the pump isolated to minimize vibration to the monitor?	☐ Yes☐ No Estimated Distance:	Distance between the T640x and external pump will help to minimize vibration. Even placed a few feet away and not on same surface will help.
9	Describe any heat on or near the ASC. Is the downtube insulated?	☐ Yes☐ No ☐ Heat Sources:	Although insulating the downtube is not required, this may help the ASC perform better.
10	Ask operator to open the front door of monitor. Observe internal filter and document a date of install (if noted) and condition of the filter (e.g. note color of filter or any darkness). Note:	Date of install: Filter Condition:	We recommend dating the filter with a date of install to track its life. Check logbooks. Note: direction of filter unit's installation may result in aerosol accumulating on the inner layer of the filter rather than outer layer; therefore, it may be difficult to observe without very careful examination.

Date:			
Question #	Item	Response	Comments
11	With front door of monitor still open, observe tubing that leads from the optical cell: 1. Is there any noticeable SpanDust [this will be white to beige in color]. 2. Is there any SpanDust visible in any other tubing?	☐ Yes☐ No If yes, where: ☐ Yes☐ No If yes, where: ———————————————————————————————————	tubing from optical cell cup and T&RH sensor 2.5mm hex screws 2.5mm hex screws 2.5mm hex screws view tubing with the main cover off; that option is usually not available. Recommend using a flashlight or light on phone to get a better view of the tubing. Temp & RH sensor T&RH sensor tubing
12	T640x only - Observe the filter connected to the back of the monitor. Document a date of install (if noted) and condition of the filter (e.g. note color of filter or any darkness).	Date of install: Filter Condition if viewable:	Check logbooks.
13	Ask the operator to show you the supplies and equipment used for cleaning the optics chamber. Are the appropriate supplies and equipment available?	□ Yes □ No	 Minimally, this should at least include: Disposable lint-free cloth or similar. Can of air designed to use with computer parts (do not use cylinder compressed air or similar as this may be too strong and damage parts). Can use cotton tip applicator or similar for areas where cloth won't fit.

Date:			
Question #	Item	Response	Comments
	Note: some agencies take units to their lab to perform cleaning; therefore, equipment may not readily be available in the field.		
14	Walk-in shelter installations only – [does not apply to set-ups located in an outdoor shelter] – Does the downtube inside the shelter have a "Slip Coupler"? This allows the sample flow and SpanDust verification/calibration to be conducted inside the shelter.	□ Yes □ No	Walk-in shelters should include use of a slip coupler. This allows flow verifications, calibrations, and audits of sample flow (5 lpm) from inside a walk-in shelter. Slip Coupler in normal position (to the left). Slip coupler in open position (to the right).
15 16	Walk-in shelter installations only – [does not apply to set-ups located in an outdoor shelter] – Ask the operator to show you a separate ambient temperature probe available for temporary use when flow verifications/calibrations are being conducted. Is this available? Describe any other issues with the monitor.	□ Yes □ No	This ambient temperature device will have a quick connect to temporally attach to the temperature connection at the back of the T640 chassis. A temperature probe for use inside the walk-in shelter is required as the ambient temperature probe attached to the monitor must represent the same air being used in the flow verification/calibration/audit.
	monitor.		
Items to revi	iew in the Firmware and data logger:	<u> </u>	
	Review Dashboard Parameters	Amb P. (mm Hg/kPa	Sample Temp. (°C)
47	available through the front panel	Amb T. (°C)	Sample RH (%) [≤35%]
17	display of the monitor. Document	PM _{2.5} Conc. (μg/m ³)	Current PMT hv
	the parameters listed and note any	PM ₁₀ Conc. (μg/m ³)	LED Temp. (°C)

Date:			
Question #	Item	Response	Comments
	outside of an acceptable tolerance or that may appear to be incorrect (e.g.,	PM ₁₀ STP (μg/m ³) [T640x only]	Pump PWM (%) [<80%]
	a pressure that cannot represent	PMT Setting	Sample Flow (lpm) [±5%; 4.75 – 5.25 lpm)
	ambient pressure). Parameters with	Box T. (°C)	Valve PWM (%) [<85%]
	an acceptable tolerance are identified in bold.	ASC Heater Duty	Total Flow (lpm) [±5%; 15.87 – 17.54 lpm)
	identined in bold.	P3 Value	
18	Are there any alerts that have been initiated on the front panel display?	□ Yes □ No	List any alerts with date and time.
19	What version of software is identified on the monitor? Firmware is listed on the dashboard as the "Package Version"		Approved firmware includes: 1.0.2.126 or later Latest version of firmware as of Spring 2022 is: 1.4.24.512 Note: it is not always necessary to upgrade to the latest firmware; check manufacturer's web site for details.
20	Review the most recent zero-test data from monthly QC sheet. Does the zero-value read 0.0 for each PM metric (i.e., PM ₁₀ and PM _{2.5})?	□ Yes □ No	Zero test may also be described as the leak test.
21	During the last Zero Test was any maintenance performed to get the PM metrics to 0.0 ug/m3?	□ Yes □ No	Describe/identify maintenance if any:
22	Observe the last PM _{2.5} and PM ₁₀ data reported on the LCD screen and compare this to data reported at the	□ Yes □ No	Note, a T640x may be reporting both PM10 LC and PM10 STP. A T640 monitor may only have PM10 LC for PM10. PM10: PM2.5:

Date:			
Question #	Item	Response	Comments
	station data logger; are they the same?		PM10-2.5:
		□ Yes	
		□ No	An AIRNowTech account is required to access the concentration
	Are data from this monitor being	Start Hour:	data; however, the "obs" file page is available without a password at:
	reported to AIRNow/AIRNowTech or	Datalogger PM2.5:	http://files.airnowtech.org/?prefix=airnow/today/
	their own agencies web site? If so,	Datalogger Fiviz.5.	Review monitor data for the appropriate hour in file:
23	document the last hour for $PM_{2.5}$ (include PM_{10} , if available) on the	AIRNow PM2.5:	"pmfine_MMDDYY.obs"
	data logger and compare to same	Datalogger PM10:	Note: There may be minor differences in what's viewed as
	hour from AIRNow/AIRowTech.		AirNow truncates data as it comes in to 1 decimal place for
		AIRNow PM10:	PM _{2.5} and integers for PM ₁₀ .
	Is the clock on the T640/T640x set to	□ Yes	
24	run on local standard time (i.e., not day light savings time)?	□ No	
		□ Yes	
		□ No Monitor Time:	
	Compare time on T640/T640x to	Wioritor Time.	Differences of up to one minute should be considered
25	time of data logger; is there any	Datalogger	acceptable. Even if there is a difference of more than a minute
23	difference in time and if so how many minutes?	Time:	the data are still acceptable as the datalogger clock establishes the time period of record.
		Min	
		Difference:	
			1

Date:				
Question #	Item	Res	ponse	Comments
26	If applicable, describe any other issues in the firmware or data logger?			
Activities to	review at monitors' inlet:			
27	Is the PM inlet a "pie pan" design? Or a Teledyne TSP inlet?		PM10 pie pan inlet Teledyn e TSP Other?	
28	Does the monitors inlet meet siting criteria?		Yes No	2-15 meters above ground level; >2 meters from supporting structures; >10 meters from trees. See Table E-4 of Part 58 for more details.
29	Is the monitors inlet intended to be "collocated" with another PM monitor or sampler?		Yes No	The basic requirement is 1-4 meters in the horizontal plane. A waiver allowing up to 10 meters horizontal distance and up to 3 meters vertical distance (inlet to inlet) between a primary and collocated sampler may be approved by the Regional
	And if it is, does it meet requirements for collocation?		Yes No	Administrator for sites at a neighborhood or larger scale of representation during the annual network plan approval process. See Appendix A to Part 58; section 3.2.3.4(c)
30	Open the inside of the PM ₁₀ inlet. Describe the cleanliness of the inlet well.			The PM ₁₀ inlet should only be inspected with data not being collected on the data management system.
31	Is there a gill screen or similar near the inlet that is also connected to the PM _{2.5} continuous monitor to provide an ambient temperature reading?		Yes No	

Date:			
Question #	Item	Response	Comments
32	Do the Inlet and down tube appear perpendicular to the ground?	□ Yes	Best judgement is fine.
33	Describe any other issues at the monitors' inlet?		
Maintenance	e and QC Records to review:	T	
34	Does the agency use an audit sheet for regular maintenance and verifications? Or logbook?	□ Yes □ No	Describe what is being used: Is there a logbook for the site or monitor or both? Electronic or hardcopy logbooks:
35	Monthly checks: Is there a record documenting that the following checks are being performed at least monthly?	Yes No ☐ Zero Test (May be labeled as a leak check) ☐ Barometric Pressure ☐ Ambient Temperature check ☐ Total Flow - (T640x only) ☐ Sample Flow ☐ PM10 inlet well is cleaned is cleaned at least monthly - (T640x only)	
36	Quarterly checks: Is there a record documenting that the following checks have been performed within the last 3 months?	□ □ PM10	Dust check inlet (above the well) - (T640x only) inlet - (T640 only)
37	6-month maintenance: Is there a record documenting that the following maintenance has been performed within the last 6 months?	□ □ Temp	al monitor cleaning – RH and optical sensor? erature sensor cleaning? tube cleaning?
38	12-month maintenance: Is there a record documenting that the following maintenance has been performed within the last 12 months?		nternal (5.0 lpm) Disposable Filter Unit (DFU) [inside front panel] xternal (11.67 lpm) Disposable Filter Unit [at back of instrument]

Date:			
Question #	Item	Response	Comments
39	Are the appropriate audit devices and equipment available as needed? Also, is certification within last 12 months? Expiration/Calibration date of flow audit device:	☐ ☐ Tempe	netric Pressure? erature? or 16.7 lpm (T640x only)? or 5.0 lpm?
	For the SpanDust, what is the stated value and expiration date on the side of the bottle?	Value identified on Span dust bottle: Expiration date of SpanDust listed on bottle:	
40	Is the SpanDust bottle secured in a manner such that ambient dust or dirt cannot get into the bottle while stored? (i.e., tubing is connected to both ports on top of bottle)	SpanDust that is more than 12 months in age is expected to continue to function properly. EPA recommends using a SpanDust lifespan of 3 years when stored appropriately (dry and secured) – or longer where there is evidence to support it. Yes No	
41	Describe any other preventative or routine maintenance being conducted.		

While on site, also perform the following:

- a. Interview the operator and have routine procedures described.
- b. Ask for documentation providing evidence that the flow standards being utilized by the operator and the agency's own auditor (these are required to be separate devices) are NIST traceable and within certification. The Agency office may need to be contacted for these.
- c. Communicate any items that can be addressed in the field without compromising data quality.
- d. Identify any photos collected for TSA documentation.