


ONE VISION. ZERO EMISSIONS.



# Reshaping The Grid Through Gas Stewardship:

## How Insulating Gas Reconditioning and Recycling Can Lower Your Carbon Footprint

DILLO  
CERTIFIED GAS






Let's start with a



ONE VISION. ZERO EMISSIONS.



# SF<sub>6</sub> – A brief overview





- Discovered in 1901 by Henri Moissan & Paul LaBeau
- Characteristics:
  - **Manmade**
  - **Colorless & Odorless**
  - **Inert**
  - **Dielectrically Strong & Unmatched Arc Quenching**
  - **Thermally Stable**
  - **Self-Healing**




- 100-year Global Warming Potential (GWP) 23,900<sup>1</sup>
- Atmospheric Lifespan of 3,200 years<sup>1</sup>
- 1lb of SF<sub>6</sub> emitted is equal to 10.3 tons CO<sub>2</sub>
  - *2.2 Passenger vehicles driven for one year*
  - OR*
  - *24,786 miles driven by an average passenger vehicle*




1: Source: Climate Change 1995, The Science of Climate Change: Summary for Policymakers and Technical Summary of the Working Group I Report, page 22  
Retrieved from: <http://unfccc.int/process/transparency-and-reporting/greenhouse-gas-data/greenhouse-gas-data-unfccc/global-warming-potentials>

- Manufactured by method of electrolysis
- Manufacturing in North America outlawed by the Kyoto Protocol
  - Currently manufactured overseas in Russia and Asia
- By-products and impurities are a side effect of production
  - $SF_4$ ,  $SF_2$ ,  $S_2F_2$ ,  $S_2F_{10}$
  - Air, moisture,  $CO_2$
- Contaminants are filtered as a part of the refining process
- Approximately 10,000 tons of  $SF_6$  are produced each year
- Manufacturing process is known source of emissions<sup>2</sup>



2: Source: Hu Jianxin, et al. "Sulfur Hexafluoride (SF<sub>6</sub>) Emission Estimates for China: An Inventory for 1990-2010 and a Projection to 2020." Environmental Science & Technology, April 2013, Vol. 47, Issue 8, pp 3848-3855.

ONE VISION. ZERO EMISSIONS.



# SF<sub>6</sub> Gas – The Challenge



### Initiating a Greener Solution

In Nov 2002, at the **International Conference on SF<sub>6</sub> and the Environment: Emission and Reduction Strategies EPA workshop**, a Technical Paper & Case Study by Solvay Fluor, AGA Gas and AEP, was presented regarding a program launched which provided the opportunity to initiate an SF<sub>6</sub> gas re-use program consistent with environmental awareness and protection. The case study summarized the process to the following highlighted principles:

- Analyze failed SF<sub>6</sub> gas
- Recover & reclaim SF<sub>6</sub> gas into temp storage containers for proper transport
- Transport SF<sub>6</sub> gas
- Perform reconditioning
- Return to the supply stream for use in GIE



They understood that the SF<sub>6</sub> gas needed to meet the requirements for GIE that previously relied on the use of virgin SF<sub>6</sub> gas. The case study also outlined the importance of inventory management. It was very clear that the user needed transparency to ensure that every kilogram/pound of used SF<sub>6</sub> was accounted for and tracked throughout the cycle of the Re-Use Program.





In reference to the recently updated Intergovernmental Panel on Climate Change (ipcc) document, 2019 Refinement of the 2006 IPCC Guidelines for National Greenhouse Gas Inventories, we determined that an estimate of 0.03kg to 0.08kg of SF<sub>6</sub> gas is emitted to the atmosphere per every 1kg (2.2lbs) of SF<sub>6</sub> gas produced.

Based on this estimate it may be determined that for every 100lbs (45.35kg) of Virgin SF<sub>6</sub> gas received into North America, an estimated 3.0lbs to 8.0lbs. of SF<sub>6</sub> gas is emitted into the atmosphere during production.

During the reconditioning process we estimate that for reconditioning of 100lbs (45.35kg) of SF<sub>6</sub> gas that starts at 95% pure and is reconditioned to 99.0% or greater, <0.64lbs of SF<sub>6</sub> gas is emitted into the atmosphere.

When proper handling is performed in the field during recycling, < 0.05lbs of SF<sub>6</sub> gas is emitted.

The document goes on to further state, *“In addition to the compounds being intentionally produced, a variety of fluorinated GHG by-products can be emitted from fluorochemical manufacturing processes. Emissions of these other fluorinated GHGs can exceed emissions of the compound being intentionally produced.”*




100lbs of Virgin SF<sub>6</sub> Gas produced



100lbs of Reconditioned SF<sub>6</sub> Gas  
(95% purity to >99.0%)



100lbs of Recycled SF<sub>6</sub> Gas  
(>97.0%)





**Task Force on National Greenhouse Gas Inventories**

ipcc  
INTERGOVERNMENTAL PANEL ON climate change

WMO UNEP

IPCC web sites

**Publications**

**2019 Refinement**


Top Vol1 GGR Vol2 Energy Vol3 IPPU Vol4 AFOLU Vol5 Waste

**2019 Refinement to the 2006 IPCC Guidelines for National Greenhouse Gas Inventories**  
Volume 3  
**Industrial Processes and Product Use**

Chapter	Chapter Name
-	Cover Page of Volume 3
1	Introduction
3	Chemical Industry Emissions
4	Metal Industry Emissions
6	Electronics Industry Emissions
7	Emissions of Fluorinated Substitutes for Ozone Depleting Substances Calculation Example for 2F1 (Tier 2) (MS-Excel)
8	Other Product Manufacture and Use
Annex 1	Worksheets
Annex 4	Glossary for Industrial Processes and Product Use Sector
Annex 5	Mapping Tables
Appendix 1	Possible Approaches for Estimating Fluorinated Compounds Emissions from Textile, Carpet, Leather and Paper Industries: Basis for Future Methodological Development


Home IPCC  
IPCC-TFI Home  
Organization  
Publications  
2019 Refinement  
Wetlands Supplement  
KP Supplement  
2006 IPCC Guidelines  
GPG-LULUCF  
Degradation of Forest  
GPG2000  
Revised 1996 IPCC Guidelines  
Technical Bulletins  
Presentations  
Support to Inventory Compilers  
Emission Factor Database (EFDB)  
Inventory Software  
Meetings  
FAQs  
Links  
Electronic Discussion Group (EDG)

© The Nobel Foundation  
IPCC honoured with the 2007 Nobel Peace Prize



<https://www.ipcc-nggip.iges.or.jp/public/2019rf/vol3.html>

ONE VISION. ZERO EMISSIONS.



What about the alternatives?






		Sulfur-hexafluoride	Clean-Air	Carbon Dioxide and Oxygen	C4-Fluoronitrile	C5-Fluoroketone
Base Gas	Chemical Formula	SF <sub>6</sub>	80% N <sub>2</sub> + 20% O <sub>2</sub>	70% CO <sub>2</sub> + 30% O <sub>2</sub>	(CF <sub>3</sub> ) <sub>2</sub> CFCN	(CF <sub>3</sub> ) <sub>2</sub> CFC(O)CF <sub>3</sub>
	CO <sub>2</sub> <sub>e</sub> (GWP)	23,500	0	<1	2,210	1
	Boiling Point	-64°C	<-183°C	-50C	-5°C	+27°C
	Dielectric Strength	1.00	0.43	0.77	2.20	1.70
Gas Mixture	Background (gases)	Pure or with N <sub>2</sub> or CF <sub>4</sub>	80% N <sub>2</sub> + 20% O <sub>2</sub>	70% CO <sub>2</sub> + 30% O <sub>2</sub>	~90% CO <sub>2</sub>	~90% O <sub>2</sub> With N <sub>2</sub> or CO <sub>2</sub>
	CO <sub>2</sub> <sub>e</sub> (GWP)	23,500	0	<1	~380	<1
	Lowest Operating Temperature	-30°C *	-50°C	-50C	-30°C	0°C to +5°C -20°C possible
Internal Arc Reaction	Decomposition Products	HF, S <sub>x</sub> F <sub>y</sub> , SOF <sub>x</sub> , F <sub>2</sub> , SO <sub>x</sub> , CF <sub>4</sub>	If applicable: O <sub>3</sub> , NO <sub>x</sub>	CO, HF, O <sub>3</sub>	CO, HF, C <sub>n</sub> F <sub>2n+2</sub> , other Fluorinated Compounds	CO, HF, COF <sub>2</sub> , C <sub>x</sub> F <sub>y</sub> , other Fluorinated Compounds
	Toxicity of Decomposition Products	Slightly toxic (Hodge-Sterner)	Typically None	Relatively harmless (Hodge-Sterner)	Practically non-toxic (Hodge-Sterner)	

## Alternatives to SF<sub>6</sub> are proving to be a promising advancement in the environmental control of GHG emissions

- However, it is also important to consider the following<sup>1</sup>:
  - No measurable improvements currently exist as it is related to safety for handling of SF<sub>6</sub> alternatives vs SF<sub>6</sub>
  - New gas mixtures generate arc byproducts. Compatibility testing with existing switchgear materials have led to acceptable solutions
  - Toxicity of both the base gas and arc byproducts must be considered. Evaluation of these compounds for health and safety is paramount.
  - The interrupting capability of switchgear using SF<sub>6</sub> alternatives is largely based upon CO<sub>2</sub> gas mixtures. CO<sub>2</sub>, in orders of magnitude, is more permeable than SF<sub>6</sub> and the sealing technologies of switchgear will be affected.
  - SF<sub>6</sub> alternative equipment using “Technical Grade Air” and vacuum interrupters operates at a significantly higher pressure than SF<sub>6</sub> equipment. The static seals and dynamic seals presently used in switchgear will be challenged to cope with the higher pressures.
  - Vacuum interrupters in equipment using “Technical Grade Air” currently are still limited in their power handling.
  - All the new gas mixtures operate at higher pressures as compared to SF<sub>6</sub>. This presents two challenges; first, the design of pressure vessels which can operate safely and reliably for long periods of time; and second, customer acceptance of switchgear with higher operating pressures. Higher gas pressures can also mean higher leakage rates.

<sup>1</sup>(Ref: Alt Gas Mixtures Status and Strategy Considerations – George Becker – Power Engineer)

ONE VISION. ZERO EMISSIONS.



# On-Site Gas Processing for Immediate Re-Use









Accountability starts with nameplate value & actual pressure vs temperature (i.e. identifying leaks and/or previous reporting inaccuracies)

BREAKER TYPE	120-SPNT-63J	MECHANISM TYPE	CURRENT SWITCHING	BW-J4
RATED MAXIMUM VOLTAGE	145 kV	RATED CAPACITANCE CURRENT SWITCHING		
RATED CONTINUOUS CURRENT	3000 A	RATED OVERHEAD LINE CHARGING CURRENT	53 A	
RATED POWER FREQUENCY	50 Hz	ISOLATED BANKABLE CURRENT	35 A	
RATED SHORT CIRCUIT CURRENT	403 kA	BACK TO BACK SHORT CURRENT	N/A	
RATED OPERATING DUTY CYCLE	O-0.3s-CO-15s-CO	TRANSIENT INRUSH CURRENT PEAK	N/A	
PERCENT 50% COMPONENT	53%	TRANSIENT INRUSH CURRENT FREQUENCY	N/A	
SHORT-TIME CURRENT DURATION	1 s	GAS WEIGHT	5603 kg	
RATED INTERRUPTING TIME	3 CYCLES	TOTAL WEIGHT	85 psig	
RATED PULL WAVE LIGHTNING IMPULSE	650 kV	GAS PRESSURE AT 20°C (68°F) NORMAL	71 psig	
WITHSTAND VOLTAGE	1575 kA	ALARM	MINIMUM	
RATED OUT OF PHASE SWITCHING CURRENT	N/A kV	MOTOR CONTROL VOLTAGE RANGE	104 TO 127 VAC	
RATED SWITCHING IMPULSE WITHSTAND VOLTAGE	N/A kV	MOTOR CURRENT AT RATED VOLTAGE	2.0 A	
TERM TO TERM CIRCUIT BREAKER OPEN	80 TO 140 VDC	CLOSE CURRENT AT RATED VOLTAGE	6.3 A	
TERM TO END CIRCUIT BREAKER CLOSED	70 TO 140 VDC	TRIP CURRENT AT RATED VOLTAGE	2 x I.E.A	
CONTROL VOLTAGE RANGE-CLOSING	TRIPPING	SCHEMATIC DIAGRAM	020360	
SERIAL NUMBER	36000097270006	INSTRUCTION BOOK	PEB-0154	
YEAR OF MANUFACTURE	2010	PARTS LIST	PEB-0160	
AMBIENT TEMPERATURE RANGE	-30C TO +45C			
70% S.F. WITH TRV CAPACITOR	83KA			
50% S.F. WITH TRV CAPACITOR	83KA			
70% S.F. W/O TRV CAPACITOR	80KA			
50% S.F. W/O TRV CAPACITOR	80KA			

100 KA RATING FOR 30% SHORT LINE FAULTS REQUIRES 3000F INSULATION CAPACITANCE PER PHASE, LOCATED ON THE LINE SIDE OF THE BREAKER AND WITHIN 30 FEET FROM THE JUNCTION OF THE LINE CIRCUIT WITH THE STATION BUS.





## Key Tools and Resources

*Having the proper tools is the key to success...*



*What size and type gas handling system is required?*



*What is the quality of the gas?*



*How much gas storage?*



*Are adapter fittings needed?*



*Is additional filtration required?*

- Perform condition analysis of the gas in the GIE
  - Ideally test at least three parameters:
    - **Moisture content**
    - **Purity**
    - **Arc Byproduct**
  - Alternative mixtures may require additional contaminants to be detected
  - This is also a good time to check your service hoses for integrity via the “leak-up” method



Contaminant	In-service	Re-use
Non-reactive gases (air / N <sub>2</sub> )	Up to 3%	Up to 3%
Reactive gases (SO <sub>2</sub> , SOF <sub>2</sub> )	500 PPM <sub>v</sub>	12 PPM <sub>v</sub>
Moisture – GCB only	200 PPM <sub>v</sub>	200 PPM <sub>v</sub>

	IEC 60376 specification for new SF6 gas	IEC 60480 specification for used SF6 gas	IEC 62271-4 SF6 reuse specification
Air / CF <sub>4</sub>	Max. 1 vol.-%	< 3 vol.-%	< 30 vol-% air < 5 vol-% CF <sub>4</sub>
Moisture (Dew point)	-36 °C* at p <sub>a</sub> 1 bar < 25 ppm (mass)	-23 °C* at p <sub>a</sub> 1 bar <b>(medium voltage)</b> -36 °C* at p <sub>a</sub> 1 bar <b>(high voltage)</b>	< 1,000 ppm (mass) approx. +4.5 °C at p <sub>a</sub> 1 bar
Oil	< 10 ppm (mass)	< 10 ppm (mass)	< 1,000 ppm (mass)
HF, SO <sub>2</sub>	< 1 ppm <sub>v</sub>	< 12 ppm <sub>v</sub> SO <sub>2</sub> < 50 ppm <sub>v</sub> total	> 12 ppm <sub>v</sub> SO <sub>2</sub> > 50 ppm <sub>v</sub> total
* measured at ambient pressure			


- On-site reconditioning is achieved with filtration systems
  - Pre-filter (external to gas handling cart)
  - On-board filters
    - A combination of both is ideal for best results
- Filtration systems reduce moisture and eliminate by-products
  - Air and other non-reactive gases CANNOT be removed by on-site processes
- Reconditioned gas qualifies for immediate re-use
- Standards for re-use are set by:
  - CIGRE
  - IEC
  - IEEE
  - ANSI



The perfect recovery is achieved with zero emissions

- Determine how much gas is recovered
  - Track the initial and final compartment pressure
  - Track and log weight of the gas recovered
- Different rules apply to leaking SF<sub>6</sub> GIE
  - Recovery prematurely stopped at 1-3 psig
  - Recover remaining gas into separate cylinders
    - Air intrusion is almost certain once in the vacuum stage of recovery
    - Separating the positive & vacuum stages ensures maximum reusable SF<sub>6</sub> on-site
  - C4/C5 mixtures may require complete replacement due to ratio conflicts with partial recovery

Recovery Percentage Chart



$$\left( \frac{P_i - P_f}{P_i} \right) \times 100 = \% \text{recovered}$$


PI = Initial System Pressure in mmHg absolute  
 PF = Final System Pressure in mmHg absolute

## FILLING

- Be sure to check the OEM's manual or nameplate for accurate SF<sub>6</sub> capacity information.
- Accidentally overfilling GIE could result in an SF<sub>6</sub> emission by engaging a pressure relief valve (rupture disk).
- Tracking gas weights by documenting SF<sub>6</sub> movements and using a cylinder weight scale and/or mass flow meter can aid with preventing both positive and negative emissions.
- Always set regulators in a static environment. Failure to do so may result in excessive pressure settings and potential rupture disk failures.



ONE VISION. ZERO EMISSIONS.



# Off-Site Reconditioning Process for Insulating Gases








### Intake & Analysis of Used SF<sub>6</sub>

- Low Purity
- High H<sub>2</sub>O\*
- Presence of SO<sub>2</sub>\*



Account for weight of SF<sub>6</sub> analyzed and to be reconditioned

\* CIGRE ; IEEE; ANSI; IEC; ASTM




Introduce into SF<sub>6</sub> supply stream



Perform SF<sub>6</sub> reconditioning



Analysis of Reconditioned SF<sub>6</sub>




Fill into clean (non-contaminated) SF<sub>6</sub> storage containers



Confirm analysis of reconditioned SF<sub>6</sub> meets/exceeds standards for re-use\*

Report#:	S-2975	Service#:	0	Date:	1/20/2020	Pallet#:	1	
AssetTag Number	Cylinder Serial Number	Cylinder Certification Date	Purity (Vol %)	Moisture	Decomp (SO <sub>2</sub> /SO <sub>2</sub> F <sub>2</sub> )	Tare Weight	Gross Weight	SF <sub>6</sub> Weight
	SG862500Y	9/2014+	100.0%	<40 PPMv	PPMv	1,454.0 LBS	2,554.0 LBS	1,100.0 lbs
	6169-33	8/2014+	100.0%	<40 PPMv	PPMv	1,388.0 LBS	2,488.0 LBS	1,100.0 lbs
	4890-26	4/2011+	100.0%	<40 PPMv	PPMv	1,452.0 LBS	2,562.0 LBS	1,100.0 lbs
	4057-0	9/2014+	100.0%	<40 PPMv	PPMv	1,430.0 LBS	2,530.0 LBS	1,100.0 lbs
	4057-17	9/2014+	100.0%	<40 PPMv	PPMv	1,407.0 LBS	2,507.0 LBS	1,100.0 lbs



Account for weight of SF<sub>6</sub> analyzed and reconditioned



IEC specifications (standards) for sulphur hexafluoride

	IEC 60376 Specification for new SF <sub>6</sub> gas	IEC 60480 Specification for used SF <sub>6</sub>
<b>SF<sub>6</sub></b>	> 98.5 vol.-% For gas mixtures: > 99.7 Vol.-%	> 97 Vol.-% For gas mixtures: ±5 % from the nominal value
<b>Air/CF<sub>4</sub></b>	Air: < 10,000 µl/l (i.e. 1 Vol.-%) for pure SF <sub>6</sub> gas For gas mixtures: < 2,000 µl/l (i.e. 0.2 vol.-%) CF <sub>4</sub> : < 4,000 µl/l (i.e. 0.4 Vol.-%) for pure SF <sub>6</sub> gas For gas mixtures: < 800 µl/l (i.e. 0.08 vol.-%)	< 30,000 µl/l (i.e. 3 % vol.) For gas mixtures: SF <sub>6</sub> /N <sub>2</sub> mixtures: < 30,000 µl/l (air and/or CF <sub>4</sub> ) SF <sub>6</sub> /CF <sub>4</sub> mixtures: < 30,000 µl/l (air and/or N <sub>2</sub> )
<b>Moisture (dew point)</b>	< 200 µl/l (i.e. 200 ppm <sub>v</sub> ; -36 °C frost point @ atm)	< 200 µl/l (i.e. 200 ppm <sub>v</sub> ; -36 °C frost point @ atm.)
<b>Oil</b>	< 10 mg/kg (i.e. 10 ppm <sub>w</sub> )	< 10 mg/kg (i.e. 10 ppm <sub>w</sub> )
<b>HF, SO<sub>2</sub></b>	< 7 µl/l (i.e. 7 ppm) total	< 50 µl/l total (i.e. 50 ppm) or 12 µl/l (i.e. 12 ppm) For (SO <sub>2</sub> +SO <sub>2</sub> ) or 25 µl/l (i.e. 25 ppm) HF

Substance	DIL0		
	Certified Gas	IEC 60376:2018* (Virgin gas)	ASTM D2472-15
SF <sub>6</sub>	> 99 Vol. %	> 98,5 Vol. %	≥ 99,8 wt%
H <sub>2</sub> O	≤ 8 µl/l	< 200 µl/l	≤ 8 ul/l
Frost point (100 kPa)	≤ -62 °C	-36 °C	-62 °C
Total acidity (HF equiv.)	< 0,1 µl/l	< 7 µl/l	≤ 0,3 ppm <sub>w</sub>
Air	< 500 µl/l	< 10.000 µl/l	≤ 500 ppm <sub>w</sub> (± 2500 µl/l)
CF <sub>4</sub>	< 500 µl/l	< 4.000 µl/l	≤ 500 ppm <sub>w</sub> (± 830 µl/l)
Oil mist	< 1 mg/kg	< 10 mg/kg	–
SO <sub>2</sub>	< 0,1 µl/l	–	–

\*For use in mixtures with N<sub>2</sub>/CF<sub>4</sub>, SF<sub>6</sub> purity of 99.7 % by volume is recommended.  
µl/l = ppm<sub>v</sub>; mg/kg = ppm<sub>w</sub>; wt% = percentage by weight

Off-site reconditioned SF<sub>6</sub> gas should come with the following report information for accurate recordkeeping:


Report#:	AIR#191017	Service#	S-2878		Date:	10/17/2019	Pallet#	1
AssetTag Number	Cylinder Serial Number	Cylinder Certification Date	Purity (vol %)	Moisture	Decomp (SO <sub>2</sub> /SO <sub>2</sub> )	Tare Weight	Gross Weight	SF <sub>6</sub> Weight
EHR603	N-339679	07/17*	99.9%	<40 PPMv	PPMv	119.0 LBS	233.8 LBS	114.8 lbs
GTE931	419416	11/16+	99.9%	<40 PPMv	PPMv	121.8 LBS	236.3 LBS	114.5 lbs
HLY311	73251805	11/17+*	99.9%	<40 PPMv	PPMv	110.7 LBS	225.3 LBS	114.6 lbs
FKN258	SG2095B	7/14+*	99.9%	<40 PPMv	PPMv	123.0 LBS	238.3 LBS	115.3 lbs
HLY301	U36035	11/17+	99.9%	<40 PPMv	PPMv	117.4 LBS	232.7 LBS	115.3 lbs
HKV358	32	03/17+	99.9%	<40 PPMv	PPMv	118.0 LBS	233.2 LBS	115.2 lbs
GTC978	OX-4-408947	12/16+	99.9%	<40 PPMv	PPMv	114.0 LBS	228.8 LBS	114.8 lbs
FKP274	C6657014	08/16+*	99.9%	<40 PPMv	PPMv	121.0 LBS	235.9 LBS	114.9 lbs
HAW447	179273	08/17+	99.9%	<40 PPMv	PPMv	127.0 LBS	242.2 LBS	115.2 lbs
DJT090	N-278340	07/14+	99.9%	<40 PPMv	PPMv	118.0 LBS	232.9 LBS	114.9 lbs
JCU279	X-379544	07/18+	99.9%	<40 PPMv	PPMv	113.6 LBS	228.9 LBS	115.3 lbs

Example of Outgoing Report for over 1,200 pounds of reconditioned SF<sub>6</sub> gas in 115 Capacity Cyl's

Report#:	S-2975	Service#	0		Date:	1/20/2020	Pallet#	1
AssetTag Number	Cylinder Serial Number	Cylinder Certification Date	Purity (vol %)	Moisture	Decomp (SO <sub>2</sub> /SO <sub>2</sub> )	Tare Weight	Gross Weight	SF <sub>6</sub> Weight
	SG862500Y	9/2014+	100.0%	<40 PPMv	PPMv	1,454.0 LBS	2,554.0 LBS	1,100.0 lbs
	6169-33	8/2014+	100.0%	<40 PPMv	PPMv	1,388.0 LBS	2,488.0 LBS	1,100.0 lbs
	4890-26	4/2011+	100.0%	<40 PPMv	PPMv	1,452.0 LBS	2,552.0 LBS	1,100.0 lbs
	4057-0	9/2014+	100.0%	<40 PPMv	PPMv	1,430.0 LBS	2,530.0 LBS	1,100.0 lbs
	4057-17	9/2014+	100.0%	<40 PPMv	PPMv	1,407.0 LBS	2,507.0 LBS	1,100.0 lbs

Example of Outgoing Report for 5,500 pounds of reconditioned SF<sub>6</sub> gas in 1,100 capacity tonners

ONE VISION. ZERO EMISSIONS.



**What else can you do?**



## TRAINING

According to the Environmental Protection Agency:

*“Training raises awareness of emissions, environmental and health impacts of SF<sub>6</sub> and by-products, and potential reduction options, but training also enables employees to follow procedures and protocols properly.”*<sup>3</sup>

... And in most cases with equipment ownership, **IT'S FREE!**


... at least with DILO, it is. ;)



3: Source: (August 2018) Overview of SF<sub>6</sub> Emissions Sources and Reduction Options in Electric Power Systems.

## Gas Connections & Material Replacements

- Check to see that fittings used for connection to GIE and other accessories (manifolds, analyzers, cylinders, etc.) are leak tested.
- Refrain from using threaded connections, which are prone to leak over time:
  - NPT (Taper)
  - JIC (Flare)
  - Compression (i.e. Swagelok, HyLok, etc.)
- Identify and replace rubber components, such as hoses and diaphragms, every 5 years, if possible.






## Cylinder Consolidation

- Ensures all gas is accounted for throughout your locations.
- Ideally, all partial cylinders should be returned to a single inventory point, such as a dedicated bottle shop.
- Can also help to identify poor quality gas that will require reconditioning before being put back into service.





- DILO. Whitepapers
- DILO. Training & Certification
- DILO Media
  - Check out our Blog!
  - Pro-tip videos
  - DILO Americas – YouTube Channel




### WELCOME TO THE DILO BLOG

Share 07/06/2022


[Back to overview](#)

#### ALTERNATIVES TO SF6 GAS: WHAT ARE THE AVAILABLE OPTIONS?

Alternatives to SF<sub>6</sub> gas are gaining traction in the Electrical Industry. Why are SF<sub>6</sub> alternatives becoming popular? What available options are there to replace SF<sub>6</sub> gas? Can users keep the same switchgear when looking for a replacement? Read on to learn all this and more.



ONE VISION. ZERO EMISSIONS.



# Questions?

SF<sub>6</sub> GAS

ALTERNATIVE  
GASES

INDUSTRIAL  
GAS EQUIPMENT

HIGH PRESSURE  
PRODUCTS

