

RHODE ISLAND DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF WATER RESOURCES  
PERMITS SECTION  
235 PROMENADE STREET  
PROVIDENCE, RHODE ISLAND 02908-5767

PUBLIC NOTICE OF PROPOSED PERMIT ACTIONS UNDER THE RHODE ISLAND POLLUTANT DISCHARGE ELIMINATION SYSTEM (RIPDES) PROGRAM WHICH REGULATES DISCHARGES INTO THE WATERS OF THE STATE UNDER CHAPTER 46-12 OF THE RHODE ISLAND GENERAL LAWS OF 1956, AS AMENDED.

DATE OF NOTICE: February 9, 2024

PUBLIC NOTICE NUMBER: PN 24-01

**DRAFT RIPDES PERMITS**

RIPDES PERMIT NUMBER: RI0100366

NAME AND MAILING ADDRESS OF APPLICANT:

Town of Jamestown  
P.O. Box 377  
Jamestown, Rhode Island 02835

NAME AND ADDRESS OF FACILITY WHERE DISCHARGE OCCURS:

Jamestown Wastewater Treatment Facility  
Taylor Point  
Jamestown, Rhode Island 02835

RECEIVING WATER: Narragansett Bay (Waterbody ID #:RI0007029E-01F)

RECEIVING WATER CLASSIFICATION: SB1

The facility, which is the source of the discharge, is located in Jamestown and is engaged in the treatment of domestic and commercial sewage from the sanitary sewer system in the Town of Jamestown. On June 1, 2021, the facility reapplied to the Rhode Island Department of Environmental Management for reissuance of an individual RIPDES permit to discharge water from the treatment plant, which includes the use of the following equipment: course screening, grit removal using an aerated grit chamber, extended aeration, secondary clarification, and chlorination. The discharge of treated effluent is made to Narragansett Bay through outfall 001A. The permit includes limits to ensure that the discharge will not cause a water quality violation.

The draft permit contains new requirements for monitoring perfluorinated compounds, additional monitoring of Nitrogen parameters, more stringent limits for biotoxicity, the submittal of a resiliency plan, and inspection of the facility's outfall.

RIPDES PERMIT NUMBER: RI0100196

NAME AND MAILING ADDRESS OF APPLICANT:

New Shoreham Sewer Commission & New Shoreham Water Commission  
P.O. Drawer 774  
Block Island, RI 02807

NAME AND ADDRESS OF FACILITY WHERE DISCHARGE OCCURS:

New Shoreham Water Pollution Control Facility  
20 Spring Street  
Block Island, RI 02807  
&  
Block Island Water Company  
436 Sand's Pond Road  
Block Island, RI 02807

RECEIVING WATER: Rhode Island Sound (Waterbody ID: RI0010046E-02A (Block Island Waters))

RECEIVING WATER CLASSIFICATION: SB1

The facility which is the source of the wastewater discharge is engaged in treatment of wastewater from the sanitary sewer system in New Shoreham. On March 9, 2021, the facility reapplied to the Rhode Island Department of Environmental Management for reissuance of an individual RIPDES permit to discharge water from the treatment plant. The wastewater is treated via coarse screening/bar racks, grit removal, fine screening/mechanical filter screen, aeration, secondary settling, chlorination and dechlorination. The Block Island Water Company is engaged in the operation of a Reverse Osmosis (RO) process located on Sands Pond Road to treat well water for domestic consumption. The discharges are from the New Shoreham WPCF effluent (Outfall 100A) that discharges into Rhode Island Sound. The above two facilities are the sources of the wastewater discharges. The permit includes limits to ensure that the discharge will not cause a water quality violation.

The draft permit contains new requirements for monitoring perflourinated compounds, additional monitoring of Nitrogen parameters, for the submittal of a resiliency plan, and for inspection of the facility's outfall.

RIPDES PERMIT NUMBER: RI0100374

NAME AND MAILING ADDRESS OF APPLICANT:

Town of South Kingstown  
180 High Street  
Wakefield, RI 02879

NAME AND ADDRESS OF FACILITY WHERE DISCHARGE OCCURS:

South Kingstown Regional Wastewater Treatment Plant  
275 Westmoreland Street

Narragansett, Rhode Island

RECEIVING WATER: Rhode Island Sound (Waterbody ID: RI0010042E-01A)

RECEIVING WATER CLASSIFICATION: SB1

The facility, which is the source of the wastewater discharge, is located in South Kingstown and is engaged in treatment of wastewater from the sewer system in the Town of South Kingstown. On November 18, 2021, the facility reapplied to the Rhode Island Department of Environmental Management for reissuance of an individual RIPDES Permit to discharge water from the treatment plant, which includes the use of the following equipment and processes: coarse screening, comminution, primary settling, fine bubble aeration, secondary settling, chlorination, and dechlorination. The discharge of treated effluent is made to Rhode Island Sound through outfall 001A. The permit includes limits to ensure that the discharge will not cause a water quality violation.

The draft permit contains new requirements for monitoring perfluorinated compounds, additional monitoring of Nitrogen parameters, for the submittal of a resiliency plan, and for inspection of the facility's outfall.

**II. DRAFT RIPDES PERMIT MODIFICATIONS**

RIPDES PERMIT NUMBER: RI0100455

NAME AND MAILING ADDRESS OF APPLICANT:

Burrillville Sewer Commission  
P.O. Box 71  
Harrisville, RI 02830

NAME AND ADDRESS OF FACILITY WHERE DISCHARGE OCCURS:

Burrillville Wastewater Treatment Facility  
141 Clear River Drive  
Harrisville, Rhode Island 02830

RECEIVING WATER: Clear River [RI0001002R-05D]

RECEIVING WATER CLASSIFICATION: B1

The facility, which is the source of the wastewater discharge, is engaged in the treatment of domestic sewage from the sanitary sewer system in the Town of Burrillville. The treatment system consists of the following processes: Treatment consists of Preliminary Treatment, Primary Settling, Activated Sludge, Secondary Clarification, Phosphorous Removal, Chlorination/Dechlorination and Effluent Re-Aeration. DEM reissued the facility's RIPDES permit on February 8, 2020. On November 8, 2023, the facility submitted a written request to DEM that the facility's permit be modified allow the facility to begin using an Aluminum-based flocculant compound in its wastewater treatment process. The permit modification, which was drafted in response to the November 8, 2023 request, permits the use of the Aluminum-based flocculant compound and ensures that the discharge will not cause a water quality violation.

The DEM has determined that the proposed activities comply with the Policy on the Implementation of the Antidegradation Provisions of the Rhode Island Water Quality Regulations and that existing uses will be maintained and protected. A detailed evaluation of the water quality impact from the proposed activities and any important benefits demonstrations, if required, may be found in the fact sheets which are available as noted below.

**FURTHER INFORMATION:**

Fact sheets (describing the type of facility and significant factual, legal and policy questions considered in these permit actions) may be obtained at no cost by writing or calling DEM as noted below:

Samuel Kaplan, P.E.  
Environmental Engineer II  
Rhode Island Department of Environmental Management  
Office of Water Resources  
Permits Section  
235 Promenade Street  
Providence, Rhode Island 02908-5767  
samuel.kaplan@dem.ri.gov  
(401) 537-4240

The administrative record containing all documents relating to these permit actions is on file and may be inspected, by appointment, at the DEM's Providence office mentioned above between 8:30 a.m. and 4:00 p.m., Monday through Friday, except holidays.

**PUBLIC COMMENT AND REQUEST FOR PUBLIC HEARING:**

Pursuant to Chapter 42-17.4 of the Rhode Island General Laws a public hearing has been scheduled to consider these permits if requested. Requests for a Public Hearing must be submitted in writing to the attention of Samuel Kaplan at the address indicated above. Notice should be taken that if DEM receives a request from twenty-five (25) people, a governmental agency or subdivision, or an association having no less than twenty-five (25) members on or before 4:00 PM, March 12, a public hearing will be held at the following time and place:

5:00 PM Wednesday, March 20  
Room 280  
235 Promenade Street  
Providence, Rhode Island 02908

Interested persons should contact DEM to confirm if a hearing will be held at the time and location noted above.

235 Promenade Street is accessible to individuals who are handicapped. If communication assistance (readers/interpreters/captioners) is needed, or any other accommodation to ensure equal participation, please call Samuel Kaplan or RI Relay 711 at least three (3) business days prior to the meeting so arrangements can be made to provide such assistance at no cost to the person requesting.

Interested parties may submit comments on the permit actions and the administrative record to the address above no later than 4:00 PM Thursday, March 21.

If, during the public comment period, significant new questions are raised concerning the permit, DEM may require a new draft permit or statement of basis or may reopen the public comment period. A public notice will be issued for any of these actions.

Any person, including the permittee/applicant, who believes these permit actions are inappropriate, must raise all reasonably ascertainable issues and submit all reasonably available arguments and factual grounds supporting their position, including all supporting material, by the close of the public comment period under 250-RICR-150-10-1.42 of the Regulations for the Rhode Island Pollutant Discharge Elimination System. The public comment period is from February 9, 2024 to March 21, 2024. Commenters may request a longer comment period if necessary to provide a reasonable opportunity to comply with these requirements. Comments should be directed to DEM as noted above.

**FINAL DECISION AND APPEALS:**

Following the close of the comment period, and after a public hearing, if such hearing is held, the Director will issue a final decision and forward a copy of the final decision to the permittee and each person who has submitted written comments or requested notice. Within 30 days following the notice of the final decision, any interested person may submit a request for a formal hearing in accordance with the requirements of 250-RICR-150-10-1.50 of the Regulations for the Rhode Island Pollutant Discharge Elimination System.

01 Feb 2024  
Date

Heidi Traverso  
Heidi Travers, P.E.  
Environmental Engineer IV  
RIPDES, Office of Water Resources  
Department of Environmental Management

AUTHORIZATION TO DISCHARGE UNDER THE  
RHODE ISLAND POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of Chapter 46-12 of the Rhode Island General Laws, as amended, the

**Town of South Kingstown**  
180 High Street  
Wakefield, RI 02879

is authorized to discharge from a facility located at the

**South Kingstown Regional Wastewater Treatment Plant**  
275 Westmoreland Street  
Narragansett, Rhode Island

to receiving waters named

**Rhode Island Sound (Waterbody ID: RI0010042E-01A)**

in accordance with effluent limitations, monitoring requirements and other conditions set forth herein.

This permit shall become effective on \_\_\_\_\_, 20\_\_.

This permit and the authorization to discharge expire at midnight, five (5) years from the effective date.

This permit supersedes the permit issued on September 1, 2017.

This permit consists of twenty-three (23) pages in Part I including effluent limitations, monitoring requirements, etc. and nine (9) pages in Part II including General Conditions.

Signed this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_.

# DRAFT

Joseph B. Haberek, P.E., Administrator for Surface Water Protection  
Office of Water Resources  
Rhode Island Department of Environmental Management  
Providence, Rhode Island

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date and lasting through permit expiration, the permittee is authorized to discharge from outfall serial number 001A. Outfall 001A is the final discharge after dechlorination. Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristic	Discharge Limitations					Monitoring Requirement	
	Quantity – lbs./day		Concentration – Specify Units			Measurement Frequency	Sample Type
	Average Monthly	Maximum Daily	Average Monthly	Average Weekly	Maximum Daily		
Flow <sup>1</sup>	5.0 MGD	--- MGD				Continuous	Recorder
BOD <sub>5</sub> <sup>2</sup>	1,251	2,085	30 mg/l	45 mg/l	50 mg/l	3/Week	24-Hr. Comp.
BOD <sub>5</sub> - % Removal <sup>2</sup>			≥85%			1/Month	Calculated
TSS <sup>2</sup>	1,251	2,085	30 mg/l	45 mg/l	50 mg/l	3/Week	24-Hr. Comp.
TSS - % Removal <sup>2</sup>			≥85%			1/Month	Calculated
Settleable Solids <sup>1</sup>				--- ml/l	--- ml/l	1/Day	Grab

--- Signifies a parameter which must be monitored, and data must be reported; no limit has been established at this time.

<sup>1</sup>Sampling for Flow and Settleable Solids shall be performed Sunday-Saturday.

<sup>2</sup>Influent and effluent sampling is required for TSS and BOD<sub>5</sub>. Sampling for TSS and BOD<sub>5</sub> influent and effluent shall be performed Sunday, Tuesday, and Thursday with appropriate allowances for hydraulic detention (flow-through) time.

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

2. During the period beginning on the effective date and lasting through permit expiration, the permittee is authorized to discharge from outfall serial number 001A. Outfall 001A is the final discharge after dechlorination. Such discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristic	Discharge Limitations					Monitoring Requirement	
	Quantity – lbs./day		Concentration – Specify Units			Measurement Frequency	Sample Type
	Average Monthly	Maximum Daily	Average Monthly *(Minimum)	Average Weekly	Maximum Daily *(Maximum)		
Enterococci			35 cfu/100 ml <sup>1</sup>		276 cfu/100 ml <sup>1</sup>	3/Week	Grab
Fecal Coliform			--- MPN/100 ml <sup>1</sup>		--- MPN/100 ml <sup>1</sup>	3/Week	Grab
Total Residual Chlorine (TRC) <sup>3</sup>			885 µg/l <sup>2</sup>		1,040 µg/l <sup>2</sup>	3/Day	Grab
pH <sup>3</sup>			(6.0 SU)		(9.0 SU)	2/Day	Grab

--- Signifies a parameter which must be monitored, and data must be reported; no limit has been established at this time.

<sup>1</sup>Values in parentheses () are to be reported as Minimum/Maximum for the reporting period rather than Average Monthly/ Maximum Daily.

<sup>1</sup>Two (2) of the three (3) Enterococci samples are to be taken on Tuesday and Thursday at the same times as one of the TRC samples. The Fecal Coliform samples shall be taken at the same time as the Enterococci samples. The Geometric Mean shall be used to obtain the "average monthly" values. The facility shall immediately report to DEM, verbally, any fecal coliform sample result that exceeds 400 MPN/100 mL.

<sup>2</sup>The use of a continuous TRC recorder after chlorination and prior to dechlorination is required to provide a record that proper disinfection was achieved at all times. Compliance with these limitations shall be determined by taking three grab samples per day, Monday - Friday (except holidays), equally spaced over one (1) eight hour working shift with a minimum of three hours between grabs, and on Saturdays, Sundays, and Holidays by taking at least (2) grab samples each day with a minimum of two (2) hours between grabs. The maximum daily and average monthly values are to be computed from the averaged grab sample results for each day. The following methods may be used to analyze the grab samples: (1) DPD Spectrophotometric, EPA No. 330.5 or Standard Methods (18<sup>th</sup> Edition) No. 4500-CI G; (2) DPD Titrimetric, EPA No. 330.4 or Standard Methods (18<sup>th</sup> Edition) No. 4500-CI F; (3) Amperometric Titration, EPA No. 330.1 or Standard Methods (18<sup>th</sup> Edition) No. 4500-CI D or ASTM No. D1253-86(92); (4) Iodometric Direct Titration, EPA No. 330.3 or Standard Methods (18<sup>th</sup> Edition) No. 4500-CI B; (5) Iodometric Back Titration (either end-point), EPA No. 330.2 or Standard Methods (18<sup>th</sup> Edition) No. 4500-CI C.

<sup>3</sup>Sampling for pH and Chlorine Residual shall be performed Sunday-Saturday.



PART 1

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

3. During the period beginning on the effective date and lasting through permit expiration, the permittee is authorized to discharge from outfall serial number 001A. Outfall 001A is the final discharge after dechlorination. Such Discharges shall be monitored by the permittee as specified below:

Effluent Characteristic	Discharge Limitations					Monitoring Requirement	
	Quantity – lbs/day		Concentration – Specify Units			Measurement Frequency	Sample Type
	Average Monthly	Maximum Daily	Average Monthly	Average Weekly	Maximum Daily		
Oil and Grease					--- mg/l	1/Quarter	3 Grabs <sup>1</sup>
TKN (as N)			--- mg/l		--- mg/l	1/Month	24-Hr. Comp.
Nitrate, Total (as N)			--- mg/l		--- mg/l	1/Month	24-Hr. Comp.
Nitrite, Total (as N)			--- mg/l		--- mg/l	1/Month	24-Hr. Comp.
Nitrogen, Total (TKN + Nitrate + Nitrite, as N)	--- lb/day		--- mg/l		--- mg/l	1/Month	Calculated

--- signifies a parameter which must be monitored, and data must be reported; no limit has been established at this time.

<sup>1</sup>Three (3) grab samples shall be equally spaced over the course of one (1) eight (8) hour shift with a minimum of three (3) hours between grabs. Each grab sample must be analyzed individually, and the maximum values reported.

Samples taken in compliance with the monitoring requirements specified above shall be taken Monday through Friday.

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

4. During the period beginning on the effective date and lasting through permit expiration, the permittee is authorized to discharge from outfall serial number 001A. Outfall 001A is the final discharge after dechlorination. Such discharged shall be limited and monitored by the permittee as specified below:

Effluent Characteristic	Discharge Limitations					Monitoring Requirement	
	Quantity – lbs/day		Concentration – Specify Units			Measurement Frequency	Sample Type
	Average Monthly	Maximum Daily	Average Monthly	Average Weekly	Maximum Daily		
Copper, Total <sup>1</sup>			--- µg/l		--- µg/l	1/Quarter	24-Hr. Comp.
Cyanide, Free <sup>1</sup>			--- µg/l		--- µg/l	1/Quarter	Composite <sup>2</sup>
Phenols, Total			--- µg/l		--- µg/l	1/Quarter	Grab
Cadmium, Total <sup>1</sup>			--- µg/l		--- µg/l	1/Quarter	24-Hr. Comp.
Lead, Total <sup>1</sup>			--- µg/l		--- µg/l	1/Quarter	24-Hr. Comp.
Chromium, Hexavalent <sup>1</sup>			--- µg/l		--- µg/l	1/Quarter	24-Hr. Comp.
Zinc, Total <sup>1</sup>			--- µg/l		--- µg/l	1/Quarter	24-Hr. Comp.
Nickel, Total <sup>1</sup>			--- µg/l		--- µg/l	1/Quarter	24-Hr. Comp.
Aluminum, Total <sup>1</sup>			--- µg/l		--- µg/l	1/Quarter	24-Hr. Comp.
Ammonia, Total (as N) <sup>1</sup>			-- mg/L		-- mg/L	1/Quarter	24-Hr. Comp.
Organic Carbon, Total <sup>1</sup>			-- mg/L		-- mg/L	1/Quarter	24-Hr. Comp.

--- Signifies a parameter which must be monitored, and data must be reported; no limit has been established at this time.

<sup>1</sup>Monitoring data may be obtained in conjunction with bioassay testing required in Part 1.B of the permit

<sup>2</sup>Composite shall be conducted by taking three (3) grab samples per day, with a minimum of three (3) hours between grabs and preserved immediately upon collection. All three (3) samples shall be composited then analyzed for free Cyanide.

Samples taken in compliance with the monitoring requirements specified above shall be taken Monday through Friday.

PART 1

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

5. During the period beginning on the effective date and lasting through permit expiration, the permittee is authorized to discharge from outfall serial number 001A. Outfall 001A is the final discharge after dechlorination. Such discharged shall be limited and monitored by the permittee as specified below:

Effluent Characteristic	Discharge Limitations					Monitoring Requirement	
	Quantity – lbs/day		Concentration – Specify Units			Measurement Frequency	Sample Type
	Average Monthly	Maximum Daily	Average Monthly	Average Weekly	Maximum Daily		
Mysidopsis bahia <sup>1</sup> LC <sub>50</sub> <sup>2</sup>					≥100%	1/Quarter	24-Hr. Comp.

<sup>1</sup>Testing may be conducted using *Americamysis bahia*.

<sup>2</sup>LC<sub>50</sub> is defined as the concentration of wastewater that causes mortality to 50% of the test organisms. Therefore, a 100% limit means that a sample of 100% effluent (no dilution) shall cause no more than a 50% mortality rate.

Samples taken in compliance with the monitoring requirements in accordance with Part 1.B. of the permit.

**A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**

6. During the period beginning on the effective date and lasting through permit expiration, the permittee is authorized to discharge from outfall serial number 001A. Outfall 001A is the final discharge after dechlorination. Such discharges shall be monitored by the permittee as specified below:

Effluent Characteristic	Discharge Limitations					Monitoring Requirement	
	Quantity – lbs/day		Concentration – Specify Units			Measurement Frequency	Sample Type
	Average Monthly	Maximum Daily	Average Monthly	Average Weekly	Maximum Daily		
PFAS Analytes <sup>1</sup>					--- ng/L	1/Quarter	Grab <sup>2</sup>

--- signifies a parameter which must be monitored, and data must be reported; no limit has been established at this time.

<sup>1</sup>Influent and effluent sampling for the listed PFAS parameters listed in Attachment A. PFAS shall be analyzed using Clean Water Act wastewater draft analytical method 1633 until a 40 CFR Part 136 approved test method for wastewater is approved. Report in NetDMR the results of all PFAS analytes required to be tested as part of the method as shown in Attachment A. Sampling and analysis for PFAS Analytes shall begin no earlier than July 1, 2024, or during the first calendar quarter in which the permit becomes effective, whichever is later.

<sup>2</sup>Influent samples taken in compliance with the monitoring requirements specified above shall be taken at the facility headworks at the same sampling location where influent BOD<sub>5</sub> and influent TSS are sampled. Effluent samples shall be taken after the chlorination contact tank.

7. Per 40 CFR 122.42(b), prior to acceptance, the permittee shall notify DEM of the following:
  - a. Any new introduction of pollutants into the Permittee's treatment facility from an indirect discharger which would be subject to section 301 or 306 of CWA if it were directly discharging those pollutants; and
  - b. Any substantial change in the volume or character of pollutants being introduced into the Permittee's treatment facility by a source that was discharging pollutants into the facility at the time of permit issuance.
  - c. Notice shall include information on:
    - (i) the quality and quantity of effluent introduced into the Permittee's treatment facility, and
    - (ii) any anticipated impact of the change on the quantity and quality of effluent to be discharged from the Permittee's treatment facility.
  
8.
  - a. The pH of the effluent shall not be less than 6.0 nor greater than 9.0 standard units at any time, unless these values are exceeded due to natural causes or as a result of the approved treatment processes.
  - b. The discharge shall not cause visible discoloration of the receiving waters.
  - c. The effluent shall contain neither a visible oil sheen, foam, nor floating solids at any time.
  - d. The Permittee's treatment facility shall maintain a minimum of 85 percent removal of both total suspended solids and 5-day biochemical oxygen demand. The percent removal shall be based on monthly average values.
  - e. When the effluent discharged for a period of 90 consecutive days exceeds 80 percent of the designed flow, the permittee shall submit to the permitting authorities a projection of loadings up to the time when the design capacity of the treatment facility will be reached, and a program for maintaining satisfactory treatment levels consistent with approved water quality management plans.
  - f. The Permittee shall analyze its effluent annually for the EPA Priority Pollutants as listed in 40 CFR 122, Appendix D, Tables II and III. The results of these analyses shall be submitted to the Department of Environmental Management by October 15<sup>th</sup> of each year. All sampling and analysis shall be done in accordance with EPA Regulations, including 40 CFR, Part 136; grab and composite samples shall be taken as appropriate.
  - g. This permit serves as the State's Water Quality Certificate for the discharges described herein.

**B. BIOMONITORING REQUIREMENTS AND INTERPRETATION OF RESULTS**

1. General

Beginning on the effective date of the permit, the permittee shall perform four (4) acute toxicity tests per year on dechlorinated effluent samples collected from discharge Outfall 001A. The permittee shall conduct the tests during dry weather periods (no rain within forty-eight (48) hours prior to or during sampling unless approved by DEM) according to the following test frequency and protocols. Acute data shall be reported as outlined in Part I.B.9. The State may require additional screening, range finding, definitive acute or chronic bioassays as deemed necessary based on the results of the initial bioassays required herein. Indications of toxicity could result in requiring a Toxicity

Reduction Evaluation (TRE) to investigate the causes and to identify corrective actions necessary to eliminate or reduce toxicity to an acceptable level.

2. Test Frequency

On four (4) sampling events, (one (1) each calendar quarter) the permittee shall conduct forty-eight (48) hour acute definitive toxicity tests on the species listed below, for a total of four (4) acute toxicity tests per year.

<b>Species</b>	<b>Test Type</b> One (1) Species Test Four (4) Times Annually	<b>Frequency</b>
Mysids ( <i>Mysidopsis bahia</i> )	Definitive 48-Hour Acute Static (LC <sub>50</sub> )	Quarterly

3. Testing Methods

Acute definitive toxicity tests shall be conducted in accordance with protocols listed in 40 CFR Part 136.

4. Sample Collection

For each sampling event a twenty-four-(24) hour flow-proportioned composite effluent sample shall be collected at a location after dechlorination during dry weather (no rain forty-eight (48) hours prior to or during sampling unless approved by DEM). This sample shall be kept cool (at 4°C), and testing shall begin within twenty-four (24) hours after the last sample of the composite is collected. In the laboratory, the sample will be split into two (2) subsamples, after thorough mixing, for the following:

- A: Chemical Analysis
- B: Acute Toxicity Testing

All samples held overnight shall be refrigerated at 4°C. Grab samples must be used for pH and temperature.

5. Salinity Adjustment

Prior to the initiation of testing, the effluent must be adjusted to make the salinity of the effluent equal to that of the marine dilution water. The test solution must be prepared by adding non-toxic dried ocean salts to a sufficient quantity of 100% effluent to raise the salinity to the desired level. After the addition of the dried salts, stir gently for thirty (30) to sixty (60) minutes, preferably with a magnetic stirrer, to ensure that the salts are in solution. It is important to check the final salinity with a refractometer or salinometer. Salinity adjustments following this procedure and in accordance with EPA protocol will ensure that the concentrations (% effluent) of each dilution are real and allow for an accurate evaluation with the acute permit limit and acute monitoring requirements.

6. Dilution Water

Dilution water used for marine acute toxicity analyses should be of sufficient quality to meet minimum acceptability of test results (See Part I.B.7.). Natural seawater shall be used as the dilution water. This water shall be collected from Narragansett Bay off the dock at the URI's Graduate School of Oceanography on South Ferry Road, Narragansett. It is noted that the University claims no responsibility for the personal safety on this dock. The permittee shall observe the rules posted at the dock. If this natural seawater diluent is found to be, or suspected to be toxic or unreliable, an alternate source of natural seawater or deionized water mixed with hypersaline brine or artificial sea salts of known quality with a salinity and pH similar to that of the receiving water may be substituted AFTER RECEIVING WRITTEN APPROVAL FROM DEM.

7. Effluent Toxicity Test Conditions for Mysids (*Mysidopsis bahia*)

Test conditions are required to be compliant with 40 CFR 136 using the following effluent concentrations:

Five (5) dilutions plus a control: 100%, 50%, 25%, 12.5%, 6.25%, and 0% effluent.

#### 8. Chemical Analysis

The following chemical analysis shall be performed for each sampling event. A sample analyzed as part of the required third-quarter priority pollutant scan may be used to satisfy this sampling requirement.

Parameter	Effluent	Saline Diluent	Detection Limit
pH	√	√	--
Specific Conductance	√	√	--
Total Solids and Suspended Solids	√	√	--
Total Ammonia	√		0.1 mg/L
Total Organic Carbon	√		0.5 mg/L
Free Cyanide <sup>1</sup>	√		0.01 mg/L
Total Phenols	√		0.05 mg/L
Salinity	√	√	PPT (0/00)
Total Cadmium <sup>2</sup>	√	√	0.1 µg/L
Hexavalent Chromium <sup>3</sup>	√	√	20.0 µg/L
Total Copper <sup>2</sup>	√	√	1.0 µg/L
Total Lead <sup>2</sup>	√	√	1.0 µg/L
Total Zinc <sup>2</sup>	√	√	5.0 µg/L
Total Nickel <sup>2</sup>	√	√	1.0 µg/L
Total Aluminum	√	√	5.0 µg/L

<sup>1</sup> Free cyanide analysis is in addition to the total cyanide analysis that is required as part of the priority pollutant scan.

<sup>2</sup> Priority pollutant.

<sup>3</sup> Hexavalent chromium analysis is in addition to the total chromium analysis that is required as part of the priority pollutant scan.

The above analysis may be used to fulfill, in part or in whole, monitoring requirements in the permit for these specific metals.

During the third calendar quarter bioassay sampling event, the final effluent sample collected during the same twenty-four (24) hour period as the bioassay sample, shall be analyzed for priority pollutants (as listed in Tables II and III of Appendix D of 40 CFR 122). The bioassay priority pollutant scan shall be a full scan and may be coordinated with other permit conditions to fulfill any other pollutant scan requirements.

#### 9. Toxicity Test Report Elements

A report of results will include the following:

- Description of sample collection procedures and site description.
- Names of individuals collecting and transporting samples, times, and dates of sample collection and analysis.
- General description of tests: age of test organisms, origin, dates, and results of standard toxicant tests (quality assurance); light and temperature regime; dilution water description; other information on test conditions if different than procedures recommended.
- The method used to adjust the salinity of the effluent must be reported.

- All chemical and physical data generated (include detection limits).
- Raw data and bench sheets.
- Any other observations or test conditions affecting test outcome.

Toxicity test data shall include the following:

- Survival for each concentration and replication at time twenty-four (24) and forty-eight (48) hours.
- LC<sub>50</sub> and 95% confidence limits shall be calculated using one of the following methods in order of preference: Probit, Trimmed Spearman Karber, Moving Average Angle, or the graphical method. All printouts (along with the name of the program, the date, and the author(s)) and graphical displays must be submitted. When data is analyzed by hand, worksheets should be submitted. The report shall also include the No Observed Acute Effect Level (NOAEL), which is defined as the highest concentration of the effluent (in % effluent) in which 90% or more of the test animals survive.
- The Probit, Trimmed Spearman Karber, and Moving Average Angle methods of analyses can only be used when mortality of some of the test organisms are observed in at least two (2) of the (percent effluent) concentrations tested (i.e., partial mortality). If a test results in a 100% survival and 100% mortality in adjacent treatments ("all or nothing" effect), an LC<sub>50</sub> may be estimated using the graphical method.

10. Special Condition

Due to the fact that the suggested dilution water for this facility to use in conducting the bioassays is from the end of the dock at the URI's Narragansett Bay Campus, a Letter of Agreement shall be signed and submitted to the Graduate School of Oceanography granting authorization to collect samples. Requests to use another source of dilution water will have to be approved by the Department of Environmental Management, Office of Water Resources.

11. Species Sensitivity Screening Report.

For four (4) quarters of the permit beginning the third year of the permit (April 1, 2027), the permittee shall conduct a chronic species sensitivity screening for the discharge. Species sensitivity screening for chronic toxicity shall include, at minimum, chronic toxicity testing for four consecutive calendar quarters using 40 CFR Part 136 approved methods for mysid (*Mysidopsis bahia*), sea urchin (*Arbacia punctulate*), and fish (*Menidia beryllina*). Samples shall be obtained from the dechlorinated effluent collected from Outfall 001A during dry weather periods (no rain within forty-eight (48) hours prior to or during sampling unless approved by DEM). The above analysis may fulfill the quarterly acute monitoring requirements in Part I.A.5 provided that all tests are conducted in accordance with protocols listed in 40 CFR Part 136.

If only a single species in the species sensitivity screening testing exceeds 1 chronic Toxic Unit (TUc) (as 100/NOEC), then that species shall be established as the most sensitive species. If there are more than one species that exceed 1 TUc (as 100/NOEC), then the species with the highest TUc (as 100/NOEC) shall be established as the most sensitive species. DEM shall have final discretion to determine which species is the most sensitive considering the test results from the species sensitivity screening.

Test No.	Quarter Screening is to be Performed
1	April 1, 2027 – June 30, 2027
2	July 1, 2027 – September 30, 2027
3	October 1, 2027 – December 31, 2027
4	January 1, 2028 – March 30, 2028



The final Species Sensitivity Screening Report shall include all the elements required under Part I.B.9 for each quarterly test and shall be submitted to DEM by June 30, 2028.

12. Reporting of Bioassay Testing  
Bioassay Testing shall be conducted as follows:

Quarter Testing to be Performed	Report Due No Later Than	Results Submitted on DMR for
January 1 – March 31	April 15	March
April 1 – June 30	July 15	June
July 1 – September 30	October 15	September
October 1 – December 31	January 15	December

Reports shall be maintained by the permittee and shall be made available upon request by DEM.

**C. INDUSTRIAL PRETREATMENT PROGRAM**

1. Definitions

For the purpose of this permit, the following definitions apply.

- a. 40 CFR 403 and sections thereof refer to the General Pretreatment regulations, 40 CFR Part 403 as revised.
- b. Categorical Pretreatment Standards mean any regulation containing pollutant discharge limits promulgated by the USEPA in accordance with section 307(b) and (c) of the Clean Water Act (33 USC 1251), as amended, which apply to a specific category of industrial users and which appears in 40 CFR Chapter I, Subchapter N.
- c. Pretreatment Standards include all specific prohibitions and prohibitive discharge limits established pursuant to 40 CFR 403.5, including but not limited to, local limits, and the Categorical Pretreatment Standards.
- d. Regulated Pollutants shall include those pollutants contained in applicable categorical standards and any other pollutants listed in the Pretreatment Standards which have reasonable potential to be present in an industrial user’s effluent.

2. Implementation

The authority and procedures of the Industrial Pretreatment Program shall at all times be fully and effectively exercised and implemented, in compliance with the requirements of this permit and in accordance with the legal authorities, policies, procedures and financial provisions described in the permittee's approved Pretreatment Program and Sewer Use Ordinance, the Rhode Island Pretreatment Regulations and the General Pretreatment Regulations 40 CFR 403. The permittee shall maintain adequate resource levels to accomplish the objectives of the Pretreatment Program.

3. Local Limits Monitoring Plan

The permittee shall submit a Local Limits Monitoring Plan (LLMP) that is current with EPA’s Local Limits Development Guidance (LLDG, EPA 833-R-04-002A, July 2004) and EPA Region 1 policy. A LLMP defines pollutants of concern (POC), sampling locations and sampling frequencies. The permittee shall submit LLMP amendments within six (6) months of permit effective date. The LLMP shall be subject to DEM review and approval. Changes made to the LLMP shall be in accordance with part I.C.6.f and shall meet the following minimum requirements:

- a. Identify all sampling locations, including but not limited to: POTW influent, POTW effluent, POTW sludge, septage and hauled wastes, and domestic wastewater (i.e., key manhole sampling). Domestic sampling location(s) must be strictly domestic and separate from any potential commercial or industrial sources or contributions.

- b. Pollutants of concern (POCs) that will be sampled for at each sampling location. At minimum, the following pollutants should be sampled for: arsenic, cadmium, chromium, copper, cyanide, lead, mercury, nickel, silver, zinc, molybdenum, selenium, BOD, TSS, and ammonia. In addition, the IPP must identify as POCs any pollutants for which there are RIPDES permit effluent limitations or any other POCs that the IPP has identified. If any of the listed POCs would not be sampled for at a particular location, this must be justified by the LLMP.
- c. Sampling type for each pollutant (grab, composite, time-proportioned, flow-proportioned). All sampling and reporting requirements shall be in accordance with 40 CFR 136.
- d. Identification of analytical methods being used, which would include minimum detection levels (MDL) and minimum quantitative levels (MQL) for the analysis of each pollutant.
- e. The sample frequency at each sampling location. For pollutants that have an associated local limit, sampling must take place quarterly at a minimum. For POCs without a local limit, sampling must take place annually at a minimum. Other organic priority pollutants must be sampled at the influent at a minimum of annually. TCLP results must be taken for POTW sludge a minimum of annually.
- f. The sampling plan must account for POTW detention time. For example, if the detention time through the facility is 24 hours, then effluent samples should be collected 24 hours after influent samples.
- g. Identification of data to be recorded for each sample (date, time, initials of sampler, preservation, location, sample type, wastewater flow, etc.).

Deviations from the above requirements may be approved at the DEM's discretion based on reasonable technical justification.

4. Local Limits

Pollutants introduced into POTWs by a non-domestic source (user) shall not: pass through the POTW, interfere with the operation or performance of the works, contaminate sludge as to adversely affect disposal options, or adversely affect worker safety and health. South Kingstown shall continue to implement the local limits incorporated into the Town Sewer Use Ordinance on June 12, 2023.

5. Enforcement Response Plan (ERP)

The permittee has an approved ERP dated July 15, 2008 that meets the requirements of 40 CFR 403.8(f)(5). The permittee shall continue to implement its approved ERP and any subsequent amendments at all times. Changes to the ERP shall be in accordance with Part I.C.6.f of this permit.

6. General

- a. The permittee shall carry out inspection, surveillance, and monitoring procedures which will determine, independent of information supplied by the industrial user, whether the industrial user is in compliance with Pretreatment Standards. At a minimum, all significant industrial users shall be inspected and monitored for all regulated pollutants at the frequency established in the approved Industrial Pretreatment Program but in no case less than once per year (one (1) year being determined as the reporting year established in Part I.C.8 of this permit). In addition, these inspections, monitoring and surveillance activities must be conducted in accordance with EPA's Industrial User Inspection and Sampling Manual for POTW's, January 2017 (EPA-831B17001). All inspections, monitoring, and surveillance activities shall be performed, and have records maintained, with sufficient care to produce evidence admissible in enforcement proceedings or judicial actions. The permittee shall evaluate, at least every two years unless specific superseding 40 CFR 403 streamlining provisions have been adopted, whether each SIU requires a Slug Control Plan. If a Slug Control Plan is required, it shall include the contents specified by 40 CFR 403.8(f)(2)(vi).
- b. The permittee shall reissue all necessary Industrial User (IU) control mechanisms within thirty (30) days of their expiration date. The permittee shall issue, within sixty (60) days after the determination that an IU is a Significant Industrial User (SIU), all SIU control mechanisms. All SIU control mechanisms must contain, at a minimum, those conditions stated in 40 CFR

- 403.8(f)(1)(iii)(B). All control mechanisms must be mailed via Certified Mail, Return Receipt Requested. A complete bound copy of the control mechanism with the appropriate receipt must be kept as part of the Industrial User's permanent file. In addition, the permittee must develop a fact sheet describing the basis for the SIU's permit and retain this fact sheet as part of the SIU's permanent file.
- c. The permittee must identify each instance of noncompliance with any pretreatment standard and/or requirement and take a formal documented action for each instance of noncompliance. Copies of all such documentation must be maintained in the Industrial User's permanent file.
  - d. The permittee shall prohibit Industrial Users from the dilution of a discharge as a substitute for adequate treatment in accordance with 40 CFR 403.6(d).
  - e. The permittee shall prohibit Industrial Users from introducing into the POTW:
    - i. any pollutant which causes pass-through or interference as defined in 40 CFR 403.3.
    - ii. pollutants which create a fire or explosion hazard in the POTW, including, but not limited to, wastestreams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21;
    - iii. Pollutants which will cause corrosive structural damage to the POTW, but in no case Discharges with pH lower than 5.0, unless the works is specifically designed to accommodate such Discharges;
    - iv. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW resulting in interference;
    - v. Any pollutants, including oxygen demanding pollutants (BOD, etc.) released in a Discharge at a flowrate and/or pollutant concentration which will cause Interference with the POTW.
    - vi. Heat in amounts which will inhibit biological activity in the POTW resulting in Interference, but in no case heat in such quantities that the temperature at the POTW Treatment Plant exceeds 40°C (104°F) unless the Approval Authority, upon request of the POTW, approves alternative temperature limits.
    - vii. Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through;
    - viii. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems;
    - ix. Any trucked or hauled pollutants, except at discharge points designated by the POTW.
  - f. The permittee shall comply with the procedures of 40 CFR 403.18 for instituting any modifications of the permittee's approved Pretreatment Program. Significant changes in the operation of a POTW's approved Pretreatment Program must be submitted and approved following the procedures outlined in 40 CFR 403.18(b) and 403.9(b). However, the endorsement of local officials responsible for supervising and/or funding the pretreatment program required by 403.9(b)(2) will not be required until DEM completes a preliminary review of the submission. The DEM will evaluate and review the permittee's initial proposal for a modification and provide written notification either granting preliminary approval of the proposed modifications or stating the deficiencies contained therein. DEM's written notification will also include a determination whether the submission constitutes a substantial or non-

substantial program modification as defined by 40 CFR 403.18. Should DEM determine that a deficiency exists in the proposed modification, the permittee shall submit to DEM, within thirty (30) days of the receipt of said notice, a revised submission consistent with DEM's notice of deficiency.

Pretreatment program modifications which the permittee considers Non-substantial, shall be deemed to be approved within forty-five (45) days after submission of the request for modification, unless DEM determines that the modification is in fact a substantial modification or notifies the permittee of deficiencies. Upon receipt of notification that DEM has determined the modification is substantial, the permittee shall initiate the procedures and comply with the deadlines for substantial modifications, which are outlined below.

For substantial modifications, the permittee shall, within sixty (60) days (unless a longer time frame is granted) of the receipt of DEM's preliminary approval of the proposed modification, submit documentation (as required by 403.9(b)(2)) that any local public notification/participation procedures required by law have been completed, including any responses to public comments, and a statement that the local officials will endorse and/or approve the modification upon approval by DEM.

Within thirty (30) days of DEM's final approval of the proposed modification(s), the permittee shall implement the modification and submit proof that the local officials have endorse and/or approved the modification(s) to the DEM. Upon final approval by the DEM and adoption by the permittee, this modification(s) shall become part of the approved pretreatment program and shall be incorporated into this permit in accordance with 40 CFR 122.63(g).

- g. All sampling and analysis required of the permittee, or by the permittee of any Industrial User, must be performed in accordance with the techniques described in 40 CFR 136.
- h. For those Industrial Users with discharges that are not subject to Categorical Pretreatment Standards, the permittee shall require appropriate reporting in accordance with 40 CFR 403.12(h).
- i. The permittee shall, in accordance with 40 CFR 403.12(f), require all Industrial Users to immediately notify the permittee of all discharges by the Industrial User that could cause problems to the POTW, including slug loadings, as summarized in 40 CFR 403.5(b). The permittee shall also notify DEM of each substantial change in discharge prior to acceptance.
- j. The permittee shall require New Sources to install and have in operation all pollution control equipment required to meet applicable Pretreatment Standards before beginning to discharge. In addition, the permittee shall require New Sources to meet all applicable Pretreatment Standards within the shortest feasible time which shall not exceed ninety (90) days in accordance with 40 CFR 403.6(b).
- k. The permittee shall require all Industrial Users who are required to sample their effluent and report the results of analysis to the POTW to comply with signatory requirements contained in 40 CFR 403.12(l) when submitting such reports.
- l. The permittee shall determine, based on the criteria set forth in 40 CFR 403.8(f)(2)(viii), using the EPA method of "rolling quarters", the compliance status of each Industrial User. Any Industrial User determined to meet Significant Non-Compliance (SNC) criteria shall be included in an annual public notification as specified in 40 CFR 403.8(f)(2)(viii).
- m. The permittee shall require Industrial Users to comply with the notification and certification requirements of 40 CFR 403.12(p)(1), (3) and (4) pertaining to the discharge of substances to the POTW, which if disposed of otherwise, would be a hazardous waste under 40 CFR Part 261.

- n. The permittee shall continue to designate, as SIUs, those Industrial Users (IUs) which meet the definition contained in 40 CFR 403.3 and the permittee's sewer use ordinance.

The permittee shall notify each newly designated SIU of its classification as an SIU within thirty (30) days of identification and shall inform the SIU of the requirements of an SIU contained in 40 CFR 403.12.

7. Categorical Industrial Users (CIUs)

- a. The permittee shall require Industrial Users to comply with applicable Categorical Pretreatment Standards in addition to all applicable Pretreatment Standards and Requirements. The permittee shall require of all Categorical Industrial Users (CIUs), all reports on compliance with applicable Categorical Pretreatment Standards and Categorical Pretreatment Standard deadlines as specified in and in accordance with Sections (b), (d), (e) and (g) of 40 CFR 403.12. In addition, the permittee shall require Categorical Industrial Users to comply with the report signatory requirements contained in 40 CFR 403.12(l) when submitting such reports.
- b. If the permittee applies the Combined Wastestream Formula (CWF) to develop fixed alternative discharge limits of Categorical Pretreatment Standards, the application of the CWF and the enforcement of the resulting limits must comply with 40 CFR 403.6(e). The permittee must document all calculations within the control mechanism fact sheet and the resulting limits within the CIU's control mechanism. The permittee must ensure that the most stringent limit is applied to the CIU's effluent at end-of-pipe based upon a comparison of the resulting CWF limits and the permittee's local limits.
- c. If the permittee has or obtains the authority to apply and enforce equivalent mass per- day and/or concentration limitations of production---based Categorical Pretreatment Standards, then the permittee shall calculate and enforce the limits in accordance with 40 CFR 403.6(c). The permittee must document all calculations within the control mechanism fact sheet and the resulting limits within the CIU's control mechanism.

8. Annual Report

The annual report for the permittee's Industrial Pretreatment Program shall contain information pertaining to the reporting year which shall extend from October 1st through September 30th and shall be submitted electronically to the DEM by December 15<sup>th</sup> each year as a NetDMR attachment or by an alternative electronic reporting system as it becomes available. The requirements for the annual report are included in Attachment B of this permit.

9. Interjurisdictional Agreement

The permittee has an approved Interjurisdictional Agreement with the Town of Narragansett dated March 22, 2007, which shall continue to be implemented at all times. Any additional interjurisdictional agreements which may become necessary must be submitted to the DEM in draft form for approval prior to signature and execution.

10. Sewer Use Ordinance

The permittee has an approved Sewer Use Ordinance which shall continue to be implemented at all times

11. Monitoring and Reporting for Emerging Contaminants

The Permittee shall commence annual sampling of the below-listed types of industrial discharges into the POTW. PFAS sampling requirements do not apply to any below-listed industries that only discharge sanitary waste. PFAS shall be analyzed using Clean Water Act wastewater draft analytical method 1633 until a 40 CFR Part 136 approved test method for wastewater is made available to the public.

- Platers/Metal Finishers

- Paper and Packaging Manufacturers
- Tanneries and Leather/Fabric/Carpet Treaters
- Manufacturers of Parts with Polytetrafluorethylene (PTFE) or Teflon type coatings (i.e. bearings)
- Landfill Leachate
- Centralized Waste Treaters
- Contaminated Sites
- Fire Fighting Training Facilities
- Airports
- Any Other Known or Expected Sources of PFAS

Sampling shall be for the PFAS analytes as shown in Attachment A.

The industrial discharges sampled, and the sampling results shall be summarized and included in the Annual Report required by Part I.C.7. of the permit. In the case that there are no relevant dischargers, the Annual Report must include a description of the process used to determine that there were no relevant dischargers. If the first year's PFAS sampling is not completed by the due date of the Annual Report, the Annual Report shall include a listing of the relevant dischargers along with the anticipated sampling date within one year of **this permit's effective date**.

#### **D. OPERATION AND MAINTENANCE OF THE SEWER SYSTEM**

Operation and maintenance of the sewer system shall be in compliance with the General Requirements of Part II and the following terms and conditions:

1. **Maintenance Staff**

The permittee shall provide an adequate staff to carry out the operation, maintenance, repair, and testing functions required to ensure compliance with the terms and conditions of this permit.

2. **Infiltration/Inflow**

The permittee shall minimize infiltration/inflow to the sewer system. A summary report of all actions taken to minimize infiltration/inflow during the previous two (2) years shall be submitted to DEM, Office of Water Resources, by the 15<sup>th</sup> day of January every odd year.

3. **Resiliency Planning**

Within one year of the effective date of this permit, the Town shall submit a Resiliency Plan and schedule of short-term and long-term actions that will be taken to maintain, operate, and protect key collection and treatment system assets. The plan shall be consistent with the most recent version of DEM's Guidance for the Consideration of Climate Change Impacts in the Planning and Design of Municipal Wastewater Collection and Treatment Infrastructure and include consideration of the findings of the 2017 DEM report Implications of Climate Change for Rhode Island Wastewater Collection and Treatment Infrastructure. The Resiliency Plan shall include, but not be limited to: (i) an assessment of current and projected impacts from natural hazards on critical components within the Town's collection and treatment systems, as well as on the systems themselves; (ii) a plan to adapt and protect vulnerable components and systems; (iii) an analysis that provides justification for selected adaptation methods, including relevant cost-benefit analyses. The overall analysis must consider component and system design life and sea-level rise projections. For the purpose of this Resiliency Plan, critical components are considered those necessary to ensure the forward flow and treatment of wastewater in accordance with the limits set forth in this permit. The Resiliency Plan shall also consider impacts – such as debris carried on high winds – on the Town's treatment facility and wastewater collection system from neighboring facilities during high hazard events. This Plan shall be subject to DEM review and approval. If DEM determines that modifications need to be made to the Plan, DEM shall notify the permittee in writing which elements of the Plan need to be modified and the reason for the needed modification. This notification shall

include a schedule for making required changes. After such notification from the DEM, the permittee shall make changes to the Plan and submit the revisions to the DEM for their approval.

**E. SLUDGE**

The permittee shall conform and adhere to all conditions, practices and regulations as contained in the State of Rhode Island Rules and Regulations for Sewage Sludge Management (250-ICR-150-10-3). The permittee shall comply with its DEM Order of Approval for the disposal of sludge.

**F. DETECTION LIMITS**

All analyses of parameters under this permit must comply with the National Pollutant Discharge Elimination System (NPDES): *Use of Sufficiently Sensitive Test Methods for Permit Applications and Reporting* rule. Only sufficiently sensitive test methods may be used for analysis of parameters under this permit. The permittee shall assure that all wastewater testing required by this permit, is performed in conformance with the method detection limits below. All sludge testing required by this permit shall be in conformance with the method detection limits found in 40 CFR 503.8. In accordance with 40 CFR Part 136, EPA approved analysis techniques, quality assurance procedures and quality control procedures shall be followed for all reports required to be submitted under the RIPDES program. These procedures are described in "Methods for the Determination of Metals in Environmental Samples" (EPA/600/4-91/010) and "Methods for Chemical Analysis of Water and Wastes" (EPA/600/4-79/020).

The report entitled "Methods for the Determination of Metals in Environmental Samples" includes a test which must be performed in order to determine if matrix interferences are present, and a series of tests to enable reporting of sample results when interferences are identified. Each step of the series of tests becomes increasingly complex, concluding with the complete Method of Standard Additions analysis. The analysis need not continue once a result which meets the applicable quality control requirements has been obtained. Documentation of all steps conducted to identify and account for matrix interferences shall be submitted along with the monitoring reports.

If, after conducting the complete Method of Standard Additions analysis, the laboratory is unable to determine a valid result, the laboratory shall report "could not be analyzed." Documentation supporting this claim shall be submitted along with the monitoring report. If valid analytical results are repeatedly unobtainable, DEM may require that the permittee determine a method detection limit (MDL) for their effluent or sludge as outlined in 40 CFR Part 136, Appendix B.

Therefore, all sample results shall be reported as: an actual value, "could not be analyzed", less than the reagent water MDL, or less than an effluent or sludge specific MDL. The effluent or sludge specific MDL must be calculated using the methods outlined in 40 CFR Part 136, Appendix B. Samples which have been diluted to ensure that the sample concentration will be within the linear dynamic range shall not be diluted to the extent that the analyte is not detected. If this should occur the analysis shall be repeated using a lower degree of dilution.

When calculating sample averages for reporting on discharge monitoring reports (DMRs):

- a. "could not be analyzed" data shall be excluded, and shall not be considered as failure to comply with the permit sampling requirements;
- b. results reported as less than the MDL shall be included as zeros.





### OTHER TOXIC POLLUTANTS

	MDL ug/l (ppb)
Antimony, Total	3.0
Arsenic, Total	1.0
Beryllium, Total	0.2
Cadmium, Total	0.1
Chromium, total	1.0
Chromium, Hexavalent	20.0
Copper, Total	1.0
Lead, Total	1.0
Mercury, Total	0.2
Nickel, Total	1.0
Selenium, Total	2.0
Silver, Total	0.5
Thallium, Total	1.0
Zinc, Total	5.0
Asbestos	**
Cyanide, Free Available	10.0
Phenols, Total	50.0
TCDD	**
MTBE (Methyl Tert Butyl Ether)	1.0
Aluminum, Total***	5.0

\*\*No Rhode Island Department of Environmental Management (DEM) MDL

#### NOTE:

The MDL for a given analyte may vary with the type of sample. MDLs which are determined in reagent water may be lower than those determined in wastewater due to fewer matrix interferences. Wastewater is variable in composition and may therefore contain substances (interferents) that could affect MDLs for some analytes of interest. Variability in instrument performance can also lead to inconsistencies in determinations of MDLs.

To help verify the absence of matrix or chemical interference the analyst is required to complete specific quality control procedures. For the metals analyses listed above the analyst must withdraw from the sample two equal aliquots; to one aliquot add a known amount of analyte, and then dilute both to the same volume and analyze. The unspiked aliquot multiplied by the dilution factor should be compared to the original. Agreement of the results within 10% indicates the absence of interference. Comparison of the actual signal from the spiked aliquot to the expected response from the analyte in an aqueous standard should help confirm the finding from the dilution analysis. (Methods for Chemical Analysis of Water and Wastes EPA-600/4-79/020).

For Methods 624 and 625 the laboratory must on an ongoing basis, spike at least 5% of the samples from each sample site being monitored. For laboratories analyzing 1 to 20 samples per month, at least one spiked sample per month is required. The spike should be at the discharge permit limit or 1 to 5 times higher than the background concentration determined in Section 8.3.2, whichever concentration would be larger. (40 CFR Part 136 Appendix B Method 624 and 625 subparts 8.3.1 and 8.3.11).

**G. MONITORING AND REPORTING**

The monitoring program in the permit specifies sampling and analysis, which will provide continuous information on compliance and the reliability and effectiveness of the installed pollution abatement equipment. The approved analytical procedures found in 40 CFR Part 136 are required unless other procedures are explicitly required in the permit. The Permittee is obligated to monitor and report sampling results to the DEM within the time specified within the permit.

Unless otherwise specified in this permit, the permittee shall submit reports, requests, and information and provide notices in the manner described in this section.

1. Submittal of DMRs Using NetDMR

The permittee shall continue to submit its monthly monitoring data in discharge monitoring reports (DMRs) to DEM no later than the 15th day of the month electronically using NetDMR. When the permittee submits DMRs using NetDMR, it is not required to submit hard copies of DMRs to DEM.

2. Submittal of Reports as NetDMR Attachments

Unless otherwise specified in this permit, the permittee must submit electronic copies of documents in NetDMR that are directly related to the DMR. These include the following:

- DMR Cover Letters
- Below Detection Limit summary tables
- Monthly Operating Reports
- Pretreatment Annual Reports (see Part I.C.8) (December 15 each year)

All other reports (i.e. I/I reports, Priority Pollutant Scans, etc.) should be submitted to DEM hard copy via regular US mail (see Part I.G.4 below).

3. Submittal of Unauthorized Discharges Using NeT-SewerOverflow

The permittee shall submit, as needed to comply with Part II of this permit, written notice of unauthorized discharges, including Sanitary Sewer Overflow (SSO) reporting, bypasses, dry weather CSO reporting, extreme event, and anticipated bypasses using NeT-SewerOverflow. The permittee is not required to submit hard copies of these reports to DEM.

4. Submittal of Requests and Reports to DEM

The following requests, reports, and information described in this permit shall be submitted to the DEM.

- A. Transfer of Permit notice
- B. Request for changes in sampling location
- C. Request for reduction in testing frequency
- D. Request for reduction in WET testing requirement
- E. Report on unacceptable dilution water/request for alternative dilution water for WET testing

These reports, information, and requests shall be submitted to DEM by hard copy mail to the following address:

Rhode Island Department of Environmental Management  
RIPDES Program  
235 Promenade Street  
Providence, Rhode Island 02908

4. Submittal of Reports in Hard Copy Form

The following notifications and reports shall be submitted as hard copy with a cover letter describing the submission. These reports shall be signed and dated originals submitted to DEM.

- A. Written notifications required under Part II (as needed) other than those required to be submitted using NeT-SewerOverflow as described in Part I.G.3 above.
- B. Priority Pollutant Scan results (October 15 each year)
- C. Species Sensitivity Report (**Add Date Here**)

- D. Local Limits Monitoring Plan (within 6 months of effective permit date)
- E. Infiltration/Inflow Reports (January 15 every odd year; first report is due January 15, 2025)
- F. Resiliency Plan (within 1 year of effective permit date)

This information shall be submitted to DEM at the following address:

Rhode Island Department of Environmental Management  
RIPDES Program  
235 Promenade Street  
Providence, Rhode Island 02908

5. Verbal Reports and Verbal Notifications

Any verbal reports or verbal notifications, if required in Parts I and/or II of this permit, shall be made to the DEM. This includes verbal reports and notifications which require reporting within 24 hours. (See Part II(I)(5) General Requirements for 24-hour reporting) Verbal reports and verbal notifications shall be made to DEM at (401) 222-4700 or (401) 222-3070 at night.

**PART II**

**TABLE OF CONTENTS**

GENERAL REQUIREMENTS ..... 2

- a) Duty to Comply ..... 2
- b) Duty to Reapply ..... 2
- c) Need to Halt or Reduce Not a Defense ..... 2
- d) Duty to Mitigate ..... 2
- e) Proper Operation and Maintenance ..... 2
- f) Permit Actions ..... 2
- g) Property Rights ..... 3
- h) Duty to Provide Information ..... 3
- i) Inspection and Entry ..... 3
- j) Monitoring and Records ..... 3
- k) Signatory Requirement ..... 4
- l) Reporting Requirements ..... 4
- m) Bypass ..... 5
- n) UpsetP ..... 6
- o) Change in Discharge ..... 6
- p) Removed Substances ..... 6
- q) Power Failures ..... 7
- r) Availability of Reports ..... 7
- s) State Laws ..... 7
- t) Other Laws ..... 7
- u) Severability ..... 7
- v) Reopener Clause ..... 7
- w) Confidentiality of Information ..... 7
- x) Best Management Practices ..... 8
- y) Right of Appeal ..... 8

DEFINITIONS ..... 9

## GENERAL REQUIREMENTS

### a) Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of Chapter 46-12 of the Rhode Island General Laws and the Clean Water Act (CWA) and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

- (1) The permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.
- (2) The CWA provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the CWA is subject to a civil penalty not to exceed \$10,000 per day of such violation. Any person who willfully or negligently violates permit conditions implementing Sections 301, 302, 306, 307 or 308 of the Act is subject to a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment of not more than 1 year, or both.
- (3) Chapter 46-12 of the Rhode Island General Laws provides that any person who violates a permit condition is subject to a civil penalty of not more than \$5,000 per day of such violation. Any person who willfully or negligently violates a permit condition is subject to a criminal penalty of not more than \$10,000 per day of such violation and imprisonment for not more than 30 days, or both. Any person who knowingly makes any false statement in connection with the permit is subject to a criminal penalty of not more than \$5,000 for each instance of violation or by imprisonment for not more than 30 days, or both.

### b) Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The permittee shall submit a new application at least 180 days before the expiration date of the existing permit unless permission for a later date has been granted by the Director. (The Director shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)

### c) Need to Halt or Reduce Not a Defense

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

### d) Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

### e) Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures, and, where applicable, compliance with DEM "Rules and Regulations Pertaining to the Operation and Maintenance of Wastewater Treatment Facilities" and "Rules and Regulations Pertaining to the Disposal and Utilization of Wastewater Treatment Facility Sludge." This provision requires the operation of back-up or auxiliary facilities or similar systems only when the operation is necessary to achieve compliance with the conditions of the permit.

### f) Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause, including but not limited to: (1) Violation of any terms or conditions of this permit; (2) Obtaining this permit by misrepresentation or failure to disclose all relevant facts; or (3) A change in any conditions that requires either a temporary or permanent

reduction or elimination of the authorized discharge. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

g) Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege.

h) Duty to Provide Information

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

i) Inspection and Entry

The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:

- (1) Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- (2) Have access to and copy, at reasonable times any records that must be kept under the conditions of this permit;
- (3) Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices or operations regulated or required under this permit; and
- (4) Sample or monitor any substances or parameters at any location, at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the CWA or Rhode Island law.

j) Monitoring and Records

- (1) Samples and measurements taken for the purpose of monitoring shall be representative of the volume and nature of the discharge over the sampling and reporting period.
- (2) The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings from continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 5 years from the date of the sample, measurement, report or application. This period may be extended by request of the Director at any time.
- (3) Records of monitoring information shall include:
  - (i) The date, exact place, and time of sampling or measurements;
  - (ii) The individual(s) who performed the sampling or measurements;
  - (iii) The date(s) analyses were performed;
  - (iv) The individual(s) who performed the analyses;
  - (v) The analytical techniques or methods used; and
  - (vi) The results of such analyses.

- (4) Monitoring must be conducted according to test procedures approved under 40 CFR Part 136 and applicable Rhode Island regulations, unless other test procedures have been specified in this permit.
- (5) The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under this permit shall upon conviction, be punished by a fine of not more than \$10,000 per violation or by imprisonment for not more than 6 months per violation or by both. Chapter 46-12 of the Rhode Island General Laws also provides that such acts are subject to a fine of not more than \$5,000 per violation, or by imprisonment for not more than 30 days per violation, or by both.
- (6) Monitoring results must be reported on a Discharge Monitoring Report (DMR).
- (7) If the permittee monitors any pollutant more frequently than required by the permit, using test procedures approved under 40 CFR Part 136, applicable State regulations, or as specified in the permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR.

k) Signatory Requirement

All applications, reports, or information submitted to the Director shall be signed and certified in accordance with 250-RICR-150-10-1.12 of the Rhode Island Pollutant Discharge Elimination System (RIPDES) Regulations. Rhode Island General Laws, Chapter 46-12 provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$5,000 per violation, or by imprisonment for not more than 30 days per violation, or by both.

l) Reporting Requirements

- (1) Planned changes. The permittee shall give notice to the Director as soon as possible of any planned physical alterations or additions to the permitted facility.
- (2) Anticipated noncompliance. The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with the permit requirements.
- (3) Transfers. This permit is not transferable to any person except after written notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under State and Federal law.
- (4) Monitoring reports. Monitoring results shall be reported at the intervals specified elsewhere in this permit.
- (5) Twenty-four-hour reporting. The permittee shall immediately report any noncompliance which may endanger health or the environment by calling DEM at (401) 222-4700 or (401) 222-3070 at night.

A written submission shall also be provided within five (5) days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

The following information must be reported immediately:

- (i) Any unanticipated bypass which causes a violation of any effluent limitation in the permit; or
- (ii) Any upset which causes a violation of any effluent limitation in the permit; or
- (iii) Any violation of a maximum daily discharge limitation for any of the pollutants specifically listed by the Director in the permit.

The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

- (6) Other noncompliance. The permittee shall report all instances of noncompliance not reported under paragraphs (1), (2), and (5), of this section, at the time monitoring reports are submitted. The reports shall contain the information required in paragraph (l)(5) of the section.
- (7) Other information. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, they shall promptly submit such facts or information.

m) Bypass

"Bypass" means the intentional diversion of waste streams from any portion of a treatment facility.

- (1) Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs (2) and (3) of this section.
- (2) Notice.
  - (i) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten (10) days before the date of the bypass.
  - (ii) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in 250-RICR-150-10-1.14(R) of the RIPDES Regulations.
- (3) Prohibition of bypass.
  - (i) Bypass is prohibited, and the Director may take enforcement action against a permittee for bypass, unless:
    - (A) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage, where "severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production;
    - (B) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and



- (C) The permittee submitted notices as required under paragraph (2) of this section.
- (ii) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph (3)(i) of this section.

n) Upset

"Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

- (1) Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of paragraph (2) of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- (2) Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (i) An upset occurred and that the permittee can identify the cause(s) of the upset;
  - (ii) The permitted facility was at the time being properly operated;
  - (iii) The permittee submitted notice of the upset as required in 250-RICR-150-10-1.14(R) of the RIPDES Regulations; and
  - (iv) The permittee complied with any remedial measures required under 250-RICR-150-10-1.14(E) of the RIPDES Regulations.
- (3) Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.

o) Change in Discharge

All discharges authorized herein shall be consistent with the terms and conditions of this permit. Discharges which cause a violation of water quality standards are prohibited. The discharge of any pollutant identified in this permit more frequently than or at a level in excess of that authorized shall constitute a violation of the permit. Any anticipated facility expansions, production increases, or process modifications which will result in new, different or increased discharges of pollutants must be reported by submission of a new NPDES application at least 180 days prior to commencement of such discharges, or if such changes will not violate the effluent limitations specified in this permit, by notice, in writing, to the Director of such changes. Following such notice, the permit may be modified to specify and limit any pollutants not previously limited.

Until such modification is effective, any new or increased discharge in excess of permit limits or not specifically authorized by the permit constitutes a violation.

p) Removed Substances

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall be disposed of in a manner consistent with applicable Federal and State laws and regulations including, but not limited to the CWA and the Federal Resource Conservation and Recovery Act, 42 U.S.C. §§6901 et seq., Rhode Island General Laws, Chapters 46-12, 23-19.1 and regulations promulgated thereunder.

q) Power Failures

In order to maintain compliance with the effluent limitation and prohibitions of this permit, the permittee shall either:

In accordance with the Schedule of Compliance contained in Part I, provide an alternative power source sufficient to operate the wastewater control facilities;

or if such alternative power source is not in existence, and no date for its implementation appears in Part I,

Halt reduce or otherwise control production and/or all discharges upon the reduction, loss, or failure of the primary source of power to the wastewater control facilities.

r) Availability of Reports

Except for data determined to be confidential under paragraph (w) below, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the DEM, 235 Promenade Street, Providence, Rhode Island 02908. As required by the CWA, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the CWA and under Section 46-12-14 of the Rhode Island General Laws.

s) State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law.

t) Other Laws

The issuance of a permit does not authorize any injury to persons or property or invasion of other private rights, nor does it relieve the permittee of its obligation to comply with any other applicable Federal, State, and local laws and regulations.

u) Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

v) Reopener Clause

The Director reserves the right to make appropriate revisions to this permit in order to incorporate any appropriate effluent limitations, schedules of compliance, or other provisions which may be authorized under the CWA or State law. In accordance with 250-RICR-150-10-1.16 and 250-RICR-150-10-1.24 of the RIPDES Regulations, if any effluent standard or prohibition, or water quality standard is promulgated under the CWA or under State law which is more stringent than any limitation on the pollutant in the permit, or controls a pollutant not limited in the permit, then the Director may promptly reopen the permit and modify or revoke and reissue the permit to conform to the applicable standard.

w) Confidentiality of Information

- (1) Any information submitted to DEM pursuant to these regulations may be claimed as confidential by the submitter. Any such claim must be asserted at the time of submission in the manner prescribed on the application form or instructions or, in the case of other submissions, by stamping the words "confidential business information" on each page containing such information. If no claim is made at the time of submission, DEM may make the information available to the public without further notice.

- (2) Claims of confidentiality for the following information will be denied:
- (i) The name and address of any permit applicant or permittee;
  - (ii) Permit applications, permits and any attachments thereto; and
  - (iii) NPDES effluent data.

x) Best Management Practices

The permittee shall adopt Best Management Practices (BMP) to control or abate the discharge of toxic pollutants and hazardous substances associated with or ancillary to the industrial manufacturing or treatment process and the Director may request the submission of a BMP plan where the Director determines that a permittee's practices may contribute significant amounts of such pollutants to waters of the State.

y) Right of Appeal

Within thirty (30) days of receipt of notice of a final permit decision, the permittee or any interested person may submit a request to the Director for an adjudicatory hearing to reconsider or contest that decision. The request for a hearing must conform to the requirements of 250-RICR-150-10-1.50 of the RIPDES Regulations.

**DEFINITIONS**

1. For purposes of this permit, those definitions contained in the RIPDES Regulations, and the Rhode Island Pretreatment Regulations shall apply.
2. The following abbreviations, when used, are defined below.

cu. M/day or M <sup>3</sup> /day	cubic meters per day
mg/l	milligrams per liter
µg/l	micrograms per liter
lbs/day	pounds per day
kg/day	kilograms per day
Temp. °C	temperature in degrees Centigrade
Temp. °F	temperature in degrees Fahrenheit
Turb.	turbidity measured by the Nephelometric Method (NTU)
TNFR or TSS	total nonfilterable residue or total suspended solids
DO	dissolved oxygen
BOD	five-day biochemical oxygen demand unless otherwise specified
TKN	total Kjeldahl nitrogen as nitrogen
Total N	total nitrogen
NH <sub>3</sub> -N	ammonia nitrogen as nitrogen
Total P	total phosphorus
COD	chemical oxygen demand
TOC	total organic carbon
Surfactant	surface-active agent
pH	a measure of the hydrogen ion concentration
PCB	polychlorinated biphenyl
CFS	cubic feet per second
MGD	million gallons per day
Oil & Grease	Freon extractable material
Total Coliform	total coliform bacteria
Fecal Coliform	total fecal coliform bacteria
ml/l	milliliter(s) per liter
NO <sub>3</sub> -N	nitrate nitrogen as nitrogen
NO <sub>2</sub> -N	nitrite nitrogen as nitrogen
NO <sub>3</sub> -NO <sub>2</sub>	combined nitrate and nitrite nitrogen as nitrogen
Cl <sub>2</sub>	total residual chlorine

Attachment A

PFAS Analyte List

Target Analyte Name	Abbreviation	CAS Number
<b>Perfluoroalkyl carboxylic acids</b>		
Perfluorobutanoic acid	PFBA	375-22-4
Perfluoropentanoic acid	PFPeA	2706-90-3
Perfluorohexanoic acid	PFHxA	307-24-4
Perfluoroheptanoic acid	PFHpA	375-85-9
Perfluorooctanoic acid	PFOA	335-67-1
Perfluorononanoic acid	PFNA	375-95-1
Perfluorodecanoic acid	PFDA	335-76-2
Perfluoroundecanoic acid	PFUnA	2058-94-8
Perfluorododecanoic acid	PFDoA	307-55-1
Perfluorotridecanoic acid	PFTrDA	72629-94-8
Perfluorotetradecanoic acid	PFTeDA	376-06-7
<b>Perfluoroalkyl sulfonic acids</b>		
<i>Acid Form</i>		
Perfluorobutanesulfonic acid	PFBS	375-73-5
Perfluoropentanesulfonic acid	PFPeS	2706-91-4
Perfluorohexanesulfonic acid	PFHxS	355-46-4
Perfluoroheptanesulfonic acid	PFHpS	375-92-8
Perfluorooctanesulfonic acid	PFOS	1763-23-1
Perfluorononanesulfonic acid	PFNS	68259-12-1
Perfluorodecanesulfonic acid	PFDS	335-77-3
Perfluorododecanesulfonic acid	PFDoS	79780-39-5
<b>Fluorotelomer sulfonic acids</b>		
1H,1H, 2H, 2H-Perfluorohexane sulfonic acid	4:2FTS	757124-72-4
1H,1H, 2H, 2H-Perfluorooctane sulfonic acid	6:2FTS	27619-97-2
1H,1H, 2H, 2H-Perfluorodecane sulfonic acid	8:2FTS	39108-34-4
<b>Perfluorooctane sulfonamides</b>		
Perfluorooctanesulfonamide	PFOSA	754-91-6
N-methyl perfluorooctanesulfonamide	NMeFOSA	31506-32-8
N-ethyl perfluorooctanesulfonamide	NEtFOSA	4151-50-2
<b>Perfluorooctane sulfonamidoacetic acids</b>		
N-methyl perfluorooctanesulfonamidoacetic acid	NMeFOSAA	2355-31-9
N-ethyl perfluorooctanesulfonamidoacetic acid	NEtFOSAA	2991-50-6
<b>Perfluorooctane sulfonamide ethanols</b>		
N-methyl perfluorooctanesulfonamidoethanol	NMeFOSE	24448-09-7
N-ethyl perfluorooctanesulfonamidoethanol	NEtFOSE	1691-99-2
<b>Per- and Polyfluoroether carboxylic acids</b>		
Hexafluoropropylene oxide dimer acid	HFPO-DA	13252-13-6
4,8-Dioxa-3H-perfluorononanoic acid	ADONA	919005-14-4
Perfluoro-3-methoxypropanoic acid	PFMPA	377-73-1
Perfluoro-4-methoxybutanoic acid	PFMBA	863090-89-5
Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	151772-58-6

<b>Ether sulfonic acids</b>		
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9Cl-PF3ONS	756426-58-1
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	763051-92-9
Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	113507-82-7
<b>Fluorotelomer carboxylic acids</b>		
3-Perfluoropropyl propanoic acid	3:3FTCA	356-02-5
2H,2H,3H,3H-Perfluorooctanoic acid	5:3FTCA	914637-49-3
3-Perfluoroheptyl propanoic acid	7:3FTCA	812-70-4

**Attachment B**  
**Industrial Pretreatment Program Annual Report Requirements**

The permittee shall provide an annual report to the DEM that describes the POTW's pretreatment program activities, including activities of all participating agencies, if more than one jurisdiction is involved in the local program. The report required by this section shall be submitted electronically by December 15 annually as a NetDMR attachment or by an alternative electronic reporting system as it becomes available. The report must include, at a minimum, the applicable required data in appendix A to 40 CFR Part 127. The report required by this section must also include a summary of changes to the POTW's pretreatment program that have not been previously reported to the DEM and any other relevant information requested by the DEM. Each item below must be addressed separately and any items which are not applicable must be so indicated. If any item is deemed not applicable a brief explanation must be provided.

The permittee shall submit to the DEM a report that contains the following information:

1. A listing of Industrial Users which complies with requirements stated in 40 CFR 403.12(i). The list shall identify all Categorical Industrial Users (CIUs), Significant Industrial Users (SIUs), Non-Significant Categorical Industrial Users (NSCIUs), Middle Tier Categorical Industrial Users (MTCIUs), and any other categories of users established by the permittee;
  - a. Names and addresses, or a list of deletions and additions keyed to a previously submitted list. The POTW shall provide a brief explanation of each deletion. The POTW shall also list the Industrial Users subject to categorical Pretreatment Standards that are subject to reduced reporting requirements under paragraph (e)(3).
  - b. Permit status. Whether each SIU has an unexpired control mechanism and an explanation as to why any SIUs are operating without a current, unexpired control mechanism (e.g. permit);
  - c. Baseline monitoring reporting requirements for newly promulgated industries;
  - d. A brief description of the industry and general activities. The Standard Industrial Classification (SIC) codes that represent the economic activities of SIUs and/or CIUs must be included. If the SIC code is not provided, then the six-digit North American Industry Classification System (NAICS) code/description that represents the economic activity of SIUs must be included. If more than one SIC/NAICS code applies, each must be included;
  - e. For each CIU, the permittee must state the applicable categorical standard(s) by its 40 CFR part number (e.g., Metal Finishing – part 433, Electrical and Electronic Components – part 469);
  - f. For each CIU, the permittee must indicate whether the CIU is subject to one or more local limits that are more stringent than the applicable categorical standards;
  - g. For each SIU and NSCIU, the maximum monthly average wastewater flow rate (in gallons per day) must be identified for the pretreatment year;
  - h. For each NSCIU, identify whether the facility has reported its required annual compliance certification to the Control Authority; and

- i. For each MTSIU, identify whether the Control Authority has granted reduced reporting requirements in accordance with 40 CFR 403.12(e)(3).
2. A summary, including dates, of any notifications received by the permittee of any substantial change in the volume or character of pollutants being introduced into the POTW by new or existing IUs. If applicable, an evaluation of the quality and quantity of influent introduced into the POTW and any anticipated impact due to the changed discharge on the quantity or quality of effluent to be discharged from the POTW shall be included.
3. A summary of compliance and enforcement activities of each Industrial User as of the end of last quarter covered by the annual report. The list shall identify all IUs in noncompliance, the pretreatment program requirement which the IU failed to meet, and the type and date of the enforcement action initiated by the permittee in response to the violation. If applicable, the list shall also contain the date which IUs in noncompliance returned to compliance, a description of corrective actions ordered, and the penalties levied. This includes, but is not limited to:
  - a. The number of SIUs inspected by the POTW (including inspection dates for each industrial user);
  - b. SIUs sampled by the POTW for each industrial user; (including sampling dates for each industrial user);
  - c. For each SIU, the number of required self-monitoring sampling events submitted to the Control Authority, and, if the SIU sampled more frequently, the actual number of self-monitoring sampling events;
  - d. Compliance schedules issued (include list of subject users);
  - e. Written notices of violations issues (include list of subject users);
  - f. Administrative orders issued (include list of subject users);
  - g. Criminal or civil suits filed (include list of subject users);
  - h. Penalties obtained (include list of subject users and penalty amounts); and
  - i. Other enforcement actions conducted in accordance with the approved Enforcement response Plan.
4. A list of industries which were determined, in accordance with Part I.C.6.(1) of this permit, to be in significant noncompliance required to be published in a local newspaper and a copy of proof of publication from the newspaper that the names of these violators has been published, and the month(s) that the IU(s) were in SNC.
5. A summary of permit issuance/reissuance activities including the name of the industrial user, expiration date of previous permit, issuance date of new permit, and a brief description of any changes to the permit.
6. A list including the report/notification type, due date, and receipt date for each report/notification required by 40 CFR 403.12.



7. A summary of public participation efforts including meetings and workshops held with the public and/or industry and notices/newsletters/bulletins published and/or distributed.

8. A program evaluation in terms of program effectiveness, local limits application and resources which addresses but is not limited to:

- A description of the actions being taken to reduce the incidence of SNC by Industrial Users;
- Effectiveness of enforcement response program;
- Sufficiency of funding and staffing;
- Sufficiency of the SUO, Rules and Regulations and/or statutory authority;

9. An evaluation of recent/proposed program modifications, both substantial and non-substantial, in terms of the modification type, implementation and actual/ expected effect (note proposed modifications must be submitted under separate cover along with the information required by 40 CFR 403.18);

10. A detailed description of all interference and passthrough that occurred during the past year and, if applicable;

- A description of any problems (e.g., interference with the use or disposal of biosolids or sewage sludge, violation of RIPDES permit requirements or EPA's regulations at 40 CFR 503) with the POTW's biosolids or sewage sludge within the pretreatment year.
- A thorough description of all investigations into interference and pass-through during the past year;
- A description of the monitoring, sewer inspections and evaluations which were done during the past year to detect interference and passthrough, specifying pollutants analyzed and frequencies;

11. A summary of the average, maximum concentration, minimum concentration, and number of data points used for pollutant analytical results for influent, effluent, sludge and any toxicity or bioassay data from the wastewater treatment facility. The summary shall include a comparison of influent sampling results versus the maximum allowable headworks loadings contained in the approved local limits evaluation and effluent sampling results versus water quality standards. This summary may use the Annual Pretreatment Report Summary Sheet in part to fulfill this requirement. Such a comparison shall be based on the analytical results required in Parts I.A and I.B of this permit and any additional sampling data available to the permittee; and

12. A completed Annual Pretreatment Report Summary Sheet (See below).

**Annual Pretreatment Report Summary Sheet**

- POTW Name:
- RIPDES Permit #:
- Pretreatment Report Period Start Date:
- Pretreatment Report Period End Date:
- # of Significant Industrial Users (SIUs):
- # of SIUs Without Control Mechanisms:
- # of SIUs not Inspected
- # of SIUs not Sampled:
- # of SIUs in Significant Noncompliance (SNC) with Pretreatment Standards:
- # of SIUs in SNC with Reporting Requirements:
- # of SIUs in SNC with Pretreatment Compliance Schedule:
- # of SIUs in SNC Published in Newspaper:
- # of SIUs with Compliance Schedules:
- # of Violation Notices Issued to SIUs:
- # of Administrative Orders Issued to SIUs:
- # of Civil Suits Filed Against SIUs:
- # of Criminal Suits Filed Against SIUs:
- # of Categorical Industrial Users (CIUs):
- # of CIUs in SNC:

Penalties

- Total Dollar Amount of Penalties Collected (\$):
- # of IUs from which Penalties have been collected:

Local Limits

- Date of Most Recent Technical Evaluation of Local Limits:
- Date of Most Recent Adoption of Technically Based Local Limits:

Using current POTW influent sampling data, fill in Column (3) using the maximum and average of the 12 monthly average flows over the past year. In Column (4), list your Maximum Allowable Headwork Loading (MAHL) values used to derive your Technically-Based Local Limits as submitted in your most recent approved Local Limits Evaluation. Include extra sheets as necessary.

Column 1	Column 2	Column 3		Column 4
Pollutant	Local Limit	Influent Data Analysis (lb/day)		MAHL values (lb/day)
		Maximum	Average	


RHODE ISLAND DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
OFFICE OF WATER RESOURCES  
235 PROMENADE STREET  
PROVIDENCE, RHODE ISLAND 02908-5767

**FACT SHEET**

RHODE ISLAND POLLUTANT DISCHARGE ELIMINATION SYSTEM (RIPDES) PERMIT TO DISCHARGE TO WATERS OF THE STATE

RIPDES PERMIT NO. RI0100374

NAME AND ADDRESS OF APPLICANT:

Town of South Kingstown  
180 High Street  
Wakefield, RI 02879

NAME AND ADDRESS OF FACILITY WHERE DISCHARGE OCCURS:

South Kingstown Regional Wastewater Treatment Plant  
275 Westmoreland Street  
Narragansett, RI 02882

**RECEIVING WATER:** Rhode Island Sound  
**WBID:** RI0010042E-01A  
**CLASSIFICATION:** SB1

**FACT SHEET TABLE OF CONTENTS**

I. Proposed Action, Type of Facility, and Discharge Location ..... 1

II. Description of Discharge..... 1

III. Permit Limitations and Conditions ..... 1

IV. Permit Basis and Explanation of Effluent Limitation Derivation..... 1

    Variances, Alternatives, and Justifications for Waivers of Application Requirements ..... 1

    Facility Description ..... 1

    Receiving Water Description ..... 1

    Industrial Pretreatment Program ..... 2

    Local Limits ..... 2

    Annual Report..... 2

    Permit Limit Development ..... 2

    WWTP Conventional Pollutant Permit Limitations..... 3

        Flow Limits ..... 3

        BOD<sub>5</sub>, TSS, and pH..... 3

        Settleable Solids..... 3

        Oil and Grease ..... 3

        Bacteria ..... 3

    WWTP Toxic Pollutant Limits ..... 3

        Water Quality Based Permit (WQBEL) Limitations ..... 3

        Mixing Zones and Dilution Factors..... 4

        Wasteload Allocation..... 5

        Priority Pollutants ..... 5

        WET Testing..... 6

        Nutrients ..... 6

        Ammonia ..... 6

    Emerging Contaminants ..... 6

    Antibacksliding and Antidegradation..... 8

        Antibacksliding ..... 8

        Antidegradation..... 8

    Operations and Maintenance..... 10

        Resiliency Planning Requirements ..... 10

        Sludge Requirements..... 10

        Other Conditions ..... 10

    Permit Limit Summary..... 10

V. Comment Period, Hearing Requests, and Procedures for Final Decisions..... 12

VI. DEM Contact..... 12

## **I. PROPOSED ACTION, TYPE OF FACILITY, AND DISCHARGE LOCATION**

The above-named applicant has applied to the Rhode Island Department of Environmental Management (DEM) for reissuance of a Rhode Island Discharge Elimination System (RIPDES) Permit to discharge into the designated receiving water. The facility is engaged in the treatment of domestic and industrial sewage. The discharge to Rhode Island Sound is from the South Kingstown Regional Wastewater Treatment Plant at Outfall 001A. The latitude / longitude coordinates of the outfall are 41.422944, -71.452889, which is approximately 1040 feet from shore, and is located in water approximately 41 feet deep at mean low water. Site layout and process diagrams of the facility are shown in Attachments A-1 and A-2 respectively.

## **II. DESCRIPTION OF DISCHARGE**

A quantitative description of the discharge in terms of significant effluent parameters based on the facility's Discharge Monitoring Report (DMR) data from December 2016 through August 2023 is shown on Attachment A-3. A review of the historic discharge data demonstrates that the South Kingstown Regional Wastewater Treatment Plant can comply with all limitations given.

## **III. PERMIT LIMITATIONS AND CONDITIONS**

The final effluent limitations and monitoring requirements may be found in the permit.

## **IV. PERMIT BASIS AND EXPLANATION OF EFFLUENT LIMITATION DERIVATION**

### **Variances, Alternatives, and Justifications for Waivers of Application Requirements**

No variances or alternatives to required standards were requested or granted. No waivers were requested or granted for any application requirements per 40 CFR §122.21(j) or (q).

### **Facility Description**

The Town of South Kingstown ("the Town") owns and operates a regional wastewater treatment facility located at 275 Westmoreland Street, Narragansett, Rhode Island. The discharge to Rhode Island Sound consists of treated sanitary sewage contributed by the municipalities of South Kingstown (including the University of Rhode Island) and Narragansett. Treatment consists of the following: Coarse Screening, Comminution, Primary Settling, Fine Bubble Aeration, Secondary Settling, Chlorination, and Dechlorination. A topographic map of the facility is included in Attachment A-1, a process flow diagram is included as Attachment A-2, and an aerial photograph with superimposed acute and chronic mixing zones is included as Attachment A-4.

The Town's most recent RIPDES permit, authorizing discharges from the above-mentioned facility, was issued on July 10, 2017. The permit became effective on September 1, 2017 and expired on August 31, 2022. The Town submitted an application for permit reissuance to the DEM on October 30, 2021, which was received on November 18, 2021. On November 23, 2021 the DEM issued an application complete letter to the Town. In accordance with Rule 13(a) of the Regulations for the Rhode Island Pollutant Discharge Elimination System, the Town's July 10, 2017 permit remains in effect since the DEM has determined that a timely and complete permit application was submitted. Once this permit is reissued, it will supersede the July 10, 2017 permit.

### **Receiving Water Description**

The waterbody segment in the Rhode Island Sound that receives the discharge from the South Kingstown WWTP is described as coastal waters in the vicinity of Tucker's Dock which are within a 500 foot radius of the South Kingstown/Narragansett Regional Wastewater Treatment Plant outfall. The waterbody identification for this water body is RI0010042E-01A. This segment is located in Narragansett and is classified as a class SB1 water body according to the Rhode Island Water Quality Regulations. SB1 waters

are designated for primary and secondary contact recreational activities and fish and wildlife habitat. They shall be suitable for aquacultural uses, navigation, and industrial cooling. These waters shall have good aesthetic value. Primary contact recreational activities may be impacted due to pathogens from approved wastewater discharges. However, all Class SB criteria must be met. This segment is not listed as impaired on DEM's March 2022 Integrated Report. Impaired waters include those where TMDLs are required (i.e., Category 5 Waters or 303d List of Impaired Waters) and those where TMDLs are not required (i.e., Category 4 Waters).

### **Industrial Pretreatment Program**

The permit contains a reporting requirement for a local program to regulate industrial discharges to the sewer system (referred to as pretreatment program). This program is being required under authority of Section 402(b)(8) of the CWA and 40 CFR 122.44 (j) and 403.8 because the Town receives significant discharges from 1 significant industrial user (SIUs).

The South Kingstown WWTP's Industrial Pretreatment Program was first approved by DEM on September 13, 1984, and was most recently modified on June 12, 2023, to incorporate changes from the June 2021 Derivation Report. Contributing Industrial Users to the POTW include restaurants, hotels, laundromats, schools and local businesses. The POTW accepts hauled waste from twelve (12) licensed haulers, eleven (11) septic waste haulers and one (1) port-a-john hauler.

### **Local Limits**

South Kingstown submitted to the DEM a technical evaluation of its local limits on September 16, 2021. On September 28, 2021 the DEM issued preliminary approval of the Local Limits Evaluation and these changes have since been incorporated into the Town Sewer Use Ordinance as of June 12, 2023. Since the permit limits in this permit have not changed; no further updates will be required at this time.

### **Annual Report**

The permit requires that South Kingstown submit an annual report for their industrial pretreatment program pertaining to the reporting year (October 1<sup>st</sup> – September 30<sup>th</sup> by December 15<sup>th</sup> every year. These reports are to be submitted as NetDMR attachments as outlined in Part I.C.8 of this permit. The requirements for the annual report are outlined in Attachment B of the permit.

### **Permit Limit Development**

The requirements set forth in this permit are from the State's Water Quality Regulations and the State's Regulations for the Rhode Island Pollutant Discharge Elimination System, both filed pursuant to RIGL Chapter 46-12, as amended. DEM's primary authority over the permit comes from EPA's delegation of the program in September 1984 under the Federal Clean Water Act (CWA).

Development of Rhode Island Pollutant Discharge Elimination System (RIPDES) permit limitations is a multi-step process consisting of the following steps: calculating allowable discharge levels based on instream criteria, background data and available dilution; assigning applicable Technology-based limits and appropriate Best Professional Judgement (BPJ) limits; determining if technology based limits apply; comparing existing permit limits to the new allowable discharge levels; and evaluating the ability of the facility to meet the final permit effluent limits.

Water quality criteria are comprised of numeric and narrative criteria. Numeric criteria are scientifically derived ambient concentrations developed by EPA or States for various pollutants of concern to protect human health and aquatic life. Narrative criteria are statements that describe the desired water quality goal. A water quality-based permit limit protects receiving water quality by ensuring that water quality standards are met.

A technology-based limit is a numeric limit, which is determined by examining the capability of a treatment process to reduce or eliminate pollutants.

## **WWTP Conventional Pollutant Permit Limitations**

### **Flow Limits**

The basis for the facility's flow limit of 5.0 MGD is the facility's Facilities Plan dated October 1994.

### **BOD<sub>5</sub>, TSS, and pH**

The "Average Monthly" and "Average Weekly" biochemical oxygen demand (BOD<sub>5</sub>) and total suspended solids (TSS) permit limitations, the "Percent Removal" requirements for BOD<sub>5</sub> and TSS, and the effluent limitations for pH are based upon the secondary treatment requirements in Section 301(b)(1)(B) of the Clean Water Act (CWA), as defined in 40 CFR 133.102 (a) & (c). "Maximum Daily" BOD<sub>5</sub> and TSS limits are based on Rhode Island requirements for Publicly Owned Treatment Works (POTWs) under Rule 17.04(b) of the RIPDES Regulations and as provided in 40 CFR 123.25.

### **Settleable Solids**

Settleable Solids monitoring has been included as a process-control parameter that can aid in the assessment of the operation of the plant but need not have an effluent limit.

### **Oil and Grease**

Oil and Grease monitoring requirements that were assigned have been maintained in this permit in order to serve as a process control parameter. Monitoring data will serve as an indicator of excessive levels of Oil and Grease which may result in blockages in the collection system and that are typically attributed to restaurants and other sources of Oil and Grease loading which discharge to the sewer collection system. The Town of South Kingstown and the DEM will be able to use this data to track and potentially initiate corrective action if necessary to prevent backups and blockages within the sewer collection system.

### **Bacteria**

Table 10.E.1 of the RI Water Quality Regulations (RICR 250-RICR-150-05-1) include enterococci criteria for primary contact/swimming of a geometric mean of 35 colonies/100 ml and a single sample maximum of 104 colonies/100 ml. However, the "single sample maximum" value is only used by the Rhode Island Department of Health to evaluate swimming advisories at public beaches and is not applied to the receiving water in the area of the South Kingstown WWTP's outfall. EPA's November 12, 2008 memorandum regarding "Initial Zones of Dilution for Bacteria in Rivers and Streams Designated for Primary Contact Recreation" specifies that it is not appropriate to use dilution for bacteria criteria in receiving waters that are designated for primary contact recreation. Therefore, because the receiving water is designated for primary contact recreation, the DEM has assigned a monthly average enterococci limit of 35 colonies/100 ml. The daily maximum enterococci limit has been set at the 90% upper confidence level value for "lightly used full body contact recreation" of 276 colonies/100 ml.

The DEM has also assigned fecal coliform monitoring to ensure that the discharge from the WWTP will not have an impact on any areas designated for shellfish harvesting outside of the immediate vicinity of the outfall.

## **WWTP Toxic Pollutant Limits**

### **Water Quality Based Permit (WQBEL) Limitations**

The allowable effluent limitations were established on the basis of acute and chronic aquatic life criteria and human health criteria using the following: available instream dilution; an allocation factor; and background concentrations when available and/or appropriate. The aquatic life and human health criteria are specified in the Rhode Island Water Quality Regulations (250-RICR-150-05-1), as amended. Aquatic life criteria have been established to ensure the protection and propagation of aquatic life while human health criteria represent the pollutant levels that would not result in a significant risk to public health from ingestion of aquatic organisms. The more stringent of the two criteria was then used in establishing allowable effluent limitations. Details concerning the calculation of potential permit limitations, selection of factors, which influence their calculation, and the selection of final permit limitations are included below or in the attached



documents. The Town's first permit to contain water quality-based limits was issued in November 1995. The permit was subsequently reissued in May 2001, July 2006, January 2012, and July 2017. Most of the conditions from the July 2017 RIPDES permit have remained intact and the basis for conditions which have been carried forward from the 2017 permit and the basis for those which are new to the 2023 draft permit is detailed below.

### **Mixing Zones and Dilution Factors**

In order to evaluate the need for water quality-based limits, it is necessary to determine the mixing which occurs in the immediate vicinity of the discharge (initial dilution). The WWTPs effluent is discharged through a 28-inch pipe that is approximately 1,040 feet offshore and is fitted with a diffuser consisting of five (5) twelve (12) inch ports, each of which is five (5) feet in length. Rule 17 of the RIPDES Regulations requires the use of the design flow when establishing limits for POTWs. Permit limits were established based on acute and chronic dilution factors of 80:1 and 118:1 with respective mixing zone radii of 135 meters (approximately 443 feet) and 13.5 meters (approximately 44.3 feet), determined from the EPA computer model CORMIX2 assuming the design flow of 5.0 MGD, a mean low water depth of the outfall of approximately 41 feet, a wind speed of two (2) knots, and a conservative estimate of ambient current velocity (0.16 feet per second). Please refer to the November 27, 1995 Development Document for additional details regarding the dilution modeling. Because the conditions that were used to calculate the dilution factors in November of 1995 have not changed, the same dilution factors have been used during the reissuance of this permit. The South Kingstown WWTP mixing zone is presented as an aerial photograph in Attachment A-4.

The Rhode Island Water Quality Regulations at 250-RICR-150-05-1.18(N)(1) require in-stream concentrations of discharged pollutants to be determined by specific formulas, or other methods which may be found to be acceptable.

Using these dilution factors, the allowable discharge limits were calculated as follows:

- a) Background concentration unknown or available data is impacted by sources that have not yet achieved water quality-based limits.

$$Limit_1 = (DF) * (Criteria) * (80\%)$$

Where: DF = acute or chronic dilution factor, as appropriate

- b) Using available background concentration data.

$$Limit_1 = (DF) * (Criteria) * 90\% - (Background) * (DF - 1)$$

Where: DF = acute or chronic dilution factor, as appropriate.

Since background data in the area of the discharge, was not available, water quality-based permit limits were calculated using equation (a) above. Reference Attachment A-5 for calculations of allowable limits based on Aquatic Life and Human Health Criteria. A summary of Discharge Monitoring Report (DMR) data for the period December 2016 – August 2023 and facility Priority Pollutant Scan data for the period September 2017 – September 2022 are provided in Attachments A-6 and A-7, respectively. RIPDES Permit application data from 2021 is included in Attachment A-6. Attachment A-8 is a summary comparison of the allowable limits versus the DMR data, Priority Pollutant Scan data, and permit application data. Note that permit application data includes Priority Pollutant Scan data from 2017-2020.

The formulas and data noted above were applied with the following exceptions:

- a) Pollutants that based on the acute and chronic dilution factors, have a higher allowable chronic limit than allowable acute limit. For this situation, both the "Monthly Average" and "Daily Maximum" limits were set at the allowable acute limit.
- b) Total residual chlorine. The limits for total residual chlorine (TRC) were established in accordance with the DEM Effluent Disinfection Policy. The "Monthly Average" and "Daily Maximum" were based on a 100% allocation, a zero background concentration, and the appropriate dilution factor(s). The 100% allocation factor for TRC was used due to the non-conservative nature of chlorine and the improbability of the receiving water having a detectable background TRC concentration.

- c) Pollutants with water quality based monthly average limits in the previous RIPDES permit. The relaxation of monthly average limits from the previous permit was restricted in accordance with the antibacksliding provisions of the Clean Water Act and the Policy on the Implementation of the Antidegradation Provisions of the Rhode Island Water Quality Regulations.

### ***Wasteload Allocation***

In accordance with 40 CFR 122.4(d)(1)(iii), it is only necessary to establish water-quality-based permit limits for those pollutants in the discharge which have the reasonable potential to cause or contribute to the exceedance of instream criteria. Reasonable potential to cause an exceedance is determined using the dilution factors presented in the previous section as well as the saltwater aquatic life and non-Class AA human health criteria, from the Rhode Island Water Quality Regulations (250-RICR-150-05-1) to determine allowable discharge concentrations. Allowable discharge concentrations for all parameters in Attachment A-5 were calculated using 80% allocation for pollutants without background data, 90% allocation for pollutants with background data, and 100% allocation of total residual chlorine (TRC) due to the fact that chlorine is not expected to be found in ambient water and it is a non-conservative pollutant. In the case of ammonia, since removal is strongly dependent on temperature (nitrification rate decreases as temperature decreases) and ammonia does not bioaccumulate or accumulate in sediment, seasonal dilution factors and historical pH and temperature background data were used to determine the appropriate potential ammonia limitations.

When evaluating reasonable potential, the allowable discharge concentrations (potential permit limits) were compared to Discharge Monitoring Report (DMR) data, Priority Pollutant Scan data, and data provided in the October 30, 2021 permit application. Specifically, the mean of the monthly average DMR data, the average of the Priority Pollutant Scan data reported as greater than the detection limit, and the average concentration reported on the permit application, were compared to the “monthly average” allowable discharge concentrations, calculated using the chronic water quality criteria. Similarly, the mean of the daily maximum DMR data, the maximum of the Priority Pollutant data, and the maximum reported in the permit application were compared to the “daily maximum” allowable discharge concentrations, calculated using the acute water quality criteria. When doing this, DEM used DMR data collected during the previous six and a half years (since the 2017 permit became effective). When the monitoring data exceeds fifty percent of the allowable discharge concentration, there is “reasonable potential”, and DEM assigns a water-quality-based permit limit. When the monitoring data is less than twenty-five percent of the allowable discharge concentration, there is not “reasonable potential”, and DEM does not assign a water-quality-based permit limit. While DEM does not typically assign a permit limit when data is between twenty-five and fifty percent of the allowable discharge concentration, a water-quality-based permit limit may be assigned if it is determined that one is needed to be protective of human health and/or aquatic life (e.g., there is a significant variability in effluent data).

Based on these comparisons, water quality limitations have only been found to be necessary for Total Residual Chlorine. Total Residual Chlorine Limitations are being maintained at an acute limit of 1040 ug/L and chronic limit of 885 ug/L. Cyanide limits found in the 2017 permit were removed due to a lack of reasonable potential. In addition, quarterly monitoring for Aluminum, Ammonia, Copper, Cadmium, Chromium, Lead, Nickel, Zinc, has been maintained. Quarterly monitoring for Cyanide has been discontinued, and quarterly monitoring for Free Cyanide has been added.

### ***Priority Pollutants***

The required priority pollutants scans are to be performed annually for the EPA Priority Pollutants as listed in 40 CFR 122, Appendix D, Tables II and III. The priority pollutant scans are typically performed during the third calendar quarter bioassay sampling event.

### **WET Testing**

The biomonitoring requirements are set forth in 40 CFR 131.11 and in the State's Water Quality Regulations (RICR 250-RICR-150-05-1), § 1.10(B)(1), containing narrative conditions that state, at a minimum, all waters shall be free of pollutants in concentrations or combinations or from anthropogenic activities subject to these regulations that: adversely affect the composition of fish and wildlife; adversely affect the physical, chemical, or biological integrity of the habitat; interfere with the propagation of fish and wildlife; adversely alter the life cycle functions, uses, processes, and activities of fish and wildlife; or adversely affect human health. In order to determine compliance with many of these conditions, WET testing is required. If toxicity is demonstrated, then toxicity identification and reduction will be required.

DEM's toxicity permitting policy is based on past toxicity data and the level of available dilution. South Kingstown's bioassay limit of  $\geq 100\%$  effluent for an  $LC_{50}$  value is based on is based upon 40 CFR 131.11(b)(2). The permit requires that acute toxicity tests be conducted once per quarter on Mysids. If recurrent toxicity is demonstrated, then toxicity identification and reduction will be required. Whole Effluent Toxicity (WET) testing requirements can be found in Section I.B. of the permit. Section I.B.11 contains a requirement for a Species Sensitivity Screening Report to be submitted XXXX. Section I.B.11 of the permit has been added to ensure the WET limits in the permit are evaluated using the most sensitive applicable marine species.

Past bioassay monitoring data for South Kingstown indicates that the Town had no occurrence of toxicity between October 2016 and June 2023. The data can be found in Appendix A-3.

### **Nutrients**

The effluent monitoring requirements have been specified in accordance with the RIPDES regulations as well as 40 CFR 122.41 (j), 122.44 (i), and 122.48 to yield data representative of the discharge. At this time, nutrient criteria have not been established for the receiving water. Seasonal (May through October) testing requirements for TKN, Nitrate, and Nitrite have been extended to year-round testing at a frequency of once per month.

### **Ammonia**

The potential ammonia limitations were derived from acute and chronic water quality criteria for saltwater from the Rhode Island Water Quality Regulations (250-RICR-150-05-1.26.L.2), which are based upon salinity, pH, and temperature. A salinity equal to 30 ppt., pH equal to 8.4 standard units for the winter season (November-April), pH equal to 8.0 units for the summer season (May-October), and average temperatures equal to 20°C and 5°C during Summer and Winter seasons, respectively, were used to calculate the allowable water quality-based discharge levels for ammonia. Salinity and temperature values were based upon data contained in the Narragansett Bay Project Reports, #NBP-89-22 and #NBP-89-24, titled "Water Quality Survey of Narragansett Bay-A Summary of the SINBADD 1985-1986" and "SPRAY Cruise-Dissolved Oxygen and Chlorophyll", respectively. The pH value was determined from data contained in a report titled "Monitoring of the Providence and Seekonk Rivers for Trace Metals and Associated Parameters-SPRAY Cruises I, II, III" [Deoring et al., 1988], and from a University of Rhode Island Graduate School of Oceanography research paper titled "Co-occurrence of Dinoflagellate Blooms and High pH in Marine Enclosures", [Hinga, 1992]. As mentioned previously, water quality-based limits were not found to be necessary, based on a lack of reasonable potential.

### **Emerging Contaminants**

Per- and polyfluoroalkyl substances (PFAS) are a group of synthetic chemicals that have been in use since the 1940s. They are found in a wide array of consumer and industrial products. PFAS manufacturing and processing facilities, facilities using PFAS in production of other products, airports, and military installations can be contributors of PFAS releases into the air, soil, and water. Due to their widespread use and persistence in the environment, most people in the United States have been exposed to PFAS. Exposure to some PFAS above certain levels may increase risk of adverse health effects<sup>1</sup>. DEM is collecting information to evaluate

---

<sup>1</sup> EPA, *EPA's Per- and Polyfluoroalkyl Substances (PFAS) Action Plan*, EPA 823R18004, February 2019.

the potential impacts that discharges of PFAS from wastewater treatment plants may have on downstream uses, which can include drinking water, recreational and aquatic life uses depending on the receiving water.

The Environmental Protection Agency (EPA) established a Drinking Water Health Advisory in 2016 for Perfluorooctanoic Acid (PFOA), Perfluorooctanesulfonic Acid (PFOS), or a combination of these chemicals at 70 parts per trillion (ppt) or 70 nanogram per liter (ng/l). This Drinking Water Health Advisory was established to protect against adverse health effects that studies have indicated can be caused by exposure to these chemicals. In 2017, the Rhode Island Department of Health (DOH) began the process of sampling public wells for these pollutants due to increasing public health concerns about their possible presence in drinking water. Also in 2017, DEM adopted the EPA health advisory as a groundwater quality standard.

In 2022, Rhode Island passed a law concerning PFAS in drinking water, groundwater and surface waters. The Rhode Island law establishes monitoring requirements for public water supplies as well as drinking water treatment requirements if the sum of the concentrations of the following six species of PFAS exceed 20 ppt.

- Perfluorohexanesulfonic acid (PFHxS)
- Perfluoroheptanoic acid (PFHpA)
- Perfluorononanoic acid (PFNA)
- Perfluorooctanesulfonic acid (PFOS)
- Perfluorooctanoic acid (PFOA)
- Perfluorodecanoic acid (PFDA)

The 2022 Rhode Island law is consistent with the Massachusetts Department of Environmental Protection (Mass DEP) public drinking water standard regarding allowable concentrations and PFAS species. In addition to drinking water requirements, the 2022 Rhode Island law also compels DEM to adopt a groundwater quality standard and a surface water action level by December 31, 2023.

Although the Rhode Island Water Quality Regulations (250-RICR-150-05-1) do not include numeric criteria for PFAS, the RI Water Quality Regulations § 1.10(E)(1)(saltwater) under Chemical Constituents have narrative requirements that prohibits the discharge of pollutants in concentration or combinations that could be harmful to humans or fish and wildlife for the most sensitive and governing water class use.

Since PFAS chemicals are persistent in the environment and may lead to adverse human health and environmental effects, the Permit requires that the facility conduct quarterly influent and effluent sampling for PFAS chemicals and annual sampling of certain industrial users using draft EPA Method 1633 until a 40 CFR Part 136 approved method is made available to the public.

The purpose of this monitoring and reporting requirement is to better understand potential discharges of PFAS from this facility and to inform future permitting decisions, including the potential development of water quality-based effluent limits on the facility-specific basis. DEM is authorized to require this monitoring and reporting by CWA § 308(a), which states:

“SEC. 308. (a) Whenever required to carry out the objective of this Act, including but not limited to (1) developing or assisting in the development of any effluent limitation, or other limitation, prohibition, or effluent standard, pretreatment standard, or standard of performance under this Act; (2) determining whether any person is in violation of any such effluent limitation, or other limitation, prohibition or effluent standard, pretreatment standard, or standard of performance; (3) any requirement established under this section; or (4) carrying out sections 305, 311, 402, 404 (relating to State permit programs), 405, and 504 of this Act –

- a. The Administrator shall require the owner or operator of any point source to (i) establish and maintain such records, (ii) make such reports, (iii) install, use, and maintain such monitoring equipment or methods (including where appropriate, biological monitoring methods), (iv) sample such effluents (in accordance with such methods, at such locations, at such intervals,

---

[http://www.epa.gov/sites/production/files/201902/documents/pfas\\_action\\_plan\\_021319\\_508compliant\\_1.pdf](http://www.epa.gov/sites/production/files/201902/documents/pfas_action_plan_021319_508compliant_1.pdf)

and in such manner as the Administrator shall prescribe), and (v) provide such other information as he may reasonably require...”

Since an EPA method for sampling and analyzing PFAS in wastewater is not currently available, the permit requires that PFAS be analyzed using draft EPA method 1633 until a 40 CFR Part 136 approved test method for wastewater is made available to the public. This approach is consistent with 40 CFR § 122.44(i)(1)(iv)(b) which states that in the case of pollutants or pollutant parameters for which there are no approved methods under 40 CFR Part 136 or methods are not otherwise required under 40 CFR chapter I, subchapter N or O, monitoring shall be conducted according to a test procedure specified in the permit for such pollutants or pollutant parameters.

The reporting requirement for the listed PFAS parameter takes effect the [REDACTED]. The PFAS Analytes that are required to be reported are listed in Attachment A of the permit. Sampling requirements include influent, effluent, and any relevant industrial users.

### ***Antibacksliding and Antidegradation***

Provided below is a brief introduction to Antibacksliding and Antidegradation, as well as a discussion on how the two policies were used to calculate water quality-based limits.

#### ***Antibacksliding***

Antibacksliding restricts the level of relaxation of water quality-based limits from the previous permit. Section 303(d)(4) of the Clean Water Act addresses antibacksliding as the following:

1. Standards not attained – For receiving waters that have not attained the applicable water quality standards, limits based on a TMDL or WLA can only be revised if the water quality standards will be met. This may be done by (i) determining that the cumulative effect of all such revised limits would assure the attainment of such water quality standards; or (ii) removing the designated use which is not being attained in accordance with regulations under Section 303.
2. Standards attained – For receiving waters achieving or exceeding applicable water quality standards, limits can be relaxed if the revision is consistent with the State's Antidegradation Policy.

Therefore, in order to determine whether backsliding is permissible, the first question that must be asked is whether or not the receiving water is attaining the water quality standard. The Office has determined the most appropriate evaluation of existing water quality is by calculating pollutant levels, which would result after the consideration of all currently valid RIPDES permit limits or historic discharge data (whichever is greater), background data (when available), and any new information (i.e., dilution factors).

#### ***Antidegradation***

The DEM's Water Quality Regulations (250-RICR-150-05-1.20) establishes four tiers of water quality protection:

**Tier 1.** In all surface waters, existing uses and the level of water quality necessary to protect the existing uses shall be maintained and protected.

**Tier 2.** In waters where the existing water quality criteria exceeds the levels necessary to support the propagation of fish and wildlife and recreation in and on the water, that quality shall be maintained and protected except for insignificant changes in water quality as determined by the Director and in accordance with the Antidegradation Implementation Policy, as amended. In addition, the Director may allow significant degradation, which is determined to be necessary to achieve important economic or social benefits to the State in accordance with the Antidegradation Policy.

**Tier 2½.** Where high quality waters constitute Special Resource Protection Waters SRPWs<sup>2</sup>, there shall be no measurable degradation of the existing water quality necessary to protect the characteristics which cause the waterbody to be designated a SRPW. Notwithstanding that all public drinking water supplies are SRPWs, public drinking water suppliers may undertake temporary and short-term activities within the boundary perimeter of a public drinking water supply impoundment for essential maintenance or to address emergency conditions in order to prevent adverse effect on public health or safety. These activities must comply with the requirements set forth in Tier 1 and Tier 2.

**Tier 3.** Where high quality waters constitute an Outstanding Natural Resource ONRWs<sup>3</sup>, that water quality shall be maintained and protected. The State may allow some limited activities that result in temporary or short-term changes in the water quality of an ONRW. Such activities must not permanently degrade water quality or result in water quality lower than necessary to protect the existing uses in the ONRW.

The formulas previously presented ensure that permit limitations are based upon water quality criteria and methodologies established to ensure that all designated uses will be met.

In terms of the applicability of Tier 2 of the Policy, a water body is assessed as being high quality on a parameter-by-parameter basis. In accordance with Part II of the Policy, "Antidegradation applies to all new or increased projects or activities which may lower water quality or affect existing water uses, including but not limited to all 401 Water Quality Certification reviews and any new, reissued, or modified RIPDES permits." Part VI.A of the Policy indicates that it is not applicable to activities which result in insignificant (i.e., short-term minor) changes in water quality and that significant changes in water quality will only be allowed if it is necessary to accommodate important economic and social development in the area in which the receiving waters are located (important benefits demonstration). Part VI.B.4 of the Policy states that: "Theoretically, any new or increased discharge or activity could lower existing water quality and thus require the important benefits demonstration. However, DEM will: 1) evaluate applications on a case-by-case basis, using BPJ and all pertinent and available facts, including scientific and technical data and calculations as provided by the applicant; and 2) determine whether the incremental loss is significant enough to require the important benefits demonstration described below. [If not then as a general rule DEM will allocate no more than 20%.] Some of the considerations which will be made to determine if an impact is significant in each site specific decision are: 1) percent change in water quality parameter value and their temporal distribution; 2) quality and value of the resource; 3) cumulative impact of discharges and activities on water quality to date; 4) measurability of the change; 5) visibility of the change; 6) impact on fish and wildlife habitat; and 7) impact on potential and existing uses. As a general guide, any discharge or activity which consumes greater than 20% of the remaining assimilative capacity may be deemed significant and invoke full requirements to demonstrate important economic or social benefits."

In terms of a RIPDES permit, an increased discharge is defined as an increase in any limitation, which would result in an increased mass loading to a receiving water. The baseline for this comparison would be the monthly average mass loading established in the previous permit. It would be inappropriate to use the daily maximum mass loading since the Policy is not applicable to short-term changes in water quality.

For the purposes of ensuring that the revised limit is consistent with the requirements of antidegradation, existing water quality must be defined. As explained earlier, DEM evaluates existing water quality by determining the pollutant levels which would result under the design conditions appropriate for the particular criteria (i.e., background water quality, when available and/or appropriate, non-point source inputs; and existing RIPDES permit limitations or recent historical discharge data, whichever is higher). In general, available data would be used to make this determination.

---

<sup>2</sup> SRPWs are surface waters identified by the Director as having significant recreational or ecological uses.

<sup>3</sup> ONRWs are a special subset of high-quality water bodies, identified by the State as having significant recreational or ecological water uses.

Use the above-mentioned criteria, the present instream water quality  $C_p$  is defined as:

$$C_p = \frac{(DF - 1) \cdot C_B + (1 \cdot C_d)}{DF}$$

where:  $C_b$  = background concentration<sup>4</sup>  
 $C_d$  = discharge data<sup>5</sup>  
DF = dilution factor

In this permit, all monthly average limitations are either the same as or more stringent than the limits in the 2017 permit. Therefore, the limits contained in this permit are consistent with the Department's anti-degradation policy.

### **Operations and Maintenance**

#### **Resiliency Planning Requirements**

The permit (Part I.D.3) requires that, within one year of the effective date of this permit, the Town shall submit a Resiliency Plan and schedule of short- and long-term actions that will be taken to maintain, operate, and protect key collection and treatment system assets. The plan shall be consistent with the most current version of DEM's *Guidance for the Consideration of Climate Change Impacts in the Planning and Design of Municipal Wastewater Collection and Treatment Infrastructure* and include consideration of the findings of the 2017 DEM report *Implications of Climate Change for Rhode Island Wastewater Collection and Treatment Infrastructure*. The Resiliency Plan shall include, but not be limited to: (i) an assessment of current and projected impacts from natural hazards on critical components within the Town's collection and treatment systems, as well as on the system themselves; (ii) a plan to adapt and protect vulnerable components and systems; (iii) an analysis that provides justification for selected adaptation methods, including relevant cost-benefit analyses. The overall analysis must consider component and system design life and sea-level rise projections. For the purpose of this Resiliency Plan, critical components are considered those necessary to ensure the forward flow and treatment of wastewater in accordance with the limits set forth in this permit. The Resiliency Plan shall also consider impacts – such as debris carried in high winds – on the Town's treatment facility and wastewater collection system from neighboring facilities during high hazard events.

#### **Sludge Requirements**

The permit contains requirements for the permittee to comply with the State's Sludge Regulations and the most current DEM Order of Approval for sludge disposal in accordance with the requirements of Section 405(d) of the Clean Water Act (CWA). Permits must contain sludge conditions requiring compliance with limits, state laws, and applicable regulations as per Section 405(d) of the CWA and 40 CFR 503. The DEM Sludge Order of Approval sets forth the conditions to ensure this compliance.

#### **Other Conditions**

The permit also requires that infiltration/inflow reports be submitted every two (2) years that summarize all actions taken to minimize infiltration/inflow.

The remaining general and specific conditions of the permit are based on the RIPDES regulations as well as 40 CFR Parts 122 through 125 and consist primarily of management requirements common to all permits.

#### **Permit Limit Summary**

Presented in Table 1 is a summary of the permit limitations and the corresponding sampling frequency.

---

<sup>4</sup> Data collected at a location that is unimpacted by significant point source discharges.

<sup>5</sup> Discharge data refers to the maximum of the permit limit or the historic discharge level. The historic discharge level is determined by calculating the upper 95<sup>th</sup> confidence interval for the monthly average reported data for the past five (5) years. For specific cases, changes in treatment efficiency or pretreatment limitations may support the use of an alternative period of time.

**Table 1 Permit Limits – Outfall 001A (final discharge after dechlorination)**

<b>Effluent Characteristic</b>	<b>Monthly Average Permit Limit</b>	<b>Weekly Average Permit Limit</b>	<b>Daily Max Permit Limit</b>	<b>Sampling Frequency</b>
<b>Flow</b>	5.0 MGD		--- MGD	Continuous
<b>BOD<sub>5</sub> Load<sup>1</sup></b>	1,251 lbs/day		2,085 lbs/day	3/Week
<b>BOD<sub>5</sub> Concentration<sup>1</sup></b>	30 mg/L	45 mg/L	50 mg/L	3/Week
<b>BOD<sub>5</sub> - % Removal<sup>1</sup></b>	≥85%			1/Month
<b>TSS Load<sup>1</sup></b>	1,251 lbs/day		2,085 lbs/day	3/Week
<b>TSS Concentration<sup>1</sup></b>	30 mg/L	45 mg/L	50 mg/L	3/Week
<b>TSS - % Removal<sup>1</sup></b>	≥85%			1/Month
<b>Settleable Solids</b>		--- ml/L	--- ml/L	Daily
<b>Fecal Coliform</b>	--- MPN/100 ml		--- MPN/100 ml	3/Week
<b>Enterococci</b>	35 cfu/100 ml		276 cfu/100 ml	3/Week
<b>Total Residual Chlorine (TRC)</b>	885 µg/L		1,040 µg/L	3/Day
<b>pH</b>	(6.0 SU)		(9.0 SU)	2/Day
<b>Oil and Grease</b>			--- mg/L	1/Quarter
<b>TKN (as N)</b>	--- mg/L		--- mg/L	1/Month
<b>Nitrate, Total (as N)]</b>	--- mg/L		--- mg/L	1/Month
<b>Nitrite, Total (as N)</b>	--- mg/L		--- mg/L	1/Month
<b>Nitrogen, Total</b>	--- mg/L		--- mg/L	1/Month
<b>Nitrogen, Total</b>	--- lb/day			1/Month
<b>Total Copper<sup>2</sup></b>	--- µg/L		--- µg/L	1/Quarter
<b>Free Cyanide<sup>2</sup></b>	--- µg/L		--- µg/L	1/Quarter
<b>Total Cadmium<sup>2</sup></b>	--- µg/L		--- µg/L	1/Quarter
<b>Phenols, Total<sup>2</sup></b>	--- µg/L		--- µg/L	1/Quarter
<b>Total Cadmium<sup>2</sup></b>	--- µg/L		--- µg/L	1/Quarter
<b>Total Lead<sup>2</sup></b>	--- µg/L		--- µg/L	1/Quarter
<b>Hexavalent Chromium<sup>2</sup></b>	--- µg/L		--- µg/L	1/Quarter
<b>Total Zinc<sup>2</sup></b>	--- µg/L		--- µg/L	1/Quarter
<b>Total Nickel<sup>2</sup></b>	--- µg/L		--- µg/L	1/Quarter
<b>Total Aluminum<sup>2</sup></b>	--- µg/L		--- µg/L	1/Quarter
<b>Ammonia, Total (as N) <sup>2</sup></b>	-- mg/L		-- mg/L	1/Quarter
<b>Organic Carbon, Total<sup>2</sup></b>	-- mg/L		-- mg/L	1/Quarter
<b>Mysidopsis bahia LC<sub>50</sub><sup>3</sup></b>			≥100%	1/Quarter
<b>PFAS Analytes<sup>1,4</sup></b>			--- ng/L	1/Quarter

( ) Values in parentheses represent the minimum and maximum values.

--- Signifies a parameter which must be monitored, and data must be reported; no limit has been established at this time.

<sup>1</sup>Samples shall be taken on the influent and effluent with appropriate allowances for hydraulic detention (flow-through) time.



<sup>2</sup>Monitoring data may be obtained in conjunction with the bioassay testing required in Part I.B of the permit.

<sup>3</sup>LC<sub>50</sub> is defined as the concentration of wastewater that causes mortality to 50% of the test organisms. Therefore, a 100% limit means that a samples of 100% effluent (no dilution) shall cause no more than a 50% mortality rate.

<sup>4</sup>Influent and effluent sampling requirements for the listed PFAS parameters takes effect \_\_\_\_\_ PFAS shall be analyzed using Clean Water Act wastewater draft analytical method 1633 until a 40 CFR Part 136 approved test method for wastewater is approved. Additionally, report in NetDMR the results of all other PFAS analytes required to be tested as part of the method as shown in Attachment A of the permit.

#### V. COMMENT PERIOD, HEARING REQUESTS, AND PROCEDURES FOR FINAL DECISIONS

All persons, including applicants, who believe any condition of the draft permit is inappropriate must raise all issues and submit all available arguments and all supporting material for their arguments in full by the close of the public comment period, to the Rhode Island Department of Environmental Management, Office of Water Resources, 235 Promenade Street, Providence, Rhode Island, 02908-5767. A public hearing will be held after a thirty (30) day public notice. In reaching a final decision on the draft permit the Director will respond to all significant comments and make these responses available to the public at DEM's Providence Office.

Following the close of the comment period, and after the public hearing, the Director will issue a final permit decision and forward a copy of the final decision to the applicant and each person who has submitted written comments or requested notice. Within thirty (30) days following the notice of the final permit decision any interested person may submit a request for a formal hearing to reconsider or contest the final decision. Requests for formal hearings must satisfy the requirements of Rule 49 of the Regulations for the Rhode Island Pollutant Discharge Elimination System.

#### VI. DEM CONTACT

Additional information concerning the permit may be obtained between the hours of 8:30 a.m. and 4:00 p.m., Monday through Friday, excluding holidays from:

Samuel Kaplan, P.E.  
Environmental Engineer II  
Department of Environmental Management  
Office of Water Resources  
235 Promenade Street  
Providence, Rhode Island 02908  
Telephone: (401) 222-4700 ext. 2777604  
Email: [samuel.kaplan@dem.ri.gov](mailto:samuel.kaplan@dem.ri.gov)

06 Feb 2024  
Date

Heidi Travers  
Heidi Travers, P.E.  
Environmental Engineer IV  
RIPDES Program  
Office of Water Resources  
Department of Environmental Management  
Providence, Rhode Island

ATTACHMENT A-1

South Kingstown Wastewater Treatment Plant  
Topographic Map



Town of South Kingstown

# SK Regional Wastewater Treatment Facility

**One Mile Radius**

0 500 1,000 2,000 3,000 Feet

Geographic Information System

1:24,000  
Attachment A-1: Topo Map

USGS 7.5 Minute Topographic Quadrangles, Kingston and Narragansett Pier

PS16-18 cpb 3/16

ATTACHMENT A-2

South Kingstown Wastewater Treatment Plant  
Process Flow Diagram




Menu of Screens

Log In

Ack	Date Last	Time Last	Description	Value	Status
✓	3/29/2016	05:47:31.264	Plant Alarm Disarm Status	DISARMED	CFN
✓	3/29/2016	05:46:48.472	Security Alarm Disarm Status	DISARMED	CFN

8:22:47 AM  
3/29/2016

Attachment A-2: Process Diagram



ATTACHMENT A-3 Historical Effluent Data

**DESCRIPTION OF DISCHARGE:** Secondary treated domestic and industrial wastewater.

**DISCHARGE:** 001A - Secondary Treatment Discharge

**EFFLUENT CHARACTERISTICS AT POINT OF DISCHARGE:**

Parameter	Monthly Average <sup>1</sup>	Weekly Average <sup>2</sup>	Daily Maximum <sup>3</sup>
Flow, MGD	2.645		3.944 <sup>4</sup>
BOD <sub>5</sub> , mg/L	12.40	16.92	26.29
BOD <sub>5</sub> , lbs/day	265.83		601.18
BOD <sub>5</sub> , % removal	93.85		
TSS, mg/L	7.352	11.22	16.83
TSS, lbs/day	165.49		414.09
TSS, % removal	96.72		
Fecal Coliform, MPN/100 ml	3.042 <sup>5</sup>		26.61
Enterococci, CFU/100 ml	2.238 <sup>6</sup>		13.55
pH, S.U.	6.48 (Minimum)		7.06 (Maximum)
Total Residual Chlorine, µg/L	57.79		253.43
Oil & Grease, mg/L			2.44
Nitrogen, Nitrite (Total as N), mg/L			1.13
Nitrogen, Nitrate (Total as N), mg/L			4.47
Nitrogen, Total Kjeldhal (Total as N), mg/L			14.65 mg/L
Nitrogen (Total), mg/L			20.25
Settleable Solids, ml/L		0.172	1.06
Aluminum, Total, µg/L	34.02		34.02
Cadmium, Total, µg/L	0.0037		0.0037
Chromium, Total, µg/L	0.0741		0.0741
Copper, Total, µg/L	14.76		14.87
Cyanide, Free Available µg/L <sup>7</sup>	2.692		2.692
Cyanide, Total, µg/L <sup>8</sup>	0		0
Lead, Total, µg/L	0.0704		0.0704
Nickel, Total, µg/L	1.319		1.319
Zinc, Total, µg/L	68.33		68.38

<sup>1</sup>Data represents the mean of the monthly average data from 12/01/2016 – 08/31/2023

<sup>2</sup>Data represents the mean of the weekly average data from 12/01/2016 – 08/31/2023

<sup>3</sup>Data represents the mean of the daily maximum data 12/01/2016 – 08/31/2023

<sup>4</sup>Maximum monthly value of maximum flow from 12/01/2016 – 08/31/2023

<sup>5</sup>Mean of the monthly geometric means from 12/01/2016 – 08/31/2023

<sup>6</sup>Due to reporting change, Enterococci mean of the monthly geometric mean calculated from 09/30/2017 – 08/31/2023

<sup>7</sup>Free available Cyanide was sampled from 3/31/2020 to present

<sup>8</sup>Total Cyanide was sampled from 12/31/2016 through 12/31/2019

Biotoxicity Data LC<sub>50</sub> Values (in percent effluent) Mysid


Year	Quarter 1	Quarter 2	Quarter 3	Quarter 4
2016				100
2017	>100	>100	>100	>100
2018	>100	>100	>100	>100
2019	>100	100	>100	>100
2020	>100	>100	>100	>100
2021	>100	>100	>100	>100
2022	>100	>100	>100	>100
2023	>100	>100		

ATTACHMENT A-4

South Kingstown Wastewater Treatment Plant  
Aerial Photograph with Superimposed Acute and Chronic Mixing Zones



## South Kingstown WWTF Mixing Zones and Dilution



ATTACHMENT A-5

Calculation of Allowable Acute and Chronic Discharge Limitations  
Based on Saltwater Aquatic Life Criteria and Human Health Criteria

## CALCULATION OF WATER QUALITY BASED SALTWATER DISCHARGE LIMITS FACILITY SPECIFIC DATA INPUT SHEET

NOTE: LIMITS BASED ON RI WATER QUALITY CRITERIA DATED JULY 2006

FACILITY NAME: **South Kingstown WWTF 2023**

RIPDES PERMIT #: **RI0100374**

	DISSOLVED BACKGROUND DATA (ug/L)	ACUTE METAL TRANSLATOR	CHRONIC METAL TRANSLATOR
ALUMINUM	NA	NA	NA
ARSENIC	NA	1	1
CADMIUM	NA	0.994	0.994
CHROMIUM III	NA	NA	NA
CHROMIUM VI	NA	0.993	0.993
COPPER	NA	0.83	0.83
LEAD	NA	0.951	0.951
MERCURY	NA	0.85	NA
NICKEL	NA	0.99	0.99
SELENIUM	NA	0.998	0.998
SILVER	NA	0.85	0.85
ZINC	NA	0.946	0.946

**USE NA WHEN NO DATA IS AVAILABLE**

NOTE 1: BACKGROUND DATA BASED ON AVERAGE CONCENTRATIONS IN ATTACHMENT B.

NOTE 2: METAL TRANSLATORS FROM RI WATER QUALITY REGS.

DILUTION FACTORS	
ACUTE =	<b>80</b> x
CHRONIC =	<b>118</b> x
HUMAN HEALTH =	<b>118</b> x

NOTE: TEST WWTF'S DILUTION FACTORS OBTAINED FROM A DYE STUDY.

TOTAL AMMONIA CRITERIA (ug/L)	
WINTER ACUTE =	<b>8700</b>
CHRONIC =	<b>1300</b>
SUMMER ACUTE =	<b>7300</b>
CHRONIC =	<b>1100</b>

NOTE 1: LIMITS ARE FROM TABLE 3 IN THE RI WATER QUALITY REGS. USING:

SALINITY = 30 g/Kg  
 WINTER (NOV-APRIL) pH=8.4 s.u.;  
 SUMMER (MAY-OCT) pH=8.0 s.u.  
 WINTER (NOV-APRIL) TEMP=5.0 C;  
 SUMMER (MAY-OCT) TEMP=20.0 C.

**CALCULATION OF WATER QUALITY BASED SALTWATER DISCHARGE LIMITS**

FACILITY NAME: South Kingstown WWTF 2023    RIPDES PERMIT #: RI0100374

NOTE: METALS CRITERIA ARE DISSOLVED, METALS LIMITS ARE TOTAL; AMMONIA CRITERIA AND LIMITS HAVE BEEN CONVERTED TO ug/l N.

CHEMICAL NAME	CAS #	BACKGROUND CONCENTRATION (ug/L)	SALTWATER CRITERIA ACUTE (ug/L)	DAILY MAX LIMIT (ug/L)	SALTWATER CRITERIA CHRONIC (ug/L)	HUMAN HEALTH NON-CLASS A CRITERIA (ug/L)	MONTHLY AVE LIMIT (ug/L)
<b>PRIORITY POLLUTANTS:</b>							
<b>TOXIC METALS AND CYANIDE</b>							
ANTIMONY	7440360			No Criteria		640	60416
ARSENIC (limits are total recoverable)	7440382	NA	69	4416	36	1.4	132.16
ASBESTOS	1332214			No Criteria			No Criteria
BERYLLIUM	7440417			No Criteria			No Criteria
CADMIUM (limits are total recoverable)	7440439	NA	40	2575.452716	8.8		835.7344064
CHROMIUM III (limits are total recoverable)	16065831	NA		No Criteria			No Criteria
CHROMIUM VI (limits are total recoverable)	18540299	NA	1100	70896.27392	50		4753.27291
COPPER (limits are total recoverable)	7440508	NA	4.8	370.1204819	3.1		352.5783133
CYANIDE	57125		1	64.00	1	140	94.4
LEAD (limits are total recoverable)	7439921	NA	210	14132.49211	8.1		804.0378549
MERCURY (limits are total recoverable)	7439976	NA	1.8	135.5294118	0.94	0.15	14.16
NICKEL (limits are total recoverable)	7440020	NA	74	4783.838384	8.2	4600	781.8989899
SELENIUM (limits are total recoverable)	7782492	NA	290	18597.19439	71	4200	6715.831663
SILVER (limits are total recoverable)	7440224	NA	1.9	143.0588235			No Criteria
THALLIUM	7440280			No Criteria		0.47	44.368
ZINC (limits are total recoverable)	7440666	NA	90	6088.794926	81	26000	8082.875264
<b>VOLATILE ORGANIC COMPOUNDS</b>							
ACROLEIN	107028			No Criteria		290	27376
ACRYLONITRILE	107131			No Criteria		2.5	236
BENZENE	71432			No Criteria		510	48144
BROMOFORM	75252			No Criteria		1400	132160
CARBON TETRACHLORIDE	56235			No Criteria		16	1510.4
CHLOROBENZENE	108907			No Criteria		1600	151040
CHLORODIBROMOMETHANE	124481			No Criteria		130	12272
CHLOROFORM	67663			No Criteria		4700	443680
DICHLOROBROMOMETHANE	75274			No Criteria		170	16048
1,2DICHLOROETHANE	107062			No Criteria		370	34928
1,1DICHLOROETHYLENE	75354			No Criteria		7100	670240
1,2DICHLOROPROPANE	78875			No Criteria		150	14160
1,3DICHLOROPROPYLENE	542756			No Criteria		21	1982.4
ETHYLBENZENE	100414			No Criteria		2100	198240
BROMOMETHANE (methyl bromide)	74839			No Criteria		1500	141600
CHLOROMETHANE (methyl chloride)	74873			No Criteria			No Criteria
METHYLENE CHLORIDE	75092			No Criteria		5900	556960

1,1,2,2TETRACHLOROETHANE	79345			No Criteria		40	3776
TETRACHLOROETHYLENE	127184			No Criteria		33	3115.2
TOLUENE	108883			No Criteria		15000	1416000
1,2TRANSDICHLOROETHYLENE	156605			No Criteria		10000	944000
1,1,1TRICHLOROETHANE	71556			No Criteria			No Criteria
1,1,2TRICHLOROETHANE	79005			No Criteria		160	15104
TRICHLOROETHYLENE	79016			No Criteria		300	28320
VINYL CHLORIDE	75014			No Criteria		2.4	226.56
ACID ORGANIC COMPOUNDS							
2CHLOROPHENOL	95578			No Criteria		150	14160
2,4DICHLOROPHENOL	120832			No Criteria		290	27376
2,4DIMETHYLPHENOL	105679			No Criteria		850	80240
4,6DINITRO2METHYL PHENOL	534521			No Criteria		280	26432
2,4DINITROPHENOL	51285			No Criteria		5300	500320
4NITROPHENOL	88755			No Criteria			No Criteria
PENTACHLOROPHENOL	87865	13		832	7.9	30	745.76
PHENOL	108952			No Criteria		1700000	160480000
2,4,6TRICHLOROPHENOL	88062			No Criteria		24	2265.6
BASE NEUTRAL COMPUNDS							
ACENAPHTHENE	83329			No Criteria		990	93456
ANTHRACENE	120127			No Criteria		40000	3776000
BENZIDINE	92875			No Criteria		0.002	0.1888
POLYCYCLIC AROMATIC HYDROCARBONS				No Criteria		0.18	16.992
BIS(2CHLOROETHYL)ETHER	111444			No Criteria		5.3	500.32
BIS(2CHLOROISOPROPYL)ETHER	108601			No Criteria		65000	6136000
BIS(2ETHYLHEXYL)PHTHALATE	117817			No Criteria		22	2076.8
BUTYL BENZYL PHTHALATE	85687			No Criteria		1900	179360
2CHLORONAPHTHALENE	91587			No Criteria		1600	151040
1,2DICHLOROBENZENE	95501			No Criteria		1300	122720
1,3DICHLOROBENZENE	541731			No Criteria		960	90624
1,4DICHLOROBENZENE	106467			No Criteria		190	17936
3,3DICHLOROBENZIDENE	91941			No Criteria		0.28	26.432
DIETHYL PHTHALATE	84662			No Criteria		44000	4153600
DIMETHYL PHTHALATE	131113			No Criteria		1100000	103840000
DInBUTYL PHTHALATE	84742			No Criteria		4500	424800
2,4DINITROTOLUENE	121142			No Criteria		34	3209.6
1,2DIPHENYLHYDRAZINE	122667			No Criteria		2	188.8
FLUORANTHENE	206440			No Criteria		140	13216
FLUORENE	86737			No Criteria		5300	500320
HEXACHLOROBENZENE	118741			No Criteria		0.0029	0.27376
HEXACHLOROBUTADIENE	87683			No Criteria		180	16992
HEXACHLOROCYCLOPENTADIENE	77474			No Criteria		1100	103840
HEXACHLOROETHANE	67721			No Criteria		33	3115.2
ISOPHORONE	78591			No Criteria		9600	906240

NAPHTHALENE	91203			No Criteria			No Criteria
NITROBENZENE	98953			No Criteria		690	65136
NNITROSODIMETHYLAMINE	62759			No Criteria		30	2832
NNITROSODINPROPYLAMINE	621647			No Criteria		5.1	481.44
NNITROSODIPHENYLAMINE	86306			No Criteria		60	5664
PYRENE	129000			No Criteria		4000	377600
1,2,4trichlorobenzene	120821			No Criteria		70	6608
PESTICIDES/PCBs							
ALDRIN	309002		1.3	83.2		0.0005	0.0472
Alpha BHC	319846			No Criteria		0.049	4.6256
Beta BHC	319857			No Criteria		0.17	16.048
Gamma BHC (Lindane)	58899		0.16	10.24		1.8	169.92
CHLORDANE	57749		0.09	5.76	0.004	0.0081	0.3776
4,4DDT	50293		0.13	8.32	0.001	0.0022	0.0944
4,4DDE	72559			No Criteria		0.0022	0.20768
4,4DDD	72548			No Criteria		0.0031	0.29264
DIELDRIN	60571		0.71	45.44	0.0019	0.00054	0.050976
ENDOSULFAN (alpha)	959988		0.034	2.176	0.0087	89	0.82128
ENDOSULFAN (beta)	33213659		0.034	2.176	0.0087	89	0.82128
ENDOSULFAN (sulfate)	1031078			No Criteria		89	8401.6
ENDRIN	72208		0.037	2.368	0.0023	0.06	0.21712
ENDRIN ALDEHYDE	7421934			No Criteria		0.3	28.32
HEPTACHLOR	76448		0.053	3.392	0.0036	0.00079	0.074576
HEPTACHLOR EPOXIDE	1024573		0.053	3.392	0.0036	0.00039	0.036816
POLYCHLORINATED BIPHENYLS3	1336363			No Criteria	0.03	0.00064	0.060416
2,3,7,8TCDD (Dioxin)	1746016			No Criteria		0.000000051	4.8144E-06
TOXAPHENE	8001352		0.21	13.44	0.0002	0.0028	0.01888
TRIBUTYLTIN			0.42	26.88	0.0074		0.69856
NON PRIORITY POLLUTANTS:							
OTHER SUBSTANCES							
ALUMINUM (limits are total recoverable)	7429905	NA		No Criteria			No Criteria
AMMONIA as N (winter/summer)	7664417		8700   7300	457690 384038	1300   1100		100876   85356.5
4BROMOPHENYL PHENYL ETHER				No Criteria			No Criteria
CHLORIDE	16887006			No Criteria			No Criteria
CHLORINE	7782505		13	1040	7.5		885
4CHLORO2METHYLPHENOL				No Criteria			No Criteria
1CHLORONAPHTHALENE				No Criteria			No Criteria
4CHLOROPHENOL	106489			No Criteria			No Criteria
2,4DICHLORO6METHYLPHENOL				No Criteria			No Criteria
1,1DICHLOROPROPANE				No Criteria			No Criteria
1,3DICHLOROPROPANE	142289			No Criteria			No Criteria
2,3DINITROTOLUENE				No Criteria			No Criteria
2,4DINITRO6METHYL PHENOL				No Criteria			No Criteria
IRON	7439896			No Criteria			No Criteria

pentachlorobenzene	608935		No Criteria	No Criteria
PENTACHLOROETHANE			No Criteria	No Criteria
1,2,3,5tetrachlorobenzene			No Criteria	No Criteria
1,1,1,2TETRACHLOROETHANE	630206		No Criteria	No Criteria
2,3,4,6TETRACHLOROPHENOL	58902		No Criteria	No Criteria
2,3,5,6TETRACHLOROPHENOL			No Criteria	No Criteria
2,4,5TRICHLOROPHENOL	95954		No Criteria	No Criteria
2,4,6TRINITROPHENOL	88062		No Criteria	No Criteria
XYLENE	1330207		No Criteria	No Criteria

## CALCULATION OF WATER QUALITY BASED SALTWATER DISCHARGE LIMITS

FACILITY NAME: South Kingstown WWTF 2023RIPDES PERMIT #: RI0100374

CHEMICAL NAME	CAS#	DAILY MAX LIMIT (ug/L)	MONTHLY AVE LIMIT (ug/L)
<b>PRIORITY POLLUTANTS:</b>			
<b>TOXIC METALS AND CYANIDE</b>			
ANTIMONY	7440360	No Criteria	60416.00
ARSENIC, TOTAL	7440382	4416.00	132.16
ASBESTOS	1332214	No Criteria	No Criteria
BERYLLIUM	7440417	No Criteria	No Criteria
CADMIUM, TOTAL	7440439	2575.45	835.73
CHROMIUM III, TOTAL	16065831	No Criteria	No Criteria
CHROMIUM VI, TOTAL	18540299	70896.27	4753.27
COPPER, TOTAL	7440508	370.12	352.58
CYANIDE	57125	64.00	64.00
LEAD, TOTAL	7439921	14132.49	804.04
MERCURY, TOTAL	7439976	135.53	14.16
NICKEL, TOTAL	7440020	4783.84	781.90
SELENIUM, TOTAL	7782492	18597.19	6715.83
SILVER, TOTAL	7440224	143.06	No Criteria
THALLIUM	7440280	No Criteria	44.37
ZINC, TOTAL	7440666	6088.79	6088.79
<b>VOLATILE ORGANIC COMPOUNDS</b>			
ACROLEIN	107028	No Criteria	27376.00
ACRYLONITRILE	107131	No Criteria	236.00
BENZENE	71432	No Criteria	48144.00
BROMOFORM	75252	No Criteria	132160.00
CARBON TETRACHLORIDE	56235	No Criteria	1510.40
CHLOROBENZENE	108907	No Criteria	151040.00
CHLORODIBROMOMETHANE	124481	No Criteria	12272.00
CHLOROFORM	67663	No Criteria	443680.00
DICHLOROBROMOMETHANE	75274	No Criteria	16048.00
1,2DICHLOROETHANE	107062	No Criteria	34928.00
1,1DICHLOROETHYLENE	75354	No Criteria	670240.00
1,2DICHLOROPROPANE	78875	No Criteria	14160.00
1,3DICHLOROPROPYLENE	542756	No Criteria	1982.40
ETHYLBENZENE	100414	No Criteria	198240.00
BROMOMETHANE (methyl bromide)	74839	No Criteria	141600.00
CHLOROMETHANE (methyl chloride)	74873	No Criteria	No Criteria
METHYLENE CHLORIDE	75092	No Criteria	556960.00
1,1,2,2TETRACHLOROETHANE	79345	No Criteria	3776.00

CHEMICAL NAME	CAS#	DAILY MAX LIMIT (ug/L)	MONTHLY AVE LIMIT (ug/L)
TETRACHLOROETHYLENE	127184	No Criteria	3115.20
TOLUENE	108883	No Criteria	1416000.00
1,2TRANS-DICHLOROETHYLENE	156605	No Criteria	944000.00
1,1,1TRICHLOROETHANE	71556	No Criteria	No Criteria
1,1,2TRICHLOROETHANE	79005	No Criteria	15104.00
TRICHLOROETHYLENE	79016	No Criteria	28320.00
VINYL CHLORIDE	75014	No Criteria	226.56
<b>ACID ORGANIC COMPOUNDS</b>			
2CHLOROPHENOL	95578	No Criteria	14160.00
2,4DICHLOROPHENOL	120832	No Criteria	27376.00
2,4DIMETHYLPHENOL	105679	No Criteria	80240.00
4,6DINITRO-2METHYL PHENOL	534521	No Criteria	26432.00
2,4DINITROPHENOL	51285	No Criteria	500320.00
4NITROPHENOL	88755	No Criteria	No Criteria
PENTACHLOROPHENOL	87865	832.00	745.76
PHENOL	108952	No Criteria	160480000.00
2,4,6TRICHLOROPHENOL	88062	No Criteria	2265.60
<b>BASE NEUTRAL COMPOUNDS</b>			
ACENAPHTHENE	83329	No Criteria	93456.00
ANTHRACENE	120127	No Criteria	3776000.00
BENZIDINE	92875	No Criteria	0.19
PAHs		No Criteria	16.99
BIS(2CHLOROETHYL)ETHER	111444	No Criteria	500.32
BIS(2CHLOROISOPROPYL)ETHER	108601	No Criteria	6136000.00
BIS(2ETHYLHEXYL)PHTHALATE	117817	No Criteria	2076.80
BUTYL BENZYL PHTHALATE	85687	No Criteria	179360.00
2CHLORONAPHTHALENE	91587	No Criteria	151040.00
1,2DICHLOROBENZENE	95501	No Criteria	122720.00
1,3DICHLOROBENZENE	541731	No Criteria	90624.00
1,4DICHLOROBENZENE	106467	No Criteria	17936.00
3,3DICHLOROBENZIDENE	91941	No Criteria	26.43
DIETHYL PHTHALATE	84662	No Criteria	4153600.00
DIMETHYL PHTHALATE	131113	No Criteria	103840000.00
DI-n-BUTYL PHTHALATE	84742	No Criteria	424800.00
2,4DINITROTOLUENE	121142	No Criteria	3209.60
1,2DIPHENYLHYDRAZINE	122667	No Criteria	188.80
FLUORANTHENE	206440	No Criteria	13216.00



FLUORENE	86737	No Criteria	500320.00
HEXACHLORO BENZENE	118741	No Criteria	0.27
HEXACHLORO BUTADIENE	87683	No Criteria	16992.00
HEXACHLORO CYCLOPENTADIENE	77474	No Criteria	103840.00
HEXACHLORO ETHANE	67721	No Criteria	3115.20
ISOPHORONE	78591	No Criteria	906240.00
NAPHTHALENE	91203	No Criteria	No Criteria
NITROBENZENE	98953	No Criteria	65136.00
N-NITROSODIMETHYLAMINE	62759	No Criteria	2832.00
N-NITROSODI-N-PROPYLAMINE	621647	No Criteria	481.44
N-NITROSODIPHENYLAMINE	86306	No Criteria	5664.00
PYRENE	129000	No Criteria	377600.00
1,2,4trichlorobenzene	120821	No Criteria	6608.00
<b>PESTICIDES/PCBs</b>			
ALDRIN	309002	83.20	0.05
Alpha BHC	319846	No Criteria	4.63
Beta BHC	319857	No Criteria	16.05
Gamma BHC (Lindane)	58899	10.24	10.24
CHLORDANE	57749	5.76	0.38
4,4DDT	50293	8.32	0.09
4,4DDE	72559	No Criteria	0.21
4,4DDD	72548	No Criteria	0.29
DIELDRIN	60571	45.44	0.05
ENDOSULFAN (alpha)	959988	2.18	0.82
ENDOSULFAN (beta)	33213659	2.18	0.82
ENDOSULFAN (sulfate)	1031078	No Criteria	8401.60
ENDRIN	72208	2.37	0.22
ENDRIN ALDEHYDE	7421934	No Criteria	28.32
HEPTACHLOR	76448	3.39	0.07
HEPTACHLOR EPOXIDE	1024573	3.39	0.04
POLYCHLORINATED BIPHENYLS3	1336363	No Criteria	0.06
2,3,7,8TCDD (Dioxin)	1746016	No Criteria	0.00
TOXAPHENE	8001352	13.44	0.02
TRIBUTYLTIN		26.88	0.70

NON PRIORITY POLLUTANTS:			
OTHER SUBSTANCES			
ALUMINUM, TOTAL	7429905	No Criteria	No Criteria
AMMONIA (as N), WINTER (NOV-APR)	7664417	457689.60	100875.84
AMMONIA (as N), SUMMER (MAY-OC)	7664417	384038.40	85356.48
4BROMOPHENYL PHENYL ETHER		No Criteria	No Criteria
CHLORIDE	16887006	No Criteria	No Criteria
CHLORINE	7782505	1040.00	885.00
4CHLORO2METHYLPHENOL		No Criteria	No Criteria
1CHLORONAPHTHALENE		No Criteria	No Criteria
4CHLOROPHENOL	106489	No Criteria	No Criteria
2,4DICHLORO6METHYLPHENOL		No Criteria	No Criteria
1,1DICHLOROPROPANE		No Criteria	No Criteria
1,3DICHLOROPROPANE	142289	No Criteria	No Criteria
2,3DINITROTOLUENE		No Criteria	No Criteria
2,4DINITRO6METHYL PHENOL		No Criteria	No Criteria
IRON	7439896	No Criteria	No Criteria
pentachlorobenzene	608935	No Criteria	No Criteria
PENTACHLOROETHANE		No Criteria	No Criteria
1,2,3,5tetrachlorobenzene		No Criteria	No Criteria
1,1,1,2TETRACHLOROETHANE	630206	No Criteria	No Criteria
2,3,4,6TETRACHLOROPHENOL	58902	No Criteria	No Criteria
2,3,5,6TETRACHLOROPHENOL		No Criteria	No Criteria
2,4,5TRICHLOROPHENOL	95954	No Criteria	No Criteria
2,4,6TRINITROPHENOL	88891	No Criteria	No Criteria
XYLENE	1330207	No Criteria	No Criteria

ATTACHMENT A-6

Summary of Discharge Monitoring Report Data  
December 2016 through August 2023

**SOUTH KINGSTOWN WWTF****DMR Data Summary 1/8/24 (Used Data from 12/01/2016 to 09/01/2023)****\*\*\* NOT ICIS CERTIFIED\*\*\***001A

BOD, 5-day, 20 deg. C Location= 1

	MO AVG lb/d	DAILY MX lb/d	
Mean	265.8296	601.1802	
Minimum	43.8	77.9	
Maximum	745.4	4829.2	
Data Count	81	81	
	MO AVG mg/L	WKLY AVG mg/L	DAILY MX mg/L
Mean	12.3988	16.9247	26.2901
Minimum	.9	2.	2.9
Maximum	32.	76.7	219.
Data Count	81	81	81

Chlorine, total residual Location= 1

	MO AVG ug/L	DAILY MX ug/L
Mean	57.7926	253.4321
Minimum	9.2	40.
Maximum	195.	870.
Data Count	81	81

Coliform, fecal general Location= 1

	MO GEO MPN/100mL	DAILY MX MPN/100mL
Mean	3.042	26.6123
Minimum	1.	1.
Maximum	13.9	201.
Data Count	81	81

Enterococci Location= 1

	MO AVG CFU/100mL	MO GEO CFU/100mL	DAILY MX CFU/100mL
Mean	2.8111	2.2375	13.5481
Minimum	1.	1.	1.
Maximum	5.4	10.	363.4
Data Count	9	72	81

## Flow, in conduit or thru treatment plant Loc

	MO AVG MGD
Mean	2.6446
Minimum	1.837
Maximum	3.944
Data Count	81

## Nitrogen, Kjeldahl, total [as N] Location= 1

	DAILY MX mg/L
Mean	14.646
Minimum	2.33
Maximum	34.
Data Count	40

## Nitrogen, nitrate total [as N] Location= 1

	DAILY MX mg/L
Mean	4.4694
Minimum	.
Maximum	19.4
Data Count	40

## Nitrogen, nitrite total [as N] Location= 1

	DAILY MX mg/L
Mean	1.1322
Minimum	.1
Maximum	2.4
Data Count	40

## Nitrogen, total [as N] Location= 1

	DAILY MX mg/L
Mean	20.2472

Minimum	9.35
Maximum	35.6
Data Count	40

## pH Location= 1

	MINIMUM SU	MAXIMUM SU
Mean	6.4674	7.0752
Minimum	5.79	6.71
Maximum	7.01	7.47
Data Count	81	81

## Solids, settleable Location= 1

	WKLY AVG mL/L	DAILY MX mL/L
Mean	.1721	1.0596
Minimum	.	.
Maximum	9.3	65.
Data Count	81	81

## Solids, total suspended Location= 1

	MO AVG lb/d	DAILY MX lb/d
Mean	165.4901	414.0864
Minimum	66.5	88.3
Maximum	799.1	2794.3
Data Count	81	81

	MO AVG mg/L	WKLY AVG mg/L	DAILY MX mg/L
Mean	7.3519	11.2247	16.8272
Minimum	2.6	3.5	3.9
Maximum	34.9	63.6	123.
Data Count	81	81	81

## BOD, 5-day, 20 deg. C Location= G

	MO AVG lb/d	DAILY MX lb/d
Mean	4282.8346	6265.2654
Minimum	3276.3	4068.3
Maximum	5265.1	12904.7
Data Count	81	81

	MO AVG mg/L	WKLY AVG mg/L	DAILY MX mg/L
Mean	201.9519	229.1741	276.9519
Minimum	127.5	140.7	157.
Maximum	301.1	372.3	585.
Data Count	81	81	81

## Solids, total suspended Location= G

	MO AVG lb/d	DAILY MX lb/d	
Mean	4935.9617	9018.0938	
Minimum	3482.	4590.3	
Maximum	7415.7	24265.2	
Data Count	81	81	

	MO AVG mg/L	WKLY AVG mg/L	DAILY MX mg/L
Mean	231.8765	294.1148	424.8765
Minimum	138.9	154.7	190.
Maximum	378.2	889.	1470.
Data Count	81	81	81

## BOD, 5-day, percent removal Location= K

	MO AV MN %	MO AV MN %
Mean	96.6	93.5036
Minimum	94.1	82.48
Maximum	98.6	99.5
Data Count	9	72

## Solids, suspended percent removal Locatio

	MO AV MN %	MO AV MN %
Mean	96.1556	96.7894
Minimum	93.8	85.46
Maximum	98.5	98.93
Data Count	9	72

001Q

## Aluminum, total [as Al] Location= 1

	MO AVG ug/L	DAILY MX ug/L
Mean	34.0222	34.0222

Minimum	.	.
Maximum	95.3	95.3
Data Count	27	27

## Cadmium, total [as Cd] Location= 1

	MO AVG ug/L	DAILY MX ug/L
Mean	.0037	.0037
Minimum	.	.
Maximum	.1	.1
Data Count	27	27

## Chromium, total [as Cr] Location= 1

	MO AVG ug/L	DAILY MX ug/L
Mean	.0741	.0741
Minimum	.	.
Maximum	2.	2.
Data Count	27	27

## Copper, total [as Cu] Location= 1

	MO AVG ug/L	DAILY MX ug/L
Mean	14.7607	14.8681
Minimum	6.5	6.5
Maximum	69.2	69.2
Data Count	27	27

## Cyanide, free available Location= 1

	MO AVG ug/L	DAILY MX ug/L
Mean	2.6923	2.6923
Minimum	.	.
Maximum	20.1	20.1
Data Count	13	13

## Cyanide, total [as CN] Location= 1

	MO AVG ug/L	DAILY MX ug/L
Mean	.	.
Minimum	.	.
Maximum	.	.

Data Count	13	13
------------	----	----

## Lead, total [as Pb] Location= 1

	MO AVG ug/L	DAILY MX ug/L
Mean	.0704	.0704
Minimum	.	.
Maximum	1.3	1.3
Data Count	27	27

## Nickel, total [as Ni] Location= 1

	MO AVG ug/L	DAILY MX ug/L
Mean	1.3185	1.3185
Minimum	.	.
Maximum	3.	3.
Data Count	27	27

## Oil &amp; Grease Location= 1

	DAILY MX mg/L
Mean	2.4422
Minimum	.
Maximum	9.6
Data Count	27

## Zinc, total [as Zn] Location= 1

	MO AVG ug/L	DAILY MX ug/L
Mean	68.3278	68.3815
Minimum	.	.
Maximum	146.	146.
Data Count	27	27

001T

## LC50 Static Renewal 48Hr Acute American

	MINIMUM %
Mean	100.
Minimum	100.
Maximum	100.



Data Count

27

ATTACHMENT A-7

Summary of Priority Pollutant Scan Data  
2017-2022

Priority Pollutant	2017	2018	2019	2020	2021	2022	Maximum	Conversion to µg/L	Average	Conversion to µg/L
Aluminum (mg/L)	0.0387	0.0113	0.0953				0.0953	95.3	0.0484333	48.43333333
Antimony (mg/L)			0.0062				0.0062	6.2	0.0062	6.2
Copper (mg/L)	0.0182	0.0096	0.0149	0.0078	0.0096	0.0103	0.0182	18.2	0.01174	11.74
Nickel (mg/L)	0.002	0.0014					0.002	2	0.0017	1.7
Zinc (mg/L)	0.146	0.106	0.0566	0.095	0.0695	0.0593	0.146	146	0.0887333	88.73333333
Endosulfan I [2C] (µg/L)					0.0211		0.0211	0.0211	0.0211	0.0211
bis(2-Ethylexyl)phthalate (µg/L)						3.93	3.93	3.93	3.93	3.93
Phenols (mg/L)	0.076	0.059				0.051	0.076	76	0.062	62
Bromodichloromethane (mg/L)						0.00035	0.00035	0.35	0.00035	0.35
Chloroform (mg/L)						0.0005	0.0005	0.5	0.0005	0.5

ATTACHMENT A-8

Comparison of Allowable Limits with Discharge Monitoring Report Data  
and Priority Pollutant Scan Data

Facility Name: *South Kingstown WWTF*

RIPDES Permit #: *RI0100374*

Outfall #: *001A*

NOTE: METALS LIMITS ARE TOTAL METALS

Parameter	CAS #	Concentration Limits (ug/L) Based on WQ Criteria		Antideg. Limits (ug/L) Monthly Ave	Higher of Ave PPS Data (ug/L) or Oct. '21 app. Data 09/2017 - 09/2022		Ave. DMR Data (ug/L) 12/2016-08/2023		Potential Permit Limits (ug/L)		Daily Max	Monthly Ave	Reasonable Potential?
		Daily Max	Monthly Ave		Max	Ave	Daily Max	Monthly Ave	Daily Max	Monthly Ave			
		PRIORITY POLLUTANTS											
TOXIC METALS AND CYANIDE													
ANTIMONY	7440360	No Criteria	60416.00	---	6.2	6.2	---	---	---	60416		N	
ARSENIC (limits are total recoverable)	7440382	4416.00	132.16	---	---	---	---	---	4416	132.16			
ASBESTOS	1332214	No Criteria	No Criteria	---	---	---	---	---	---	---			
BERYLLIUM	7440417	No Criteria	No Criteria	---	---	---	---	---	---	---			
CADMIUM (limits are total recoverable)	7440439	2575.45	835.73	---	---	---	0.0037	0.0037	2575.4527	835.73441			
CHROMIUM III (limits are total recoverable)	16065831	No Criteria	No Criteria	---	---	---	---	---	---	---			
CHROMIUM VI (limits are total recoverable)	18540299	70896.27	4753.27	---	---	---	---	---	70896.274	4753.2729			
COPPER (limits are total recoverable)	7440508	370.12	352.58	---	18.2	11.74	14.87	14.76	370.12048	352.57831	N	N	
CYANIDE	57125	64.00	64.00	---	---	---	2.69	2.69	64	64	N	N	
LEAD (limits are total recoverable)	7439921	14132.49	804.04	---	---	---	0.0704	0.0704	14132.492	804.03785			
MERCURY (limits are total recoverable)	7439976	135.53	14.16	---	---	---	---	---	135.52941	14.16			
NICKEL (limits are total recoverable)	7440020	4783.84	781.90	---	2	1.7	1.32	1.32	4783.8384	781.89899	N	N	
SELENIUM (limits are total recoverable)	7782492	18597.19	6715.83	---	---	---	---	---	18597.194	6715.8317			
SILVER (limits are total recoverable)	7440224	143.06	No Criteria	---	---	---	---	---	143.05882	143.05882			
THALLIUM	7440280	No Criteria	44.37	---	---	---	---	---	---	44.368			
ZINC (limits are total recoverable)	7440666	6088.79	6088.79	---	146	88.733	68.38	68.33	6088.7949	6088.7949	N	N	
VOLATILE ORGANIC COMPOUNDS													
ACROLEIN	107028	No Criteria	27376.00	---	---	---	---	---	---	27376			
ACRYLONITRILE	107131	No Criteria	236.00	---	---	---	---	---	---	236			
BENZENE	71432	No Criteria	48144.00	---	---	---	---	---	---	48144			
BROMOFORM	75252	No Criteria	132160.00	---	---	---	---	---	---	132160			
CARBON TETRACHLORIDE	56235	No Criteria	1510.40	---	---	---	---	---	---	1510.4			
CHLOROBENZENE	108907	No Criteria	151040.00	---	---	---	---	---	---	151040			
CHLORODIBROMOMETHANE	124481	No Criteria	12272.00	---	---	---	---	---	---	12272			
CHLOROFORM	67663	No Criteria	443680.00	---	0.5	0.5	---	---	---	443680		N	

Attachment A-8

DICHLOROBROMOMETHANE	75274	No Criteria	16048.00	---	0.35	0.35	---	---	16048	N
1,2DICHLOROETHANE	107062	No Criteria	34928.00	---	---	---	---	---	34928	
1,1DICHLOROETHYLENE	75354	No Criteria	670240.00	---	---	---	---	---	670240	
1,2DICHLOROPROPANE	78875	No Criteria	14160.00	---	---	---	---	---	14160	
1,3DICHLOROPROPYLENE	542756	No Criteria	1982.40	---	---	---	---	---	1982.4	
ETHYLBENZENE	100414	No Criteria	198240.00	---	---	---	---	---	198240	
BROMOMETHANE (methyl bromide)	74839	No Criteria	141600.00	---	---	---	---	---	141600	
CHLOROMETHANE (methyl chloride)	74873	No Criteria	No Criteria	---	---	---	---	---	---	
METHYLENE CHLORIDE	75092	No Criteria	556960.00	---	---	---	---	---	556960	
1,1,2,2TETRACHLOROETHANE	79345	No Criteria	3776.00	---	---	---	---	---	3776	
TETRACHLOROETHYLENE	127184	No Criteria	3115.20	---	---	---	---	---	3115.2	
TOLUENE	108883	No Criteria	1416000.00	---	---	---	---	---	1416000	
1,2TRANSDICHLOROETHYLENE	156605	No Criteria	944000.00	---	---	---	---	---	944000	
1,1,1TRICHLOROETHANE	71556	No Criteria	No Criteria	---	---	---	---	---	---	
1,1,2TRICHLOROETHANE	79005	No Criteria	15104.00	---	---	---	---	---	15104	
TRICHLOROETHYLENE	79016	No Criteria	28320.00	---	---	---	---	---	28320	
VINYL CHLORIDE	75014	No Criteria	226.56	---	---	---	---	---	226.56	
ACID ORGANIC COMPOUNDS										
2CHLOROPHENOL	95578	No Criteria	14160.00	---	---	---	---	---	14160	
2,4DICHLOROPHENOL	120832	No Criteria	27376.00	---	---	---	---	---	27376	
2,4DIMETHYLPHENOL	105679	No Criteria	80240.00	---	---	---	---	---	80240	
4,6DINITRO2METHYL PHENOL	534521	No Criteria	26432.00	---	---	---	---	---	26432	
2,4DINITROPHENOL	51285	No Criteria	500320.00	---	---	---	---	---	500320	
4NITROPHENOL	88755	No Criteria	No Criteria	---	---	---	---	---	---	
PENTACHLOROPHENOL	87865	832.00	745.76	---	---	---	---	832	745.76	
PHENOL	108952	No Criteria	160480000.00	---	76	62	---	---	160480000	N
2,4,6TRICHLOROPHENOL	88062	No Criteria	2265.60	---	---	---	---	---	2265.6	
BASE NEUTRAL COMPOUNDS										
ACENAPHTHENE	83329	No Criteria	93456.00	---	---	---	---	---	93456	
ANTHRACENE	120127	No Criteria	3776000.00	---	---	---	---	---	3776000	
BENZIDINE	92875	No Criteria	0.19	---	---	---	---	---	0.1888	
POLYCYCLIC AROMATIC HYDROCARBONS		No Criteria	16.99	---	---	---	---	---	16.992	
BIS(2CHLOROETHYL)ETHER	111444	No Criteria	500.32	---	---	---	---	---	500.32	
BIS(2CHLOROISOPROPYL)ETHER	108601	No Criteria	6136000.00	---	---	---	---	---	6136000	
BIS(2ETHYLHEXYL)PHTHALATE	117817	No Criteria	2076.80	---	3.93	3.93	---	---	2076.8	N
BUTYL BENZYL PHTHALATE	85687	No Criteria	179360.00	---	---	---	---	---	179360	
2CHLORONAPHTHALENE	91587	No Criteria	151040.00	---	---	---	---	---	151040	
1,2DICHLOROBENZENE	95501	No Criteria	122720.00	---	---	---	---	---	122720	
1,3DICHLOROBENZENE	541731	No Criteria	90624.00	---	---	---	---	---	90624	
1,4DICHLOROBENZENE	106467	No Criteria	17936.00	---	---	---	---	---	17936	

3,3DICHLOOROBENZIDENE	91941	No Criteria	26.43	---	---	---	---	---	26.432	
DIETHYL PHTHALATE	84662	No Criteria	4153600.00	---	---	---	---	---	4153600	
DIMETHYL PHTHALATE	131113	No Criteria	103840000.00	---	---	---	---	---	103840000	
DInBUTYL PHTHALATE	84742	No Criteria	424800.00	---	---	---	---	---	424800	
2,4DINITROTOLUENE	121142	No Criteria	3209.60	---	---	---	---	---	3209.6	
1,2DIPHENYLHYDRAZINE	122667	No Criteria	188.80	---	---	---	---	---	188.8	
FLUORANTHENE	206440	No Criteria	13216.00	---	---	---	---	---	13216	
FLUORENE	86737	No Criteria	500320.00	---	---	---	---	---	500320	
HEXACHLOOROBENZENE	118741	No Criteria	0.27	---	---	---	---	---	0.27376	
HEXACHLOOROBUTADIENE	87683	No Criteria	16992.00	---	---	---	---	---	16992	
HEXACHLOOROCYCLOPENTADIENE	77474	No Criteria	103840.00	---	---	---	---	---	103840	
HEXACHLOOROETHANE	67721	No Criteria	3115.20	---	---	---	---	---	3115.2	
ISOPHORONE	78591	No Criteria	906240.00	---	---	---	---	---	906240	
NAPHTHALENE	91203	No Criteria	No Criteria	---	---	---	---	---	---	
NITROBENZENE	98953	No Criteria	65136.00	---	---	---	---	---	65136	
NNITROSODIMETHYLAMINE	62759	No Criteria	2832.00	---	---	---	---	---	2832	
NNITROSODINPROPYLAMINE	621647	No Criteria	481.44	---	---	---	---	---	481.44	
NNITROSODIPHENYLAMINE	86306	No Criteria	5664.00	---	---	---	---	---	5664	
PYRENE	129000	No Criteria	377600.00	---	---	---	---	---	377600	
1,2,4trichlorobenzene	120821	No Criteria	6608.00	---	---	---	---	---	6608	
PESTICIDES/PCBs										
ALDRIN	309002	83.20	0.05	---	---	---	---	83.2	0.0472	
Alpha BHC	319846	No Criteria	4.63	---	---	---	---	---	4.6256	
Beta BHC	319857	No Criteria	16.05	---	---	---	---	---	16.048	
Gamma BHC (Lindane)	58899	10.24	10.24	---	---	---	---	10.24	10.24	
CHLORDANE	57749	5.76	0.38	---	---	---	---	5.76	0.3776	
4,4DDT	50293	8.32	0.09	---	---	---	---	8.32	0.0944	
4,4DDE	72559	No Criteria	0.21	---	---	---	---	---	0.20768	
4,4DDD	72548	No Criteria	0.29	---	---	---	---	---	0.29264	
DIELDRIN	60571	45.44	0.05	---	---	---	---	45.44	0.050976	
ENDOSULFAN (alpha)	959988	2.18	0.82	---	0.0211	0.0211	---	2.176	0.82128	N N
ENDOSULFAN (beta)	33213659	2.18	0.82	---	---	---	---	2.176	0.82128	
ENDOSULFAN (sulfate)	1031078	No Criteria	8401.60	---	---	---	---	---	8401.6	
ENDRIN	72208	2.37	0.22	---	---	---	---	2.368	0.21712	
ENDRIN ALDEHYDE	7421934	No Criteria	28.32	---	---	---	---	---	28.32	
HEPTACHLOR	76448	3.39	0.07	---	---	---	---	3.392	0.074576	
HEPTACHLOR EPOXIDE	1024573	3.39	0.04	---	---	---	---	3.392	0.036816	
POLYCHLORINATED BIPHENYLS3	1336363	No Criteria	0.06	---	---	---	---	---	0.060416	
2,3,7,8TCDD (Dioxin)	1746016	No Criteria	0.00	---	---	---	---	---	4.814E-06	
TOXAPHENE	8001352	13.44	0.02	---	---	---	---	13.44	0.01888	

Attachment A-8

TRIBUTYL TIN		26.88	0.70	---	---	---	---	---	26.88	0.69856		
NON PRIORITY POLLUTANTS:												
OTHER SUBSTANCES												
ALUMINUM (limits are total recoverable)	7429905	No Criteria	No Criteria	---	95.3	48.43	34.02	34.02	---	---	N	N
AMMONIA (winter)	7664417	457689.60	100875.84	---	---	---	---	---	457689.6	100875.84		
AMMONIA (summer)	7664417	384038.40	85356.48	---	---	---	---	---	384038.4	85356.48		
4BROMOPHENYL PHENYL ETHER CHLORIDE	16887006	No Criteria	No Criteria	---	---	---	---	---	---	---		
CHLORINE	7782505	1040.00	885.00	---	---	---	253.43	57.79	1040	885	N	N
4CHLORO2METHYLPHENOL		No Criteria	No Criteria	---	---	---	---	---	---	---		
1CHLORONAPHTHALENE		No Criteria	No Criteria	---	---	---	---	---	---	---		
4CHLOROPHENOL	106489	No Criteria	No Criteria	---	---	---	---	---	---	---		
2,4DICHLORO6METHYLPHENOL		No Criteria	No Criteria	---	---	---	---	---	---	---		
1,1DICHLOROPROPANE		No Criteria	No Criteria	---	---	---	---	---	---	---		
1,3DICHLOROPROPANE	142289	No Criteria	No Criteria	---	---	---	---	---	---	---		
2,3DINITROTOLUENE		No Criteria	No Criteria	---	---	---	---	---	---	---		
2,4DINITRO6METHYL PHENOL		No Criteria	No Criteria	---	---	---	---	---	---	---		
IRON	7439896	No Criteria	No Criteria	---	---	---	---	---	---	---		
pentachlorobenzene	608935	No Criteria	No Criteria	---	---	---	---	---	---	---		
PENTACHLOROETHANE		No Criteria	No Criteria	---	---	---	---	---	---	---		
1,2,3,5tetrachlorobenzene		No Criteria	No Criteria	---	---	---	---	---	---	---		
1,1,1,2TETRACHLOROETHANE	630206	No Criteria	No Criteria	---	---	---	---	---	---	---		
2,3,4,6TETRACHLOROPHENOL	58902	No Criteria	No Criteria	---	---	---	---	---	---	---		
2,3,5,6TETRACHLOROPHENOL		No Criteria	No Criteria	---	---	---	---	---	---	---		
2,4,5TRICHLOROPHENOL	95954	No Criteria	No Criteria	---	---	---	---	---	---	---		
2,4,6TRINITROPHENOL	88891	No Criteria	No Criteria	---	---	---	---	---	---	---		
XYLENE	1330207	No Criteria	No Criteria	---	---	---	---	---	---	---		
Total Chromium							0.074	0.074	---	---		