

CALCULATIONS OF NEW MEXICO WATER QUALITY-BASED EFFLUENT LIMITATIONS

NMAC 20.6.4. NMWQS as of 2023 (EPA Approved January 19, 2023)

Calculations Specifications: Excel Revised (in red text, except strikethrough) as of February 2023

Prepared By: Ruben 24-Jan-24 8:00 AM

STEP 1: REFERENCE IMPLEMENTATION PROCEDURES
INPUT FACILITY AND RECEIVING STREAM DATA
LIST SOURCE OF DATA INPUT

APPENDIX A
of FACT SHEET

IMPLEMENTATION PROCEDURES

The State of New Mexico Standards for Interstate and Intrastate Surface Waters are implemented in this spread sheet by using procedures established in the current "Procedures for Implementing NPDES Permits in New Mexico"

FACILITY		DATA INPUT
Permittee		Springer
NPDES Permit No.		NM0030627
Outfall No.(s)		1
Plant Effluent Flow (MGD)		0.018
Plant Effluent Flow (cfs)		0.0279
		For industrial and federal facility, use the highest monthly average flow for the past 24 months. For POTWs, use the design flow.

RECEIVING STREAM

Receiving Stream Name		non classified
Basin Name		Canadian
Waterbody Segment Code No.		
Is a publicly owned lake or reservoir (enter "1" if it's a lake, "0" if not)		0
Are acute aquatic life criteria considered (1= yes, 0= no)		1
Are chronic aquatic life criteria considered (1= yes, 0=no)		1
Are domestic water supply criteria considered (1= yes, 0=no)		0
Are irrigation water supply criteria considered (1= yes, 0=no)		1
Livestock watering and wildlife habitat criteria applied to all streams		
USGS Flow Station		USGS
WQ Monitoring Station No.		SJR
Receiving Stream TSS (mg/l)		8
Receiving Stream Hardness (mg/l as CaCOs)	RANGE: 0 - 400	150
Receiving Stream Critical Low Flow (4Q3) (cfs)		0
Receiving Stream Harmonic Mean Flow (cfs)		0.001
Avg. Receiving Water Temperature (C)		15
pH (Avg), Receiving Stream		7.7
Fraction of stream allowed for mixing (F)		1
Fraction of Critical Low Flow		0
		Enter 1, if stream morphology data is not available or for intermittent streams.

STEP 2: INPUT AMBIENT AND EFFLUENT DATA
CALCULATE IN-STREAM WASTE CONCENTRATIONS

DATA INPUT

Input pollutant geometric mean concentration as micro-gram per liter (ug/l or ppb)
unless other unit is specified for the parameter.
Effluent value reported as "< detection level" (DL) but the DL is greater than MQL, input "1/2 DL" for calculation.
Effluent value reported as "< detection level" (DL) and the DL is smaller than MQL, no data is inputted.
If a less than MQL vakue is reported, input either the reported value or "0" for calculation.

The following formular is used to calculate the Instream Waste Concentration (Cd)
See the current "Procedures for Implementing NPDES Permits in New Mexico"
 $Cd = [(F*Qa*Ca) + (Qe*2.13*Ce)] / (F*Qa + Qe)$
Where:
Cd = Instream Waste Concentration
F = Fraction of stream allowed for mixing (see "Procedures for Implementing NPDES Permits in New Mexico")
Ce = Reported concentration in effluent
Ca = Ambient stream concentration upstream of discharge
Qe = Plant effluent flow
Qa = Critical low flow of stream at discharge point expressed as the 4Q3 or harmonic mean flow for human health criteria

The following formular convert metals reported in total form to dissolved form if criteria are in dissolved form
See the current "Procedures for Implementing NPDES Permits in New Mexico"
 $Kp = Kpo * (TSS**a)$ Kp = Linear partition coefficient; Kpo and a can be found in table below
 $C/Ct = 1/ (1 + Kp*TSS* 10^{-6})$ TSS = Total suspended solids concentration found in receiving stream (or in effluent for intermittent stream)
Total Metal Criteria (Ct) = Cr / (C/Ct) C/Ct = Fraction of metal dissolved; and Cr = Dissolved criteria value

		Stream Linear Partition Coefficient					Lake Linear Partition Coefficient				
Total Metals	Total Value	Kpo	alpha (a)	Kp	C/Ct	Dissolved Value in Stream	Kpo	alpha (a)	Kp	C/Ct	Dissolved Value in Lake
Arsenic	4.4	480000	-0.73	105192.6866	0.543023333	0	480000	-0.73	105192.6866	0.543023333	0
Chromium III		3360000	-0.93	485809.0372	0.204646612	0	2170000	-0.27	1237728.632	0.091727727	0
Copper		1040000	-0.74	223227.0135	0.358961238	1.57942945	2850000	-0.9	438595.1973	0.221790392	0.97587773
Lead	10	2800000	-0.8	530500.7983	0.190693894	0	2040000	-0.53	677629.7652	0.155738057	0
Nickel		490000	-0.57	149773.434	0.454920253	4.54920253	2210000	-0.76	455034.037	0.215504595	2.15504595
Silver		2390000	-1.03	280682.4213	0.308122791	0	2390000	-1.03	280682.4213	0.308122791	0
Zinc		1250000	-0.7	291572.8099	0.300067592	0	3340000	-0.68	812166.8811	0.133380727	0

The following formular is used to calculate hardness dependent criteria
(Please refer to State Water Quality Standards for details)

Dissolved
WQC (ug/l)

Aluminum (T)	Acute	$e(1.3695[\ln(\text{hardness})]+1.8308)$	5960.234085	If Stream pH < 6.5, enter 750 in cell O114 If Stream pH < 6.5, enter 87 in cell P114
	Chronic	$e(1.3695[\ln(\text{hardness})]+0.9161)$	2387.889106	
Cadmium (D)	Acute	$e(0.8968[\ln(\text{hardness})]-3.5699)*CF1$	2.334682657	CF1 = 1.136672 - 0.041838*ln(hardness)
	Chronic	$e(0.7647[\ln(\text{hardness})]-4.2180)*CF2$	0.606157872	CF2 = 1.101672 - 0.041838*ln(hardness)

			Dissolved		WQC (ug/l)	
Chromium III (D)	Acute	0.316 e(0.819[ln(hardness)]+3.7256)	794.1697588			
	Chronic	0.860 e(0.819[ln(hardness)]+0.6848)	103.3051693			
Copper (D)	Acute	0.960 e(0.9422[ln(hardness)]-1.700)	19.69172663			
	Chronic	0.960 e(0.8545[ln(hardness)]-1.702)	12.66403219			
Lead (D)	Acute	e(1.273[ln(hardness)]-1.46)*CF3	100.1285732		CF3 = 1.46203 - 0.145712*ln(hardness)	
	Chronic	e(1.273[ln(hardness)]-4.705)*CF4	3.90186675		CF4 = 1.46203 - 0.145712*ln(hardness)	
Manganese (D)	Acute	e(0.3331[ln(hardness)]+6.4676)	3417.424979			
	Chronic	e(0.3331[ln(hardness)]+5.8743)	1888.130786			
Nickel (D)	Acute	0.998 e(0.846[ln(hardness)]+2.255)	659.8387296			
	Chronic	0.997 e(0.846[ln(hardness)]+0.0584)	73.28771162			
Silver (D)	Acute	0.85 e(1.72[ln(hardness)]-6.59)	6.46093327			
Zinc (D)	Acute	0.978 e(0.9094[ln(hardness)]+0.9095)	231.3487073			
	Chronic	0.986 e(0.90947[ln(hardness)]+0.6235)	175.2868117			

			Instream Waste Concentration						Livestock&	Acute	Chronic	Human	Need		
POLLUTANTS			Ambient	Effluent	Acute	Domestic	Chronic	Human	Domestic	Irrigation	Wildlife	Aquatic	Aquatic	Health	TMDL
	CAS No.	MQL	Conc.	Conc.	Aquatic	Supply	Aquatic	Health	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria	
			Ca (ug/l)	Ce (ug/l)	2.13*Ce	Cd,dom (ug/l)	Cd (ug/l)	Cd,hh (ug/l)	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	
Radioactivity, Nutrients, and Chlorine															
Aluminum, total	7429-90-5	2.5	1800		3834	3834	3834	3701.33564	1E+100	1E+100	1E+100	5960.234085	2387.88911	1E+100	N/A
Aluminum, dissolved	7429-90-5				0	0	0	0	1E+100	5000	1E+100	1E+100	1E+100	1E+100	N/A
Barium, dissolved	7440-39-3	100			0	0	0	0	2000	1E+100	1E+100	1E+100	1E+100	1E+100	N/A
Boron, dissolved	7440-42-8	100			0	0	0	0	1E+100	750	5000	1E+100	1E+100	1E+100	N/A
Chloride	1688-70-06				0	0	0	0	1E+100	1E+100	1E+100	860000	230000	1E+100	N/A
Cobalt, dissolved	7440-48-4	50			0	0	0	0	1E+100	50	1000	1E+100	1E+100	1E+100	N/A
Uranium, dissolved	7440-61-1	0.1			0	0	0	0	30	1E+100	1E+100	1E+100	1E+100	1E+100	N/A
Vanadium, dissolved	7440-62-2	50			0	0	0	0	1E+100	100	100	1E+100	1E+100	1E+100	N/A
Ra-226 and Ra-228 (pCi/l)					0	0	0	0	5	1E+100	30	1E+100	1E+100	1E+100	N/A
Strontium (pCi/l)					0	0	0	0	8	1E+100	1E+100	1E+100	1E+100	1E+100	N/A
Tritium (pCi/l)					0	0	0	0	20000	1E+100	20000	1E+100	1E+100	1E+100	N/A
Gross Alpha (pCi/l)					0	0	0	0	15	1E+100	15	1E+100	1E+100	1E+100	N/A
Asbestos (fibers/l)					0	0	0	0	7000000	1E+100	1E+100	1E+100	1E+100	1E+100	N/A
Total Residual Chlorine	7782-50-5	33			0	0	0	0	1E+100	1E+100	11	19	11	1E+100	N/A
Ammonia as N, total (mg/l)					0	0	0	0	1E+100	1E+100	1E+100	Criterion	Criterion	1E+100	N/A
Nitrate as N (mg/l)					0	0	0	0	10	1E+100	1E+100	1E+100	1E+100	1E+100	N/A
Nitrite + Nitrate (mg/l)					0	0	0	0	1E+100	1E+100	132	1E+100	1E+100	1E+100	N/A
METALS AND CYANIDE															
Antimony, dissolved (P)	7440-36-0	60			0	0	0	0	6	1E+100	1E+100	1E+100	1E+100	640	N/A
Arsenic, dissolved (P)	7440-38-2	0.5	0		0	0	0	0	10	100	200	340	150	9	N/A
Beryllium, dissolved	7440-41-7	0.5			0	0	0	0	4	1E+100	1E+100	1E+100	1E+100	1E+100	N/A
Cadmium, dissolved	7440-43-9	1			0	0	0	0	5	10	50	2.334682657	0.60615787	1E+100	N/A
Chromium (III), dissolved	16065-83-1	10	0		0	0	0	0	1E+100	1E+100	1E+100	794.1697588	103.305169	1E+100	N/A
Chromium (VI), dissolved	18540-29-9	10			0	0	0	0	1E+100	1E+100	1E+100	16	11	1E+100	N/A
Chromium, dissolved	7440-47-3				0	0	0	0	100	100	1000	1E+100	1E+100	1E+100	N/A

Copper, dissolved	7440-50-8	0.5	4.4	9.372	9.372	9.372	9.04770934	1300	200	500	19.69172663	12.6640322	1E+100	N/A
Iron	7439-89-6			0	0	0	0	1E+100	1E+100	1E+100	1E+100	1000	1E+100	N/A
Lead, dissolved	7439-92-1	0.5	0	0	0	0	0	15	5000	100	100.1285732	3.90186675	1E+100	N/A
Manganese, dissolved	7439-96-5			0	0	0	0	1E+100	1E+100	1E+100	3417.424979	1888.13079	1E+100	N/A

2,4-Dichlorophenol	120-83-2	10		0	0	0	0	105	1E+100	1E+100	1E+100	1E+100	60	N/A
2,4-Dimethylphenol	105-67-9	10		0	0	0	0	700	1E+100	1E+100	1E+100	1E+100	3000	N/A
3-Methyl-4-chlorophenol	59-50-7			0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	2000	N/A
2-Methyl-4,6-dinitrophenol	534-52-1	50		0	0	0	0	14	1E+100	1E+100	1E+100	1E+100	30	N/A

POLLUTANTS	CAS No.	MQL	Instream Waste Concentration								Livestock&	Acute	Chronic	Human	Need TMDL
			Ambient	Effluent	Acute	Domestic	Chronic	Human	Domestic	Irrigation	Wildlife	Aquatic	Aquatic	Health	
			Conc	Conc.	Aquatic	Supply	Aquatic	Health	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria	
			Ca (ug/l)	Ce (ug/l)	2.13*Ce	Cd,dom (ug/l)	Cd (ug/l)	Cd,hh (ug/l)	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	
2,4-Dinitrophenol	51-28-5	50			0	0	0	0	70	1E+100	1E+100	1E+100	1E+100	300	N/A
Pentachlorophenol	87-86-5	50			0	0	0	0	1	1E+100	1E+100	19	15	30	N/A
Phenol	108-95-2	10			0	0	0	0	10500	1E+100	1E+100	1E+100	1E+100	860000	N/A
2,4,5-Trichlorophenol	95-95-4				0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	600	N/A
2,4,6-Trichlorophenol	88-06-2	10			0	0	0	0	32	1E+100	1E+100	1E+100	1E+100	28	N/A
2-(2,4,5Trichlorophenoxy)propionic acid (Silvex)					0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	400	N/A
BASE/NEUTRAL															
Acenaphthene	83-32-9	10			0	0	0	0	2100	1E+100	1E+100	1E+100	1E+100	90	N/A
Anthracene	120-12-7	10			0	0	0	0	10500	1E+100	1E+100	1E+100	1E+100	400	N/A
Benzidine	92-87-5	50			0	0	0	0	0.0015	1E+100	1E+100	1E+100	1E+100	0.11	N/A
Benzo(a)anthracene	56-55-3	5			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	0.013	N/A
Benzo(a)pyrene	50-32-8	5			0	0	0	0	0.2	1E+100	1E+100	1E+100	1E+100	0.0013	N/A
3,4-Benzofluoranthene	205-99-2	10			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	0.0013	N/A
Benzo(k)fluoranthene	207-08-9	5			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	0.13	N/A
Bis(2-chloroethyl)Ether	111-44-4	10			0	0	0	0	0.3	1E+100	1E+100	1E+100	1E+100	22	N/A
Bis(2-chloro-1-methylethyl) ether	108-60-1	10			0	0	0	0	1400	1E+100	1E+100	1E+100	1E+100	4000	N/A
Bis(2-ethylhexyl)Phthalate	117-81-7	10			0	0	0	0	6	1E+100	1E+100	1E+100	1E+100	3.7	N/A
Bis(chloromethyl) ether	542-88-1				0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	0.17	N/A
Butyl Benzyl Phthalate	85-68-7	10			0	0	0	0	7000	1E+100	1E+100	1E+100	1E+100	1	N/A
Carbaryl	63-25-2				0	0	0	0	1E+100	1E+100	1E+100	2.1	2.1	1E+100	N/A
2-Chloronapthalene	91-58-7	10			0	0	0	0	2800	1E+100	1E+100	1E+100	1E+100	1000	N/A
Chrysene	218-01-9	5			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	1.3	N/A
Demeton	8065-48-3				0	0	0	0	1E+100	1E+100	1E+100	1E+100	0.1	1E+100	N/A
2,4-Dichlorophenoxyacetic acid	94-75-7				0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	12000	N/A
Dibenzo(a,h)anthracene	53-70-3	5			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	0.0013	N/A
1,2-Dichlorobenzene	95-50-1	10			0	0	0	0	600	1E+100	1E+100	1E+100	1E+100	3000	N/A
1,3-Dichlorobenzene	541-73-1	10			0	0	0	0	469	1E+100	1E+100	1E+100	1E+100	10	N/A
1,4-Dichlorobenzene	106-46-7	10			0	0	0	0	75	1E+100	1E+100	1E+100	1E+100	900	N/A
3,3'-Dichlorobenzidine	91-94-1	5			0	0	0	0	0.78	1E+100	1E+100	1E+100	1E+100	1.5	N/A
Diethyl Phthalate	84-66-2	10			0	0	0	0	28000	1E+100	1E+100	1E+100	1E+100	600	N/A
Dimethyl Phthalate	131-11-3	10			0	0	0	0	350000	1E+100	1E+100	1E+100	1E+100	2000	N/A
Di-n-Butyl Phthalate	84-74-2	10			0	0	0	0	3500	1E+100	1E+100	1E+100	1E+100	30	N/A
2,4-Dinitrotoluene	121-14-2	10			0	0	0	0	1.1	1E+100	1E+100	1E+100	1E+100	17	N/A
1,2-Diphenylhydrazine	122-66-7	20			0	0	0	0	0.44	1E+100	1E+100	1E+100	1E+100	2	N/A
Fluoranthene	206-44-0	10			0	0	0	0	1400	1E+100	1E+100	1E+100	1E+100	20	N/A
Fluorene	86-73-7	10			0	0	0	0	1400	1E+100	1E+100	1E+100	1E+100	70	N/A
Guthion	86-50-0				0	0	0	0	1E+100	1E+100	1E+100	1E+100	0.01	1E+100	N/A
Hexachlorobenzene	118-74-1	5			0	0	0	0	1	1E+100	1E+100	1E+100	1E+100	0.00079	N/A
Hexachlorobutadiene	87-68-3	10			0	0	0	0	4.5	1E+100	1E+100	1E+100	1E+100	0.1	N/A
Hexachlorocyclohexane (HCH)-	608-73-1				0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	0.1	N/A
Hexachlorocyclopentadiene	77-47-4	10			0	0	0	0	50	1E+100	1E+100	1E+100	1E+100	4	N/A
Hexachloroethane	67-72-1	20			0	0	0	0	25	1E+100	1E+100	1E+100	1E+100	1	N/A
Indeno(1,2,3-cd)Pyrene	193-39-5	5			0	0	0	0	0.048	1E+100	1E+100	1E+100	1E+100	0.013	N/A
Isophorone	78-59-1	10			0	0	0	0	368	1E+100	1E+100	1E+100	1E+100	18000	N/A
Malathion	121-75-5				0	0	0	0	1E+100	1E+100	1E+100	1E+100	0.1	1E+100	N/A

Methoxychlor	72-43-5			0	0	0	0	1E+100	1E+100	1E+100	1E+100	0.03	0.02	N/A
Nitrobenzene	98-95-3	10		0	0	0	0	18	1E+100	1E+100	1E+100	1E+100	600	N/A
Nitrosamines	Various			0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	12.4	N/A
Nitrosodibutylamine	924-16-3			0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	2.2	N/A
Nitrosodiethylamine	55-18-5			0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	12.4	N/A
n-Nitrosodimethylamine	62-75-9	50		0	0	0	0	0.0069	1E+100	1E+100	1E+100	1E+100	30	N/A
n-Nitrosodi-n-Propylamine	621-64-7	20		0	0	0	0	0.05	1E+100	1E+100	1E+100	1E+100	5.1	N/A
n-Nitrosodiphenylamine	86-30-6	20		0	0	0	0	71	1E+100	1E+100	1E+100	1E+100	60	N/A
N-Nitrosopyrrolidine	930-55-2			0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	340	N/A
Nonylphenol	84852-15-3			0	0	0	0	1E+100	1E+100	1E+100	28	6.6	1E+100	N/A
Parathion	56-38-2			0	0	0	0	1E+100	1E+100	1E+100	0.065	0.013	1E+100	N/A
Pentachlorobenzene	608-93-5			0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	0.1	N/A
Pyrene	129-00-0	10		0	0	0	0	1050	1E+100	1E+100	1E+100	1E+100	4000	N/A
1,2,4-Trichlorobenzene	120-82-1	10		0	0	0	0	70	1E+100	1E+100	1E+100	1E+100	0.76	N/A

POLLUTANTS	Instream Waste Concentration											Livestock&	Acute	Chronic	Human	Need
	CAS No.	MQL	Ambient	Effluent	Acute	Domestic	Chronic	Human	Domestic	Irrigation	Wildlife	Aquatic	Aquatic	Aquatic	Health	TMDL
			Conc	Conc.	Aquatic	Supply	Aquatic	Health	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria	
			Ca (ug/l)	Ce (ug/l)	2.13*Ce	Cd,dom (ug/l)	Cd (ug/l)	Cd,hh (ug/l)	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	
PESTICIDES AND PCBS																
Aldrin	309-00-2	0.01			0	0	0	0	0.021	1E+100	1E+100	3	1E+100	1E+100	0.0000077	N/A
Alpha-BHC	319-84-6	0.05			0	0	0	0	0.056	1E+100	1E+100	1E+100	1E+100	1E+100	0.0039	N/A
Beta-BHC	319-85-7	0.05			0	0	0	0	0.091	1E+100	1E+100	1E+100	1E+100	1E+100	0.14	N/A
gamma-BHC (Lindane)	58-89-9	0.05			0	0	0	0	0.2	1E+100	1E+100	0.95	1E+100	1E+100	4.4	N/A
Chlordane	57-74-9	0.2			0	0	0	0	2	1E+100	1E+100	2.4	0.0043	0.0043	0.0032	N/A
Dichlorodiphenyldichloroethane (DDD)					0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	1E+100	0.0012	N/A
Dichlorodiphenyldichloroethylene (DDE)					0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	1E+100	0.00018	N/A
Dichlorodiphenyltrichloroethane (DDT)					0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	1E+100	0.0003	N/A
4,4'-DDT and derivatives	50-29-3	0.02			0	0	0	0	1	1E+100	0.001	1.1	0.001	0.001	1E+100	N/A
Dieldrin	60-57-1	0.02			0	0	0	0	0.022	1E+100	1E+100	0.24	0.056	0.056	0.000012	N/A
Diazinon	333-41-5				0	0	0	0	1E+100	1E+100	1E+100	0.17	0.17	0.17	1E+100	N/A
Alpha-Endosulfan	959-98-8	0.01			0	0	0	0	62	1E+100	1E+100	0.22	0.056	0.056	30	N/A
Beta-Endosulfan	33213-65-9	0.02			0	0	0	0	62	1E+100	1E+100	0.22	0.056	0.056	40	N/A
Endosulfan sulfate	1031-7-8	0.1			0	0	0	0	62	1E+100	1E+100	1E+100	1E+100	1E+100	40	N/A
Endrin	72-20-8	0.02			0	0	0	0	2	1E+100	1E+100	0.086	0.036	0.036	0.03	N/A
Endrin Aldehyde	7421-93-4	0.1			0	0	0	0	10.5	1E+100	1E+100	1E+100	1E+100	1E+100	1	N/A
Heptachlor	76-44-8	0.01			0	0	0	0	0.4	1E+100	1E+100	0.52	0.0038	0.0038	0.000059	N/A
Heptachlor Epoixde	1024-57-3	0.01			0	0	0	0	0.2	1E+100	1E+100	0.52	0.0038	0.0038	0.00032	N/A
PCBs	336-36-3	0.2			0	0	0	0	0.5	1E+100	0.014	2	0.014	0.014	0.00064	N/A
Toxaphene	8001-35-2	0.3			0	0	0	0	3	1E+100	1E+100	0.73	0.0002	0.0002	0.0071	N/A

STEP 3: SCAN POTENTIAL INSTREAM WASTE CONCENTRATIONS AGAINST WATER QUALITY CRITERIA AND ESTABLISH EFFLUENT LIMITATIONS FOR ALL APPLICABLE PARAMETERS

No limits are established if the receiving stream is not designated for the particular uses.

No limits are established if the potential instream waste concentrations are less than the chronic water quality criteria.

The most applicable stringent criteria are used to establish effluent limitations for a given parameter.

Water quality criteria apply at the end-of-pipe for acute aquatic life criteria and discharges to public lakes.

If background concentration exceeds the water quality criteria, water quality criteria apply. And "Need TMDL" shown to the next column of Avg. Mass

Monthly avg concentration = daily max. / 1.5.

APPLICABLE WATER QUALITY-BASED LIMITS

The following formular is used to calculate the allowable daily maximum effluent cincetration

Daily Max. Conc. = $Cs + (Cs - Ca)(F*Qa/Qe)$

Where:

Cs = Applicable water quality standard

Ca = Ambient stream concentration

F = Fraction of stream allowed for mixing (1.0 is assigned to domestic water supply and human health uses)

Qe = Plant effluent flow

Qa = Criteria Low flow (4Q3) or Harmonic Mean flow for Human Health Criteria

See the current "Procedures for Implementing NPDES Permits in New Mexico"

Monthly Avg. Conc. = Daily Max. Conc. / 1.5

POLLUTANTS	CAS No.	STORET	Domestic Limits	Irrigation Limits	Livestock or Wildlife Limits	Acute Aquatic Limits	Chronic Aquatic Limits	Human Health Limits	Daily	Monthly	Daily Max	Mon. Avg	Daily	Monthly
									Max Conc ug/l	Avg Conc ug/l	Total ug/l	Total ug/l	Max Load lb/day	Avg Load lb/day
Radioactivity, Nutrients, and Chlorine, as Total														
Aluminum, Total	7429-90-5	01105	N/A	N/A	N/A	N/A	2387.88911	N/A	2387.889106	2387.889106	2387.889106	2387.88911	0.35846991	0.358469913
Aluminum, dissolved	7429-90-5		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Barium, Total	7440-39-3	01007	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Boron, Total	7440-42-8	01022	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chloride	1688-70-06		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cobalt, Total	7440-48-4	01037	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Uranium, Total	7440-61-1	22706	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Vanadium, Total	7440-62-2	01087	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Ra-226 and Ra-228 (pCi/l)		11503	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Strontium (pCi/l)		13501	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Tritium (pCi/l)		04124	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Gross Alpha (pCi/l)		80029	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Asbestos (fibers/l)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total Residual Chlorine	7782-50-5	50060	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Ammonia as N, total (mg/l)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrate as N (mg/l)		00620	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrite + Nitrate (mg/l)		00630	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
METALS AND CYANIDE, as Total														
Antimony, Total (P)	7440-36-0	01097	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Arsenic, Total (P)	7440-38-2	1002	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Beryllium, Total	7440-41-7	01012	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cadmium, Total	7440-43-9	01027	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chromium (III), dissolved	16065-83-1	01033	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chromium (VI), dissolved	18540-29-9	01034	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chromium, Total	7440-47-3	01034	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Copper, Total	7440-50-8	01042	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Iron	7439-89-6		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Lead, Total	7439-92-1	01051	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Manganese, dissolved	7439-96-5	01056	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mercury, Dissolved	7439-97-6	71900	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mercury, Total	7439-97-6	71900	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Molybdenum, dissolved	7439-98-7	1060	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Molybdenum, total recoverable	7439-98-7	01062	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nickel, Total (P)	7440-02-0	01067	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Selenium, Total (P)	7782-49-2	01147	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Selenium, Total (SO4 >500 mg/l)		01147	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Selenium, Total recoverable	7782-49-2	01147	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Silver, Total	7440-22-4	01077	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Thallium, Total (P)	7440-28-0	01059	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Zinc, Total	7440-66-6	1092	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cyanide, total recoverable	57-12-5	00720	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DIOXIN														0
2,3,7,8-TCDD	1746-01-6	34675	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
VOLATILE COMPOUNDS														
Acrolein	107-02-8	34210	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

[illegible]

