

NPDES authorization to discharge to waters of the United States, Permit No. NM0031208

The applicant's mailing address is:

Quail Run Services, LLC  
Postal Office Box 570177  
Houston, TX 77257

The discharge from this facility is located on Pearl Valley Road (CR 43) at U.S. HWY 62, City of Hobbs, Lea County, New Mexico. Under the SIC code 4950, the applicant privately operates a proposed WWTP named Quail Run Services – Hobbs, which has a discharge flow of 0.15 MGD; expected date to discharge is January 1, 2019. Effluent is chlorinated before discharged via Outfall 001 to unnamed tributary to Ironhouse Draw and/or Monument Draw. Designated uses of the receiving water are stated in the fact sheet, which is available.

This is a renewal of a permit issued November 28, 2018, with an effective date of December 28, 2018, and an expiration date of December 27, 2023.

Changes from the previous permit are:

- Added PFAS language and reporting requirements.
- Added e-reporting requirements implementing the e-Reporting Rule.
- Added influent reporting for BOD<sub>5</sub> and TSS.

A Fact Sheet is available.

Note: All data submitted by the applicant is available as part of the administrative record. Further information regarding the administrative record may be requested from the EPA contact below or viewed at the address below between 8 a.m. and 4:30 p.m., Monday through Friday. It is recommended that you write or call for an appointment, so the record (s) will be available at your convenience.

Ms. Evelyn Rosborough  
U.S. Environmental Protection Agency  
NPDES Review Section (6WD-PN)  
1201 Elm Street, Suite 500  
Dallas, Texas 75270-2102  
(214) 665-7515 or [rosborough.evelyn@epa.gov](mailto:rosborough.evelyn@epa.gov)

#### State Certification

This Notice also serves as Public Notice of the intent of the New Mexico Environment Department, Surface Water Quality Bureau to consider issuing Clean Water Act (CWA) Section 401 Certification. The purpose of such certification is to reasonably ensure that the permitted activities will be conducted in a manner that will comply with applicable New Mexico water quality standards, including the antidegradation policy, and the statewide water quality

management plan. The NPDES permit will not be issued until the certification requirements of Section 401 have been met.

If you want to comment on State Certification submit written comments within the 30-day period to:

Susan A. Lucas Kamat  
Surface Water Quality Bureau  
Program Manager  
Point Source Regulation Section  
New Mexico Environment Department  
1190 Saint Francis Drive  
P.O. Box 5469  
Santa Fe, NM 87502-5469  
Phone: 505-946-8924  
Email: [Susan.LucasKamat@env.nm.gov](mailto:Susan.LucasKamat@env.nm.gov)