
2021 – 4th Quarter Report
Support for Conducting Systems &
Performance Audits of Clean Air Status and
Trends Network (CASTNET) Sites and
National Atmospheric Deposition Program
(NADP) Monitoring Stations - II
EPA Contract No. EP-W-18-005

Prepared for:

U. S. Environmental Protection Agency

Prepared by:



4577E NW 6th St Ext.
Gainesville, FL 32609

Report Submitted
March 2022

Table of Contents

1.0 CASTNET Quarterly Report.....	1
1.1 Introduction.....	1
1.2 Project Objectives	2
1.3 CASTNET Sites Visited Fourth Quarter 2021	4
1.4 Audit Results.....	5
2.0 NADP Quarterly Report	6
2.1 Introduction.....	6
2.2 Project Objectives	6
2.3 NADP Sites Visited Fourth Quarter 2021	7
2.4 Survey Results.....	8

List of Appendices

- Appendix A** CASNTET Audit Report Forms
- Appendix B** CASTNET Site Spot Report Forms

List of Tables

Table 1. Performance Audit Challenge and Acceptance Criteria.....	2
Table 2. CASTNET Site Audit Visits	4
Table 3. NADP Site Survey Visits	7

List of Acronyms and Abbreviations

% diff	percent difference
A/D	analog to digital converter
ARS	Air Resource Specialists, Inc.
ASTM	American Society for Testing and Materials
BLM	Bureau of Land Management
BLM-WSO	Bureau of Land Management – Wyoming State Office
CAL	Central Analytical Laboratory
CASTNET	Clean Air Status and Trends Network
CMAQ	Community Multiscale Air Quality
DAS	data acquisition system
deg	degree
DVM	digital voltmeter
ECCC	Environment and Climate Change Canada
EEMS	Environmental, Engineering & Measurement Services, Inc.
EPA	U.S. Environmental Protection Agency
ESC	Environmental Systems Corporation
FSA	Field Systems Audit
FSAD	Field Site Audit Database
GPS	geographical positioning system
HAL	Mercury Analytical Laboratory
LADCO	Lake Michigan Air Directors Consortium
lpm	liters per minute
ME DEP	Maine Department of Environmental Protection
MD DNR	Maryland Department of Natural Resources
MLM	Multilayer Model
MN PCA	Minnesota Pollution Control Agency
m/s	meters per second
mv	millivolt
NESCAUM	Northeast States for Coordinated Air Use Management
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPS	National Park Service
NYDEC	New York Department of Conservation
NYSERDA	New York State Energy Research and Development Authority
OH EPA	Ohio Environmental Protection Agency
PE	Performance Evaluation
QAPP	Quality Assurance Project Plan
SCDHEC	South Carolina Department of Health and Environmental Control
SFWMD	South Florida Water Management District
SOP	standard operating procedure
TDEP	Total Deposition
TEI	Thermo Environmental Instruments
USDA-FS	United States Department of Agriculture – Forest Service
USFS	United States Forest Service

USFWS	United States Fish and Wildlife Service
USGS	United States Geological Survey
USNO	United States Naval Observatory
VDC	volts direct current
WDEQ	Wyoming Department of Environmental Quality
WDNR	Wisconsin Department of Natural Resources
WRR	World Radiation Reference
WSLH	Wisconsin State Laboratory of Hygiene

1.0 CASTNET Quarterly Report

1.1 Introduction

The Clean Air Status and Trends Network (CASTNET) is a national air monitoring program established in 1988 by the US EPA. Nearly all CASTNET sites measures weekly concentrations of acidic gases and particles to provide accountability for EPA’s emission reduction programs. Most sites measure ground-level ozone as well as supplemental measurements such as meteorology and/or other trace gas concentrations.

Ambient concentrations are used to estimate deposition rates of the various pollutants with the objective of determining relationships between emissions, air quality, deposition, and ecological effects. In conjunction with other national monitoring networks, CASTNET data are used to determine the effectiveness of national emissions control programs and to assess temporal trends and spatial deposition patterns in atmospheric pollutants. CASTNET data are also used for long-range transport model evaluations and critical loads research.

Historically, CASTNET pollutant flux measurements have been reported as the aggregate product of weekly measured concentrations and model-estimated deposition velocities. The Multi-layer Model (MLM) was used to derive deposition velocity estimates from on-site meteorological parameters, land use types, and site characteristics. In 2011, EPA discontinued meteorological measurements at most EPA-sponsored CASTNET sites.

Currently, CASTNET pollutant flux estimates are calculated as the aggregate product of weekly measured chemical concentrations and gridded model-estimated deposition velocities. Total deposition is assessed using the NADP’s Total Deposition Hybrid Method (TDEP; EPA, 2015c; Schwede and Lear, 2014), which combines data from established ambient monitoring networks and chemical-transport models. To estimate dry deposition, ambient measurement data from CASTNET and other networks were merged with dry deposition rates and flux output from the Community Multiscale Air Quality (CMAQ) modeling system.

Since 2011 nearly all CASTNET ozone monitors have adhered to the requirements for State or Local Air Monitoring Stations (SLAMS) as specified by the EPA in 40 CFR Part 58. As such, the ozone data collected must meet the requirements in 40 CFR Part 58 Appendix A, which defines the quality assurance (QA) requirements for gaseous pollutant ambient air monitoring. The audits performed by EEMS under this contract fulfilled the requirement for annual performance evaluation audits of pollutant monitors in the network. The QA requirements can be found at:

<https://www.epa.gov/amtic/regulations-guidance-and-monitoring-plans>

Currently 87 CASTNET sites at 85 distinct locations measure ground-level ozone concentrations. Annual performance evaluation (PE), ozone audit data are submitted to the Air Quality System (AQS) database.

As of December 2021, the network is comprised of 97 active rural sampling sites across the United States and Canada, cooperatively operated by the Environmental Protection Agency (EPA), the National Park Service (NPS), Bureau of Land Management – Wyoming State Office (BLM-WSO) and several independent partners. Wood Environment and Infrastructure Solutions (Wood) is responsible for operating the EPA sponsored sites, and Air Resource Specialists, Inc. (ARS) is responsible for operating the NPS and BLM-WSO sponsored sites

1.2 Project Objectives

The objectives of this project are to establish an independent and unbiased program of performance and systems audits for all CASTNET sampling sites. Ongoing Quality Assurance (QA) programs are an essential part of any long-term monitoring network.

Performance audits verify that all reported variables are consistent with the accuracy goals as defined in the CASTNET Quality Assurance Project Plan (QAPP). The parameter specific accuracy goals are presented in Table 1.

Table 1. Performance Audit Challenge and Acceptance Criteria

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Precipitation	Response	10 manual tips	1 DAS count per tip
Precipitation	Accuracy	2 introductions of known amounts of water	$\leq \pm 10.0\%$ of input amount
Relative Humidity	Accuracy	Compared to reference instrument or standard solution	$\leq \pm 10.0\%$ RH
Solar Radiation	Accuracy	Compared to WRR traceable standard	$\leq \pm 10.0\%$ of daytime average
Surface Wetness	Response	Distilled water spray mist	Positive response
Surface Wetness	Sensitivity	1% decade resistance	N/A
Temperature	Accuracy	Comparison to 3 NIST measured baths (~ 0° C, ambient, ~ full-scale)	$\leq \pm 0.5^\circ \text{C}$
Temperature Difference	Accuracy	Comparison to station temperature sensor	$\leq \pm 0.50^\circ \text{C}$

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Shelter Temperature	Accuracy	Comparison to station temperature sensor	$\leq \pm 2.0^{\circ} \text{ C}$
Wind Direction	Orientation Accuracy	Parallel to alignment rod/crossarm, or sighted to distant point	$\leq \pm 5^{\circ}$ from degrees true
Wind Direction	Linearity	Eight cardinal points on test fixture	$\leq \pm 5^{\circ}$ mean absolute error
Wind Direction	Response Threshold	Starting torque tested with torque gauge	$< 10 \text{ g-cm}$ Climatronics; $< 20 \text{ g-cm}$ R.M. Young
Wind Speed	Accuracy	Shaft rotational speed generated and measured with certified synchronous motor	$\leq \pm 0.5 \text{ mps}$ below 5.0 mps input; $\leq \pm 5.0\%$ of input at or above 5.0 mps
Wind Speed	Starting Threshold	Starting torque tested with torque gauge	$< 0.5 \text{ g-cm}$
Mass Flow Controller	Flow Rate	Comparison with Primary Standard	$\leq \pm 5.0\%$ of designated rate
Ozone	Slope	Linear regression of multi-point test gas concentration as measured with a certified transfer standard	$0.9000 \leq m \leq 1.1000$
Ozone	Intercept		$-5.0 \text{ ppb} \leq b \leq 5.0 \text{ ppb}$
Ozone	Correlation Coefficient		$0.9950 \leq r$
Ozone	Percent Difference	Comparison with Level 2 standard concentration	$\leq \pm 15.1\%$ of test gas concentration and $\leq \pm 0.0015 \text{ ppm}$ actual difference
DAS	Accuracy	Comparison with certified standard	$\leq \pm 0.003 \text{ VDC}$

Performance audits are conducted using standards that are traceable to the National Institute of Standards and Technology (NIST), or another authoritative organization, at least annually.

Field site systems audits (FSA) are intended to provide a qualitative appraisal of the total measurement system. Site planning, organization, and operation are evaluated to ensure that good Quality Assurance/Quality Control (QA/QC) practices are being applied. At a minimum the following audit issues were addressed at each site systems audit:

- Site locations and configurations match those provided in the CASTNET QAPP.
- Meteorological instruments are in good physical and operational condition and are sited to meet EPA ambient monitoring guidelines (EPA-600/4-82-060).
- Sites are accessible, orderly, and if applicable, compliant with OSHA safety standards.
- Sampling lines are free of leaks, kinks, visible contamination, weathering, and moisture.
- Site shelters provide adequate temperature control.

- All ambient air quality instruments are functional, being operated in the appropriate range, and the zero-air supply desiccant is unsaturated.
- All instruments are in current calibration.
- Site documentation (maintenance schedules, on-site SOPs, etc.) is current and log book records are complete.
- All maintenance and on-site SOPs are performed on schedule.
- Corrective actions are documented and appropriate for required maintenance/repair activity.
- Site operators demonstrate an adequate knowledge and ability to perform required site activities, including documentation and maintenance activities.

1.3 CASTNET Sites Visited Fourth Quarter 2021

This report consists of the systems and performance, and other audit results from the CASTNET sites visited during the fourth quarter (October through December) of 2021. The site locations, sponsor, visit dates, and parameters audited, are included in Table 2.

Table 2. CASTNET Site Audit Visits

Site ID	Sponsor	Date	MET	FSA	O3 PE	SO2	CO	NOy	FLOW
CHA467	NPS	10/1/2021			1				
CAV436	NPS	10/5/2021			1				
PAL190	EPA	10/6/2021		1	1				1
DEN417	NPS	10/12/2021			1				
BVL130	EPA	10/13/2021	1	1	1	1	1	1	1
SPD111	EPA	10/15/2021			1				
ESP127	EPA	10/16/2021			1				
STK138	EPA	10/16/2021		1	1				1
OXF122	EPA	10/19/2021		1	1				1
THR422	NPS	10/19/2021		1					1
SAN189	EPA	10/20/2021		1	1				1
ALH157	EPA	10/21/2021		1	1				1
MCK131	EPA	10/22/2021		1	1				1
MCK231	EPA	10/22/2021		1	1				1

Site ID	Sponsor	Date	MET	FSA	O3 PE	SO2	CO	NOy	FLOW
ABT147	EPA	10/24/2021			1				
LAV410	NPS	11/4/2021		1	1				1
PED108	EPA	11/10/2021		1	1				1
CDR119	EPA	11/11/2021		1	1				1
PAR107	EPA	11/12/2021		1	1				1
MKG113	EPA	11/29/2021			1				
QAK172	EPA	11/30/2021		1	1				1
BFT142	EPA	12/6/2021		1	1				1
PNF126	EPA	12/7/2021			1			1	
GRS420	NPS	12/8/2021		1	1			1	1

1.4 Audit Results

The observations and results of the systems, performance, and Ozone PE audits are included in Appendix A, *CASTNET Audit Report Forms* by site, arranged by audit date. Photographs of site conditions are included within each system report where necessary. Copies of the spot reports that were sent following the audit of each site are included as Appendix B, *CASTNET Site Spot Report Forms*.

Results of the PE audits of the gaseous pollutant monitors other than ozone, were submitted immediately following the PE and are not included in this report. All TTP PE results of gaseous pollutant monitors are uploaded to AQS and are available there. All audit data and reports are available from the EPA CASTNET website: <https://java.epa.gov/castnet/reportPage.do>

2.0 NADP Quarterly Report

2.1 Introduction

The National Atmospheric Deposition Program (NADP) operates two precipitation chemistry networks and two atmospheric concentration networks. The National Trends Network (NTN) has been measuring acidic precipitation since 1978. The network currently has more than 250 sites. The precipitation event-based Atmospheric Integrated Research Monitoring Network (AIRMOn) began operation in 1992, and as of July 2019 is no longer in operation. The Mercury Deposition Network (MDN) measures total mercury in precipitation samples from approximately 90 stations. The MDN began operation in 1996 and includes sites throughout the US and Canada. The Atmospheric Mercury Network (AMNet) and the Ammonia Monitoring Network (AMoN) measure ambient concentrations of mercury and ammonia, respectively.

The NADP and other long-term monitoring networks provide critical information to the EPA regarding evaluating the effectiveness of emission reduction control programs from the power industry. The networks of the NADP are sponsored by several federal, state, and local agencies as well as private organizations.

The NADP Program Office (PO) operates and administers the two precipitation chemistry networks (NTN and MDN), two atmospheric concentration networks (AMNet and AMoN), and two analytical laboratories (CAL and HAL), from the Wisconsin State Lab of Hygiene (WSLH) at the University of Wisconsin in Madison. The network equipment depot (NED) is also located at the WSLH.

2.2 Project Objectives

The objective of this project is to perform independent and unbiased evaluations of the sites and their operation. These evaluations provide quality assurance pertaining to siting, sample collection and handling, equipment operation and maintenance, record keeping and field laboratory procedures.

More specifically, the surveys determine and report findings based on an established methodology consisting of completing a site questionnaire, testing the equipment and documenting with photographs the location, siting criteria, existing equipment, and any issues encountered that require such documentation.

2.3 NADP Sites Visited Fourth Quarter 2021

This report presents the NADP sites surveyed during the fourth quarter (October through December) of 2021. The station locations, sponsors, network, and dates of the surveys are presented in Table 3.

Table 3. NADP Site Survey Visits

Site ID	Sponsor_	Date	NTN	MDN	AMoN
AZ98	EPA / NPS	10/1/2021	1		1
AZ99	USGS	10/4/2021	1		
TX43	Texas A&M University / EPA	10/6/2021	1		1
MO46	US Fish and Wildlife Service	10/11/2021		1	
IL11	EPA	10/13/2021			1
TN04	EPA	10/15/2021			1
TN07	EPA	10/16/2021			1
IL37	EPA	10/16/2021			1
OH09	USGS / EPA	10/19/2021	1		1
NE98	EPA	10/20/2021			1
IL46	EPA	10/21/2021			1
KY03	EPA	10/22/2021			1
CT15	EPA	10/24/2021			1
CA96	NPS	11/5/2021	1		
VA24	EPA	11/10/2021		1	1
WV05	EPA	11/11/2021			1
WV18	EPA	11/12/2021			1
CA28	USDA-FS	11/16/2021	1		
MD00	MD Department of Natural Resources	11/16/2021		1	
VA00	USGS	11/17/2021	1		
WV04	USGS	11/18/2021	1		
PA56	EPA	11/29/2021			1

Site ID	Sponsor_	Date	NTN	MDN	AMoN
OK06		11/30/2021		1	
OH99		11/30/2021			1
OK04		12/1/2021		1	
OK01		12/2/2021		1	
NC06		12/6/2021	1		1
NC02		12/7/2021			1
TN01	NPS	12/8/2021			1
NC29		12/16/2021	1		
NC08		12/17/2021		1	
GA99		12/20/2021	1		

2.4 Survey Results

Site survey results are entered into a relational database. The database in turn generates Site Spot Reports which are distributed among the interested parties as soon as all the site data has been entered. Database tables with all the data collected and reviewed are then sent to the NADP Program Office and to the U.S. EPA Project Officers.

Other items gathered during the surveys (i.e., photographs, Belfort charts, etc.) are uploaded to the EPA OneDrive account where the NADP PO and the U.S. EPA POs can access them and download them as needed.

Given the volume of data generated, and the fact that data is distributed and/or is available via the internet, no survey results are included in this report.

APPENDIX A

CASTNET Audit Report Forms

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
CHA467-Martin Valvur-10/01/2021						
1	10/1/2021	DAS	Environmental Sys Corp	90611	8816	2613
2	10/1/2021	Ozone	ThermoElectron Inc	none	49i A3NAA	CM08460007
3	10/1/2021	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	CM08460051
4	10/1/2021	Zero air pump	Werther International	none	PC70/4	000665785

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

CM08460007

CHA467

Martin Valvur

10/01/2021

Ozone

none

Slope:

0.97452

Slope:

0.00000

Intercept

-0.26322

Intercept

0.00000

CorrCoff

0.99998

CorrCoff

0.00000

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00340

Intercept

0.02230

Cert Date

1/20/2021

CorrCoff

1.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.10	0.07	0.23	ppb		0.16	
primary	2	17.87	17.79	16.77	ppb		-1.02	
primary	3	38.44	38.29	36.82	ppb	-3.91		
primary	4	67.03	66.80	64.81	ppb	-3.02		
primary	5	118.22	117.83	114.70	ppb	-2.69		

Sensor Component

Audit Pressure

Condition

638 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT <100 vehicles further than 2

Condition

150 m

Status

fail

Sensor Component

ADT >100 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.1

Status

pass

Sensor Component

Span

Condition

1.019

Status

pass

Sensor Component

Zero Voltage

Condition

0.000

Status

pass

Sensor Component

Fullscale Voltage

Condition

0.9998

Status

pass

Sensor Component

Cell A Freq.

Condition

90.1 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

1.5 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.70 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

631.5 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

35.1 C

Status

pass

Sensor Component

Cell B Freq.

Condition

91.5 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

1.9 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.67 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

631.5 mmHg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>CAV436-Martin Valvur-10/05/2021</i>						
1	10/5/2021	DAS	Environmental Sys Corp	None	8864	C2602
2	10/5/2021	Ozone	ThermoElectron Inc	none	49i A3NAA	1231755663
3	10/5/2021	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	CM08460009
4	10/5/2021	Zero air pump	Werther International	none	C 70/4	000915011

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1231755663

CAV436

Martin Valvur

10/05/2021

Ozone

none

Slope:

0.98549

Slope:

0.00000

Intercept

-0.04320

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00340

Intercept

0.02230

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.12	0.09	0.21	ppb		0.12	
primary	2	16.53	16.45	16.17	ppb		-0.28	
primary	3	37.66	37.52	36.78	ppb	-1.99		
primary	4	67.59	67.35	66.18	ppb	-1.75		
primary	5	116.38	115.99	114.40	ppb	-1.38		
Sensor Component	Audit Pressure		Condition	655.4 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	150 m		Status	Fail	
Sensor Component	ADT >100 vehicles further than 5		Condition	150 m		Status	Fail	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.1		Status	pass	
Sensor Component	Span		Condition	0.992		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	93.6 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.7 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.64 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	638.6 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	37.1 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	99.9 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.8 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.63 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	638.0 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>PAL190-Martin Valvur-10/06/2021</i>						
1	10/6/2021	Computer	Dell	07056	Inspiron 15	Unknown
2	10/6/2021	DAS	Campbell	000343	CR3000	2122
3	10/6/2021	Elevation	Elevation	None	1	None
4	10/6/2021	Filter pack flow pump	Thomas	02752	107CA110	11920011905
5	10/6/2021	Flow Rate	Apex	000654	AXMC105LPMDPCV	54774
6	10/6/2021	Infrastructure	Infrastructure	none	none	none
7	10/6/2021	Modem	Digi	07175	LR54	Illegible
8	10/6/2021	Ozone	ThermoElectron Inc	000726	49i A1NAA	1105347314
9	10/6/2021	Ozone Standard	ThermoElectron Inc	000735	49i A3NAA	0726124696
10	10/6/2021	Sample Tower	Aluma Tower	missing	B	AT-7200-582
11	10/6/2021	Shelter Temperature	Campbell	none	107-L	10755-148
12	10/6/2021	Siting Criteria	Siting Criteria	None	1	None
13	10/6/2021	Temperature	RM Young	06303	41342VO	12542
14	10/6/2021	Zero air pump	Werther International	06922	C 70/4	000836217

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2122	PAL190	Martin Valvur	10/06/2021	DAS	Primary

Das Date:	10/6 /2021	Audit Date	10/6 /2021
Das Time:	11:14:00	Audit Time	11:14:00
Das Day:	279	Audit Day	279
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0002	0.0003	0.0002	0.0003

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	0.0021	0.0020	V	V	-0.0001	
7	0.1000	0.0997	0.0995	V	V	-0.0002	
7	0.3000	0.2996	0.2995	V	V	-0.0001	
7	0.5000	0.4999	0.4996	V	V	-0.0003	
7	0.7000	0.6996	0.6995	V	V	-0.0001	
7	0.9000	0.8999	0.8996	V	V	-0.0003	
7	1.0000	0.9992	0.9991	V	V	-0.0001	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	54774		PAL190	Martin Valvur	10/06/2021	Flow Rate	000654

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00850	Intercept	0.00160
Cert Date	2/10/2021	CorrCoff	0.99999

DAS 1:	DAS 2:	Cal Factor Zero	0.05
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.33%	0.33%		
		Cal Factor Full Scale	1.04
		Rotometer Reading:	3.2

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.03	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	-0.01	0.000	0.04	l/m	l/m	
primary	test pt 1	3.030	3.000	2.98	0.000	3.01	l/m	l/m	0.33%
primary	test pt 2	3.040	3.010	2.98	0.000	3.00	l/m	l/m	-0.33%
primary	test pt 3	3.040	3.010	2.98	0.000	3.00	l/m	l/m	-0.33%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	6.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	0.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	135 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347314

PAL190

Martin Valvur

10/06/2021

Ozone

000726

Slope:

0.99513

Slope:

0.00000

Intercept

-0.19568

Intercept

0.00000

CorrCoff

0.99997

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00340

Intercept

0.02230

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.32	0.29	0.51	ppb		0.22	
primary	2	14.36	14.29	13.96	ppb		-0.33	
primary	3	36.92	36.78	36.08	ppb	-1.92		
primary	4	65.46	65.23	64.39	ppb	-1.3		
primary	5	114.13	113.75	113.30	ppb	-0.4		
Sensor Component	Audit Pressure		Condition	677.8 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	True		Status	pass	
Sensor Component	ADT >100 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-1.1		Status	pass	
Sensor Component	Span		Condition	1.026		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	83.5 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.67 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	651.0 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	31.9 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	90.0 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.68 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	650.7 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	12542		PAL190	Martin Valvur	10/06/2021	Temperature	06303

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	0.99975	Intercept	-0.00824
Cert Date	2/9/2021	CorrCoff	1.00000

0.07	0.14		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.12	0.13	0.000	0.1	C	-0.04
primary	Temp Mid Range	25.02	25.03	0.000	25.0	C	-0.03
primary	Temp High Range	48.19	48.21	0.000	48.4	C	0.14

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	10755-148		PAL190	Martin Valvur	10/06/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.23	0.43		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	0.99975	Intercept	-0.00824
Cert Date	2/9/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	25.06	25.07	0.000	25.3	C	0.23
primary	Temp Mid Range	25.31	25.32	0.000	25.3	C	-0.02
primary	Temp Mid Range	25.18	25.19	0.000	25.6	C	0.43
Sensor Component	System Memo		Condition		Status	pass	

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

10/06/2021

Shelter Make	Shelter Model	Shelter Size
Shelter One	E-8109-26012-2	720 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample train is leak tested every two weeks.

2 Parameter: SitingCriteriaCom

The site is located 40 km southeast of Amarillo TX which has a population of approximately 178,000.

3 Parameter: ShelterCleanNotes

The shelter is in good condition.

4 Parameter: MetSensorComme

The meteorological tower and sensors have been removed.

5 Parameter: MetOpMaintCom

The temperature signal cable is showing signs of wear.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID PAL190 Technician Martin Valvur Site Visit Date 10/06/2021

Site Sponsor (agency)	EPA	USGS Map	Fortress Cliff
Operating Group	TX A&M University	Map Scale	
AQS #	48-381-9991	Map Date	
Meteorological Type	R.M. Young		
Air Pollutant Analyzer	Ozone	QAPP Latitude	
Deposition Measurement	dry, wet	QAPP Longitude	
Land Use	agriculture	QAPP Elevation Meters	
Terrain	Complex	QAPP Declination	
Conforms to MLM	Marginally	QAPP Declination Date	
Site Telephone		Audit Latitude	34.88061
Site Address 1		Audit Longitude	-101.664703
Site Address 2		Audit Elevation	1053
County	Randall	Audit Declination	6.6
City, State	Canyon, TX		
Zip Code	79015	Fire Extinguisher	<input checked="" type="checkbox"/> Present No inspection date
Time Zone	Central	First Aid Kit	<input checked="" type="checkbox"/>
Primary Operator		Safety Glasses	<input type="checkbox"/>
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>
Backup Operator		Security Fence	<input checked="" type="checkbox"/>
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Shelter One
		Model	E-8109-26012-2
		Shelter Size	720 cuft
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is in good condition.
Site OK	<input checked="" type="checkbox"/>	Notes	

Driving Directions From I27 take exit 99 and go east on Hungate road to the first stop sign. Turn right (south) onto Eastern which is a dirt road. At the next intersection turn left (east) on Lawrence (also dirt). Continue and follow sharp left turn onto Pullman. Continue and follow sharp right turn onto game lands. Continue through two gates and past storage building. Site will be visible on the left.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

10/06/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological tower and sensors have been removed.

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

10/06/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input type="checkbox"/>	Signs of wear
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature signal cable is showing signs of wear.

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

10/06/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 15 meters
4	Describe dry dep sample tube.		3/8 teflon by 15 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

10/06/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>										
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	<div>met tower removed</div>										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

10/06/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2014	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	Oct 2014	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	Electronic copy	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☒
- 2

Are the Site Status Report Forms being completed and current?

☒
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

10/06/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Trained on site by MACTEC during site installation

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone sample train is leak tested every two weeks.

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

10/06/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

F-02058-1500-S10-rev002

Site Visit Date	10/06/2021
------------------------	------------

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07056
DAS	Campbell	CR3000	2122	000343
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA110	11920011905	02752
Flow Rate	Apex	AXMC105LPMDPC	54774	000654
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07175
Ozone	ThermoElectron Inc	49i A1NAA	1105347314	000726
Ozone Standard	ThermoElectron Inc	49i A3NAA	0726124696	000735
Sample Tower	Aluma Tower	B	AT-7200-582	missing
Shelter Temperature	Campbell	107-L	10755-148	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	12542	06303
Zero air pump	Werther International	C 70/4	000836217	06922

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
DEN417-Martin Valvur-10/12/2021					
1 10/12/2021	DAS	Environmental Sys Corp	90600	8816	2274
2 10/12/2021	Ozone	ThermoElectron Inc	90778	49C	49C-77033-384
3 10/12/2021	Ozone Standard	ThermoElectron Inc	none	49C	49C-71310-368
4 10/12/2021	Zero air pump	Werther International	none	PC70/4	526281

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

49C-77033-384

DEN417

Martin Valvur

10/12/2021

Ozone

90778

Slope:

1.00407

Slope:

0.00000

Intercept

0.87987

Intercept

0.00000

CorrCoff

1.00000

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00340

Intercept

0.02230

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.02	0.00	0.81	ppb		0.81	
primary	2	15.10	15.03	15.98	ppb		0.95	
primary	3	35.30	35.16	36.32	ppb	3.25		
primary	4	65.73	65.50	66.57	ppb	1.62		
primary	5	110.74	110.37	111.70	ppb	1.2		
Sensor Component	Audit Pressure			Condition	687.5 mmHg		Status	pass
Sensor Component	26.6 degree unobstructed rule			Condition	True		Status	pass
Sensor Component	Tree dewline >10m or below inlet			Condition	True		Status	pass
Sensor Component	ADT <100 vehicles further than 2			Condition	130 m		Status	Fail
Sensor Component	ADT >100 vehicles further than 5			Condition	130 m		Status	Fail
Sensor Component	Sample Train			Condition	Good		Status	pass
Sensor Component	Inlet Filter Condition			Condition	Clean		Status	pass
Sensor Component	Offset			Condition	-1.0		Status	pass
Sensor Component	Span			Condition	1.008		Status	pass
Sensor Component	Zero Voltage			Condition	0.0002		Status	pass
Sensor Component	Fullscale Voltage			Condition	1.0001		Status	pass
Sensor Component	Cell A Freq.			Condition	74.8 kHz		Status	pass
Sensor Component	Cell A Noise			Condition	0.6 ppb		Status	pass
Sensor Component	Cell A Flow			Condition	0.6 lpm		Status	pass
Sensor Component	Cell A Pressure			Condition	676.3 mmHg		Status	pass
Sensor Component	Cell A Tmp.			Condition	35.3 C		Status	pass
Sensor Component	Cell B Freq.			Condition	60.2 kHz		Status	pass
Sensor Component	Cell B Noise			Condition	0.8 ppb		Status	pass
Sensor Component	Cell B Flow			Condition	0.60 lpm		Status	pass
Sensor Component	Cell B Pressure			Condition	675.8 mmHg		Status	pass
Sensor Component	System Memo			Condition			Status	pass

Site Inventory by Site Visit

Site	Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
BVL130-Korey Devins-10/13/2021						
1	10/13/2021	CO	Teledyne	000760	T300U	87
2	10/13/2021	DAS	Campbell	000332	CR3000	2111
3	10/13/2021	Elevation	Elevation	None	1	None
4	10/13/2021	Filter pack flow pump	Thomas	04860	107CAB18	060300019995
5	10/13/2021	Flow Rate	Apex	000529	AXMC105LPMDPCV	illegible
6	10/13/2021	Infrastructure	Infrastructure	none	none	none
7	10/13/2021	Met tower	Climatronics	02738	14 inch taper	none
8	10/13/2021	Modem	Digi	missing	LR54	Illegible
9	10/13/2021	Noy	Teledyne	000805	T200U	110
10	10/13/2021	Ozone	ThermoElectron Inc	000739	49i A1NAA	1105347318
11	10/13/2021	Ozone Standard	ThermoElectron Inc	000512	49i A3NAA	0922236890
12	10/13/2021	Precipitation	Texas Electronics	06334	TR-525i-HT	illegible
13	10/13/2021	Relative Humidity	Vaisala	06754	HMP50	E1140035
14	10/13/2021	Sample Tower	Aluma Tower	000182	B	unknown
15	10/13/2021	Shelter Temperature	Campbell	none	107-L	unknown
16	10/13/2021	Shield (10 meter)	RM Young	06206	Aspirated 43408	none
17	10/13/2021	Shield (2 meter)	RM Young	06166	Aspirated 43408	none
18	10/13/2021	Siting Criteria	Siting Criteria	None	1	None
19	10/13/2021	SO2	Teledyne	000787	T100U	94
20	10/13/2021	Solar Radiation	Licor	04566	LI-200	PY10653
21	10/13/2021	Solar Radiation Translator	RM Young	04340	70101-X	none
22	10/13/2021	Surface Wetness	RM Young	06151	58101	none
23	10/13/2021	Temperature	RM Young	04690	41342	6704
24	10/13/2021	Temperature2meter	RM Young	07287	41342	031778
25	10/13/2021	Wind Direction	RM Young	04666	AQ05305	61085wdr
26	10/13/2021	Wind Speed	RM Young	04666	AQ05305	61085wsp
27	10/13/2021	Zero air pump	Werther International	06926	PC70/4	000836218
28	10/13/2021	Zero air pump	Teledyne	000759	701H	576

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2111	BVL130	Korey Devins	10/13/2021	DAS	Primary

Das Date:	10/14/2021	Audit Date	10/14/2021
Das Time:	09:57:00	Audit Time	09:57:01
Das Day:	287	Audit Day	287
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0001	0.0000	0.0001

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	0.0000	0.0000	V	V	0.0000	
7	0.1000	0.0999	0.0999	V	V	0.0000	
7	0.3000	0.2998	0.2998	V	V	0.0000	
7	0.5000	0.4996	0.4997	V	V	0.0001	
7	0.7000	0.6996	0.6996	V	V	0.0000	
7	0.9000	0.8994	0.8995	V	V	0.0001	
7	1.0000	0.9993	0.9994	V	V	0.0001	

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		BVL130	Korey Devins	10/13/2021	Flow Rate	000529

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99756	Intercept	-0.00058
Cert Date	2/10/2021	CorrCoff	0.99993

DAS 1:	DAS 2:	Cal Factor Zero	0.009
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	1.02
0.89%	1.33%	Rotometer Reading:	1.4

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	-0.02	l/m	l/m	
primary	test pt 1	1.496	1.500	1.49	0.000	1.51	l/m	l/m	0.67%
primary	test pt 2	1.494	1.500	1.49	0.000	1.51	l/m	l/m	0.67%
primary	test pt 3	1.496	1.500	1.49	0.000	1.52	l/m	l/m	1.33%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Filter Distance	Condition	2.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	205 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347318

BVL130

Korey Devins

10/13/2021

Ozone

000739

Slope:

0.99738

Slope:

0.00000

Intercept

-0.60475

Intercept

0.00000

CorrCoff

1.00000

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00030

Intercept

0.30550

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.42	0.11	-0.42	ppb		-0.53	
primary	2	15.87	15.49	14.80	ppb		-0.69	
primary	3	35.13	34.67	33.99	ppb	-1.98		
primary	4	67.62	67.03	66.13	ppb	-1.35		
primary	5	111.30	110.52	109.70	ppb	-0.74		
Sensor Component	Audit Pressure		Condition	740.5 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	True		Status	pass	
Sensor Component	ADT >100 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.000		Status	pass	
Sensor Component	Span		Condition	1.008		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	89.2 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.63 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	718.4 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	36.1 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	90.8 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.3 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.72 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	719.3 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	61085wsp		BVL130	Korey Devins	10/13/2021	Wind Speed	04666

Prop or Cups SN

71566

Prop or Cups Torque

0.3

to

0.4

Prop Correction Factor

0.0512

DAS 1:

Low Range

High Range

DAS 2:

Low Range

High Range

Abs Avg Err	0.05	0.00%		
Abs Max Err	0.20	0.00%		

Use	Description:	Input Device	Input RPM	Input m/s	Out V	DAS m/s	Diff/ %Diff	Diff	WsM
	primary	none	0	0.20	0.0	0.0		-0.20	
	primary	01255	200	1.02	0.0	1.0		0.00	
	primary	01255	400	2.05	0.0	2.1		0.00	
	primary	01255	800	4.10	0.0	4.1		0.00	
	primary	01255	1200	6.14	0.0	6.1	0.00%		
	primary	01255	2400	12.29	0.0	12.3	0.00%		
	primary		4000	20.48	0.0	20.5	0.00%		
	primary		9400	48.13	0.0	48.1	0.00%		

Sensor Component

Condition

Condition

Good

Status

pass

Sensor Component

Prop or Cups Condition

Condition

Good

Status

pass

Sensor Component

Sensor Heater

Condition

N/A

Status

pass

Sensor Component

Torque

Condition

Good

Status

pass

Sensor Component

Sensor Plumb

Condition

Plumb

Status

pass

Sensor Component

50m from tree dripline

Condition

True

Status

pass

Sensor Component

obstacles >10x height above sens

Condition

True

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Wind Direction Data Form

MfgSerial Number TaSiteTechnicianSite Visit DateParameterOwner ID

RM Young61085wdrBVL130Korey Devins10/13/2021Wind Direction04666

Vane SN: N/A C. A. Align. deg. true:

VaneTorque30to407

MfgRM YoungParameterwind direction

Serial NumberNoneTfer Desc.wind direction wheel

Tfer ID01458

Slope1.00000Intercept0.00000

Cert Date1/1/2017CorrCoff1.00000

MfgUshikataParameterwind direction

Serial Number191832Tfer Desc.transit

Tfer ID01272

Slope1.00000Intercept0.00000

Cert Date2/9/2021CorrCoff1.00000

DAS 1:OrientationLinearity:DAS 2:OrientationLinearity:

Abs Avg Err7.01.8

Abs Max Err95

UseDescription	TferID	Input Raw	Linearity	Output V	Output Deg.	Difference	Change	Error
primary	01458	0	<input checked="" type="checkbox"/>	0.000	0	0	46.8	#####
primary	01458	45	<input checked="" type="checkbox"/>	0.000	44	1	43.6	-1.
primary	01458	90	<input checked="" type="checkbox"/>	0.000	88	2	44.3	#####
primary	01458	135	<input checked="" type="checkbox"/>	0.000	133	2	45.2	#####
primary	01458	180	<input checked="" type="checkbox"/>	0.000	183	3	49.7	#####
primary	01458	225	<input checked="" type="checkbox"/>	0.000	224	1	40.8	#####
primary	01458	270	<input checked="" type="checkbox"/>	0.000	269	1	45.4	#####
primary	01458	315	<input checked="" type="checkbox"/>	0.000	313	2	44.2	#####
primary	01272	7	<input type="checkbox"/>	0.000	0	7		
primary	01272	97	<input type="checkbox"/>	0.000	88	9		
primary	01272	187	<input type="checkbox"/>	0.000	183	4		
primary	01272	277	<input type="checkbox"/>	0.000	269	8		

Sensor ComponentSensor HeaterConditionN/AStatuspass

Sensor ComponentConditionConditionGoodStatuspass

Sensor ComponentSensor PlumbConditionPlumbStatuspass

Sensor ComponentMastConditionGoodStatuspass

Sensor ComponentTorqueConditionFairStatuspass

Sensor ComponentVane ConditionConditionGoodStatuspass

Sensor Component50m from tree driplineConditionTrueStatuspass

Sensor Componentobstacles >10x height above sensConditionTrueStatuspass

Sensor ComponentSystem MemoConditionSee commentsStatuspass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	6704		BVL130	Korey Devins	10/13/2021	Temperature	04690

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00743	Intercept	0.21666
Cert Date	2/18/2021	CorrCoff	1.00000

0.12	0.22		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.34	0.12	0.000	0.20	C	0.08	
primary	Temp Mid Range	29.73	29.30	0.000	29.23	C	-0.07	
primary	Temp High Range	46.10	45.54	0.000	45.32	C	-0.22	

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	031778		BVL130	Korey Devins	10/13/2021	Temperature2meter	07287

DAS 1:

DAS 2:

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err	Cert Date	CorrCoff
0.14	0.27			2/18/2021	1.00000

Mfg

Extech

Parameter

Temperature

Serial Number

H232734

Tfer Desc.

RTD

Tfer ID

01227

Slope

1.00743

Intercept

0.21666

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.34	0.12	0.000	0.20	C	0.08
primary	Temp Mid Rang	29.73	29.30	0.000	29.22	C	-0.08
primary	Temp High Rang	46.10	45.54	0.000	45.27	C	-0.27

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	E1140035		BVL130	Korey Devins	10/13/2021	Relative Humidity	06754

DAS 1:	DAS 2:	Mfg	AZ Instruments	Parameter	Relative Humidity
		Serial Number	10325189	Tfer Desc.	Psychrometer
		Tfer ID	01223		
		Slope	1.01102	Intercept	-1.94680
		Cert Date	2/9/2021	CorrCoff	1.00000

	Low Range:	High Range	Low Range:	High Range
Abs Avg Err	1.5	2.6		
Abs Max Err	2.8	2.6		

UseDesc.	Test type	Device	Input RH	GTL Raw	RH Corr.	DAS Volts	DAS %RH	Difference	
primary	RH Low Range	Psychrometer	32.8	32.2	32.8	0.000	32.6	-0.2	
primary	RH Low Range	Psychrometer	52.9	51.3	52.9	0.000	55.7	2.8	
primary	RH High Range	Psychrometer	99.1	99.1	99.1	0.000	96.5	-2.6	
Sensor Component	RH Filter		Condition	Clean		Status	pass		
Sensor Component	Shield		Condition	Clean		Status	pass		
Sensor Component	Blower		Condition	N/A		Status	pass		
Sensor Component	Blower Status Switch		Condition	N/A		Status	pass		
Sensor Component	System Memo		Condition			Status	pass		

Precipitation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Texas Electronics	illegible		BVL130	Korey Devins	10/13/2021	Precipitation	06334

DAS 1:		DAS 2:	
A Avg % Diff:	A Max % Di	A Avg %Diff	A Max % Di
1.0%	2.0%		

Mfg	PMP	Parameter	Precipitation
Serial Number	None	Tfer Desc.	250ml graduate
Tfer ID	01249		
Slope	1.00000	Intercept	0.00000
Cert Date	4/26/2013	CorrCoff	1.00000

UseDesc.	Test type	TferVolume	Iteration	TimePerTip	Eq.Ht	DAS eng	Eq.HtUnit	OSE Unit	TferUnits	PctDifference	
primary	test 1	231.5	1	10 sec	0.50	0.51	in	in	ml	2.0%	
primary	test 2	231.5	2	10 sec	0.50	0.50	in	in	ml	0.0%	

Sensor Component	Properly Sited	Condition	45 degree rule	Status	Fail
Sensor Component	Gauge Drain Screen	Condition	Installed	Status	pass
Sensor Component	Funnel Clean	Condition	Moderately clean	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Gauge Screen	Condition	Installed	Status	pass
Sensor Component	Gauge Clean	Condition	Moderately clean	Status	pass
Sensor Component	Level	Condition	Level	Status	pass
Sensor Component	Sensor Heater	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Solar Radiation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Licor	PY10653		BVL130	Korey Devins	10/13/2021	Solar Radiation	04566

Mfg	RM Young	
SN/Owner ID	none	04340
Parameter	Solar Radiation Translator	

Mfg	Eppley	Parameter	solar radiation
Serial Number	34341F3	Tfer Desc.	SR transfer sensor
Tfer ID	01245		
Slope	1.00000	Intercept	0.00000
Cert Date	2/3/2021	CorrCoff	1.00000

DAS 1:	DAS 2:		
% Diff of Avg	%Diff of Max	%Diff of Avg	%Diff of Max
4.7%	0.8%	0.0%	0.0%

UseDescription	Measure Date	MeasureTime	Tfer Raw	Tfer Corr	DAS w/m2	PctDifference	
primary	10/14/2021	00:00	0	0	0		
primary	10/14/2021	09:00	84	84	90	7.3%	
primary	10/14/2021	10:00	152	152	157	3.1%	
primary	10/14/2021	11:00	238	238	240	0.8%	
primary	10/14/2021	12:00	104	104	111	6.3%	
primary	10/14/2021	13:00	148	148	157	6.4%	
primary	10/14/2021	14:15	142	142	154	8.1%	

Sensor Component	Sensor Clean	Condition	Clean	Status	pass
Sensor Component	Sensor Level	Condition	Level	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Surface Wetness Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	none		BVL130	Korey Devins	10/13/2021	Surface Wetness	06151

Mfg	Ohmite	Parameter	surface wetness
Serial Number	296-1200	Tfer Desc.	decade box
Tfer ID	01210		
Slope	1.00000	Intercept	0.00000
Cert Date	1/4/2011	CorrCoff	1.00000

☒ Manual Test Pass

UseDescription	Test Type	Tfer kOhms	OutputSignal	DAS eng	OutputSignalEngUni	TferUnits	OutputSignalUnit
primary	dry	N/A	0.000	0.00	V	N/A	V
primary	wet	N/A	0.000	1.00	V	N/A	V
primary	Decade box off	190	0.000	0.00	V	kOhm	V
primary	Decade box on	170	0.000	1.00	V	kOhm	V

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Grid Clean	Condition	Clean	Status	pass
Sensor Component	Grid Angle	Condition	About 30 deg	Status	pass
Sensor Component	Grid Orientation	Condition	North	Status	pass
Sensor Component	Grid Condition	Condition	Good	Status	pass
Sensor Component	Grid Type	Condition	Grid without holes	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	unknown		BVL130	Korey Devins	10/13/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.32	0.59		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00743	Intercept	0.21666
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	25.70	25.30	0.000	25.9	C	0.59	
primary	Temp Mid Range	27.43	27.01	0.000	26.8	C	-0.17	
primary	Temp Mid Range	26.49	26.08	0.000	26.3	C	0.21	
Sensor Component		System Memo	Condition		Status	pass		

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition	50 m	Status	Fail
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

BVL130

Technician

Korey Devins

Site Visit Date

10/13/2021

Shelter Make	Shelter Model	Shelter Size
Ekto	8810 (s/n 2140-1)	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	Good	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Fair	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Fair	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	BVL130	Korey Devins	10/13/2021	Moisture Present	Apex	4033	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								
Wind Direction	BVL130	Korey Devins	10/13/2021	Orientation	RM Young	3188	<input type="checkbox"/>	<input type="checkbox"/>
The wind direction orientation is outside the acceptance limit of 5 degrees. This is due to a combined error from the crossarm alignment and sensor calibration.								

Field Systems Comments

1 Parameter: SiteOpsProcedures

Ozone and NCORE sample line filters are replaced, and the sample lines are leaked tested, every 2 weeks.

2 Parameter: SitingCriteriaCom

The site is located in an agricultural and atmospheric research center. There are crops within 50 meters.

3 Parameter: ShelterCleanNotes

The shelter still smells like rodent excrement. The shelter door does not completely seal and water enters during heavy rain. The water has caused damage to the floor.

4 Parameter: MetSensorComme

The tipping bucket rain gage is mounted near the meteorological tower and in violation of the 45 degree rule.

5 Parameter: MetOpMaintCom

The signal cables are showing signs of wear and previous repair.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	BVL130	Technician	Korey Devins	Site Visit Date	10/13/2021
Site Sponsor (agency)	EPA	USGS Map	Bondville		
Operating Group	ISWS	Map Scale			
AQS #	17-019-1001	Map Date			
Meteorological Type	Climatronics				
Air Pollutant Analyzer	Ozone, IMPROVE	QAPP Latitude	40.0520		
Deposition Measurement	dry, wet, Hg	QAPP Longitude	-88.3725		
Land Use	agricultural	QAPP Elevation Meters	212		
Terrain	flat	QAPP Declination	-2.1		
Conforms to MLM	Yes	QAPP Declination Date	9/16/2005		
Site Telephone	(217) 863-2602	Audit Latitude	40.052021		
Site Address 1	Bondville Road Research Station	Audit Longitude	-88.372481		
Site Address 2		Audit Elevation	213		
County	Champaign	Audit Declination	-3.3		
City, State	Seymour, IL	Present			
Zip Code	61875	Fire Extinguisher	<input checked="" type="checkbox"/>	New in 2015	
Time Zone	Central	First Aid Kit	<input checked="" type="checkbox"/>		
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input checked="" type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Step	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810 (s/n 2140-1)
		Shelter Size	640 cuft		
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter still smells like rodent excrement. The shelter door does not completely seal and water enters during heavy rain. The water has caused damage to the floor.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Champaign take I-57 south to exit 229, route CR 18. Go west on CR 18 approximately 2.5 miles and turn right (north) on CR 500E. Continue approximately 1.7 miles to the Bondville Road Research Center on the left. The site is visible in the field on the right.				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

BVL130

Technician

Korey Devins

Site Visit Date

10/13/2021

- 1 Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?
- 2 Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)
- 3 Are the tower and sensors plumb?
- 4 Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?
- 5 Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)
- 6 Is the solar radiation sensor plumb?
- 7 Is it sited to avoid shading, or any artificial or reflected light?
- 8 Is the rain gauge plumb?
- 9 Is it sited to avoid sheltering effects from buildings, trees, towers, etc?
- 10 Is the surface wetness sensor sited with the grid surface facing north?
- 11 Is it inclined approximately 30 degrees?



Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The tipping bucket rain gage is mounted near the meteorological tower and in violation of the 45 degree rule.

Site ID

BVL130

Technician

Korey Devins

Site Visit Date

10/13/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input type="checkbox"/>	Signs of wear
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The signal cables are showing signs of wear and previous repair.

Site ID

BVL130

Technician

Korey Devins

Site Visit Date

10/13/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	flow, SO2, and CO line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BVL130

Technician

Korey Devins

Site Visit Date

10/13/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>							
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>							
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only						
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>							
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>							
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>							
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>							
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>							
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded							
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>				
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
11	Tower comments?								

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID Technician Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit? ☒
- 2 Are the Site Status Report Forms being completed and current? ☒
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab? ☒
- 4 Are ozone z/s/p control charts properly completed and current? ☐ Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BVL130

Technician

Korey Devins

Site Visit Date

10/13/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Trained by previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Ozone and NCORE sample line filters are replaced, and the sample lines are leaked tested, every 2 weeks.

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID Technician Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
CO	Teledyne	T300U	87	000760
DAS	Campbell	CR3000	2111	000332
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	060300019995	04860
Flow Rate	Apex	AXMC105LPMDPC	illegible	000529
Infrastructure	Infrastructure	none	none	none
Met tower	Climatronics	14 inch taper	none	02738
Modem	Digi	LR54	Illegible	missing
Noy	Teledyne	T200U	110	000805
Ozone	ThermoElectron Inc	49i A1NAA	1105347318	000739
Ozone Standard	ThermoElectron Inc	49i A3NAA	0922236890	000512
Precipitation	Texas Electronics	TR-525i-HT	illegible	06334
Relative Humidity	Vaisala	HMP50	E1140035	06754
Sample Tower	Aluma Tower	B	unknown	000182
Shelter Temperature	Campbell	107-L	unknown	none
Shield (10 meter)	RM Young	Aspirated 43408	none	06206
Shield (2 meter)	RM Young	Aspirated 43408	none	06166
Siting Criteria	Siting Criteria	1	None	None
SO2	Teledyne	T100U	94	000787
Solar Radiation	Licor	LI-200	PY10653	04566
Solar Radiation Translator	RM Young	70101-X	none	04340
Surface Wetness	RM Young	58101	none	06151
Temperature	RM Young	41342	6704	04690
Temperature2meter	RM Young	41342	031778	07287
Wind Direction	RM Young	AQ05305	61085wdr	04666
Wind Speed	RM Young	AQ05305	61085wsp	04666
Zero air pump	Teledyne	701H	576	000759
Zero air pump	Werther International	PC70/4	000836218	06926

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
SPD111-Eric Hebert-10/15/2021					
1 10/15/2021	DAS	Campbell	000405	CR3000	2522
2 10/15/2021	Ozone	ThermoElectron Inc	000742	49i A1NAA	1105347313
3 10/15/2021	Ozone Standard	ThermoElectron Inc	000437	49i A3NAA	CM08200013
4 10/15/2021	Zero air pump	Werther International	06912	C 70/4	000829177

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347313

SPD111

Eric Hebert

10/15/2021

Ozone

000742

Slope:

1.01805

Slope:

0.00000

Intercept

0.21647

Intercept

0.00000

CorrCoff

1.00000

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00560

Intercept

0.14070

Cert Date

4/7/2021

CorrCoff

0.99990

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.24	0.09	0.32	ppb		0.23	
primary	2	18.44	17.96	18.45	ppb		0.49	
primary	3	37.73	36.89	37.91	ppb	2.73		
primary	4	68.59	67.18	68.44	ppb	1.86		
primary	5	104.14	102.07	104.20	ppb	2.07		
Sensor Component	Audit Pressure			Condition	733.0 mmHg		Status	pass
Sensor Component	26.6 degree unobstructed rule			Condition	True		Status	pass
Sensor Component	Tree dewline >10m or below inlet			Condition	True		Status	pass
Sensor Component	ADT <100 vehicles further than 2			Condition	True		Status	pass
Sensor Component	ADT >100 vehicles further than 5			Condition	265 m		Status	Fail
Sensor Component	Sample Train			Condition	Good		Status	pass
Sensor Component	Inlet Filter Condition			Condition	Clean		Status	pass
Sensor Component	Offset			Condition	0.00		Status	pass
Sensor Component	Span			Condition	1.005		Status	pass
Sensor Component	Zero Voltage			Condition	N/A		Status	pass
Sensor Component	Fullscale Voltage			Condition	N/A		Status	pass
Sensor Component	Cell A Freq.			Condition	94.5 kHz		Status	pass
Sensor Component	Cell A Noise			Condition	0.4 ppb		Status	pass
Sensor Component	Cell A Flow			Condition	0.66 lpm		Status	pass
Sensor Component	Cell A Pressure			Condition	694.1 mmHg		Status	pass
Sensor Component	Cell A Tmp.			Condition	38.4 C		Status	pass
Sensor Component	Cell B Freq.			Condition	122.5 kHz		Status	pass
Sensor Component	Cell B Noise			Condition	0.6 ppb		Status	pass
Sensor Component	Cell B Flow			Condition	0.65 lpm		Status	pass
Sensor Component	Cell B Pressure			Condition	694.3 mmHg		Status	pass
Sensor Component	System Memo			Condition			Status	pass

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
ESP127-Eric Hebert-10/16/2021					
1 10/16/2021	DAS	Campbell	000352	CR3000	2130
2 10/16/2021	Ozone	ThermoElectron Inc	000734	49i A1NAA	1105347317
3 10/16/2021	Ozone Standard	ThermoElectron Inc	000327	49i A3NAA	0622717852
4 10/16/2021	Zero air pump	Werther International	06874	C 70/4	000815256

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347317

ESP127

Eric Hebert

10/16/2021

Ozone

000734

Slope:

1.00811

Slope:

0.00000

Intercept

-0.28627

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00560

Intercept

0.14070

Cert Date

4/7/2021

CorrCoff

0.99990

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.84	0.68	0.55	ppb		-0.13	
primary	2	17.68	17.21	16.84	ppb		-0.37	
primary	3	36.46	35.64	35.63	ppb	-0.03		
primary	4	68.64	67.23	67.61	ppb	0.56		
primary	5	112.25	110.03	110.60	ppb	0.52		
Sensor Component	Audit Pressure		Condition	735.0 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	65 m		Status	Fail	
Sensor Component	ADT >100 vehicles further than 5		Condition	65 m		Status	Fail	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.30		Status	pass	
Sensor Component	Span		Condition	1.003		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	87.7 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.7 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.71 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	699.8 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	33.6 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	90.2 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.8 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.68 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	698.9 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Site Inventory by Site Visit

<i>Site</i>	<i>Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
<i>STK138-Korey Devins-10/16/2021</i>						
1	10/16/2021	Computer	Dell	07065	Inspiron 15	1Y3MC12
2	10/16/2021	DAS	Campbell	000349	CR3000	2128
3	10/16/2021	Elevation	Elevation	None	1	None
4	10/16/2021	Filter pack flow pump	Thomas	04923	107CAB18	060300019959
5	10/16/2021	Flow Rate	Apex	000461	AXMC105LPMDPCV	illegible
6	10/16/2021	Infrastructure	Infrastructure	none	none	none
7	10/16/2021	Modem	Digi	07179	LR54	unknown
8	10/16/2021	Ozone	ThermoElectron Inc	000625	49i A1NAA	1009241797
9	10/16/2021	Ozone Standard	ThermoElectron Inc	000688	49i A3NAA	1030244817
10	10/16/2021	Sample Tower	Aluma Tower	03554	A	none
11	10/16/2021	Shelter Temperature	Campbell	none	107-L	unknown
12	10/16/2021	Siting Criteria	Siting Criteria	None	1	None
13	10/16/2021	Temperature	RM Young	06407	41342VC	14040
14	10/16/2021	Zero air pump	Werther International	06915	C 70/4	000829162

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2128	STK138	Korey Devins	10/16/2021	DAS	Primary

Das Date:	10/16/2021	Audit Date	10/16/2021
Das Time:	11:45:00	Audit Time	11:45:00
Das Day:	289	Audit Day	289
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0001	0.0001	0.0001

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0001	0.0000	V	V	0.0001	
7	0.1000	0.0998	0.0998	V	V	0.0000	
7	0.3000	0.2996	0.2997	V	V	0.0001	
7	0.5000	0.4995	0.4995	V	V	0.0000	
7	0.7000	0.6994	0.6995	V	V	0.0001	
7	0.9000	0.8993	0.8993	V	V	0.0000	
7	1.0000	0.9991	0.9992	V	V	0.0001	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		STK138	Korey Devins	10/16/2021	Flow Rate	000461

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99756	Intercept	-0.00058
Cert Date	2/10/2021	CorrCoff	0.99993

DAS 1:	DAS 2:	Cal Factor Zero	-0.008
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.67%	0.67%		
		Cal Factor Full Scale	1.013
		Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	-0.01	l/m	l/m	
primary	test pt 1	1.487	1.490	1.48	0.000	1.50	l/m	l/m	0.67%
primary	test pt 2	1.485	1.490	1.48	0.000	1.50	l/m	l/m	0.67%
primary	test pt 3	1.485	1.490	1.48	0.000	1.50	l/m	l/m	0.67%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241797

STK138

Korey Devins

10/16/2021

Ozone

000625

Slope:

0.99708

Slope:

0.00000

Intercept

-0.67203

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00030

Intercept

0.30550

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.45	0.14	-0.25	ppb		-0.39	
primary	2	15.95	15.57	14.75	ppb		-0.82	
primary	3	35.15	34.69	33.71	ppb	-2.87		
primary	4	66.95	66.36	65.36	ppb	-1.52		
primary	5	110.20	109.43	108.60	ppb	-0.76		
Sensor Component	Audit Pressure		Condition	737 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	True		Status	pass	
Sensor Component	ADT >100 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.1		Status	pass	
Sensor Component	Span		Condition	1.003		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	106.1 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.64 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	706.7 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	36.4 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	99.2 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.51 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	707.3 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14040		STK138	Korey Devins	10/16/2021	Temperature	06407

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232734	Tfer Desc.	RTD
		Tfer ID	01227		
		Slope	1.00743	Intercept	0.21666
		Cert Date	2/18/2021	CorrCoff	1.00000

0.21	0.43		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.08	-0.14	0.000	0.3	C	0.43	
primary	Temp Mid Range	27.61	27.19	0.000	27.3	C	0.06	
primary	Temp High Range	45.36	44.81	0.000	44.7	C	-0.15	

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	unknown		STK138	Korey Devins	10/16/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.39	0.62		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00743	Intercept	0.21666
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	23.92	23.53	0.000	24.2	C	0.62	
primary	Temp Mid Range	24.30	23.91	0.000	24.2	C	0.25	
primary	Temp Mid Range	24.06	23.67	0.000	24.0	C	0.29	
Sensor Component	System Memo			Condition		Status	pass	

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition	20 m	Status	Fail
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

STK138

Technician

Korey Devins

Site Visit Date

10/16/2021

Shelter Make	Shelter Model	Shelter Size
Ekto	8810 (s/n 2149-21)	640 cuft

Sensor Component	Sample Tower Type	Condition	Type A	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Fair	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Fair	Status	pass
Sensor Component	Excessive mold present	Condition	Fair	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Glass bottle	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	STK138	Korey Devins	10/16/2021	Moisture Present	Apex	4031	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								

Field Systems Comments

- 1

Parameter:

SiteOpsProcedures

The ozone sample train is leak tested every 2 weeks.
- 2

Parameter:

SitingCriteriaCom

The site is located in a corn field on a cattle farm. Corn is planted within 10 meters.
- 3

Parameter:

ShelterCleanNotes

There are signs of leaks on the walls and floor rot.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Kent"/>
Operating Group	<input type="text" value="Private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="17-085-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="42.2872"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-89.9998"/>
Land Use	<input type="text" value="agricultural"/>	QAPP Elevation Meters	<input type="text" value="274"/>
Terrain	<input type="text" value="rolling"/>	QAPP Declination	<input type="text" value="1.3"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="42.287216"/>
Site Address 1	<input type="text" value="10939 E. Parker Road"/>	Audit Longitude	<input type="text" value="-89.99995"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="281"/>
County	<input type="text" value="Jo Daviess"/>	Audit Declination	<input type="text" value="-1.3"/>
City, State	<input type="text" value="Stockton, IL"/>		
Zip Code	<input type="text" value="61085"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="new in 2015"/>
Time Zone	<input type="text" value="Central"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Steps <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/> Model <input type="text" value="8810 (s/n 2149-21)"/> Shelter Size <input type="text" value="640 cuft"/>		
Shelter Clean <input type="checkbox"/>	Notes <input type="text" value="There are signs of leaks on the walls and floor rot."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From Stockton go south on 78 (Main Street) for approximately 2.5 miles. As the road turns sharply to the right, continue straight onto a dirt road. There will be a stop sign at another dirt road intersection within 100 yards. Continue through that intersection, the site will be visible in the distance on a hill-side to the left. Continue another 1.5 miles bearing to the left on dirt roads to the Evans farm. The site is past both houses in the hay field.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

STK138

Technician

Korey Devins

Site Visit Date

10/16/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	Mounted to sample tower
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

STK138

Technician

Korey Devins

Site Visit Date

10/16/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

STK138

Technician

Korey Devins

Site Visit Date

10/16/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 18 meters
4	Describe dry dep sample tube.		3/8 teflon by 18 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

STK138

Technician

Korey Devins

Site Visit Date

10/16/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>									
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>									
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only								
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>									
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>									
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>									
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>									
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded									
<input type="checkbox"/>		<input type="checkbox"/>									
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>									
10	Is the sample tower stable and grounded?										
11	Tower comments?										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

STK138

Technician

Korey Devins

Site Visit Date

10/16/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed? ☒
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed? ☐
- 3 Is the site visited regularly on the required Tuesday schedule? ☒
- 4 Are the standard CASTNET operational procedures being followed by the site operator? ☒
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation) ☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters? ☐
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters? ☒
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how? ☒

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

STK138

Technician

Korey Devins

Site Visit Date

10/16/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

STK138

Technician

Korey Devins

Site Visit Date

10/16/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	1Y3MC12	07065
DAS	Campbell	CR3000	2128	000349
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	060300019959	04923
Flow Rate	Apex	AXMC105LPMDPC	illegible	000461
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07179
Ozone	ThermoElectron Inc	49i A1NAA	1009241797	000625
Ozone Standard	ThermoElectron Inc	49i A3NAA	1030244817	000688
Sample Tower	Aluma Tower	A	none	03554
Shelter Temperature	Campbell	107-L	unknown	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VC	14040	06407
Zero air pump	Werther International	C 70/4	000829162	06915

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
OXF122-Korey Devins-10/19/2021						
1	10/19/2021	Computer	Dell	07008	Inspiron 15	694MC12
2	10/19/2021	DAS	Campbell	000425	CR3000	2528
3	10/19/2021	Elevation	Elevation	None	1	None
4	10/19/2021	Filter pack flow pump	Thomas	02660	107CAB18	Illegible
5	10/19/2021	Flow Rate	Apex	000658	AXMC105LPMDPCV	unknown
6	10/19/2021	Infrastructure	Infrastructure	none	none	none
7	10/19/2021	Modem	Digi	07163	LR54	unknown
8	10/19/2021	Ozone	ThermoElectron Inc	000610	49i A1NAA	1009241778
9	10/19/2021	Ozone Standard	ThermoElectron Inc	000545	49i A3NAA	0929938241
10	10/19/2021	Sample Tower	Aluma Tower	000018	B	AT-61152-A-H8-E
11	10/19/2021	Shelter Temperature	Campbell	none	107-L	10755-148
12	10/19/2021	Siting Criteria	Siting Criteria	None	1	None
13	10/19/2021	Temperature	RM Young	07289	41342	032128
14	10/19/2021	Zero air pump	Werther International	06908	C 70/4	000821900

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2528	OXF122	Korey Devins	10/19/2021	DAS	Primary

Das Date:	10/19/2021	Audit Date	10/19/2021
Das Time:	12:55:15	Audit Time	12:55:15
Das Day:	292	Audit Day	292
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0001	0.0000	0.0001

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0001	0.0000	V	V	0.0001	
7	0.1000	0.0998	0.0998	V	V	0.0000	
7	0.3000	0.2997	0.2997	V	V	0.0000	
7	0.5000	0.4995	0.4995	V	V	0.0000	
7	0.7000	0.6994	0.6994	V	V	0.0000	
7	0.9000	0.8993	0.8992	V	V	-0.0001	
7	1.0000	0.9991	0.9991	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	unknown		OXF122	Korey Devins	10/19/2021	Flow Rate	000658

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99756	Intercept	-0.00058
Cert Date	2/10/2021	CorrCoff	0.99993

DAS 1:	DAS 2:	Cal Factor Zero	-0.01
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.60%	0.60%		
		Cal Factor Full Scale	1.02
		Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.01	0.000	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	-0.01	0.000	-0.03	l/m	l/m	
primary	test pt 1	1.509	1.510	1.47	0.000	1.50	l/m	l/m	-0.60%
primary	test pt 2	1.507	1.510	1.47	0.000	1.50	l/m	l/m	-0.60%
primary	test pt 3	1.507	1.510	1.47	0.000	1.50	l/m	l/m	-0.60%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	45 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241778

OXF122

Korey Devins

10/19/2021

Ozone

000610

Slope:

1.01494

Slope:

0.00000

Intercept

-0.48717

Intercept

0.00000

CorrCoff

1.00000

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00030

Intercept

0.30550

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.42	0.11	-0.30	ppb		-0.41	
primary	2	15.23	14.86	14.44	ppb		-0.42	
primary	3	34.88	34.42	34.47	ppb	0.15		
primary	4	67.51	66.92	67.54	ppb	0.92		
primary	5	111.81	111.03	112.15	ppb	1		
Sensor Component	Audit Pressure		Condition	740.4 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	180 m		Status	fail	
Sensor Component	ADT >100 vehicles further than 5		Condition	180 m		Status	fail	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.4		Status	pass	
Sensor Component	Span		Condition	1.041		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	109.7 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.9 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.64 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	696.9 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	35.6 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	91.3 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.8 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.72 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	697.5 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	032128		OXF122	Korey Devins	10/19/2021	Temperature	07289

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232734	Tfer Desc.	RTD
		Tfer ID	01227		
		Slope	1.00743	Intercept	0.21666
		Cert Date	2/18/2021	CorrCoff	1.00000

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.10	0.13		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.24	0.02	0.000	0.1	C	0.04
primary	Temp Mid Range	26.62	26.21	0.000	26.1	C	-0.13
primary	Temp High Range	46.73	46.17	0.000	46.0	C	-0.13

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	10755-148		OXF122	Korey Devins	10/19/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.50	0.62		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00743	Intercept	0.21666
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	28.82	28.39	0.000	29.0	C	0.62	
primary	Temp Mid Range	26.28	25.87	0.000	26.4	C	0.55	
primary	Temp Mid Range	29.37	28.94	0.000	29.3	C	0.33	
Sensor Component	System Memo			Condition		Status	pass	

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition	25 m	Status	Fail
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

OXF122

Technician

Korey Devins

Site Visit Date

10/19/2021

Shelter Make

Ekto

Shelter Model

8810 (s/n 2107-4)

Shelter Size

640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Fair	Status	pass
Sensor Component	Excessive mold present	Condition	Fair	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

- 1

Parameter:

DasComments

The met tower is operated by the university and the temperature sensor is mounted on the sample tower in a naturally aspirated shield.
- 2

Parameter:

SitingCriteriaCom

The site is located in university agriculture research facility.
- 3

Parameter:

ShelterCleanNotes

The shelter roof has been repaired.

Site Inventory by Site Visit

Site Visit Date		Parameter	Mfg	Owner ID	Model Number	Serial Number
THR422-Martin Valvur-10/19/2021						
1	10/19/2021	Computer	Hewlett Packard	none	65606	5CB1520H68
2	10/19/2021	DAS	Environmental Sys Corp	90656	8816	2600
3	10/19/2021	Elevation	Elevation	None	1	None
4	10/19/2021	Filter pack flow pump	Thomas	none	107CAB18B	061300044081
5	10/19/2021	flow rate	Tylan	02170	FC280SAV	AW901295
6	10/19/2021	Infrastructure	Infrastructure	none	none	none
7	10/19/2021	Met tower	Rohn	none	unknown	none
8	10/19/2021	MFC power supply	Tylan	03870	RO-32	FP9508008
9	10/19/2021	Ozone	ThermoElectron Inc	E00051	49i A1NAA	1153170017
10	10/19/2021	Sample Tower	Aluma Tower	none	B	AT-81077-J5
11	10/19/2021	Shelter Temperature	ARS	none	none	none
12	10/19/2021	Siting Criteria	Siting Criteria	None	1	None
13	10/19/2021	Temperature2meter	RM Young	none	41342VC	29200
14	10/19/2021	Zero air pump	Thomas	none	107CAB18	091900065266

DAS Data Form

DAS Time Max Error: 0.37

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2600	THR422	Martin Valvur	10/19/2021	DAS	Primary

Das Date:	10/19/2021	Audit Date	10/19/2021
Das Time:	08:09:22	Audit Time	08:09:00
Das Day:	292	Audit Day	292
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0004	0.0007	0.0004	0.0007

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
9	0.0000	-0.0006	-0.0002	V	V	0.0004	
9	0.1000	0.1000	0.0998	V	V	-0.0002	
9	0.3000	0.2996	0.2998	V	V	0.0002	
9	0.5000	0.4991	0.4993	V	V	0.0002	
9	0.7000	0.6990	0.6996	V	V	0.0006	
9	0.9000	0.8993	0.8995	V	V	0.0002	
9	1.0000	0.9994	1.0001	V	V	0.0007	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW901295		THR422	Martin Valvur	10/19/2021	flow rate	02170

Mfg	Tylan	
SN/Owner ID	FP9508008	03870
Parameter:	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00850	Intercept	0.00160
Cert Date	2/10/2021	CorrCoff	0.99999

DAS 1:	DAS 2:	Cal Factor Zero	0.025
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
11.07%	11.48%		
		Cal Factor Full Scale	5.389
		Rotometer Reading:	3.25

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.03	0.0000	0.02	l/m	l/m	
primary	leak check	0.000	0.000	2.77	0.0000	3.01	l/m	l/m	
primary	test pt 1	2.730	2.710	2.77	0.0000	3.01	l/m	l/m	11.07%
primary	test pt 2	2.740	2.720	2.77	0.0000	3.01	l/m	l/m	10.66%
primary	test pt 3	2.720	2.700	2.77	0.0000	3.01	l/m	l/m	11.48%
Sensor Component	Leak Test			Condition			Status	fail	
Sensor Component	Tubing Condition			Condition	Poor		Status	Fail	
Sensor Component	Filter Position			Condition	Good		Status	pass	
Sensor Component	Rotometer Condition			Condition	Clean and dry		Status	pass	
Sensor Component	Moisture Present			Condition	No moisture present		Status	pass	
Sensor Component	Filter Distance			Condition	5.0 cm		Status	pass	
Sensor Component	Filter Depth			Condition	2.5 cm		Status	pass	
Sensor Component	Filter Azimuth			Condition	20 deg		Status	pass	
Sensor Component	System Memo			Condition	See comments		Status	pass	

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	29200		THR422	Martin Valvur	10/19/2021	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	0.99975	Intercept	-0.00824
Cert Date	2/9/2021	CorrCoff	1.00000

0.33	0.35		
------	------	--	--

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.04	0.05	0.0000	0.37C		0.32
primary	Temp Mid Range	22.40	22.41	0.0000	22.72C		0.31
primary	Temp High Rang	45.88	45.90	0.0000	46.25C		0.35

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Not properly sited	Status	Fail
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		THR422	Martin Valvur	10/19/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.56	1.28		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	0.99975	Intercept	-0.00824
Cert Date	2/9/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	24.12	24.13	0.000	23.8	C	-0.36	
primary	Temp Mid Range	22.88	22.89	0.000	22.9	C	0.05	
primary	Temp Mid Range	21.02	21.03	0.000	22.3	C	1.28	
Sensor Component	System Memo			Condition		Status	pass	

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition	300 m	Status	Fail
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition	200 m	Status	Fail

Infrastructure Data For

Site ID

THR422

Technician

Martin Valvur

Site Visit Date

10/19/2021

Shelter Make	Shelter Model	Shelter Size
Ekto	8814 (s/n 3028-1)	896 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Poor	Status	Fail
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	THR422	Martin Valvur	10/19/2021	Leak Test	Tylan	479	<input type="checkbox"/>	<input type="checkbox"/>
The dry deposition sample tubing is broken and air is not being pulled through the filter pack.								

Field Systems Comments

1 Parameter: SiteOpsProcComm

Gloves are not used to handle the filter pack. The filter bag is used as a glove.

2 Parameter: DasComments

The met tower is no longer in use.

3 Parameter: SiteOpsProcedures

The ozone sample train does not have a means to introduce test gas at the sample inlet. Results of routine zero, span, precision, and any multipoint calibration checks are maintained by the state personnel who perform the tests. The two inlet filters in the sample train are creating a large pressure drop.

4 Parameter: SitingCriteriaCom

The site is located 200 meters from an interstate rest area, and 300 meters from interstate 94. The rest area can have parked and idling vehicles for extended periods.

5 Parameter: ShelterCleanNotes

The shelter is in good condition, clean and well organized.

6 Parameter: PollAnalyzerCom

The ozone monitor is operated by the state of North Dakota.

7 Parameter: MetSensorComme

The 2-meter temperature sensor is mounted to the sample tower, which is attached to the site shelter. The sensor is 3.7 meters above ground and close to the shelter.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Oxford"/>
Operating Group	<input type="text" value="Miami University"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="39-017-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="39.5314"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-84.7231"/>
Land Use	<input type="text" value="agriculture, woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="284"/>
Terrain	<input type="text" value="gently rolling"/>	QAPP Declination	<input type="text" value="5.2"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text" value="2/23/2007"/>
Site Telephone	<input type="text" value="(513) 523-6912"/>	Audit Latitude	<input type="text" value="39.531115"/>
Site Address 1	<input type="text" value="Ecological Research Center"/>	Audit Longitude	<input type="text" value="-84.723547"/>
Site Address 2	<input type="text" value="Somerville Rd."/>	Audit Elevation	<input type="text" value="284"/>
County	<input type="text" value="Butler"/>	Audit Declination	<input type="text" value="-5.6"/>
City, State	<input type="text" value="Oxford, OH"/>		
Zip Code	<input type="text" value="45056"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="New in 2015"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Steps <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/> Model <input type="text" value="8810 (s/n 2107-4)"/> Shelter Size <input type="text" value="640 cuft"/>		
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter roof has been repaired."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		
Driving Directions	<input type="text" value="From Oxford proceed north on route 732. Just outside of town bear right onto Somerville Road. Continue approximately 1/2 mile and turn right at the sign for the Ecological Research Center. Stay on the dirt road past the buildings. The road will turn to the right along the tree line. The site is in the field on the right."/>		

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

OXF122

Technician

Korey Devins

Site Visit Date

10/19/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

OXF122

Technician

Korey Devins

Site Visit Date

10/19/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

OXF122

Technician

Korey Devins

Site Visit Date

10/19/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 15 meters
4	Describe dry dep sample tube.		3/8 teflon by 15 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

OXF122

Technician

Korey Devins

Site Visit Date

10/19/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>									
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>									
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only								
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>									
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>									
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>									
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>									
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>
Stable		Grounded									
<input type="checkbox"/>		<input type="checkbox"/>									
<input checked="" type="checkbox"/>		<input type="checkbox"/>									
10	Is the sample tower stable and grounded?										
11	Tower comments?										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The met tower is operated by the university and the temperature sensor is mounted on the sample tower in a naturally aspirated shield.

Site ID

OXF122

Technician

Korey Devins

Site Visit Date

10/19/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☒
- 2

Are the Site Status Report Forms being completed and current?

☒
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

OXF122

Technician

Korey Devins

Site Visit Date

10/19/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained onsite by previous site operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>			<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>			<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

OXF122

Technician

Korey Devins

Site Visit Date

10/19/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

OXF122

Technician

Korey Devins

Site Visit Date

10/19/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	694MC12	07008
DAS	Campbell	CR3000	2528	000425
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	Illegible	02660
Flow Rate	Apex	AXMC105LPMDPC	unknown	000658
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07163
Ozone	ThermoElectron Inc	49i A1NAA	1009241778	000610
Ozone Standard	ThermoElectron Inc	49i A3NAA	0929938241	000545
Sample Tower	Aluma Tower	B	AT-61152-A-H8-E	000018
Shelter Temperature	Campbell	107-L	10755-148	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	032128	07289
Zero air pump	Werther International	C 70/4	000821900	06908

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	THR422	Technician	Martin Valvur	Site Visit Date	10/19/2021
Site Sponsor (agency)	NPS	USGS Map	Fryburg NW		
Operating Group	NPS and state of ND	Map Scale			
AQS #	38-007-0002	Map Date			
Meteorological Type	Climatronics				
Air Pollutant Analyzer	Ozone, SO2, IMPROVE, PM2.5	QAPP Latitude	46.8947		
Deposition Measurement	dry, wet	QAPP Longitude	-103.3778		
Land Use	prairie	QAPP Elevation Meters	850		
Terrain	rolling - complex	QAPP Declination			
Conforms to MLM	Marginally	QAPP Declination Date			
Site Telephone		Audit Latitude	46.894844		
Site Address 1	Painted Canyon Visitor Center	Audit Longitude	-103.377719		
Site Address 2	Exit 32 Interstate 94	Audit Elevation	840		
County	Billings	Audit Declination	8.2		
City, State	Medora, ND				
Zip Code	58645	Fire Extinguisher	<input type="checkbox"/>	Present	
Time Zone	Mountain	First Aid Kit	<input checked="" type="checkbox"/>		
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input checked="" type="checkbox"/>		
Backup Operator		Security Fence	<input checked="" type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8814 (s/n 3028-1)
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is in good condition, clean and well organized.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Interstate 94 take exit 32 to the Painted Canyon rest area and visitor center. The site is just east of the parking lot on a gravel road.				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

THR422

Technician

Martin Valvur

Site Visit Date

10/19/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The 2-meter temperature sensor is mounted to the sample tower, which is attached to the site shelter. The sensor is 3.7 meters above ground and close to the shelter.

Site ID

THR422

Technician

Martin Valvur

Site Visit Date

10/19/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

THR422

Technician

Martin Valvur

Site Visit Date

10/19/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		3/8 teflon by 10 meters and glass manifold
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet and analyzer
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone monitor is operated by the state of North Dakota.

Site ID

THR422

Technician

Martin Valvur

Site Visit Date

10/19/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?											

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The met tower is no longer in use.

Site ID

THR422

Technician

Martin Valvur

Site Visit Date

10/19/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	Dataview	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

Dataview

2

Are the Site Status Report Forms being completed and current?

☒

Flow section only

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

THR422

Technician

Martin Valvur

Site Visit Date

10/19/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by previous site operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by current operator

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	every 2 months	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input checked="" type="checkbox"/>	every 2 months	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>		<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Not performed

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☐

Not performed

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☐

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone sample train does not have a means to introduce test gas at the sample inlet. Results of routine zero, span, precision, and any multipoint calibration checks are maintained by the state personnel who perform the tests. The two inlet filters in the sample train are creating a large pressure drop.

Site ID

THR422

Technician

Martin Valvur

Site Visit Date

10/19/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed various times
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Gloves are not used to handle the filter pack. The filter bag is used as a glove.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

THR422

Technician

Martin Valvur

Site Visit Date

10/19/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	65606	5CB1520H68	none
DAS	Environmental Sys Corp	8816	2600	90656
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18B	061300044081	none
flow rate	Tylan	FC280SAV	AW901295	02170
Infrastructure	Infrastructure	none	none	none
Met tower	Rohn	unknown	none	none
MFC power supply	Tylan	RO-32	FP9508008	03870
Ozone	ThermoElectron Inc	49i A1NAA	1153170017	E00051
Sample Tower	Aluma Tower	B	AT-81077-J5	none
Shelter Temperature	ARS	none	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342VC	29200	none
Zero air pump	Thomas	107CAB18	091900065266	none

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
<i>SAN189-Martin Valvur-10/20/2021</i>					
1 10/20/2021	Computer	Dell	07211	Latitude	2L1ZKQ2
2 10/20/2021	DAS	Campbell	000360	CR3000	2138
3 10/20/2021	Elevation	Elevation	None	1	None
4 10/20/2021	Filter pack flow pump	Thomas	06019	107CAB18	050400022576
5 10/20/2021	Flow Rate	Apex	000861	AXMC105LPMDPCV	illegible
6 10/20/2021	Infrastructure	Infrastructure	none	none	none
7 10/20/2021	Modem	Digi	07133	LR54	unknown
8 10/20/2021	Ozone	ThermoElectron Inc	000685	49i A1NAA	1030244789
9 10/20/2021	Ozone Standard	ThermoElectron Inc	000434	49i A3NAA	CM08200010
10 10/20/2021	Sample Tower	Aluma Tower	000207	B	none
11 10/20/2021	Shelter Temperature	Campbell	none	107-L	223461
12 10/20/2021	Siting Criteria	Siting Criteria	None	1	None
13 10/20/2021	Temperature	RM Young	06537	41342VC	14798
14 10/20/2021	Zero air pump	Werther International	06875	C 70/4	000814272

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2138	SAN189	Martin Valvur	10/20/2021	DAS	Primary

Das Date:	10/20/2021	Audit Date:	10/20/2021
Das Time:	09:15:00	Audit Time:	09:15:00
Das Day:	293	Audit Day:	293
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0002	0.0001	0.0002

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0005	-0.0003	V	V	0.0002	
7	0.1000	0.0995	0.0996	V	V	0.0001	
7	0.3000	0.2997	0.2997	V	V	0.0000	
7	0.5000	0.4989	0.4991	V	V	0.0002	
7	0.7000	0.6993	0.6994	V	V	0.0001	
7	0.9000	0.8991	0.8990	V	V	-0.0001	
7	1.0000	0.9997	0.9997	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		SAN189	Martin Valvur	10/20/2021	Flow Rate	000861

Mfg

BIOS

Parameter

Flow Rate

Serial Number

148613

Tfer Desc.

BIOS 220-H

Tfer ID

01421

Slope

1.00850

Intercept

0.00160

Cert Date

2/10/2021

CorrCoff

0.99999

DAS 1:	DAS 2:	Cal Factor Zero	-0.05
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.22%	0.33%		
		Cal Factor Full Scale	0.95
		Rotometer Reading:	3.65

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.06	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.05	0.000	-0.20	l/m	l/m	
primary	test pt 1	3.060	3.030	3.08	0.000	3.04	l/m	l/m	0.33%
primary	test pt 2	3.060	3.030	3.08	0.000	3.04	l/m	l/m	0.33%
primary	test pt 3	3.070	3.040	3.08	0.000	3.04	l/m	l/m	0.00%

Sensor Component

Leak Test

Condition

Status

pass

Sensor Component

Tubing Condition

Condition

Good

Status

pass

Sensor Component

Filter Position

Condition

Good

Status

pass

Sensor Component

Rotometer Condition

Condition

Clean and dry

Status

pass

Sensor Component

Moisture Present

Condition

No moisture present

Status

pass

Sensor Component

Filter Distance

Condition

4.0 cm

Status

pass

Sensor Component

Filter Depth

Condition

3.0 cm

Status

pass

Sensor Component

Filter Azimuth

Condition

270 deg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244789

SAN189

Martin Valvur

10/20/2021

Ozone

000685

Slope:

0.96856

Slope:

0.00000

Intercept

-1.07763

Intercept

0.00000

CorrCoff

1.00000

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00340

Intercept

0.02230

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.03	0.00	-1.17	ppb		-1.17	
primary	2	14.11	14.04	12.50	ppb		-1.54	
primary	3	37.37	37.23	35.02	ppb	-6.12		
primary	4	67.50	67.26	64.27	ppb	-4.55		
primary	5	116.34	115.95	111.10	ppb	-4.27		
Sensor Component	Audit Pressure		Condition	724 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	100 m		Status	Fail	
Sensor Component	ADT >100 vehicles further than 5		Condition	100 m		Status	Fail	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.000		Status	pass	
Sensor Component	Span		Condition	1.023		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	96.1 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.9 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.67 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	694.4 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	32.4 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	102 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.66 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	693.8 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14798		SAN189	Martin Valvur	10/20/2021	Temperature	06537

DAS 1:	DAS 2:	Mfg	Fluke	Parameter	Temperature
		Serial Number	3275143	Tfer Desc.	RTD
		Tfer ID	01229		
		Slope	0.99975	Intercept	-0.00824
		Cert Date	2/9/2021	CorrCoff	1.00000

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.19	0.35		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.04	0.05	0.000	0.2	C	0.15
primary	Temp Mid Range	21.53	21.54	0.000	21.6	C	0.07
primary	Temp High Range	46.99	47.01	0.000	47.4	C	0.35

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	223461		SAN189	Martin Valvur	10/20/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.28	0.65		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	0.99975	Intercept	-0.00824
Cert Date	2/9/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	22.90	22.91	0.000	23.6	C	0.65
primary	Temp Mid Range	26.96	26.98	0.000	27.0	C	-0.03
primary	Temp Mid Range	25.99	26.00	0.000	25.8	C	-0.16
Sensor Component	System Memo		Condition		Status	pass	

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition	200 m	Status	Fail
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

SAN189

Technician

Martin Valvur

Site Visit Date

10/20/2021

Shelter Make

Shelter One

Shelter Model

E8109-26012

Shelter Size

720 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	1/4 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	SAN189	Martin Valvur	10/20/2021	Accuracy	ThermoElectron	3346	<input type="checkbox"/>	<input type="checkbox"/>

Field Systems Comments

1 **Parameter:** DasComments

The met tower is not currently in use and it is somewhat unstable.

2 **Parameter:** DocumentationCo

The site operator reported that all instrument manuals are kept at the office.

3 **Parameter:** ShelterCleanNotes

The shelter is in very good condition.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Santee"/>
Operating Group	<input type="text" value="Santee Sioux Nation"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="31-107-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, SO2, NOx, CO"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="range"/>	QAPP Elevation Meters	<input type="text" value="429"/>
Terrain	<input type="text" value="rolling"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text" value="6/21/2006"/>
Site Telephone	<input type="text" value="(402) 857-2546"/>	Audit Latitude	<input type="text" value="42.829154"/>
Site Address 1	<input type="text" value="SR S54D"/>	Audit Longitude	<input type="text" value="-97.854128"/>
Site Address 2	<input type="text" value="Santee Sioux Indian Reservation"/>	Audit Elevation	<input type="text" value="434"/>
County	<input type="text" value="Knox"/>	Audit Declination	<input type="text" value="5.0"/>
City, State	<input type="text" value="Niobrara, NE"/>		
Zip Code	<input type="text" value="68760"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Time Zone	<input type="text" value="Central"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Steps <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Shelter One"/>	Model <input type="text" value="E8109-26012"/>	Shelter Size <input type="text" value="720 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is in very good condition."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		
Driving Directions	From Yankton, South Dakota go south on route 81. Turn right (south) at the intersection of route 12 and continue approximately 26 miles. Just past the casino and gas station, turn right (north) onto SR 54 toward Santee. Continue approximately 6.5 miles. The site will be visible through the farm gate on the left at the top of a hill just before reaching Santee.		

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

SAN189

Technician

Martin Valvur

Site Visit Date

10/20/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SAN189

Technician

Martin Valvur

Site Visit Date

10/20/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SAN189

Technician

Martin Valvur

Site Visit Date

10/20/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 16 meters
4	Describe dry dep sample tube.		1/4 teflon by 16 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet and analyzer
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SAN189

Technician

Martin Valvur

Site Visit Date

10/20/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>							
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>							
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input type="checkbox"/>	Temperature only						
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>							
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>							
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>							
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>							
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>							
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded							
<input type="checkbox"/>		<input checked="" type="checkbox"/>							
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>				
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
11	Tower comments?								

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The met tower is not currently in use and it is somewhat unstable.

Site ID

SAN189

Technician

Martin Valvur

Site Visit Date

10/20/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	2014	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	2014	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator reported that all instrument manuals are kept at the office.

Site ID

SAN189

Technician

Martin Valvur

Site Visit Date

10/20/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by the previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by the current operator

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>			<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>			<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>			<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SAN189

Technician

Martin Valvur

Site Visit Date

10/20/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

SAN189

Technician

Martin Valvur

Site Visit Date

10/20/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Latitude	2L1ZKQ2	07211
DAS	Campbell	CR3000	2138	000360
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	050400022576	06019
Flow Rate	Apex	AXMC105LPMDPC	illegible	000861
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07133
Ozone	ThermoElectron Inc	49i A1NAA	1030244789	000685
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200010	000434
Sample Tower	Aluma Tower	B	none	000207
Shelter Temperature	Campbell	107-L	223461	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VC	14798	06537
Zero air pump	Werther International	C 70/4	000814272	06875

Site Inventory by Site Visit

Site Visit Date		Parameter	Mfg	Owner ID	Model Number	Serial Number
ALH157-Korey Devins-10/21/2021						
1	10/21/2021	Computer	Dell	07052	Inspiron 15	DB3MC12
2	10/21/2021	DAS	Campbell	000428	CR3000	2534
3	10/21/2021	Elevation	Elevation	None	1	None
4	10/21/2021	Filter pack flow pump	Thomas	06285	107CA18	0990007057
5	10/21/2021	Flow Rate	Apex	000595	AXMC105LPMDPCV	illegible
6	10/21/2021	Infrastructure	Infrastructure	none	none	none
7	10/21/2021	Modem	Digi	07205	LR54	Illegible
8	10/21/2021	Ozone	ThermoElectron Inc	000703	49i A1NAA	1030244805
9	10/21/2021	Ozone Standard	ThermoElectron Inc	000329	49i A3NAA	0622717853
10	10/21/2021	Sample Tower	Aluma Tower	illegible	B	none
11	10/21/2021	Shelter Temperature	Campbell	none	107-L	none
12	10/21/2021	Siting Criteria	Siting Criteria	None	1	None
13	10/21/2021	Temperature	RM Young	04945	41342VC	8897
14	10/21/2021	Zero air pump	Werther International	06925	C 70/4	000836220

DAS Data Form

DAS Time Max Error: 0.02

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2534	ALH157	Korey Devins	10/21/2021	DAS	Primary

Das Date:	10/21/2021	Audit Date:	10/21/2021
Das Time:	12:30:15	Audit Time:	12:30:14
Das Day:	294	Audit Day:	294
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0002	0.0001	0.0002

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	0.0000	0.0000	V	V	0.0000	
7	0.1000	0.0998	0.0998	V	V	0.0000	
7	0.3000	0.2997	0.2996	V	V	-0.0001	
7	0.5000	0.4995	0.4994	V	V	-0.0001	
7	0.7000	0.6995	0.6993	V	V	-0.0002	
7	0.9000	0.8993	0.8991	V	V	-0.0002	
7	1.0000	0.9992	0.9990	V	V	-0.0002	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		ALH157	Korey Devins	10/21/2021	Flow Rate	000595

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99756	Intercept	-0.00058
Cert Date	2/10/2021	CorrCoff	0.99993

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.04%	0.13%		
		Cal Factor Full Scale	1
		Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.02	0.000	0.00	l/m	l/m	
primary	test pt 1	1.498	1.500	1.51	0.000	1.50	l/m	l/m	0.00%
primary	test pt 2	1.498	1.500	1.51	0.000	1.50	l/m	l/m	0.00%
primary	test pt 3	1.498	1.500	1.51	0.000	1.50	l/m	l/m	0.13%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	2.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244805

ALH157

Korey Devins

10/21/2021

Ozone

000703

Slope:

0.99079

Slope:

0.00000

Intercept

-1.30716

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00030

Intercept

0.30550

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.32	0.01	-1.09	ppb		-1.1	
primary	2	15.30	14.93	13.50	ppb		-1.43	
primary	3	34.75	34.29	32.45	ppb	-5.51		
primary	4	67.59	67.00	64.90	ppb	-3.18		
primary	5	111.94	111.16	109.00	ppb	-1.96		
Sensor Component	Audit Pressure		Condition	748 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	True		Status	pass	
Sensor Component	ADT >100 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.1		Status	pass	
Sensor Component	Span		Condition	1.007		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	100 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.4 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.73 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	720.3 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	35.5 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	97.8 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.72 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	721.2 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	8897		ALH157	Korey Devins	10/21/2021	Temperature	04945

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00743	Intercept	0.21666
Cert Date	2/18/2021	CorrCoff	1.00000

246.78	246.78		
--------	--------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary		0.00	-0.22	0.000	-247.0	C	-246.78	
Sensor Component	Shield		Condition	Moderately clean	Status	pass		
Sensor Component	Blower		Condition	N/A	Status	pass		
Sensor Component	Properly Sited		Condition	Properly sited	Status	pass		
Sensor Component	System Memo		Condition	Not tested	Status	pass		

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		ALH157	Korey Devins	10/21/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.32	0.56		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00743	Intercept	0.21666
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	28.64	28.21	0.000	28.4	C	0.22	
primary	Temp Mid Range	26.23	25.82	0.000	26.0	C	0.17	
primary	Temp Mid Range	27.65	27.23	0.000	27.8	C	0.56	
Sensor Component	System Memo			Condition		Status	pass	

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition	20 m	Status	Fail
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

ALH157

Technician

Korey Devins

Site Visit Date

10/21/2021

Shelter Make

Ekto

Shelter Model

8810 (2149-7)

Shelter Size

640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Fair	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Fair	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Fair	Status	pass
Sensor Component	Excessive mold present	Condition	Fair	Status	pass
Sensor Component	Signal Cable	Condition	Fair	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

- 1

Parameter:

SitingCriteriaCom

The site is located on a privately operated farm which rotates corn and soy bean crops.
- 2

Parameter:

ShelterCleanNotes

The shelter floor has been repaired recently. Walls have signs of leaks.
- 3

Parameter:

MetSensorComme

Temperature mounted in naturally aspirated shield on sample tower.
- 4

Parameter:

MetOpMaintCom

The temperature sensor is not functioning and reading -247 deg C. It was not audited.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	ALH157	Technician	Korey Devins	Site Visit Date	10/21/2021
Site Sponsor (agency)	EPA	USGS Map	Pocahontas		
Operating Group	private	Map Scale			
AQS #	17-119-9991	Map Date			
Meteorological Type	Climatronics				
Air Pollutant Analyzer	Ozone	QAPP Latitude	38.8690		
Deposition Measurement	dry, wet	QAPP Longitude	-89.6229		
Land Use	agricultural	QAPP Elevation Meters	164		
Terrain	flat	QAPP Declination	0.9		
Conforms to MLM	Yes	QAPP Declination Date	1/28/2004		
Site Telephone		Audit Latitude	38.869001		
Site Address 1	Fairview Road	Audit Longitude	-89.622815		
Site Address 2		Audit Elevation	164		
County	Madison	Audit Declination	-1.1		
City, State	Pocahontas, IL	Present			
Zip Code	62275	Fire Extinguisher	<input checked="" type="checkbox"/>	new in 2015	
Time Zone	Central	First Aid Kit	<input checked="" type="checkbox"/>		
Primary Operator		Safety Glasses	<input checked="" type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810 (2149-7)
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter floor has been repaired recently. Walls have signs of leaks.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From I-70 take exit 36 (Pokey Road) north to the intersection of route 140. Turn left (west) on route 140 and continue approximately 1.5 miles. Turn left (south) onto CR 5. At the first intersection turn right (west) onto Meffert road. After the road turns left 90 degrees, turn at the first farm on the left. The site is approximately 1/2 mile on the dirt road under the power lines.				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

ALH157

Technician

Korey Devins

Site Visit Date

10/21/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Temperature mounted in naturally aspirated shield on sample tower.

Site ID

ALH157

Technician

Korey Devins

Site Visit Date

10/21/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	Moderately clean
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature sensor is not functioning and reading -247 deg C. It was not audited.

Site ID

ALH157

Technician

Korey Devins

Site Visit Date

10/21/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 15 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ALH157

Technician

Korey Devins

Site Visit Date

10/21/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Temperature only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	Met tower removed										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ALH157

Technician

Korey Devins

Site Visit Date

10/21/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ALH157

Technician

Korey Devins

Site Visit Date

10/21/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Trained by previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by current operator

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>		<input type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ALH157

Technician

Korey Devins

Site Visit Date

10/21/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

ALH157

Technician

Korey Devins

Site Visit Date

10/21/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	DB3MC12	07052
DAS	Campbell	CR3000	2534	000428
DAS	Campbell	CR3000	2535	000429
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	0990007057	06285
Flow Rate	Apex	AXMC105LPMDPC	illegible	000595
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07205
Ozone	ThermoElectron Inc	49i A1NAA	1030244805	000703
Ozone Standard	ThermoElectron Inc	49i A3NAA	0622717853	000329
Sample Tower	Aluma Tower	B	none	illegible
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VC	8897	04945
Zero air pump	Werther International	C 70/4	000836220	06925

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
MCK131-Korey Devins-10/22/2021						
1	10/22/2021	Computer	Dell	07039	Inspiron 15	7M2MC12
2	10/22/2021	DAS	Campbell	000429	CR3000	2535
3	10/22/2021	Elevation	Elevation	None	1	None
4	10/22/2021	Filter pack flow pump	Thomas	00497	107CA18	118700000596
5	10/22/2021	Flow Rate	Apex	000600	AXMC105LPMDPCV	illegible
6	10/22/2021	Infrastructure	Infrastructure	none	none	none
7	10/22/2021	Modem	Digi	07177	LR54	unknown
8	10/22/2021	Ozone	ThermoElectron Inc	000613	49i A1NAA	1009241783
9	10/22/2021	Ozone Standard	ThermoElectron Inc	000453	49i A3NAA	CM08200027
10	10/22/2021	Sample Tower	Aluma Tower	03514	A	none
11	10/22/2021	Shelter Temperature	Campbell	none	107-L	none
12	10/22/2021	Siting Criteria	Siting Criteria	None	1	None
13	10/22/2021	Temperature	RM Young	07002	41342	023293
14	10/22/2021	Zero air pump	Werther International	06911	PC70/4	000829167

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2535	MCK131	Korey Devins	10/22/2021	DAS	Primary

Das Date:	10/22/2021	Audit Date	10/22/2021
Das Time:	15:03:45	Audit Time	15:03:45
Das Day:	295	Audit Day	295
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0001	0.0000	0.0001

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0001	0.0000	V	V	0.0001	
7	0.1000	0.0998	0.0998	V	V	0.0000	
7	0.3000	0.2997	0.2997	V	V	0.0000	
7	0.5000	0.4995	0.4995	V	V	0.0000	
7	0.7000	0.6994	0.6994	V	V	0.0000	
7	0.9000	0.8993	0.8993	V	V	0.0000	
7	1.0000	0.9992	0.9992	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		MCK131	Korey Devins	10/22/2021	Flow Rate	000600

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99756	Intercept	-0.00058
Cert Date	2/10/2021	CorrCoff	0.99993

DAS 1:	DAS 2:	Cal Factor Zero	-0.041
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.44%	0.66%		
		Cal Factor Full Scale	0.959
		Rotometer Reading:	1.3

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.02	0.000	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	-0.03	l/m	l/m	
primary	test pt 1	1.507	1.510	1.55	0.000	1.50	l/m	l/m	-0.66%
primary	test pt 2	1.506	1.510	1.54	0.000	1.50	l/m	l/m	-0.66%
primary	test pt 3	1.509	1.510	1.55	0.000	1.51	l/m	l/m	0.00%
Sensor Component	Leak Test	Condition		Status	pass				
Sensor Component	Tubing Condition	Condition	Good	Status	pass				
Sensor Component	Filter Position	Condition	Good	Status	pass				
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass				
Sensor Component	Moisture Present	Condition	See comments	Status	pass				
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass				
Sensor Component	Filter Depth	Condition	0.5 cm	Status	pass				
Sensor Component	Filter Azimuth	Condition	345 deg	Status	pass				
Sensor Component	System Memo	Condition		Status	pass				

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241783

MCK131

Korey Devins

10/22/2021

Ozone

000613

Slope:

0.98026

Slope:

0.00000

Intercept

-0.74366

Intercept

0.00000

CorrCoff

0.99998

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00030

Intercept

0.30550

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.44	0.13	-0.57	ppb		-0.7	
primary	2	14.93	14.56	13.33	ppb		-1.23	
primary	3	35.54	35.08	34.00	ppb	-3.13		
primary	4	68.21	67.61	65.23	ppb	-3.58		
primary	5	110.89	110.12	107.30	ppb	-2.59		
Sensor Component	Audit Pressure		Condition	736.8 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	True		Status	pass	
Sensor Component	ADT >100 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Moderately clean		Status	pass	
Sensor Component	Offset		Condition	-0.1		Status	pass	
Sensor Component	Span		Condition	1.003		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	86.9 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.8 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.68 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	724.1 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	36.6 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	95.0 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.7 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.69 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	725.0 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	023293		MCK131	Korey Devins	10/22/2021	Temperature	07002

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232734	Tfer Desc.	RTD
		Tfer ID	01227		
		Slope	1.00743	Intercept	0.21666
		Cert Date	2/18/2021	CorrCoff	1.00000

0.12	0.20		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.22	0.00	0.000	0.2	C	0.2
primary	Temp Mid Range	25.04	24.64	0.000	24.6	C	-0.09
primary	Temp High Range	46.59	46.03	0.000	46.0	C	-0.07

Sensor Component	Shield	Condition	Moderately clean	Status	Pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		MCK131	Korey Devins	10/22/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.37	0.68		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00743	Intercept	0.21666
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	25.85	25.44	0.000	25.2	C	-0.2
primary	Temp Mid Range	24.03	23.64	0.000	24.3	C	0.68
primary	Temp Mid Range	26.41	26.00	0.000	25.8	C	-0.22
Sensor Component	System Memo			Condition		Status	pass

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

MCK131

Technician

Korey Devins

Site Visit Date

10/22/2021

Shelter Make

Ekto

Shelter Model

8810

Shelter Size

640 cuft

Sensor Component	Sample Tower Type	Condition	Type A	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Fair	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	MCK131	Korey Devins	10/22/2021	Moisture Present	Apex	3991	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								

Field Systems Comments

- 1
- Parameter:

ShelterCleanNotes
- The shelter is neat and well organized.

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
MCK231-Korey Devins-10/22/2021						
1	10/22/2021	Computer	Dell	07035	Inspiron 15	3C3MC12
2	10/22/2021	DAS	Campbell	000359	CR3000	2137
3	10/22/2021	Elevation	Elevation	None	1	None
4	10/22/2021	Filter pack flow pump	Thomas	04513	107CAB18B	110000014171
5	10/22/2021	Flow Rate	Apex	000892	AXMC105LPMDPCV	illegible
6	10/22/2021	Infrastructure	Infrastructure	none	none	none
7	10/22/2021	Modem	Digi	07176	LR54	unknown
8	10/22/2021	Ozone	ThermoElectron Inc	000695	49i A1NAA	1030244801
9	10/22/2021	Ozone Standard	ThermoElectron Inc	000544	49i A3NAA	0929938242
10	10/22/2021	Shelter Temperature	Campbell	none	107-L	none
11	10/22/2021	Siting Criteria	Siting Criteria	None	1	None
12	10/22/2021	Temperature	RM Young	07003	41342	025496
13	10/22/2021	Zero air pump	Werther International	06924	C 70/4	000836205

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2137	MCK231	Korey Devins	10/22/2021	DAS	Primary

Das Date:	10/22/2021	Audit Date	10/22/2021
Das Time:	15:02:45	Audit Time	15:02:45
Das Day:	295	Audit Day	295
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0001	0.0001	0.0001

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0001	0.0000	V	V	0.0001	
7	0.1000	0.0998	0.0999	V	V	0.0001	
7	0.3000	0.2997	0.2997	V	V	0.0000	
7	0.5000	0.4995	0.4996	V	V	0.0001	
7	0.7000	0.6994	0.6995	V	V	0.0001	
7	0.9000	0.8993	0.8993	V	V	0.0000	
7	1.0000	0.9991	0.9992	V	V	0.0001	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		MCK231	Korey Devins	10/22/2021	Flow Rate	000892

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99756	Intercept	-0.00058
Cert Date	2/10/2021	CorrCoff	0.99993

DAS 1:	DAS 2:	Cal Factor Zero	0.008
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.44%	0.67%		
Cal Factor Full Scale		1	
Rotometer Reading:		1.5	

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.01	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	-0.02	0.000	-0.01	l/m	l/m	
primary	test pt 1	1.498	1.500	1.50	0.000	1.50	l/m	l/m	0.00%
primary	test pt 2	1.492	1.500	1.50	0.000	1.49	l/m	l/m	-0.67%
primary	test pt 3	1.501	1.510	1.50	0.000	1.50	l/m	l/m	-0.66%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	105 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244801

MCK231

Korey Devins

10/22/2021

Ozone

000695

Slope:

0.99682

Slope:

0.00000

Intercept

-0.20351

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00030

Intercept

0.30550

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.44	0.13	-0.25	ppb		-0.38	
primary	2	14.93	14.56	14.38	ppb		-0.18	
primary	3	35.54	35.08	35.06	ppb	-0.06		
primary	4	68.21	67.61	66.97	ppb	-0.95		
primary	5	110.89	110.12	109.60	ppb	-0.47		
Sensor Component	Audit Pressure		Condition	736.8 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	True		Status	pass	
Sensor Component	ADT >100 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Moderately clean		Status	pass	
Sensor Component	Offset		Condition	-0.1		Status	pass	
Sensor Component	Span		Condition	1.008		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	89.0 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	2.3 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.71 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	707.2 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	33.6 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	97.3 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	1.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.71 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	707.8 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	025496		MCK231	Korey Devins	10/22/2021	Temperature	07003

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232734	Tfer Desc.	RTD
		Tfer ID	01227		
		Slope	1.00743	Intercept	0.21666
		Cert Date	2/18/2021	CorrCoff	1.00000

0.22	0.27		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.22	0.00	0.000	0.3	C	0.27	
primary	Temp Mid Range	25.04	24.64	0.000	24.4	C	-0.24	
primary	Temp High Range	46.59	46.03	0.000	45.9	C	-0.15	

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		MCK231	Korey Devins	10/22/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.18	0.42		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00743	Intercept	0.21666
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.71	23.32	0.000	23.3	C	-0.03
primary	Temp Mid Range	23.34	22.95	0.000	23.1	C	0.1
primary	Temp Mid Range	22.54	22.16	0.000	22.6	C	0.42
Sensor Component	System Memo			Condition		Status	pass

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

MCK231

Technician

Korey Devins

Site Visit Date

10/22/2021

Shelter Make	Shelter Model	Shelter Size
Ekto	8810	640 cuft

Sensor Component	Sample Tower Type	Condition	Type A	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Fair	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	MCK231	Korey Devins	10/22/2021	Moisture Present	Apex	4693	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								

Field Systems Comments

1 **Parameter:** ShelterCleanNotes

The site instruments are located in the MCK131 shelter. The same site operator is servicing both sites.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID MCK131 Technician Korey Devins Site Visit Date 10/22/2021

Site Sponsor (agency)	EPA	USGS Map	Mackville
Operating Group	Private	Map Scale	
AQS #	21-229-9991	Map Date	
Meteorological Type	R.M. Young		
Air Pollutant Analyzer	Ozone	QAPP Latitude	37.7044
Deposition Measurement	dry, wet	QAPP Longitude	-85.0483
Land Use	agriculture, woodland - mixed	QAPP Elevation Meters	353
Terrain	rolling	QAPP Declination	4.25
Conforms to MLM	Marginally	QAPP Declination Date	12/28/2004
Site Telephone	(859) 262-5181	Audit Latitude	37.704678
Site Address 1	Westley Miller Road	Audit Longitude	-85.048706
Site Address 2		Audit Elevation	293
County	Washington	Audit Declination	-4.5
City, State	Harrodsburg, KY		
Zip Code	40330	Fire Extinguisher <input checked="" type="checkbox"/>	New in 2015
Time Zone	Eastern	First Aid Kit <input checked="" type="checkbox"/>	
Primary Operator		Safety Glasses <input checked="" type="checkbox"/>	
Primary Op. Phone #		Safety Hard Hat <input checked="" type="checkbox"/>	
Primary Op. E-mail		Climbing Belt <input type="checkbox"/>	
Backup Operator		Security Fence <input type="checkbox"/>	
Backup Op. Phone #		Secure Shelter <input checked="" type="checkbox"/>	
Backup Op. E-mail		Stable Entry Steps <input checked="" type="checkbox"/>	
Shelter Working Room <input checked="" type="checkbox"/>	Make Ekto	Model 8810	Shelter Size 640 cuft
Shelter Clean <input checked="" type="checkbox"/>	Notes	The shelter is neat and well organized.	
Site OK <input checked="" type="checkbox"/>	Notes		
Driving Directions	From Danville go west on 150 toward Perryville. In Perryville turn right (north) on 1920 or Battlefield Road. Continue approximately 7.3 miles to Wesley Miller Road. Turn left onto Wesley Miller Road and continue approximately 1 mile. The site is on the left through a farm gate.		

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

MCK131

Technician

Korey Devins

Site Visit Date

10/22/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK131

Technician

Korey Devins

Site Visit Date

10/22/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK131

Technician

Korey Devins

Site Visit Date

10/22/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 15 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK131

Technician

Korey Devins

Site Visit Date

10/22/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>									
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>									
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only								
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>									
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>									
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>									
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>									
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded									
<input type="checkbox"/>		<input type="checkbox"/>									
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>									
10	Is the sample tower stable and grounded?										
11	Tower comments?	Met tower removed									

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK131

Technician

Korey Devins

Site Visit Date

10/22/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	Electronic copy	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK131

Technician

Korey Devins

Site Visit Date

10/22/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Trained on-site by MACTEC technician

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK131

Technician

Korey Devins

Site Visit Date

10/22/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

MCK131

Technician

Korey Devins

Site Visit Date

10/22/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	7M2MC12	07039
DAS	Campbell	CR3000	2535	000429
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	118700000596	00497
Flow Rate	Apex	AXMC105LPMDPC	illegible	000600
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07177
Ozone	ThermoElectron Inc	49i A1NAA	1009241783	000613
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200027	000453
Sample Tower	Aluma Tower	A	none	03514
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	023293	07002
Zero air pump	Werther International	PC70/4	000829167	06911

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	MCK231	Technician	Korey Devins	Site Visit Date	10/22/2021
Site Sponsor (agency)	EPA	USGS Map	Mackville		
Operating Group	Private	Map Scale			
AQS #	21-229-9991	Map Date			
Meteorological Type	R.M. Young				
Air Pollutant Analyzer	Ozone	QAPP Latitude	37.7044		
Deposition Measurement	dry, wet	QAPP Longitude	-85.0483		
Land Use	agriculture, woodland - mixed	QAPP Elevation Meters	353		
Terrain	rolling	QAPP Declination	4.25		
Conforms to MLM	Marginally	QAPP Declination Date	12/28/2004		
Site Telephone	(859) 262-5181	Audit Latitude	37.704678		
Site Address 1	Wesley Miller Road	Audit Longitude	-85.048706		
Site Address 2		Audit Elevation	293		
County	Washington	Audit Declination	-4.5		
City, State	Harrodsburg, KY				
Zip Code	40330	Fire Extinguisher	<input checked="" type="checkbox"/>	Present	New in 2015
Time Zone	Eastern	First Aid Kit	<input checked="" type="checkbox"/>		
Primary Operator		Safety Glasses	<input checked="" type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810
		Shelter Size	640 cuft		
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The site instruments are located in the MCK131 shelter. The same site operator is servicing both sites.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Danville go west on 150 toward Perryville. In Perryville turn right (north) on 1920 or Battlefield Road. Continue approximately 7.3 miles to Wesley Miller Road. Turn left onto Wesley Miller Road and continue approximately 1 mile. The site is on the left through a farm gate.				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

MCK231

Technician

Korey Devins

Site Visit Date

10/22/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input type="checkbox"/>	Temperature facing south
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK231

Technician

Korey Devins

Site Visit Date

10/22/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK231

Technician

Korey Devins

Site Visit Date

10/22/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 15 meters
4	Describe dry dep sample tube.		3/8 teflon by 13 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK231

Technician

Korey Devins

Site Visit Date

10/22/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	Met tower removed										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK231

Technician

Korey Devins

Site Visit Date

10/22/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	Electronic copy	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1	Is the station log properly completed during every site visit?	<input checked="" type="checkbox"/>	
2	Are the Site Status Report Forms being completed and current?	<input checked="" type="checkbox"/>	
3	Are the chain-of-custody forms properly used to document sample transfer to and from lab?	<input checked="" type="checkbox"/>	
4	Are ozone z/s/p control charts properly completed and current?	<input type="checkbox"/>	Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK231

Technician

Korey Devins

Site Visit Date

10/22/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Trained on-site by MACTEC technician

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

MCK231

Technician

Korey Devins

Site Visit Date

10/22/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

MCK231

Technician

Korey Devins

Site Visit Date

10/22/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	3C3MC12	07035
DAS	Campbell	CR3000	2137	000359
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18B	110000014171	04513
Flow Rate	Apex	AXMC105LPMDPC	illegible	000892
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07176
Ozone	ThermoElectron Inc	49i A1NAA	1030244801	000695
Ozone Standard	ThermoElectron Inc	49i A3NAA	0929938242	000544
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	025496	07003
Zero air pump	Werther International	C 70/4	000836205	06924

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
ABT147-Korey Devins-10/24/2021					
1 10/24/2021	DAS	Campbell	000413	CR3000	2519
2 10/24/2021	Ozone	ThermoElectron Inc	000627	49i A1NAA	1009241772
3 10/24/2021	Ozone Standard	ThermoElectron Inc	000747	49i A3NAA	1105347330
4 10/24/2021	Zero air pump	Werther International	06930	P 70/4	000829168

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241772

ABT147

Korey Devins

10/24/2021

Ozone

000627

Slope:

0.99979

Slope:

0.00000

Intercept

-0.04868

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00030

Intercept

0.30550

Cert Date

1/20/2021

CorrCoff

1.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.55	0.24	0.27	ppb		0.03	
primary	2	15.33	14.96	14.85	ppb		-0.11	
primary	3	34.60	34.15	34.04	ppb	-0.32		
primary	4	66.82	66.23	66.19	ppb	-0.06		
primary	5	109.03	108.26	108.20	ppb	-0.06		

Sensor Component

Audit Pressure

Condition

746.5 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT <100 vehicles further than 20

Condition

True

Status

pass

Sensor Component

ADT >100 vehicles further than 50

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

0.1

Status

pass

Sensor Component

Span

Condition

1.008

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

97.9 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.6 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.71 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

720.1 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

33.6 C

Status

pass

Sensor Component

Cell B Freq.

Condition

100.4 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.8 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.67 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

720.7 mmHg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
LAV410-Martin Valvur-11/04/2021						
1	11/4/2021	Computer	Hewlett Packard	none	ProBook	Unknown
2	11/4/2021	DAS	Environmental Sys Corp	90535	8816	2026
3	11/4/2021	Elevation	Elevation	None	1	None
4	11/4/2021	Filter pack flow pump	Thomas	none	107CA18B	081700057768
5	11/4/2021	flow rate	Tylan	none	FC280SAV	AW02213004
6	11/4/2021	Infrastructure	Infrastructure	none	none	none
7	11/4/2021	Met tower	Rohn	none	unknown	none
8	11/4/2021	MFC power supply	Tylan	00042	RO-32	FP902022
9	11/4/2021	Modem	US Robotics	none	56k	unknown
10	11/4/2021	Ozone	ThermoElectron Inc	90834	49C	49C-520012-328
11	11/4/2021	Ozone Standard	ThermoElectron Inc	90567	49C	49C-59283-322
12	11/4/2021	Sample Tower	Aluma Tower	923314	B	AT-5324-F6-O
13	11/4/2021	Shelter Temperature	ARS	none	unknown	none
14	11/4/2021	Siting Criteria	Siting Criteria	None	1	None
15	11/4/2021	Temperature2meter	RM Young	none	41342VC	029458
16	11/4/2021	Zero air pump	Twin Tower Engineering	none	TT70/4E	526292

DAS Data Form

DAS Time Max Error: 1.2

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2026	LAV410	Martin Valvur	11/04/2021	DAS	Primary

Das Date:	11/4 /2021	Audit Date	11/4 /2021
Das Time:	09:02:48	Audit Time	09:04:00
Das Day:	308	Audit Day	308
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0002	0.0004	0.0002	0.0004

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
9	0.0000	-0.0004	-0.0003	V	V	0.0001	
9	0.1000	0.1003	0.1002	V	V	-0.0001	
9	0.3000	0.2998	0.2995	V	V	-0.0003	
9	0.5000	0.4997	0.4996	V	V	-0.0001	
9	0.7000	0.6999	0.7000	V	V	0.0001	
9	0.9000	0.9000	0.8996	V	V	-0.0004	
9	1.0000	0.9996	0.9995	V	V	-0.0001	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW02213004		LAV410	Martin Valvur	11/04/2021	flow rate	none

Mfg	Tylan	
SN/Owner ID	FP902022	00042
Parameter:	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00850	Intercept	0.00160
Cert Date	2/10/2021	CorrCoff	0.99999

DAS 1:	DAS 2:	Cal Factor Zero	0.474
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
4.93%	5.16%		
		Cal Factor Full Scale	10.57
		Rotometer Reading:	3.5

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.27	0.0000	0.25	l/m	l/m	
primary	leak check	0.000	0.000	-0.26	0.0000	0.25	l/m	l/m	
primary	test pt 1	2.512	2.490	2.10	0.0000	2.61	l/m	l/m	4.74%
primary	test pt 2	2.500	2.480	2.10	0.0000	2.60	l/m	l/m	4.88%
primary	test pt 3	2.506	2.480	2.10	0.0000	2.61	l/m	l/m	5.16%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	25 deg	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

49C-520012-328

LAV410

Martin Valvur

11/04/2021

Ozone

90834

Slope:

1.01500

Slope:

0.00000

Intercept

-0.86732

Intercept

0.00000

CorrCoff:

0.99991

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00340

Intercept

0.02230

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.09	-0.11	-0.14	ppb		-0.03	
primary	2	14.71	14.64	13.48	ppb		-1.16	
primary	3	36.77	36.63	35.92	ppb	-1.96		
primary	4	66.45	66.22	66.00	ppb	-0.33		
primary	5	109.49	109.12	110.30	ppb	1.08		
Sensor Component	Audit Pressure		Condition	622 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	False		Status	Fail	
Sensor Component	Tree dewline >10m or below inlet		Condition	False		Status	Fail	
Sensor Component	ADT <100 vehicles further than 20		Condition	90 m		Status	Fail	
Sensor Component	ADT >100 vehicles further than 50		Condition	09 m		Status	Fail	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.000		Status	pass	
Sensor Component	Span		Condition	1.038		Status	pass	
Sensor Component	Zero Voltage		Condition	0.0003		Status	pass	
Sensor Component	Fullscale Voltage		Condition	1.0000		Status	pass	
Sensor Component	Cell A Freq.		Condition	75.3 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.5 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.68 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	601.1 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	42.8 C		Status	Fail	
Sensor Component	Cell B Freq.		Condition	86.2 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.5 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.62 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	600.7 mmHg		Status	pass	
Sensor Component	System Memo		Condition	See comments		Status	pass	

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	029458		LAV410	Martin Valvur	11/04/2021	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	0.99975	Intercept	-0.00824
Cert Date	2/9/2021	CorrCoff	1.00000

0.61	0.71		
------	------	--	--

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	-0.01	0.00	0.0000	0.52C		0.52
primary	Temp Mid Range	24.48	24.49	0.0000	25.08C		0.59
primary	Temp High Rang	47.01	47.03	0.0000	47.74C		0.71

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		LAV410	Martin Valvur	11/04/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
1.22	1.50		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	0.99975	Intercept	-0.00824
Cert Date	2/9/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	24.96	24.97	0.000	24.0	C	-0.94
primary	Temp Mid Range	25.81	25.82	0.000	24.3	C	-1.5
primary	Temp Mid Range	25.90	25.91	0.000	24.7	C	-1.22
Sensor Component	System Memo		Condition		Status	pass	

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition	25 m	Status	Fail
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/04/2021

Shelter Make	Shelter Model	Shelter Size
		1150 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	Good	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	LAV410	Martin Valvur	11/04/2021	Accuracy	Tylan	1862	<input type="checkbox"/>	<input type="checkbox"/>
The recorded flow rate data are accurate as recorded. The flow rate is not at the target flow rate.								
Ozone	LAV410	Martin Valvur	11/04/2021	Cell A Tmp.	ThermoElectron	1344	<input type="checkbox"/>	<input type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone inlet filter is changed and the sample line conditioned every two weeks or as needed.

2 Parameter: SitingCriteriaCom

The site is located at the end of a park service facility parking lot, in a fire station. The tree line is near the building, but the prevailing wind direction is from the clearing. Tree height above the sample inlet is not twice as far away as it is high above the inlet.

3 Parameter: ShelterCleanNotes

The inside equipment is located in room within the fire station, clean, neat, and organized.

4 Parameter: PollAnalyzerCom

Trees violate the ozone sample inlet siting criteria.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID LAV410 Technician Martin Valvur Site Visit Date 11/04/2021

Site Sponsor (agency)	NPS	USGS Map	Manzanita Lake
Operating Group	NPS	Map Scale	
AQS #	06-065-1004	Map Date	
Meteorological Type	Climatronics		
Air Pollutant Analyzer	Ozone, IMPROVE	QAPP Latitude	40.5403
Deposition Measurement	dry, wet	QAPP Longitude	-121.5764
Land Use	woodland - evergreen	QAPP Elevation Meters	1756
Terrain	complex	QAPP Declination	
Conforms to MLM	Marginally	QAPP Declination Date	
Site Telephone	(530) 335-7214	Audit Latitude	40.539991
Site Address 1	38050 Hwy 36E	Audit Longitude	-121.576462
Site Address 2		Audit Elevation	1755
County	Shasta	Audit Declination	14.5
City, State	Mineral, CA		
Zip Code	96063	Fire Extinguisher <input checked="" type="checkbox"/>	Inspected August 2021
Time Zone	Pacific	First Aid Kit <input checked="" type="checkbox"/>	
Primary Operator		Safety Glasses <input type="checkbox"/>	
Primary Op. Phone #		Safety Hard Hat <input checked="" type="checkbox"/>	
Primary Op. E-mail		Climbing Belt <input type="checkbox"/>	
Backup Operator		Security Fence <input type="checkbox"/>	
Backup Op. Phone #		Secure Shelter <input checked="" type="checkbox"/>	
Backup Op. E-mail		Stable Entry Steps <input checked="" type="checkbox"/>	
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text"/>	Model <input type="text"/>	Shelter Size 1150 cuft
Shelter Clean <input checked="" type="checkbox"/>	Notes	The inside equipment is located in room within the fire station, clean, neat, and organized.	
Site OK <input checked="" type="checkbox"/>	Notes		
Driving Directions	From Redding take route 44 east for approximately 45 miles. At the park, and intersection of 44 and 89, turn right onto route 89. Turn right at the first road into the fire station and maintenance area. Take the first left, the site is behind the fire station at the end of the parking lot. One room in the fire station houses the climate controlled equipment.		

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/04/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/04/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/04/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input type="checkbox"/>	< 10 meters

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 10 meters
4	Describe dry dep sample tube.		3/8 teflon by 10 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Trees violate the ozone sample inlet siting criteria.

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/04/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>						
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>						
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only					
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>						
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>						
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>						
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>						
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>						
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded						
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>			
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
11	Tower comments?							

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/04/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	DataView2	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	July 2012	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1	Is the station log properly completed during every site visit?	<input checked="" type="checkbox"/>	
2	Are the Site Status Report Forms being completed and current?	<input checked="" type="checkbox"/>	
3	Are the chain-of-custody forms properly used to document sample transfer to and from lab?	<input checked="" type="checkbox"/>	
4	Are ozone z/s/p control charts properly completed and current?	<input type="checkbox"/>	Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/04/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Informal training provided by ARS during maintenance visits

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Not performed		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	Not performed		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Alarm values only		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Monthly		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>			<input type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>			<input type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Dataview

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone inlet filter is changed and the sample line conditioned every two weeks or as needed.

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/04/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed between 11:00 and 13:00
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, dataview
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/04/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	ProBook	Unknown	none
DAS	Environmental Sys Corp	8816	2026	90535
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18B	081700057768	none
flow rate	Tylan	FC280SAV	AW02213004	none
Infrastructure	Infrastructure	none	none	none
Met tower	Rohn	unknown	none	none
MFC power supply	Tylan	RO-32	FP902022	00042
Modem	US Robotics	56k	unknown	none
Ozone	ThermoElectron Inc	49C	49C-520012-328	90834
Ozone Standard	ThermoElectron Inc	49C	49C-59283-322	90567
Sample Tower	Aluma Tower	B	AT-5324-F6-O	923314
Shelter Temperature	ARS	unknown	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342VC	029458	none
Zero air pump	Twin Tower Engineering	TT70/4E	526292	none

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
<i>PED108-Korey Devins-11/10/2021</i>					
1 11/10/2021	Computer	Dell	07051	Inspiron 15	Unknown
2 11/10/2021	DAS	Campbell	000406	CR3000	2511
3 11/10/2021	Elevation	Elevation	None	1	None
4 11/10/2021	Filter pack flow pump	Thomas	00564	107CA18	1088003022
5 11/10/2021	Flow Rate	Apex	000527	AXMC105LPMDPCV	48100
6 11/10/2021	Infrastructure	Infrastructure	none	none	none
7 11/10/2021	Modem	Digi	07203	LR54	unknown
8 11/10/2021	Ozone	ThermoElectron Inc	000732	49i A1NAA	1105347319
9 11/10/2021	Ozone Standard	ThermoElectron Inc	000214	49i A3NAA	0622717855
10 11/10/2021	Sample Tower	Aluma Tower	000788	B	unknown
11 11/10/2021	Shelter Temperature	Campbell	none	107-L	none
12 11/10/2021	Siting Criteria	Siting Criteria	None	1	None
13 11/10/2021	Temperature	RM Young	06408	41342	14041
14 11/10/2021	Zero air pump	Werther International	06883	C 70/4	000815257

DAS Data Form

DAS Time Max Error: 0.02

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2511	PED108	Korey Devins	11/10/2021	DAS	Primary

Das Date:	11/10/2021	Audit Date	11/10/2021
Das Time:	10:53:29	Audit Time	10:53:30
Das Day:	314	Audit Day	314
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0002	0.0001	0.0002

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	0.0000	0.0000	V	V	0.0000	
7	0.1000	0.0998	0.0999	V	V	0.0001	
7	0.3000	0.2997	0.2997	V	V	0.0000	
7	0.5000	0.4995	0.4995	V	V	0.0000	
7	0.7000	0.6994	0.6993	V	V	-0.0001	
7	0.9000	0.8992	0.8991	V	V	-0.0001	
7	1.0000	0.9992	0.9990	V	V	-0.0002	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	48100		PED108	Korey Devins	11/10/2021	Flow Rate	000527

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99756	Intercept	-0.00058
Cert Date	2/10/2021	CorrCoff	0.99993

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.45%	1.35%		
		Cal Factor Full Scale	1.01
		Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	-0.02	l/m	l/m	
primary	test pt 1	1.481	1.490	1.49	0.000	1.49	l/m	l/m	0.00%
primary	test pt 2	1.481	1.480	1.49	0.000	1.50	l/m	l/m	1.35%
primary	test pt 3	1.481	1.490	1.49	0.000	1.49	l/m	l/m	0.00%
Sensor Component	Leak Test	Condition		Status	pass				
Sensor Component	Tubing Condition	Condition	Good	Status	pass				
Sensor Component	Filter Position	Condition	Good	Status	pass				
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass				
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass				
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass				
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass				
Sensor Component	Filter Azimuth	Condition	120 deg	Status	pass				
Sensor Component	System Memo	Condition		Status	pass				

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347319

PED108

Korey Devins

11/10/2021

Ozone

000732

Slope:

1.00697

Slope:

0.00000

Intercept

-0.05882

Intercept

0.00000

CorrCoff:

0.99999

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00030

Intercept

0.30550

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.46	0.15	0.26	ppb		0.11	
primary	2	15.91	15.53	15.60	ppb		0.07	
primary	3	36.23	35.77	35.74	ppb	-0.08		
primary	4	68.72	68.12	68.45	ppb	0.48		
primary	5	114.24	113.45	114.30	ppb	0.75		

Sensor Component

Audit Pressure

Condition

752.2 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT <100 vehicles further than 20

Condition

125 m

Status

Fail

Sensor Component

ADT >100 vehicles further than 50

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.1

Status

pass

Sensor Component

Span

Condition

1.031

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

92.1 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.7 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.62 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

714.2 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

33.9 C

Status

pass

Sensor Component

Cell B Freq.

Condition

111.2 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.9 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.55 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

715.1 mmHg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14041		PED108	Korey Devins	11/10/2021	Temperature	06408

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232734	Tfer Desc.	RTD
		Tfer ID	01227		
		Slope	1.00743	Intercept	0.21666
		Cert Date	2/18/2021	CorrCoff	1.00000

0.13	0.26		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.13	-0.09	0.000	0.2	C	0.26	
primary	Temp Mid Range	25.06	24.66	0.000	24.7	C	0.02	
primary	Temp High Range	46.45	45.89	0.000	45.8	C	-0.11	

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		PED108	Korey Devins	11/10/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.46	0.86		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00743	Intercept	0.21666
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	25.42	25.02	0.000	25.9	C	0.86
primary	Temp Mid Range	25.75	25.35	0.000	25.8	C	0.41
primary	Temp Mid Range	26.50	26.09	0.000	26.2	C	0.12
Sensor Component	System Memo			Condition		Status	pass

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition	125 m	Status	Fail
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

PED108

Technician

Korey Devins

Site Visit Date

11/10/2021

Shelter Make	Shelter Model	Shelter Size
Ekto	8810 (s/n 2116-13)	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Fair	Status	pass
Sensor Component	Excessive mold present	Condition	Fair	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

1 **Parameter:** SitingCriteriaCom

The site is in a clearing in an evergreen plantation in the Prince Edward-Gallion State Forest. Trees were cut within the last 11 years to increase the size of the clearing. The tree line is encroaching again and is between 25 and 35 meters from the site.

2 **Parameter:** ShelterCleanNotes

The shelter is in fair condition, clean, neat, and well organized.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID PED108 Technician Korey Devins Site Visit Date 11/10/2021

Site Sponsor (agency)	EPA	USGS Map	Green Bay
Operating Group	Private	Map Scale	
AQS #	51-147-9991	Map Date	
Meteorological Type	Climatronics		
Air Pollutant Analyzer	Ozone	QAPP Latitude	37.1653
Deposition Measurement	dry, wet	QAPP Longitude	-78.3070
Land Use	woodland - mixed	QAPP Elevation Meters	150
Terrain	rolling	QAPP Declination	-9.1
Conforms to MLM	Yes	QAPP Declination Date	2/22/2006
Site Telephone		Audit Latitude	37.165222
Site Address 1	SR 629	Audit Longitude	-78.307067
Site Address 2	Prince Edward-Gallion State Forest	Audit Elevation	149
County	Prince Edward	Audit Declination	-9.4
City, State	Burkesville, VA		
Zip Code	23922	Fire Extinguisher <input checked="" type="checkbox"/>	No inspection date
Time Zone	Eastern	First Aid Kit <input checked="" type="checkbox"/>	
Primary Operator		Safety Glasses <input type="checkbox"/>	
Primary Op. Phone #		Safety Hard Hat <input checked="" type="checkbox"/>	
Primary Op. E-mail		Climbing Belt <input checked="" type="checkbox"/>	
Backup Operator		Security Fence <input type="checkbox"/>	
Backup Op. Phone #		Secure Shelter <input checked="" type="checkbox"/>	
Backup Op. E-mail		Stable Entry Steps <input checked="" type="checkbox"/>	
Shelter Working Room <input checked="" type="checkbox"/>	Make Ekto	Model 8810 (s/n 2116-13)	Shelter Size 640 cuft
Shelter Clean <input checked="" type="checkbox"/>	Notes	The shelter is in fair condition, clean, neat, and well organized.	
Site OK <input checked="" type="checkbox"/>	Notes		

Driving Directions From Farmville travel east on 460 approximately 1 mile. Turn right (south) onto route 696 toward Twin Lakes State Park. Continue approximately 8.5 miles on 696 (do not turn at the next sign for Twin Lakes State Park near the church) into the state forest. Turn left onto route 629 and continue approximately 1.3 miles. The site is not visible from the road, and is through a gate on a gravel road to the right.

Field Systems Data Form

F-02058-1500-S3-rev002

Site IDPED108

TechnicianKorey Devins

Site Visit Date11/10/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PED108

Technician

Korey Devins

Site Visit Date

11/10/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	Moderately clean
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDPED108

TechnicianKorey Devins

Site Visit Date11/10/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 18 meters
4	Describe dry dep sample tube.		3/8 teflon by 18 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PED108

Technician

Korey Devins

Site Visit Date

11/10/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	Met tower removed										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDPED108

TechnicianKorey Devins

Site Visit Date11/10/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	July 2016	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	July 2016	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 2016	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PED108

Technician

Korey Devins

Site Visit Date

11/10/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Trained in FL in 1987 and refresher course in July 2006

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>		<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PED108

Technician

Korey Devins

Site Visit Date

11/10/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input type="checkbox"/> Unknown	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

PED108

Technician

Korey Devins

Site Visit Date

11/10/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07051
DAS	Campbell	CR3000	2511	000406
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	1088003022	00564
Flow Rate	Apex	AXMC105LPMDPC	48100	000527
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07203
Ozone	ThermoElectron Inc	49i A1NAA	1105347319	000732
Ozone Standard	ThermoElectron Inc	49i A3NAA	0622717855	000214
Sample Tower	Aluma Tower	B	unknown	000788
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	14041	06408
Zero air pump	Werther International	C 70/4	000815257	06883

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
<i>CDR119-Korey Devins-11/11/2021</i>					
1 11/11/2021	Computer	Dell	07071	Inspiron 15	Unknown
2 11/11/2021	DAS	Campbell	000633	CR3000	4935
3 11/11/2021	Elevation	Elevation	None	1	None
4 11/11/2021	Filter pack flow pump	Thomas	06027	107CAB18	060400022672
5 11/11/2021	Flow Rate	Apex	illegible	AXMC105LPMDPCV	illegible
6 11/11/2021	Infrastructure	Infrastructure	none	none	none
7 11/11/2021	Modem	Digi	07191	LR54	unknown
8 11/11/2021	Ozone	ThermoElectron Inc	000705	49i A1NAA	1030244807
9 11/11/2021	Ozone Standard	ThermoElectron Inc	000199	49i A3NAA	0607315737
10 11/11/2021	Sample Tower	Aluma Tower	928376	B	AT-51060-56
11 11/11/2021	Shelter Temperature	Campbell	none	107-L	none
12 11/11/2021	Siting Criteria	Siting Criteria	None	1	None
13 11/11/2021	Temperature	RM Young	04448	41342	4546
14 11/11/2021	Zero air pump	Werther International	06935	C 70/4	000829172

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	4935	CDR119	Korey Devins	11/11/2021	DAS	Primary

Das Date:	11/11/2021	Audit Date	11/11/2021
Das Time:	12:47:00	Audit Time	12:47:00
Das Day:	315	Audit Day	315
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0002	0.0001	0.0002

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0001	0.0000	V	V	0.0001	
7	0.1000	0.0998	0.0999	V	V	0.0001	
7	0.3000	0.2996	0.2997	V	V	0.0001	
7	0.5000	0.4995	0.4996	V	V	0.0001	
7	0.7000	0.6994	0.6996	V	V	0.0002	
7	0.9000	0.8993	0.8994	V	V	0.0001	
7	1.0000	0.9991	0.9993	V	V	0.0002	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		CDR119	Korey Devins	11/11/2021	Flow Rate	illegible

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99756	Intercept	-0.00058
Cert Date	2/10/2021	CorrCoff	0.99993

DAS 1:	DAS 2:	Cal Factor Zero	-0.015
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
1.32%	1.32%		
		Cal Factor Full Scale	0.972
		Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.01	0.000	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	-0.01	l/m	l/m	
primary	test pt 1	1.515	1.520	1.54	0.000	1.50	l/m	l/m	-1.32%
primary	test pt 2	1.512	1.520	1.54	0.000	1.50	l/m	l/m	-1.32%
primary	test pt 3	1.512	1.520	1.54	0.000	1.50	l/m	l/m	-1.32%
Sensor Component	Leak Test	Condition		Status	pass				
Sensor Component	Tubing Condition	Condition	Good	Status	pass				
Sensor Component	Filter Position	Condition	Good	Status	pass				
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass				
Sensor Component	Moisture Present	Condition	See comments	Status	pass				
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass				
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass				
Sensor Component	Filter Azimuth	Condition	200 deg	Status	pass				
Sensor Component	System Memo	Condition		Status	pass				

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244807

CDR119

Korey Devins

11/11/2021

Ozone

000705

Slope:

0.97934

Slope:

0.00000

Intercept

0.12191

Intercept

0.00000

CorrCoff:

0.99998

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00030

Intercept

0.30550

Cert Date

1/20/2021

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.34	0.03	0.54	ppb		0.51	
primary	2	15.96	15.58	15.14	ppb		-0.44	
primary	3	35.83	35.37	34.54	ppb	-2.37		
primary	4	68.56	67.96	66.60	ppb	-2.02		
primary	5	112.72	111.94	109.90	ppb	-1.84		

Sensor Component

Audit Pressure

Condition

738.1 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT <100 vehicles further than 20

Condition

31 m

Status

Fail

Sensor Component

ADT >100 vehicles further than 50

Condition

31 m

Status

Fail

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.1

Status

pass

Sensor Component

Span

Condition

1.005

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

92.8 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.4 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.48 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

718.8 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

36.2 C

Status

pass

Sensor Component

Cell B Freq.

Condition

97.8 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.6 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.50 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

719.4 mmHg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4546		CDR119	Korey Devins	11/11/2021	Temperature	04448

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232734	Tfer Desc.	RTD
		Tfer ID	01227		
		Slope	1.00743	Intercept	0.21666
		Cert Date	2/18/2021	CorrCoff	1.00000

0.25	0.33		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.30	0.08	0.000	0.4	C	0.33
primary	Temp Mid Range	27.01	26.60	0.000	26.5	C	-0.12
primary	Temp High Range	46.37	45.81	0.000	45.5	C	-0.29

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		CDR119	Korey Devins	11/11/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.26	0.36		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00743	Intercept	0.21666
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	27.55	27.13	0.000	27.3	C	0.19	
primary	Temp Mid Range	27.30	26.88	0.000	27.2	C	0.36	
primary	Temp Mid Range	28.23	27.81	0.000	28.0	C	0.22	
Sensor Component	System Memo			Condition		Status	pass	

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition	30 m	Status	Fail
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

CDR119

Technician

Korey Devins

Site Visit Date

11/11/2021

Shelter Make

Ekto

Shelter Model

8810

Shelter Size

640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Poor	Status	Fail
Sensor Component	Excessive mold present	Condition	Fair	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	CDR119	Korey Devins	11/11/2021	Moisture Present	Apex	4697	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								

Field Systems Comments

1 **Parameter:** SitingCriteriaCom

Site is in a wooded valley, within 30 meters of a lightly traveled road. Large diesel trucks use the road. Trees are taller than the sample tower and within 20 meters of the sample tower.

2 **Parameter:** ShelterCleanNotes

The shelter is in fair condition with some rot on the walls below the air conditioner.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID CDR119 Technician Korey Devins Site Visit Date 11/11/2021

Site Sponsor (agency)	EPA	USGS Map	Glenville
Operating Group	private, WV parks dept	Map Scale	
AQS #	54-021-9991	Map Date	
Meteorological Type	Climatronics		
Air Pollutant Analyzer	Ozone	QAPP Latitude	
Deposition Measurement	dry, wet	QAPP Longitude	
Land Use	woodland - mixed	QAPP Elevation Meters	
Terrain	complex	QAPP Declination	
Conforms to MLM	No	QAPP Declination Date	
Site Telephone		Audit Latitude	38.879503
Site Address 1	Cedar Creek St. Park	Audit Longitude	-80.847677
Site Address 2		Audit Elevation	240
County	Gilmer	Audit Declination	-8
City, State	Glenville, WV		
Zip Code	26351	Fire Extinguisher <input checked="" type="checkbox"/>	Inspected Oct 2015
Time Zone	Eastern	First Aid Kit <input checked="" type="checkbox"/>	
Primary Operator		Safety Glasses <input checked="" type="checkbox"/>	
Primary Op. Phone #		Safety Hard Hat <input checked="" type="checkbox"/>	
Primary Op. E-mail		Climbing Belt <input checked="" type="checkbox"/>	
Backup Operator		Security Fence <input type="checkbox"/>	
Backup Op. Phone #		Secure Shelter <input checked="" type="checkbox"/>	
Backup Op. E-mail		Stable Entry Steps <input checked="" type="checkbox"/>	
Shelter Working Room <input checked="" type="checkbox"/>	Make Ekto	Model 8810	Shelter Size 640 cuft
Shelter Clean <input checked="" type="checkbox"/>	Notes	The shelter is in fair condition with some rot on the walls below the air conditioner.	
Site OK <input checked="" type="checkbox"/>	Notes		
Driving Directions			

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

CDR119

Technician

Korey Devins

Site Visit Date

11/11/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CDR119

Technician

Korey Devins

Site Visit Date

11/11/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CDR119

Technician

Korey Devins

Site Visit Date

11/11/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	20 meters from trees

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CDR119

Technician

Korey Devins

Site Visit Date

11/11/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Temperature only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	Met tower removed										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CDR119

Technician

Korey Devins

Site Visit Date

11/11/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1	Is the station log properly completed during every site visit?	<input checked="" type="checkbox"/>	
2	Are the Site Status Report Forms being completed and current?	<input checked="" type="checkbox"/>	
3	Are the chain-of-custody forms properly used to document sample transfer to and from lab?	<input checked="" type="checkbox"/>	
4	Are ozone z/s/p control charts properly completed and current?	<input type="checkbox"/>	Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CDR119

Technician

Korey Devins

Site Visit Date

11/11/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>			<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>			<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CDR119

Technician

Korey Devins

Site Visit Date

11/11/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

F-02058-1500-S10-rev002

Site Visit Date 11/11/2021

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07071
DAS	Campbell	CR3000	4935	000633
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	060400022672	06027
Flow Rate	Apex	AXMC105LPMDPC	illegible	illegible
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07191
Ozone	ThermoElectron Inc	49i A1NAA	1030244807	000705
Ozone Standard	ThermoElectron Inc	49i A3NAA	0607315737	000199
Sample Tower	Aluma Tower	B	AT-51060-56	928376
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	4546	04448
Zero air pump	Werther International	C 70/4	000829172	06935

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>PAR107-Korey Devins-11/12/2021</i>						
1	11/12/2021	Computer	Dell	07072	Inspiron 15	Unknown
2	11/12/2021	DAS	Campbell	000333	CR3000	2112
3	11/12/2021	Elevation	Elevation	None	1	None
4	11/12/2021	Filter pack flow pump	Thomas	00859	107CA18	missing
5	11/12/2021	Flow Rate	Apex	000596	AXMC105LPMDPCV	illegible
6	11/12/2021	Infrastructure	Infrastructure	none	none	none
7	11/12/2021	Modem	Digi	07160	LR54	unknown
8	11/12/2021	Ozone	ThermoElectron Inc	000624	49i A1NAA	1009241792
9	11/12/2021	Ozone Standard	ThermoElectron Inc	000436	49i A3NAA	CM08200012
10	11/12/2021	Sample Tower	Aluma Tower	000838	B	unknown
11	11/12/2021	Shelter Temperature	Campbell	none	107-L	none
12	11/12/2021	Siting Criteria	Siting Criteria	None	1	None
13	11/12/2021	Temperature	RM Young	04316	41342VO	4013
14	11/12/2021	Zero air pump	Werther International	07291	C 120/TC	001071024

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2112	PAR107	Korey Devins	11/12/2021	DAS	Primary

Das Date:	11/12/2021	Audit Date	11/12/2021
Das Time:	11:51:30	Audit Time	11:51:30
Das Day:	316	Audit Day	316
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0001	0.0001	0.0001

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0001	0.0000	V	V	0.0001	
7	0.1000	0.0998	0.0999	V	V	0.0001	
7	0.3000	0.2996	0.2997	V	V	0.0001	
7	0.5000	0.4996	0.4996	V	V	0.0000	
7	0.7000	0.6994	0.6994	V	V	0.0000	
7	0.9000	0.8993	0.8992	V	V	-0.0001	
7	1.0000	0.9992	0.9992	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		PAR107	Korey Devins	11/12/2021	Flow Rate	000596

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99756	Intercept	-0.00058
Cert Date	2/10/2021	CorrCoff	0.99993

DAS 1:	DAS 2:	Cal Factor Zero	0.003
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.66%	0.66%		
		Cal Factor Full Scale	0.995
		Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	-0.01	0.000	-0.03	l/m	l/m	
primary	test pt 1	1.505	1.510	1.50	0.000	1.50	l/m	l/m	-0.66%
primary	test pt 2	1.504	1.510	1.50	0.000	1.50	l/m	l/m	-0.66%
primary	test pt 3	1.504	1.510	1.50	0.000	1.50	l/m	l/m	-0.66%
Sensor Component	Leak Test	Condition		Status	pass				
Sensor Component	Tubing Condition	Condition	Good	Status	pass				
Sensor Component	Filter Position	Condition	Good	Status	pass				
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass				
Sensor Component	Moisture Present	Condition	See comments	Status	pass				
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass				
Sensor Component	Filter Depth	Condition	2.5 cm	Status	pass				
Sensor Component	Filter Azimuth	Condition	120 deg	Status	pass				
Sensor Component	System Memo	Condition		Status	pass				

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241792

PAR107

Korey Devins

11/12/2021

Ozone

000624

Slope:

0.98329

Slope:

0.00000

Intercept

-0.46557

Intercept

0.00000

CorrCoff:

0.99996

CorrCoff:

0.00000

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00030

Intercept

0.30550

Cert Date

1/20/2021

CorrCoff

1.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.43	0.12	-0.21	ppb		-0.33	
primary	2	15.62	15.25	14.37	ppb		-0.88	
primary	3	34.45	34.00	33.31	ppb	-2.05		
primary	4	66.16	65.57	63.41	ppb	-3.35		
primary	5	109.12	108.35	106.35	ppb	-1.86		
Sensor Component	Audit Pressure		Condition	716 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 20		Condition	125 m		Status	Fail	
Sensor Component	ADT >100 vehicles further than 50		Condition	363 m		Status	Fail	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.1		Status	pass	
Sensor Component	Span		Condition	1.006		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	Pass	
Sensor Component	Cell A Freq.		Condition	102.3 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.71 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	684.6 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	32.7 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	103.9 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.9 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.72 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	685.2 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4013		PAR107	Korey Devins	11/12/2021	Temperature	04316

Mfg

Extech

Parameter

Temperature

Serial Number

H232734

Tfer Desc.

RTD

Tfer ID

01227

Slope

1.00743

Intercept

0.21666

Cert Date

2/18/2021

CorrCoff

1.00000

DAS 1:

DAS 2:

Abs Avg Err

Abs Max Err

Abs Avg Err

Abs Max Err

0.08

0.10

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.15	-0.07	0.000	0.0	C	0.09	
primary	Temp Mid Range	26.70	26.29	0.000	26.2	C	-0.1	
primary	Temp High Range	47.26	46.70	0.000	46.8	C	0.06	

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		PAR107	Korey Devins	11/12/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.46	0.86		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00743	Intercept	0.21666
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	20.02	19.66	0.000	20.5	C	0.86	
primary	Temp Mid Range	21.26	20.89	0.000	21.0	C	0.1	
primary	Temp Mid Range	24.30	23.91	0.000	24.3	C	0.41	
Sensor Component	System Memo			Condition		Status	pass	

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition	2.5 km	Status	Fail
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition	125 m	Status	Fail
Sensor Component	Secondary road >100 vehicles/da	Condition	363 m	Status	Fail
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

PAR107

Technician

Korey Devins

Site Visit Date

11/12/2021

Shelter Make

Ekto

Shelter Model

8810

Shelter Size

640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
-----------	------	------------	-----------	-----------	-----	------------	--------	---------

Flow Rate	PAR107	Korey Devins	11/12/2021	Moisture Present	Apex	4010	<input type="checkbox"/>	<input type="checkbox"/>
-----------	--------	--------------	------------	------------------	------	------	--------------------------	--------------------------

The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

- 1

Parameter:

SitingCriteriaCom

The city of Parsons, estimated population 1500, is within 5 km of the site.
- 2

Parameter:

ShelterCleanNotes

The shelter is in good condition, clean, neat, and well organized.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA/USFS"/>	USGS Map	<input type="text" value="Parsons"/>
Operating Group	<input type="text" value="USFS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="54-093-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="39.090434"/>
Site Address 1	<input type="text" value="USFS Timber & Watershed Lab"/>	Audit Longitude	<input type="text" value="-79.661742"/>
Site Address 2	<input type="text" value="Rt. 219, Nursery Bottom"/>	Audit Elevation	<input type="text" value="510"/>
County	<input type="text" value="Parsons"/>	Audit Declination	<input type="text" value="-9"/>
City, State	<input type="text" value="Parsons, WV"/>		
Zip Code	<input type="text" value="26287"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected July 2018"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Steps <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/> Model <input type="text" value="8810"/> Shelter Size <input type="text" value="640 cuft"/>		
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is in good condition, clean, neat, and well organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		
Driving Directions	<input type="text" value="Take highway 33W to Elkins WV. Turn onto 19N to Parsons. Continue through town to the Nursery Bottom Reservoir. The site entrance is on the right next to the visitors center."/>		

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

PAR107

Technician

Korey Devins

Site Visit Date

11/12/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAR107

Technician

Korey Devins

Site Visit Date

11/12/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAR107

Technician

Korey Devins

Site Visit Date

11/12/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAR107

Technician

Korey Devins

Site Visit Date

11/12/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?		Met tower removed									

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAR107

Technician

Korey Devins

Site Visit Date

11/12/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	March 2015	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1	Is the station log properly completed during every site visit?	<input checked="" type="checkbox"/>	Minimal information
2	Are the Site Status Report Forms being completed and current?	<input checked="" type="checkbox"/>	
3	Are the chain-of-custody forms properly used to document sample transfer to and from lab?	<input checked="" type="checkbox"/>	
4	Are ozone z/s/p control charts properly completed and current?	<input type="checkbox"/>	Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAR107

Technician

Korey Devins

Site Visit Date

11/12/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	As needed		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Call-in only

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAR107

Technician

Korey Devins

Site Visit Date

11/12/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings 90%
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

PAR107

Technician

Korey Devins

Site Visit Date

11/12/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07072
DAS	Campbell	CR3000	2112	000333
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	missing	00859
Flow Rate	Apex	AXMC105LPMDPC	illegible	000596
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07160
Ozone	ThermoElectron Inc	49i A1NAA	1009241792	000624
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200012	000436
Sample Tower	Aluma Tower	B	unknown	000838
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	4013	04316
Zero air pump	Werther International	C 120/TC	001071024	07291

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
MKG113-Eric Hebert-11/29/2021						
1	11/29/2021	DAS	Campbell	000404	CR3000	2521
2	11/29/2021	Ozone	ThermoElectron Inc	000702	49i A1NAA	1030244799
3	11/29/2021	Ozone Standard	ThermoElectron Inc	000370	49i A3NAA	0726124689
4	11/29/2021	Zero air pump	Werther International	06899	C 70/4	000821902

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244799

MKG113

Eric Hebert

11/29/2021

Ozone

000702

Slope:

1.01421

Slope:

0.00000

Intercept

0.19975

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00560

Intercept

0.14070

Cert Date

4/7/2021

CorrCoff

0.99990

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.33	0.18	0.47	ppb		0.29	
primary	2	17.52	17.05	17.54	ppb		0.49	
primary	3	36.64	35.82	36.44	ppb	1.72		
primary	4	67.41	66.02	66.98	ppb	1.44		
primary	5	109.81	107.64	109.50	ppb	1.71		

Sensor Component

Audit Pressure

Condition

725.3 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT <100 vehicles further than 20

Condition

112 m

Status

Fail

Sensor Component

ADT >100 vehicles further than 50

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.10

Status

pass

Sensor Component

Span

Condition

1.013

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

93.2 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

1.5 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.69 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

691.3 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

34.6 C

Status

pass

Sensor Component

Cell B Freq.

Condition

90.2 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

1.3 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.69 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

691.9 mmHg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
<i>QAK172-Eric Hebert-11/30/2021</i>					
1 11/30/2021	Computer	Dell	07066	Inspiron 15	Unknown
2 11/30/2021	DAS	Campbell	000410	CR3000	2508
3 11/30/2021	Elevation	Elevation	None	1	None
4 11/30/2021	Filter pack flow pump	Thomas	02357	107CAB18	1089005314
5 11/30/2021	Flow Rate	Apex	000888	AXMC105LPMDPCV	illegible
6 11/30/2021	Infrastructure	Infrastructure	none	none	none
7 11/30/2021	Modem	Digi	07139	LR54	unknown
8 11/30/2021	Ozone	ThermoElectron Inc	000676	49i A1NAA	1030244794
9 11/30/2021	Ozone Standard	ThermoElectron Inc	000367	49i A3NAA	0726124683
10 11/30/2021	Sample Tower	Aluma Tower	666368	B	AT-5107-E-4-8
11 11/30/2021	Shelter Temperature	Campbell	none	107-L	none
12 11/30/2021	Siting Criteria	Siting Criteria	None	1	None
13 11/30/2021	Temperature	RM Young	06308	41342VO	12533
14 11/30/2021	Zero air pump	Werther International	06870	PC70/4	000814278

DAS Data Form

DAS Time Max Error: 0.02

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2508	QAK172	Eric Hebert	11/30/2021	DAS	Primary

Das Date:	11/30/2021	Audit Date	11/30/2021
Das Time:	10:12:59	Audit Time	10:13:00
Das Day:	334	Audit Day	334
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0002	0.0001	0.0002

Mfg	Date1	Parameter	DAS
Serial Number	4000392	Tfer Desc.	Source generator (D
Tfer ID	01321		
Slope	1.00000	Intercept	0.00000
Cert Date	1/22/2015	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	86590148	Tfer Desc.	DVM
Tfer ID	01310		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	0.0000	0.0000	V	V	0.0000	
7	0.1000	0.1165	0.1165	V	V	0.0000	
7	0.3000	0.3504	0.3502	V	V	-0.0002	
7	0.5000	0.5005	0.5005	V	V	0.0000	
7	0.7000	0.7002	0.7001	V	V	-0.0001	
7	0.9000	0.9003	0.9002	V	V	-0.0001	
7	1.0000	1.0004	1.0003	V	V	-0.0001	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		QAK172	Eric Hebert	11/30/2021	Flow Rate	000888

Mfg	BIOS	Parameter	Flow Rate
Serial Number		Tfer Desc.	BIOS 530-H
Tfer ID	01414		
Slope	1.00185	Intercept	0.02453
Cert Date	2/10/2021	CorrCoff	0.99999

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
2.74%	2.74%		
Cal Factor Full Scale		0	
Rotometer Reading:		1.5	

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.08	0.000	0.09	l/m	l/m	
primary	test pt 1	1.483	1.460	1.49	0.000	1.50	l/m	l/m	2.74%
primary	test pt 2	1.488	1.460	1.49	0.000	1.50	l/m	l/m	2.74%
primary	test pt 3	1.492	1.460	1.49	0.000	1.50	l/m	l/m	2.74%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	5.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244794

QAK172

Eric Hebert

11/30/2021

Ozone

000676

Slope:

1.03475

Slope:

0.00000

Intercept

-0.39443

Intercept

0.00000

CorrCoff

1.00000

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00560

Intercept

0.14070

Cert Date

4/7/2021

CorrCoff

0.99990

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.81	0.65	0.38	ppb		-0.27	
primary	2	17.23	16.77	16.84	ppb		0.07	
primary	3	37.41	36.57	37.41	ppb	2.27		
primary	4	68.32	66.91	68.90	ppb	2.93		
primary	5	111.02	108.82	112.20	ppb	3.06		
Sensor Component	Audit Pressure			Condition	710.1 mmHg	Status	pass	
Sensor Component	26.6 degree unobstructed rule			Condition	True	Status	pass	
Sensor Component	Tree dewline >10m or below inlet			Condition	True	Status	pass	
Sensor Component	ADT <100 vehicles further than 2			Condition	True	Status	pass	
Sensor Component	ADT >100 vehicles further than 5			Condition	True	Status	pass	
Sensor Component	Sample Train			Condition	Good	Status	pass	
Sensor Component	Inlet Filter Condition			Condition	Moderately clean	Status	pass	
Sensor Component	Offset			Condition	0.000	Status	pass	
Sensor Component	Span			Condition	1.029	Status	pass	
Sensor Component	Zero Voltage			Condition	N/A	Status	pass	
Sensor Component	Fullscale Voltage			Condition	N/A	Status	pass	
Sensor Component	Cell A Freq.			Condition	91.5 kHz	Status	pass	
Sensor Component	Cell A Noise			Condition	0.9 ppb	Status	pass	
Sensor Component	Cell A Flow			Condition	0.71 lpm	Status	pass	
Sensor Component	Cell A Pressure			Condition	684.0 mmHg	Status	pass	
Sensor Component	Cell A Tmp.			Condition	32.6 C	Status	pass	
Sensor Component	Cell B Freq.			Condition	98.2 kHz	Status	pass	
Sensor Component	Cell B Noise			Condition	0.8 ppb	Status	pass	
Sensor Component	Cell B Flow			Condition	0.71 lpm	Status	pass	
Sensor Component	Cell B Pressure			Condition	684.6 mmHg	Status	pass	
Sensor Component	System Memo			Condition		Status	pass	

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	12533		QAK172	Eric Hebert	11/30/2021	Temperature	06308

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00751	Intercept	0.16174
Cert Date	2/18/2021	CorrCoff	1.00000

0.22	0.25		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.14	-0.02	0.000	-0.3	C	-0.25
primary	Temp Mid Range	27.58	27.21	0.000	27.1	C	-0.16
primary	Temp High Range	46.00	45.50	0.000	45.3	C	-0.25

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	QAK172	Eric Hebert	11/30/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.70	0.95		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00751	Intercept	0.16174
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	24.33	23.99	0.000	24.5	C	0.46	
primary	Temp Mid Range	23.63	23.29	0.000	24.2	C	0.95	
Sensor Component		System Memo	Condition		Status	pass		

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

QAK172

Technician

Eric Hebert

Site Visit Date

11/30/2021

Shelter Make	Shelter Model	Shelter Size
Ekto	8810 (s/n 2625-2)	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Fair	Status	pass
Sensor Component	Shelter Roof	Condition	Fair	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Fair	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator is doing an excellent job maintaining the site. The bag that the filter is shipped in is not present at the site. If the site operator is taking the bag to another location it is possible that it could be exposed to unknown contamination.

2 **Parameter:** ShelterCleanNotes

The shelter is in fair condition with some loose floor tiles.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Quaker City"/>
Operating Group	<input type="text" value="Private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="39-121-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE"/>	QAPP Latitude	<input type="text" value="39.9431"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-81.3378"/>
Land Use	<input type="text" value="woodland - mixed, agriculture"/>	QAPP Elevation Meters	<input type="text" value="372"/>
Terrain	<input type="text" value="rolling"/>	QAPP Declination	<input type="text" value="7.9"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(740) 679-3345"/>	Audit Latitude	<input type="text" value="39.942714"/>
Site Address 1	<input type="text" value="58163 St. Johns Road"/>	Audit Longitude	<input type="text" value="-81.337914"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="371"/>
County	<input type="text" value="Noble"/>	Audit Declination	<input type="text" value="-8.2"/>
City, State	<input type="text" value="Quaker City, OH"/>		
Zip Code	<input type="text" value="43773"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="New in 2015"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Steps <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/> Model <input type="text" value="8810 (s/n 2625-2)"/> Shelter Size <input type="text" value="640 cuft"/>		
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is in fair condition with some loose floor tiles."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From I-70 take exit 193, route 513 south to Quaker City. At the 4-way stop turn right and continue approximately 0.8 miles and turn left onto CR943. Continue approximately 2 miles and turn right onto Noble County Rd 34 (also St. Johns Road). Continue approximately 1.5 miles and turn left onto a dirt road which is the driveway up a steep hill to the site.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

QAK172

Technician

Eric Hebert

Site Visit Date

11/30/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

QAK172

Technician

Eric Hebert

Site Visit Date

11/30/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

QAK172

Technician

Eric Hebert

Site Visit Date

11/30/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 15 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

QAK172

Technician

Eric Hebert

Site Visit Date

11/30/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>									
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>									
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Temperature only								
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>									
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>									
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>									
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>									
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded									
<input type="checkbox"/>		<input type="checkbox"/>									
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>									
10	Is the sample tower stable and grounded?										
11	Tower comments?										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

QAK172

Technician

Eric Hebert

Site Visit Date

11/30/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Minimal information

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

QAK172

Technician

Eric Hebert

Site Visit Date

11/30/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Site operator refresher training July 2006

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

QAK172

Technician

Eric Hebert

Site Visit Date

11/30/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings 80% of the time
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is doing an excellent job maintaining the site. The bag that the filter is shipped in is not present at the site. If the site operator is taking the bag to another location it is possible that it could be exposed to unknown contamination.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

QAK172

Technician

Eric Hebert

Site Visit Date

11/30/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07066
DAS	Campbell	CR3000	2508	000410
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	1089005314	02357
Flow Rate	Apex	AXMC105LPMDPC	illegible	000888
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07139
Ozone	ThermoElectron Inc	49i A1NAA	1030244794	000676
Ozone Standard	ThermoElectron Inc	49i A3NAA	0726124683	000367
Sample Tower	Aluma Tower	B	AT-5107-E-4-8	666368
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	12533	06308
Zero air pump	Werther International	PC70/4	000814278	06870

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
BFT142-Eric Hebert-12/06/2021						
1	12/6/2021	Computer	Dell	07212	Inspiron 15	Unknown
2	12/6/2021	DAS	Campbell	000498	CR3000	3815
3	12/6/2021	Elevation	Elevation	None	1	None
4	12/6/2021	Filter pack flow pump	Thomas	04279	107CA18	129800010158
5	12/6/2021	Flow Rate	Apex	000593	AXMC105LPMDPCV	illegible
6	12/6/2021	Infrastructure	Infrastructure	none	none	none
7	12/6/2021	Modem	Digi	07292	LR54	Illegible
8	12/6/2021	Ozone	ThermoElectron Inc	000746	49i A1NAA	1105347315
9	12/6/2021	Ozone Standard	ThermoElectron Inc	000330	49i A3NAA	0622717854
10	12/6/2021	Sample Tower	Aluma Tower	000863	B	unknown
11	12/6/2021	Shelter Temperature	Campbell	none	107-L	none
12	12/6/2021	Siting Criteria	Siting Criteria	None	1	None
13	12/6/2021	Temperature	RM Young	04444	41342VO	4542
14	12/6/2021	Zero air pump	Werther International	06898	C 70/4	000821905

DAS Data Form

DAS Time Max Error: 0.02

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	3815	BFT142	Eric Hebert	12/06/2021	DAS	Primary

Das Date:	12/6 /2021	Audit Date	12/6 /2021
Das Time:	07:30:01	Audit Time	07:30:00
Das Day:	340	Audit Day	340
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0002	0.0001	0.0002

Mfg	Date1	Parameter	DAS
Serial Number	4000392	Tfer Desc.	Source generator (D
Tfer ID	01321		
Slope	1.00000	Intercept	0.00000
Cert Date	1/22/2015	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	86590148	Tfer Desc.	DVM
Tfer ID	01310		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	0.0000	0.0000	V	V	0.0000	
7	0.1000	0.1005	0.1005	V	V	0.0000	
7	0.3000	0.3013	0.3014	V	V	0.0001	
7	0.5000	0.5040	0.5039	V	V	-0.0001	
7	0.7000	0.7054	0.7053	V	V	-0.0001	
7	0.9000	0.9070	0.9068	V	V	-0.0002	
7	1.0000	1.0078	1.0076	V	V	-0.0002	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		BFT142	Eric Hebert	12/06/2021	Flow Rate	000593

Mfg	BIOS	Parameter	Flow Rate
Serial Number		Tfer Desc.	BIOS 530-H
Tfer ID	01414		
Slope	1.00185	Intercept	0.02453
Cert Date	2/10/2021	CorrCoff	0.99999

DAS 1:	DAS 2:	Cal Factor Zero	-0.01
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
1.81%	2.04%		
Cal Factor Full Scale		1	
Rotometer Reading:		1.5	

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.04	0.000	0.01	l/m	l/m	
primary	test pt 1	1.501	1.470	1.50	0.000	1.50	l/m	l/m	2.04%
primary	test pt 2	1.501	1.470	1.50	0.000	1.50	l/m	l/m	2.04%
primary	test pt 3	1.505	1.480	1.50	0.000	1.50	l/m	l/m	1.35%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347315

BFT142

Eric Hebert

12/06/2021

Ozone

000746

Slope:

0.99407

Slope:

0.00000

Intercept

-0.34410

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00560

Intercept

0.14070

Cert Date

4/7/2021

CorrCoff

0.99990

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.13	-0.01	-0.08	ppb		-0.07	
primary	2	15.70	15.27	14.69	ppb		-0.58	
primary	3	37.59	36.75	36.09	ppb	-1.81		
primary	4	70.03	68.59	67.62	ppb	-1.42		
primary	5	112.74	110.51	109.70	ppb	-0.74		
Sensor Component	Audit Pressure		Condition	760.9 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	True		Status	pass	
Sensor Component	ADT >100 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Moderately clean		Status	pass	
Sensor Component	Offset		Condition	0.30		Status	pass	
Sensor Component	Span		Condition	1.023		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	95.9 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	Not tested		Status	pass	
Sensor Component	Cell A Flow		Condition	0.60 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	708.1 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	32.5 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	110.2 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	Not tested		Status	pass	
Sensor Component	Cell B Flow		Condition	0.60 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	708.7 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4542		BFT142	Eric Hebert	12/06/2021	Temperature	04444

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232679	Tfer Desc.	RTD
		Tfer ID	01228		
		Slope	1.00751	Intercept	0.16174
		Cert Date	2/18/2021	CorrCoff	1.00000

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.09	0.13		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.41	0.25	0.000	0.3	C	0.07
primary	Temp Mid Range	23.46	23.12	0.000	23.0	C	-0.13
primary	Temp High Range	46.84	46.33	0.000	46.3	C	-0.07

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	BFT142	Eric Hebert	12/06/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
1.12	1.13		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00751	Intercept	0.16174
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	24.12	23.78	0.000	24.9	C	1.12	
primary	Temp Mid Range	23.99	23.65	0.000	24.8	C	1.13	
Sensor Component		System Memo		Condition		Status	pass	

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition	20 m	Status	Fail
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

12/06/2021

Shelter Make	Shelter Model	Shelter Size
Ekto	8810	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Poor	Status	Fail
Sensor Component	Shelter Door	Condition	Fair	Status	pass
Sensor Component	Shelter Roof	Condition	Fair	Status	pass
Sensor Component	Shelter Floor	Condition	Poor	Status	Fail
Sensor Component	Shelter walls	Condition	Poor	Status	Fail
Sensor Component	Excessive mold present	Condition	Fair	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

- 1

Parameter:

DasComments

The new sample tower is not attached to the shelter. The sample tower is not grounded.
- 2

Parameter:

SitingCriteriaCom

The site is surrounded by a corn/soy bean field, within a large-scale commercial agriculture operation.
- 3

Parameter:

ShelterCleanNotes

The shelter lights are not functioning properly. The shelter is in poor condition due to being flooded during hurricanes.
- 4

Parameter:

MetOpMaintCom

The meteorological tower has been removed and the temperature sensor is installed in a naturally aspirated shield on the sample tower.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Williston"/>
Operating Group	<input type="text" value="UNC-IMS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="37-031-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="agriculture"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="flat"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="34.884668"/>
Site Address 1	<input type="text" value="Open Grounds Farm"/>	Audit Longitude	<input type="text" value="-76.620666"/>
Site Address 2	<input type="text" value="100 Nelson Bay Rd."/>	Audit Elevation	<input type="text" value="5.3"/>
County	<input type="text" value="Carteret"/>	Audit Declination	<input type="text" value="-9.9"/>
City, State	<input type="text" value="Beaufort, NC"/>		
Zip Code	<input type="text" value="28516"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="New in 2015"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Steps <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room <input checked="" type="checkbox"/>	Make	<input type="text" value="Ekto"/>	Model	<input type="text" value="8810"/>	Shelter Size	<input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes	<input type="text" value="The shelter lights are not functioning properly. The shelter is in poor condition due to being flooded during hurricanes."/>				
Site OK <input checked="" type="checkbox"/>	Notes	<input type="text"/>				

Driving Directions From I-95 take highway 70 east through Morehead City and over the bridge. Continue through Beaufort staying on route 70 east. At East Carteret High School, route 70 turns to the right at a traffic light. Continue straight through the light on Merrimon Rd. (SR 1300), do not follow 70 to the right. Open Grounds Farm will be on the right approximately 6 miles on Merrimon Rd. Sign in at the guard house. Continue on the dirt road into the farm. Turn left at the first dirt road. The site will be visible in the corner of the field. Follow the dirt road around the field to the site.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

12/06/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

12/06/2021

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological tower has been removed and the temperature sensor is installed in a naturally aspirated shield on the sample tower.

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

12/06/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 10 meters
4	Describe dry dep sample tube.		3/8 teflon by 10 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

12/06/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Temperature only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	Met tower removed.										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The new sample tower is not attached to the shelter. The sample tower is not grounded.

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

12/06/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	2019	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	2019	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	2019	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

12/06/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

12/06/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

F-02058-1500-S10-rev002

Site Visit Date 12/06/2021

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07212
DAS	Campbell	CR3000	3815	000498
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	129800010158	04279
Flow Rate	Apex	AXMC105LPMDPC	illegible	000593
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07292
Ozone	ThermoElectron Inc	49i A1NAA	1105347315	000746
Ozone Standard	ThermoElectron Inc	49i A3NAA	0622717854	000330
Sample Tower	Aluma Tower	B	unknown	000863
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	4542	04444
Zero air pump	Werther International	C 70/4	000821905	06898

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
PNF126-Eric Hebert-12/07/2021						
1	12/7/2021	DAS	Campbell	illegible	CR3000	3817
2	12/7/2021	Ozone	ThermoElectron Inc	000741	49i A1NAA	1105347316
3	12/7/2021	Ozone Standard	ThermoElectron Inc	000363	49i A3NAA	0726124691
4	12/7/2021	Zero air pump	Werther International	06885	C 70/4	000814270

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347316

PNF126

Eric Hebert

12/07/2021

Ozone

000741

Slope:

1.02367

Slope:

0.00000

Intercept

0.36850

Intercept

0.00000

CorrCoff

0.99998

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00560

Intercept

0.14070

Cert Date

4/7/2021

CorrCoff

0.99990

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.06	-0.07	0.46	ppb		0.53	
primary	2	17.36	16.90	17.91	ppb		1.01	
primary	3	37.29	36.46	37.38	ppb	2.49		
primary	4	71.73	70.26	71.89	ppb	2.29		
primary	5	117.31	115.00	118.40	ppb	2.91		
Sensor Component	Audit Pressure		Condition	641 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT <100 vehicles further than 2		Condition	True		Status	pass	
Sensor Component	ADT >100 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.40		Status	pass	
Sensor Component	Span		Condition	1.003		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	82.9 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	Not tested		Status	pass	
Sensor Component	Cell A Flow		Condition	0.64 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	623.8 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	27.2 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	103.7 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	Not tested		Status	pass	
Sensor Component	Cell B Flow		Condition	0.70 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	624.7 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>GRS420-Eric Hebert-12/08/2021</i>						
1	12/8/2021	Computer	Hewlett Packard	none	6730b	USH01700BY
2	12/8/2021	DAS	Environmental Sys Corp	GRSM-LR	8864	C2599
3	12/8/2021	Elevation	Elevation	None	1	None
4	12/8/2021	Filter pack flow pump	Thomas	none	107CAB18B	illegible
5	12/8/2021	Flow Rate	Mykrolis	none	FC280SAV-4S	AW9510056
6	12/8/2021	Infrastructure	Infrastructure	none	none	none
7	12/8/2021	Met tower	Rohn	none	unknown	none
8	12/8/2021	MFC power supply	Mykrolis	none	RO-32	FP9510004
9	12/8/2021	Ozone	ThermoElectron Inc	none	49i A3NAA	1023943903
10	12/8/2021	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1130450193
11	12/8/2021	Sample Tower	Aluma Tower	90945	B	none
12	12/8/2021	Shelter Temperature	ARS	none	none	none
13	12/8/2021	Siting Criteria	Siting Criteria	None	1	None
14	12/8/2021	Temperature2meter	RM Young	none	41342VC	032955
15	12/8/2021	Zero air pump	Werther International	none	PC70/4	531385

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	C2599	GRS420	Eric Hebert	12/08/2021	DAS	Primary

Das Date:	12/8 /2021	Audit Date	12/8 /2021
Das Time:	10:59:00	Audit Time	11:00:30
Das Day:	342	Audit Day	342
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Date1	Parameter	DAS
Serial Number	4000392	Tfer Desc.	Source generator (D
Tfer ID	01321		
Slope	1.00000	Intercept	0.00000
Cert Date	1/22/2015	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	86590148	Tfer Desc.	DVM
Tfer ID	01310		
Slope	1.00000	Intercept	0.00000
Cert Date	2/11/2021	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
3	1.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Mykrolis	AW9510056		GRS420	Eric Hebert	12/08/2021	Flow Rate	none

Mfg

Mykrolis

SN/Owner ID

FP9510004

none

Parameter:

MFC power supply

Mfg

BIOS

Parameter

Flow Rate

Serial Number

Tfer Desc.

BIOS 530-H

Tfer ID

01414

Slope

1.00185

Intercept

0.02453

Cert Date

2/10/2021

CorrCoff

0.99999

DAS 1:	DAS 2:	Cal Factor Zero	-0.061
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
2.73%	2.73%		
		Cal Factor Full Scale	5.157
		Rotometer Reading:	3.05

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.04	0.0000	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.08	0.0000	0.02	l/m	l/m	
primary	test pt 1	2.962	2.930	2.96	0.0000	3.01	l/m	l/m	2.73%
primary	test pt 2	2.964	2.930	2.96	0.0000	3.01	l/m	l/m	2.73%
primary	test pt 3	2.964	2.930	2.96	0.0000	3.01	l/m	l/m	2.73%

Sensor Component

Leak Test

Condition

Status

pass

Sensor Component

Tubing Condition

Condition

Good

Status

pass

Sensor Component

Filter Position

Condition

Good

Status

pass

Sensor Component

Rotometer Condition

Condition

Clean and dry

Status

pass

Sensor Component

Moisture Present

Condition

No moisture present

Status

pass

Sensor Component

Filter Distance

Condition

4.5 cm

Status

pass

Sensor Component

Filter Depth

Condition

1.5 cm

Status

pass

Sensor Component

Filter Azimuth

Condition

270 deg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1023943903

GRS420

Eric Hebert

12/08/2021

Ozone

none

Slope:

1.00470

Slope:

0.00000

Intercept

0.36559

Intercept

0.00000

CorrCoff

1.00000

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00560

Intercept

0.14070

Cert Date

4/7/2021

CorrCoff

0.99990

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.18	0.03	0.43	ppb		0.4	
primary	2	15.88	15.44	15.74	ppb		0.3	
primary	3	38.18	37.33	37.93	ppb	1.59		
primary	4	69.14	67.72	68.53	ppb	1.19		
primary	5	107.81	105.67	106.45	ppb	0.74		
Sensor Component	Audit Pressure			Condition	710 mmHg	Status	pass	
Sensor Component	26.6 degree unobstructed rule			Condition	True	Status	pass	
Sensor Component	Tree dewline >10m or below inlet			Condition	True	Status	pass	
Sensor Component	ADT <100 vehicles further than 2			Condition	True	Status	pass	
Sensor Component	ADT >100 vehicles further than 5			Condition	225 m	Status	Fail	
Sensor Component	Sample Train			Condition	Good	Status	pass	
Sensor Component	Inlet Filter Condition			Condition	Clean	Status	pass	
Sensor Component	Offset			Condition	0.000	Status	pass	
Sensor Component	Span			Condition	1.001	Status	pass	
Sensor Component	Zero Voltage			Condition	N/A	Status	pass	
Sensor Component	Fullscale Voltage			Condition	N/A	Status	pass	
Sensor Component	Cell A Freq.			Condition	90.1 kHz	Status	pass	
Sensor Component	Cell A Noise			Condition	Not tested	Status	pass	
Sensor Component	Cell A Flow			Condition	0.63 lpm	Status	pass	
Sensor Component	Cell A Pressure			Condition	680.4 mmHg	Status	pass	
Sensor Component	Cell A Tmp.			Condition	30.9 C	Status	pass	
Sensor Component	Cell B Freq.			Condition	101.2 kHz	Status	pass	
Sensor Component	Cell B Noise			Condition	Not tested	Status	pass	
Sensor Component	Cell B Flow			Condition	0.56 lpm	Status	pass	
Sensor Component	Cell B Pressure			Condition	679.5 mmHg	Status	pass	
Sensor Component	System Memo			Condition		Status	pass	

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	032955		GRS420	Eric Hebert	12/08/2021	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.19	0.33		

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00751	Intercept	0.16174
Cert Date	2/18/2021	CorrCoff	1.00000

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.81	0.64	0.0000	0.97C		0.33
primary	Temp Mid Range	22.52	22.19	0.0000	22.34C		0.15
primary	Temp High Rang	49.03	48.50	0.0000	48.60C		0.1

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	GRS420	Eric Hebert	12/08/2021	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.75	0.81		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00751	Intercept	0.16174
Cert Date	2/18/2021	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	19.80	19.49	0.000	20.3	C	0.81	
primary	Temp Mid Range	19.92	19.61	0.000	20.3	C	0.69	
Sensor Component		System Memo		Condition		Status	pass	

Siting Criteria Form

Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	City > 50,000	Condition	35 km	Status	Fail
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass
Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass

Infrastructure Data For

Site ID

GRS420

Technician

Eric Hebert

Site Visit Date

12/08/2021

Shelter Make	Shelter Model	Shelter Size
Ekto	8810 (s/n 2961-1)	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	Good	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
-----------	------	------------	-----------	-----------	-----	------------	--------	---------

Temperature2meter	GRS420	Eric Hebert	12/08/2021	Properly Sited	RM Young	4705	<input type="checkbox"/>	<input type="checkbox"/>
-------------------	--------	-------------	------------	----------------	----------	------	--------------------------	--------------------------

The lower (two meter temperature sensor) shield is not mounted at 2 meters above the ground as stated in the QAPP.

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample train is leak-tested each week after the inlet filter is changed.

2 Parameter: SitingCriteriaCom

The site is located on a ridge top with the sampling height at the tops of the trees on the ridge. The site is within 40 km of Knoxville and other major sources.

3 Parameter: ShelterCleanNotes

The shelter is in good condition, clean, neat, and well organized.

4 Parameter: MetSensorComme

The temperature sensor has been relocated from 10 meters to approximately 3.9 meters above the ground.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="Blockhouse"/>
Operating Group	<input type="text" value="NPS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="47-009-0101"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, Hg, SO2, NOx, PM2.5, PM10,"/>	QAPP Latitude	<input type="text" value="35.6331"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-83.9422"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="793"/>
Terrain	<input type="text" value="complex (ridge-top)"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="35.633482"/>
Site Address 1	<input type="text" value="Look Rock"/>	Audit Longitude	<input type="text" value="-83.941606"/>
Site Address 2	<input type="text" value="Foothills Parkway"/>	Audit Elevation	<input type="text" value="801"/>
County	<input type="text" value="Blount"/>	Audit Declination	<input type="text" value="5.5"/>
City, State	<input type="text" value="Maryville, TN"/>		
Zip Code	<input type="text" value="37803"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="inspected Sept 2019"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Steps <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2961-1)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is in good condition, clean, neat, and well organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		
Driving Directions	<input type="text" value="From Maryville proceed east on 321 and turn right (south) onto the Foothills Parkway. Continue approximately 11 miles. Just before reaching the Look Rock parking area and trail, turn right on a gravel road through a locked NPS gate. The site is approximately 200 meters up the trail on the right."/>		

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

GRS420

Technician

Eric Hebert

Site Visit Date

12/08/2021

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature sensor has been relocated from 10 meters to approximately 3.9 meters above the ground.

Site ID

GRS420

Technician

Eric Hebert

Site Visit Date

12/08/2021

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

GRS420

Technician

Eric Hebert

Site Visit Date

12/08/2021

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

GRS420

Technician

Eric Hebert

Site Visit Date

12/08/2021

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>							
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>							
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only						
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>							
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>							
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>							
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>							
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>							
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded							
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>				
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
11	Tower comments?	Sample tower grounded to shelter, and slightly bent at hinge.							

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

GRS420

Technician

Eric Hebert

Site Visit Date

12/08/2021

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	UPS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	Dataview	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	10/30/2016	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

Dataview

2

Are the Site Status Report Forms being completed and current?

☒

Flow & observation sections

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

GRS420

Technician

Eric Hebert

Site Visit Date

12/08/2021

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	Monthly		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>			<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Alarm values only		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	As needed		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Dataview

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone sample train is leak-tested each week after the inlet filter is changed.

Site ID

GRS420

Technician

Eric Hebert

Site Visit Date

12/08/2021

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings in winter, changed in afternoon in summer
2	Are the Site Status Report Forms being completed and filed correctly?	<input type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

GRS420

Technician

Eric Hebert

Site Visit Date

12/08/2021

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	6730b	USH01700BY	none
DAS	Environmental Sys Corp	8864	C2599	GRSM-LR
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18B	illegible	none
Flow Rate	Mykrolis	FC280SAV-4S	AW9510056	none
Infrastructure	Infrastructure	none	none	none
Met tower	Rohn	unknown	none	none
MFC power supply	Mykrolis	RO-32	FP9510004	none
Ozone	ThermoElectron Inc	49i A3NAA	1023943903	none
Ozone Standard	ThermoElectron Inc	49i A1NAA	1130450193	none
Sample Tower	Aluma Tower	B	none	90945
Shelter Temperature	ARS	none	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342VC	032955	none
Zero air pump	Werther International	PC70/4	531385	none

APPENDIX B

CASTNET Site Spot Report Forms

EEMS Spot Report

Data Compiled: 3/8/2022 07:45:40

Site	Visit Date	Technician
ABT147	10/24/2021	Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99979	unitless	P
2	Ozone Intercept	P	0	5	4	-0.04868	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	0.3	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.03	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.11	ppb	P

EEMS Spot Report

Data Compiled:

3/4/2022 12:53:34

Site Visit Date Site

Technician

10/21/2021

ALH157

Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	246.78	c	Fail
2	Temperature max error	P	4	0.5	3	246.78	c	Fail
3	Ozone Slope	P	0	1.1	4	0.99079	unitless	P
4	Ozone Slope	P	0	1.1	4	0.99079	unitless	P
5	Ozone Intercept	P	0	5	4	-1.30716	ppb	P
6	Ozone Intercept	P	0	5	4	-1.30716	ppb	P
7	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
8	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
9	Ozone % difference avg	P	7	10	4	5.0	%	P
10	Ozone Absolute Difference g1	P	7	3	1	-1.1	ppb	P
11	Ozone Absolute Difference g2	P	7	1.5	1	-1.43	ppb	P
12	Flow Rate average % difference	P	10	5	6	0.04	%	P
13	Flow Rate max % difference	P	10	5	6	0.13	%	P
14	DAS Voltage average error	P	7	0.003	49	0.0001	V	P
15	Shelter Temperature average error	P	5	2	21	0.32	c	P
16	Shelter Temperature max error	P	5	2	21	0.56	c	P

SiteVisitDate	Site	Technician
10/21/2021	ALH157	Korey Devins

Field Systems Comments

- 1

Parameter:

SitingCriteriaCom

The site is located on a privately operated farm which rotates corn and soy bean crops.
- 2

Parameter:

ShelterCleanNotes

The shelter floor has been repaired recently. Walls have signs of leaks.
- 3

Parameter:

MetSensorComme

Temperature mounted in naturally aspirated shield on sample tower.
- 4

Parameter:

MetOpMaintCom

The temperature sensor is not functioning and reading -247 deg C. It was not audited.

EEMS Spot Report

Data Compiled: 3/4/2022 15:55:13

Site	Visit Date	Technician
BFT142	12/06/2021	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	15	0.09	c	P
2	Temperature max error	P	4	0.5	15	0.13	c	P
3	Ozone Slope	P	0	1.1	4	0.99407	unitless	P
4	Ozone Intercept	P	0	5	4	-0.3441	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	1.9	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.07	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.58	ppb	P
9	Flow Rate average % difference	P	10	5	6	1.81	%	P
10	Flow Rate max % difference	P	10	5	6	2.04	%	P
11	DAS Voltage average error	P	7	0.003	77	0.0001	V	P
12	Shelter Temperature average error	P	5	2	14	1.12	c	P
13	Shelter Temperature max error	P	5	2	14	1.13	c	P

SiteVisitDate	Site	Technician
12/06/2021	BFT142	Eric Hebert

Field Systems Comments

- 1

Parameter:

DasComments

The new sample tower is not attached to the shelter. The sample tower is not grounded.
- 2

Parameter:

SitingCriteriaCom

The site is surrounded by a corn/soy bean field, within a large-scale commercial agriculture operation.
- 3

Parameter:

ShelterCleanNotes

The shelter lights are not functioning properly. The shelter is in poor condition due to being flooded during hurricanes.
- 4

Parameter:

MetOpMaintCom

The meteorological tower has been removed and the temperature sensor is installed in a naturally aspirated shield on the sample tower.

EEMS Spot Report

Data Compiled:

3/3/2022 13:33:55

SiteVisitDate Site

Technician

10/13/2021

BVL130

Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.14	c	P
2	Temperature2meter max error	P	5	0.5	3	0.27	c	P
3	Surface Wetness Wetness Sensor		0		1	0		
4	Wind Speed average error below 5m/s in m/s	P	3	0.5	8	0.05	m/s	P
5	Wind Speed max error below 5m/s in m/s	P	3	0.5	8	0.20	m/s	P
6	Wind Speed average % difference above 5 m/s	P	3	5	8	0.0	%	P
7	Wind Speed max % difference above 5 m/s	P	3	5	8	0.0	%	P
8	Wind Speed Torque average error	P	3	0.5	1	0.35	g-cm	P
9	Wind Speed Torque max error	P	3	0.5	1	0.4	g-cm	P
10	Wind Direction Input Deg True average error (de	P	2	5	8	7.0	degrees	Fail
11	Wind Direction Input Deg True max error (deg)	P	2	5	8	9	degrees	Fail
12	Wind Direction Linearity average error (deg)	P	2	5	16	1.8	degrees	P
13	Wind Direction Linearity max error (deg)	P	2	5	16	5	degrees	P
14	Wind Direction Torque average error	P	2	30	1	35	g-cm	Fail
15	Wind Direction Torque max error	P	2	30	1	40	g-cm	Fail
16	Temperature average error	P	4	0.5	12	0.12	c	P
17	Temperature max error	P	4	0.5	12	0.22	c	P
18	Relative Humidity average above 85%	P	6	10	1	2.6	%	P
19	Relative Humidity max above 85%	P	6	10	1	2.6	%	P
20	Relative Humidity average below 85%	P	6	10	2	1.5	%	P
21	Relative Humidity max below 85%	P	6	10	2	2.8	%	P
22	Solar Radiation % diff of avg	P	9	10	42	4.68	%	P
23	Solar Radiation % diff of max STD value	P	9	10	42	0.80	%	P
24	Precipitation average % difference	P	1	10	2	1.0	%	P
25	Precipitation max % difference	P	1	10	2	2.0	%	P
26	Ozone Slope	P	0	1.1	4	0.99738	unitless	P
27	Ozone Intercept	P	0	5	4	-0.60475	ppb	P
28	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
29	Ozone % difference avg	P	7	10	4	2.1	%	P
30	Ozone Absolute Difference g1	P	7	3	1	-0.53	ppb	P
31	Ozone Absolute Difference g2	P	7	1.5	1	-0.69	ppb	P
32	Flow Rate average % difference	P	10	5	4	0.89	%	P
33	Flow Rate max % difference	P	10	5	4	1.33	%	P

Site	Visit Date	Site	Technician
------	------------	------	------------

10/13/2021	BVL130	Korey Devins						
34	DAS Voltage average error	P	7	0.003	56	0.0000	V	P
35	Surface Wetness Sensitivity test on	P	12	10000	1	170	k ohms	P
36	Surface Wetness Sensitivity test off	P	12	10000	1	190	k ohms	P
37	Surface Wetness Response	P	12	0.5	1	1.00		P
38	Shelter Temperature average error	P	5	2	21	0.32	c	P
39	Shelter Temperature max error	P	5	2	21	0.59	c	P

Field Performance Comments

- Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode:** 72
The filter sample tubing has drops of moisture in low sections outside the shelter.
- Parameter:** Wind Direction **SensorComponent:** Orientation **CommentCode:** 151
The wind direction orientation is outside the acceptance limit of 5 degrees. This is due to a combined error from the crossarm alignment and sensor calibration.

Field Systems Comments

- Parameter:** SiteOpsProcedures
Ozone and NCORE sample line filters are replaced, and the sample lines are leaked tested, every 2 weeks.
- Parameter:** SitingCriteriaCom
The site is located in an agricultural and atmospheric research center. There are crops within 50 meters.
- Parameter:** ShelterCleanNotes
The shelter still smells like rodent excrement. The shelter door does not completely seal and water enters during heavy rain. The water has caused damage to the floor.
- Parameter:** MetSensorComme
The tipping bucket rain gage is mounted near the meteorological tower and in violation of the 45 degree rule.
- Parameter:** MetOpMaintCom
The signal cables are showing signs of wear and previous repair.

EEMS Spot Report

Data Compiled: 3/8/2022 07:48:30

Site	Visit Date	Technician
CAV436	10/05/2021	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98549	unitless	P
2	Ozone Intercept	P	0	5	4	-0.0432	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.7	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.12	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.28	ppb	P

EEMS Spot Report

Data Compiled:

3/4/2022 14:57:04

Site Visit Date Site

Technician

11/11/2021

CDR119

Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	24	0.25	c	P
2	Temperature max error	P	4	0.5	24	0.33	c	P
3	Ozone Slope	P	0	1.1	4	0.97934	unitless	P
4	Ozone Intercept	P	0	5	4	0.12191	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
6	Ozone % difference avg	P	7	10	4	2.2	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.51	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.44	ppb	P
9	Flow Rate average % difference	P	10	5	2	1.32	%	P
10	Flow Rate max % difference	P	10	5	2	1.32	%	P
11	DAS Voltage average error	P	7	0.003	35	0.0001	V	P
12	Shelter Temperature average error	P	5	2	21	0.26	c	P
13	Shelter Temperature max error	P	5	2	21	0.36	c	P

SiteVisitDate	Site	Technician
11/11/2021	CDR119	Korey Devins

Field Performance Comments

- 1

Parameter: Flow Rate

SensorComponent: Moisture Present

CommentCode: 72
- The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

- 1

Parameter: SitingCriteriaCom
- Site is in a wooded valley, within 30 meters of a lightly traveled road. Large diesel trucks use the road. Trees are taller than the sample tower and within 20 meters of the sample tower.
- 2

Parameter: ShelterCleanNotes
- The shelter is in fair condition with some rot on the walls below the air conditioner.

EEMS Spot Report

Data Compiled: 3/8/2022 07:50:30

Site	Visit Date	Technician
CHA467	10/01/2021	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97452	unitless	P
2	Ozone Intercept	P	0	5	4	-0.26322	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	3.8	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.16	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-1.02	ppb	P

EEMS Spot Report

Data Compiled: 3/8/2022 07:52:19

SiteVisitDate	Site	Technician
10/12/2021	DEN417	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00407	unitless	P
2	Ozone Intercept	P	0	5	4	0.87987	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	3.1	%	P
5	Ozone Absolute Difference g2	P	7	1.5	1	0.95	ppb	P

EEMS Spot Report

Data Compiled: 3/8/2022 07:54:31

SiteVisitDate	Site	Technician
10/16/2021	ESP127	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00811	unitless	P
2	Ozone Intercept	P	0	5	4	-0.28627	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	0.8	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.13	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.37	ppb	P

EEMS Spot Report

Data Compiled: 3/4/2022 16:13:45

SiteVisitDate	Site	Technician
12/08/2021	GRS420	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.19	c	P
2	Temperature2meter max error	P	5	0.5	3	0.33	c	P
3	Ozone Slope	P	0	1.1	4	1.0047	unitless	P
4	Ozone Intercept	P	0	5	4	0.36559	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	1.4	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.40	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	0.30	ppb	P
9	Flow Rate average % difference	P	10	5	8	2.73	%	P
10	Flow Rate max % difference	P	10	5	8	2.73	%	P
11	DAS Voltage average error	P	3	0.003	2	0.0000	V	P
12	Shelter Temperature average error	P	5	2	16	0.75	c	P
13	Shelter Temperature max error	P	5	2	16	0.81	c	P

SiteVisitDate	Site	Technician
12/08/2021	GRS420	Eric Hebert

Field Performance Comments

- Parameter:** Temperature2meter **SensorComponent:** Properly Sited **CommentCode:** 142
 The lower (two meter temperature sensor) shield is not mounted at 2 meters above the ground as stated in the QAPP.

Field Systems Comments

- Parameter:** SiteOpsProcedures
 The ozone sample train is leak-tested each week after the inlet filter is changed.
- Parameter:** SitingCriteriaCom
 The site is located on a ridge top with the sampling height at the tops of the trees on the ridge. The site is within 40 km of Knoxville and other major sources.
- Parameter:** ShelterCleanNotes
 The shelter is in good condition, clean, neat, and well organized.
- Parameter:** MetSensorComme
 The temperature sensor has been relocated from 10 meters to approximately 3.9 meters above the ground.

EEMS Spot Report

Data Compiled: 3/4/2022 13:52:36

SiteVisitDate	Site	Technician
11/04/2021	LAV410	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.61	c	Fail
2	Temperature2meter max error	P	5	0.5	3	0.71	c	Fail
3	Ozone Slope	P	0	1.1	4	1.015	unitless	P
4	Ozone Intercept	P	0	5	4	-0.86732	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99991	unitless	P
6	Ozone % difference avg	P	7	10	4	2.8	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.03	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-1.16	ppb	P
9	Flow Rate average % difference	P	10	5	10	4.93	%	P
10	Flow Rate max % difference	P	10	5	10	5.16	%	Fail
11	DAS Voltage average error	P	9	0.003	63	0.0002	V	P
12	Shelter Temperature average error	P	5	2	3	1.22	c	P
13	Shelter Temperature max error	P	5	2	3	1.5	c	P

SiteVisitDate	Site	Technician
11/04/2021	LAV410	Martin Valvur

Field Performance Comments

- Parameter:** Flow Rate **SensorComponent:** Accuracy **CommentCode:** 77
 The recorded flow rate data are accurate as recorded. The flow rate is not at the target flow rate.
- Parameter:** Ozone **SensorComponent:** Cell A Tmp. **CommentCode:** 99
 This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

- Parameter:** SiteOpsProcedures
 The ozone inlet filter is changed and the sample line conditioned every two weeks or as needed.
- Parameter:** SitingCriteriaCom
 The site is located at the end of a park service facility parking lot, in a fire station. The tree line is near the building, but the prevailing wind direction is from the clearing. Tree height above the sample inlet is not twice as far away as it is high above the inlet.
- Parameter:** ShelterCleanNotes
 The inside equipment is located in room within the fire station, clean, neat, and organized.
- Parameter:** PollAnalyzerCom
 Trees violate the ozone sample inlet siting criteria.

EEMS Spot Report

Data Compiled: 3/4/2022 13:16:43

SiteVisitDate	Site	Technician
10/22/2021	MCK131	Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.12	c	P
2	Temperature max error	P	4	0.5	9	0.20	c	P
3	Ozone Slope	P	0	1.1	4	0.98026	unitless	P
4	Ozone Intercept	P	0	5	4	-0.74366	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
6	Ozone % difference avg	P	7	10	4	4.4	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.7	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-1.23	ppb	P
9	Flow Rate average % difference	P	10	5	8	0.44	%	P
10	Flow Rate max % difference	P	10	5	8	0.66	%	P
11	DAS Voltage average error	P	7	0.003	70	0.0000	V	P
12	Shelter Temperature average error	P	5	2	15	0.37	c	P
13	Shelter Temperature max error	P	5	2	15	0.68	c	P

SiteVisitDate	Site	Technician
10/22/2021	MCK131	Korey Devins

Field Performance Comments

- 1 **Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode:** 72
- The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

- 1 **Parameter:** ShelterCleanNotes
- The shelter is neat and well organized.

EEMS Spot Report

Data Compiled:

3/4/2022 13:32:32

Site Visit Date Site

Technician

10/22/2021

MCK231

Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.22	c	P
2	Temperature max error	P	4	0.5	9	0.27	c	P
3	Ozone Slope	P	0	1.1	4	0.99682	unitless	P
4	Ozone Intercept	P	0	5	4	-0.20351	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	0.7	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.38	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.18	ppb	P
9	Flow Rate average % difference	P	10	5	2	0.44	%	P
10	Flow Rate max % difference	P	10	5	2	0.67	%	P
11	DAS Voltage average error	P	7	0.003	91	0.0001	V	P
12	Shelter Temperature average error	P	5	2	15	0.18	c	P
13	Shelter Temperature max error	P	5	2	15	0.42	c	P

SiteVisitDate	Site	Technician
10/22/2021	MCK231	Korey Devins

Field Performance Comments

- 1 **Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode:** 72
- The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

- 1 **Parameter:** ShelterCleanNotes
- The site instruments are located in the MCK131 shelter. The same site operator is servicing both sites.

EEMS Spot Report

Data Compiled: 3/8/2022 07:56:15

Site	Visit Date	Technician
MKG113	11/29/2021	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01421	unitless	P
2	Ozone Intercept	P	0	5	4	0.19975	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	1.9	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.29	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	0.49	ppb	P

EEMS Spot Report

Data Compiled:

3/4/2022 10:45:22

Site Visit Date Site

Technician

10/19/2021

OXF122

Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.10	c	P
2	Temperature max error	P	4	0.5	3	0.13	c	P
3	Ozone Slope	P	0	1.1	4	1.01494	unitless	P
4	Ozone Intercept	P	0	5	4	-0.48717	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	1.2	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.41	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.42	ppb	P
9	Flow Rate average % difference	P	10	5	8	0.60	%	P
10	Flow Rate max % difference	P	10	5	8	0.60	%	P
11	DAS Voltage average error	P	7	0.003	84	0.0000	V	P
12	Shelter Temperature average error	P	5	2	21	0.50	c	P
13	Shelter Temperature max error	P	5	2	21	0.62	c	P

SiteVisitDate	Site	Technician
10/19/2021	OXF122	Korey Devins

Field Systems Comments

- 1

Parameter:

DasComments

The met tower is operated by the university and the temperature sensor is mounted on the sample tower in a naturally aspirated shield.
- 2

Parameter:

SitingCriteriaCom

The site is located in university agriculture research facility.
- 3

Parameter:

ShelterCleanNotes

The shelter roof has been repaired.

EEMS Spot Report

Data Compiled: 3/4/2022 10:05:14

SiteVisitDate	Site	Technician
10/06/2021	PAL190	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	21	0.07	c	P
2	Temperature max error	P	4	0.5	21	0.14	c	P
3	Ozone Slope	P	0	1.1	4	0.99513	unitless	P
4	Ozone Intercept	P	0	5	4	-0.19568	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
6	Ozone % difference avg	P	7	10	4	1.5	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.22	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.33	ppb	P
9	Flow Rate average % difference	P	10	5	8	0.33	%	P
10	Flow Rate max % difference	P	10	5	8	0.33	%	P
11	DAS Voltage average error	P	7	0.003	77	0.0002	V	P
12	Shelter Temperature average error	P	5	2	21	0.23	c	P
13	Shelter Temperature max error	P	5	2	21	0.43	c	P

SiteVisitDate	Site	Technician
10/06/2021	PAL190	Martin Valvur

Field Systems Comments

1 **Parameter:** SiteOpsProcedures

The ozone sample train is leak tested every two weeks.

2 **Parameter:** SitingCriteriaCom

The site is located 40 km southeast of Amarillo TX which has a population of approximately 178,000.

3 **Parameter:** ShelterCleanNotes

The shelter is in good condition.

4 **Parameter:** MetSensorComme

The meteorological tower and sensors have been removed.

5 **Parameter:** MetOpMaintCom

The temperature signal cable is showing signs of wear.

EEMS Spot Report

Data Compiled:

3/4/2022 15:14:32

SiteVisitDate Site

Technician

11/12/2021

PAR107

Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	21	0.08	c	P
2	Temperature max error	P	4	0.5	21	0.10	c	P
3	Ozone Slope	P	0	1.1	4	0.98329	unitless	P
4	Ozone Intercept	P	0	5	4	-0.46557	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99996	unitless	P
6	Ozone % difference avg	P	7	10	4	3.2	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.33	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.88	ppb	P
9	Flow Rate average % difference	P	10	5	6	0.66	%	P
10	Flow Rate max % difference	P	10	5	6	0.66	%	P
11	DAS Voltage average error	P	7	0.003	84	0.0001	V	P
12	Shelter Temperature average error	P	5	2	21	0.46	c	P
13	Shelter Temperature max error	P	5	2	21	0.86	c	P

SiteVisitDate	Site	Technician
11/12/2021	PAR107	Korey Devins

Field Performance Comments

- 1

Parameter:

Flow Rate

SensorComponent:

Moisture Present

CommentCode:

72
- The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

- 1

Parameter:

SitingCriteriaCom
- The city of Parsons, estimated population 1500, is within 5 km of the site.
- 2

Parameter:

ShelterCleanNotes
- The shelter is in good condition, clean, neat, and well organized.

EEMS Spot Report

Data Compiled: 3/4/2022 14:35:54

SiteVisitDate	Site	Technician
11/10/2021	PED108	Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.13	c	P
2	Temperature max error	P	4	0.5	12	0.26	c	P
3	Ozone Slope	P	0	1.1	4	1.00697	unitless	P
4	Ozone Intercept	P	0	5	4	-0.05882	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	0.4	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.11	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	0.07	ppb	P
9	Flow Rate average % difference	P	10	5	4	0.45	%	P
10	Flow Rate max % difference	P	10	5	4	1.35	%	P
11	DAS Voltage average error	P	7	0.003	84	0.0001	V	P
12	Shelter Temperature average error	P	5	2	21	0.46	c	P
13	Shelter Temperature max error	P	5	2	21	0.86	c	P

SiteVisitDate	Site	Technician
11/10/2021	PED108	Korey Devins

Field Systems Comments

1 **Parameter:** SitingCriteriaCom

The site is in a clearing in an evergreen plantation in the Prince Edward-Gallion State Forest. Trees were cut within the last 11 years to increase the size of the clearing. The tree line is encroaching again and is between 25 and 35 meters from the site.

2 **Parameter:** ShelterCleanNotes

The shelter is in fair condition, clean, neat, and well organized.

EEMS Spot Report

Data Compiled: 3/8/2022 07:58:36

Site	Visit Date	Technician
PNF126	12/07/2021	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.02367	unitless	P
2	Ozone Intercept	P	0	5	4	0.36850	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	3.4	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.53	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	1.01	ppb	P

EEMS Spot Report

Data Compiled: 3/4/2022 15:35:43

SiteVisitDate	Site	Technician
11/30/2021	QAK172	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	21	0.22	c	P
2	Temperature max error	P	4	0.5	21	0.25	c	P
3	Ozone Slope	P	0	1.1	4	1.03475	unitless	P
4	Ozone Intercept	P	0	5	4	-0.39443	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	2.2	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.27	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	0.07	ppb	P
9	Flow Rate average % difference	P	10	5	2	2.74	%	P
10	Flow Rate max % difference	P	10	5	2	2.74	%	P
11	DAS Voltage average error	P	7	0.003	77	0.0001	V	P
12	Shelter Temperature average error	P	5	2	4	0.70	c	P
13	Shelter Temperature max error	P	5	2	4	0.95	c	P

SiteVisitDate	Site	Technician
11/30/2021	QAK172	Eric Hebert

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator is doing an excellent job maintaining the site. The bag that the filter is shipped in is not present at the site. If the site operator is taking the bag to another location it is possible that it could be exposed to unknown contamination.

2 **Parameter:** ShelterCleanNotes

The shelter is in fair condition with some loose floor tiles.

EEMS Spot Report

Data Compiled: 3/4/2022 11:57:49

SiteVisitDate	Site	Technician
10/20/2021	SAN189	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	18	0.19	c	P
2	Temperature max error	P	4	0.5	18	0.35	c	P
3	Ozone Slope	P	0	1.1	4	0.96856	unitless	P
4	Ozone Intercept	P	0	5	4	-1.07763	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	6.4	%	P
7	Ozone Absolute Difference g2	P	7	1.5	1	-1.54	ppb	Fail
8	Flow Rate average % difference	P	10	5	6	0.22	%	P
9	Flow Rate max % difference	P	10	5	6	0.33	%	P
10	DAS Voltage average error	P	7	0.003	77	0.0001	V	P
11	Shelter Temperature average error	P	5	2	21	0.28	c	P
12	Shelter Temperature max error	P	5	2	21	0.65	c	P

SiteVisitDate	Site	Technician
10/20/2021	SAN189	Martin Valvur

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Accuracy **CommentCode:** 201

Further investigation of the ozone measurement system revealed that the site analyzer was operating with a significant difference between the A and B sample cells. This condition is an indication of an internal leak between the reference and sample cell and will contribute to the measurement error.

Field Systems Comments

1 **Parameter:** DasComments

The met tower is not currently in use and it is somewhat unstable.

2 **Parameter:** DocumentationCo

The site operator reported that all instrument manuals are kept at the office.

3 **Parameter:** ShelterCleanNotes

The shelter is in very good condition.

EEMS Spot Report

Data Compiled: 3/8/2022 08:00:16

Site	Visit Date	Technician
SPD111	10/15/2021	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01805	unitless	P
2	Ozone Intercept	P	0	5	4	0.21647	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	2.4	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.23	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	0.49	ppb	P

EEMS Spot Report

Data Compiled: 3/4/2022 10:27:11

SiteVisitDate	Site	Technician
10/16/2021	STK138	Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	18	0.21	c	P
2	Temperature max error	P	4	0.5	18	0.43	c	P
3	Ozone Slope	P	0	1.1	4	0.99708	unitless	P
4	Ozone Intercept	P	0	5	4	-0.67203	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	2.6	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.39	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.82	ppb	P
9	Flow Rate average % difference	P	10	5	4	0.67	%	P
10	Flow Rate max % difference	P	10	5	4	0.67	%	P
11	DAS Voltage average error	P	7	0.003	84	0.0001	V	P
12	Shelter Temperature average error	P	5	2	21	0.39	c	P
13	Shelter Temperature max error	P	5	2	21	0.62	c	P

SiteVisitDate	Site	Technician
10/16/2021	STK138	Korey Devins

Field Performance Comments

1 **Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode:** 72

The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

- 1 **Parameter:** SiteOpsProcedures
- The ozone sample train is leak tested every 2 weeks.
- 2 **Parameter:** SitingCriteriaCom
- The site is located in a corn field on a cattle farm. Corn is planted within 10 meters.
- 3 **Parameter:** ShelterCleanNotes
- There are signs of leaks on the walls and floor rot.

EEMS Spot Report

Data Compiled: 3/4/2022 11:25:33

SiteVisitDate	Site	Technician
10/19/2021	THR422	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.33	c	P
2	Temperature2meter max error	P	5	0.5	3	0.35	c	P
3	Flow Rate average % difference	P	10	5	6	11.07	%	Fail
4	Flow Rate max % difference	P	10	5	6	11.48	%	Fail
5	DAS Voltage average error	P	9	0.003	70	0.0004	V	P
6	Shelter Temperature average error	P	5	2	24	0.56	c	P
7	Shelter Temperature max error	P	5	2	24	1.28	c	P

SiteVisitDate	Site	Technician
10/19/2021	THR422	Martin Valvur

Field Performance Comments

- 1 **Parameter:** Flow Rate **SensorComponent:** Leak Test **CommentCode:** 207
The dry deposition sample tubing is broken and air is not being pulled through the filter pack.

Field Systems Comments

- 1 **Parameter:** SiteOpsProcComm
Gloves are not used to handle the filter pack. The filter bag is used as a glove.
- 2 **Parameter:** DasComments
The met tower is no longer in use.
- 3 **Parameter:** SiteOpsProcedures
The ozone sample train does not have a means to introduce test gas at the sample inlet. Results of routine zero, span, precision, and any multipoint calibration checks are maintained by the state personnel who perform the tests. The two inlet filters in the sample train are creating a large pressure drop.
- 4 **Parameter:** SitingCriteriaCom
The site is located 200 meters from an interstate rest area, and 300 meters from interstate 94. The rest area can have parked and idling vehicles for extended periods.
- 5 **Parameter:** ShelterCleanNotes
The shelter is in good condition, clean and well organized.
- 6 **Parameter:** PollAnalyzerCom
The ozone monitor is operated by the state of North Dakota.
- 7 **Parameter:** MetSensorComme
The 2-meter temperature sensor is mounted to the sample tower, which is attached to the site shelter. The sensor is 3.7 meters above ground and close to the shelter.