
2022 – 3rd Quarter Report
Support for Conducting Systems &
Performance Audits of Clean Air Status and
Trends Network (CASTNET) Sites and
National Atmospheric Deposition Program
(NADP) Monitoring Stations - II
EPA Contract No. EP-W-18-005

Prepared for:

U. S. Environmental Protection Agency

Prepared by:



4577E NW 6th St Ext.
Gainesville, FL 32609

Report Submitted
February 2023

Table of Contents

1.0 CASTNET Quarterly Report.....	1
1.1 Introduction.....	1
1.2 Project Objectives	2
1.3 CASTNET Sites Visited Third Quarter 2022	4
1.4 Audit Results.....	5
2.0 NADP Quarterly Report	6
2.1 Introduction.....	6
2.2 Project Objectives	6
2.3 NADP Sites Visited Third Quarter 2022.....	7
2.4 Survey Results.....	8

List of Appendices

- Appendix A** CASNTET Audit Report Forms
- Appendix B** CASTNET Site Spot Report Forms

List of Tables

Table 1. Performance Audit Challenge and Acceptance Criteria.....	2
Table 2. CASTNET Site Audit Visits	4
Table 3. NADP Site Survey Visits	7

List of Acronyms and Abbreviations

% diff	percent difference
A/D	analog to digital converter
ARS	Air Resource Specialists, Inc.
ASTM	American Society for Testing and Materials
BLM	Bureau of Land Management
BLM-WSO	Bureau of Land Management – Wyoming State Office
CAL	Central Analytical Laboratory
CASTNET	Clean Air Status and Trends Network
CMAQ	Community Multiscale Air Quality
DAS	data acquisition system
deg	degree
DVM	digital voltmeter
ECCC	Environment and Climate Change Canada
EEMS	Environmental, Engineering & Measurement Services, Inc.
EPA	U.S. Environmental Protection Agency
ESC	Environmental Systems Corporation
FSA	Field Systems Audit
FSAD	Field Site Audit Database
GPS	geographical positioning system
HAL	Mercury Analytical Laboratory
LADCO	Lake Michigan Air Directors Consortium
lpm	liters per minute
ME DEP	Maine Department of Environmental Protection
MD DNR	Maryland Department of Natural Resources
MLM	Multilayer Model
MN PCA	Minnesota Pollution Control Agency
m/s	meters per second
mv	millivolt
NESCAUM	Northeast States for Coordinated Air Use Management
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPS	National Park Service
NYDEC	New York Department of Conservation
NYSERDA	New York State Energy Research and Development Authority
OH EPA	Ohio Environmental Protection Agency
PE	Performance Evaluation
QAPP	Quality Assurance Project Plan
SCDHEC	South Carolina Department of Health and Environmental Control
SFWMD	South Florida Water Management District
SOP	standard operating procedure
TDEP	Total Deposition
TEI	Thermo Environmental Instruments
USDA-FS	United States Department of Agriculture – Forest Service
USFS	United States Forest Service

USFWS	United States Fish and Wildlife Service
USGS	United States Geological Survey
USNO	United States Naval Observatory
VDC	volts direct current
WDEQ	Wyoming Department of Environmental Quality
WDNR	Wisconsin Department of Natural Resources
WRR	World Radiation Reference
WSLH	Wisconsin State Laboratory of Hygiene

1.0 CASTNET Quarterly Report

1.1 Introduction

The Clean Air Status and Trends Network (CASTNET) is a national air monitoring program established in 1988 by the US EPA. Nearly all CASTNET sites measures weekly concentrations of acidic gases and particles to provide accountability for EPA’s emission reduction programs. Most sites measure ground-level ozone as well as supplemental measurements such as meteorology and/or other trace gas concentrations.

Ambient concentrations are used to estimate deposition rates of the various pollutants with the objective of determining relationships between emissions, air quality, deposition, and ecological effects. In conjunction with other national monitoring networks, CASTNET data are used to determine the effectiveness of national emissions control programs and to assess temporal trends and spatial deposition patterns in atmospheric pollutants. CASTNET data are also used for long-range transport model evaluations and critical loads research.

Historically, CASTNET pollutant flux measurements have been reported as the aggregate product of weekly measured concentrations and model-estimated deposition velocities. The Multi-layer Model (MLM) was used to derive deposition velocity estimates from on-site meteorological parameters, land use types, and site characteristics. In 2011, EPA discontinued meteorological measurements at most EPA-sponsored CASTNET sites.

Currently, CASTNET pollutant flux estimates are calculated as the aggregate product of weekly measured chemical concentrations and gridded model-estimated deposition velocities. Total deposition is assessed using the NADP’s Total Deposition Hybrid Method (TDEP; EPA, 2015c; Schwede and Lear, 2014), which combines data from established ambient monitoring networks and chemical-transport models. To estimate dry deposition, ambient measurement data from CASTNET and other networks were merged with dry deposition rates and flux output from the Community Multiscale Air Quality (CMAQ) modeling system.

Since 2011 nearly all CASTNET ozone monitors have adhered to the requirements for State or Local Air Monitoring Stations (SLAMS) as specified by the EPA in 40 CFR Part 58. As such, the ozone data collected must meet the requirements in 40 CFR Part 58 Appendix A, which defines the quality assurance (QA) requirements for gaseous pollutant ambient air monitoring. The audits performed by EEMS under this contract fulfilled the requirement for annual performance evaluation audits of pollutant monitors in the network. The QA requirements can be found at:

<https://www.epa.gov/amtic/regulations-guidance-and-monitoring-plans>

Currently 87 CASTNET sites at 85 distinct locations measure ground-level ozone concentrations. Annual performance evaluation (PE), ozone audit data are submitted to the Air Quality System (AQS) database.

EPA suspended the operation of several sites throughout the US in second quarter 2022. They remain suspended as of the date of this report.

As of October 2022, the network is comprised of 110 active rural sampling sites across the United States and Canada, cooperatively operated by the Environmental Protection Agency (EPA), the National Park Service (NPS), Bureau of Land Management – Wyoming State Office (BLM-WSO) and several independent partners. WSP (formally Wood Environment and Infrastructure Solutions) is responsible for operating the EPA sponsored sites, and Air Resource Specialists, Inc. (ARS) is responsible for operating the NPS and BLM-WSO sponsored sites

1.2 Project Objectives

The objectives of this project are to establish an independent and unbiased program of performance and systems audits for all CASTNET sampling sites. Ongoing Quality Assurance (QA) programs are an essential part of any long-term monitoring network.

Performance audits verify that all reported variables are consistent with the accuracy goals as defined in the CASTNET Quality Assurance Project Plan (QAPP). The parameter specific accuracy goals are presented in Table 1.

Table 1. Performance Audit Challenge and Acceptance Criteria

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Precipitation	Response	10 manual tips	1 DAS count per tip
Precipitation	Accuracy	2 introductions of known amounts of water	$\leq \pm 10.0\%$ of input amount
Relative Humidity	Accuracy	Compared to reference instrument or standard solution	$\leq \pm 10.0\%$ RH
Solar Radiation	Accuracy	Compared to WRR traceable standard	$\leq \pm 10.0\%$ of daytime average
Surface Wetness	Response	Distilled water spray mist	Positive response
Surface Wetness	Sensitivity	1% decade resistance	N/A
Temperature	Accuracy	Comparison to 3 NIST measured baths (~ 0° C, ambient, ~ full-scale)	$\leq \pm 0.5^\circ$ C

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Temperature Difference	Accuracy	Comparison to station temperature sensor	$\leq \pm 0.50^{\circ} \text{ C}$
Shelter Temperature	Accuracy	Comparison to station temperature sensor	$\leq \pm 2.0^{\circ} \text{ C}$
Wind Direction	Orientation Accuracy	Parallel to alignment rod/crossarm, or sighted to distant point	$\leq \pm 5^{\circ}$ from degrees true
Wind Direction	Linearity	Eight cardinal points on test fixture	$\leq \pm 5^{\circ}$ mean absolute error
Wind Direction	Response Threshold	Starting torque tested with torque gauge	< 10 g-cm Climatronics; < 20 g-cm R.M. Young
Wind Speed	Accuracy	Shaft rotational speed generated and measured with certified synchronous motor	$\leq \pm 0.5$ mps below 5.0 mps input; $\leq \pm 5.0\%$ of input at or above 5.0 mps
Wind Speed	Starting Threshold	Starting torque tested with torque gauge	< 0.5 g-cm
Mass Flow Controller	Flow Rate	Comparison with Primary Standard	$\leq \pm 5.0\%$ of designated rate
Ozone	Slope	Linear regression of multi-point test gas concentration as measured with a certified transfer standard	$0.9000 \leq m \leq 1.1000$
Ozone	Intercept		$-5.0 \text{ ppb} \leq b \leq 5.0 \text{ ppb}$
Ozone	Correlation Coefficient		$0.9950 \leq r$
Ozone	Percent Difference	Comparison with Level 2 standard concentration	$\leq \pm 15.1\%$ of test gas concentration and $\leq \pm 0.0015$ ppm actual difference
DAS	Accuracy	Comparison with certified standard	$\leq \pm 0.003$ VDC

Performance audits are conducted using standards that are traceable to the National Institute of Standards and Technology (NIST), or another authoritative organization, at least annually.

Field site systems audits (FSA) are intended to provide a qualitative appraisal of the total measurement system. Site planning, organization, and operation are evaluated to ensure that good Quality Assurance/Quality Control (QA/QC) practices are being applied. At a minimum the following audit issues were addressed at each site systems audit:

- Site locations and configurations match those provided in the CASTNET QAPP.
- Meteorological instruments are in good physical and operational condition and are sited to meet EPA ambient monitoring guidelines (EPA-600/4-82-060).
- Sites are accessible, orderly, and if applicable, compliant with OSHA safety standards.

- Sampling lines are free of leaks, kinks, visible contamination, weathering, and moisture.
- Site shelters provide adequate temperature control.
- All ambient air quality instruments are functional, being operated in the appropriate range, and the zero-air supply desiccant is unsaturated.
- All instruments are in current calibration.
- Site documentation (maintenance schedules, on-site SOPs, etc.) is current and log book records are complete.
- All maintenance and on-site SOPs are performed on schedule.
- Corrective actions are documented and appropriate for required maintenance/repair activity.
- Site operators demonstrate an adequate knowledge and ability to perform required site activities, including documentation and maintenance activities.

1.3 CASTNET Sites Visited Third Quarter 2022

This report consists of the systems and performance, and other audit results from the CASTNET sites visited during the third quarter (July through September) of 2022. The site locations, sponsor, visit dates, and parameters audited, are included in Table 2.

Table 2. CASTNET Site Audit Visits

Site ID	Sponsor	Date	FSA	O3 PE	SO2	CO	NOy	FLOW
ROM206	EPA	7/6/2022					1	
PED108	EPA	7/12/2022		1				
PAR107	EPA	7/14/2022		1				
WSP144	EPA	7/15/2022		1				
CAT175	EPA	7/20/2022	1					1
CHC432	NPS	7/25/2022		1				
EGB181	EPA	8/2/2022	1					1
GLR468	NPS	8/2/2022		1				
CNT169	EPA	8/9/2022		1				
CTH110	EPA	8/16/2022	1	1				1
SHN418	NPS	8/26/2022		1				
ZIO433	NPS	9/9/2022		1				
ALH157	EPA	9/10/2022		1				
BVL130	EPA	9/10/2022		1	1	1	1	
JOT403	NPS	9/13/2022	1	1				1

1.4 Audit Results

The observations and results of the systems, performance, and Ozone PE audits are included in Appendix A, *CASTNET Audit Report Forms* by site, arranged by audit date. Photographs of site conditions are included within each system report where necessary. Copies of the spot reports that were sent following the audit of each site are included as Appendix B, *CASTNET Site Spot Report Forms*.

Results of the PE audits of the gaseous pollutant monitors other than ozone, were submitted immediately following the PE and are not included in this report. All TTP PE results of gaseous pollutant monitors are uploaded to AQS and are available there. All audit data and reports are available from the EPA CASTNET website: <https://java.epa.gov/castnet/reportPage.do>

2.0 NADP Quarterly Report

2.1 Introduction

The National Atmospheric Deposition Program (NADP) operates two precipitation chemistry networks and two atmospheric concentration networks. The National Trends Network (NTN) has been measuring acidic precipitation since 1978. The network currently has more than 250 sites. The precipitation event-based Atmospheric Integrated Research Monitoring Network (AIRMOn) began operation in 1992, and as of July 2019 is no longer in operation. The Mercury Deposition Network (MDN) measures total mercury in precipitation samples from approximately 90 stations. The MDN began operation in 1996 and includes sites throughout the US and Canada. The Atmospheric Mercury Network (AMNet) and the Ammonia Monitoring Network (AMoN) measure ambient concentrations of mercury and ammonia, respectively.

The NADP and other long-term monitoring networks provide critical information to the EPA regarding evaluating the effectiveness of emission reduction control programs from the power industry. The networks of the NADP are sponsored by several federal, state, and local agencies as well as private organizations.

The NADP Program Office (PO) operates and administers the two precipitation chemistry networks (NTN and MDN), two atmospheric concentration networks (AMNet and AMoN), and two analytical laboratories (CAL and HAL), from the Wisconsin State Lab of Hygiene (WSLH) at the University of Wisconsin in Madison. The network equipment depot (NED) is also located at the WSLH.

2.2 Project Objectives

The objective of this project is to perform independent and unbiased evaluations of the sites and their operation. These evaluations provide quality assurance pertaining to siting, sample collection and handling, equipment operation and maintenance, record keeping and field laboratory procedures.

More specifically, the surveys determine and report findings based on an established methodology consisting of completing a site questionnaire, testing the equipment and documenting with photographs the location, siting criteria, existing equipment, and any issues encountered that require such documentation.

2.3 NADP Sites Visited Third Quarter 2022

This report presents the NADP sites surveyed during the third quarter (July through September) of 2022. The station locations, sponsors, network, and dates of the surveys are presented in Table 3.

Table 3. NADP Site Survey Visits

Site ID	Sponsor	Date	NTN	MDN	AMoN
CO19	National Park Service - NIFA	7/5/2022	1		
CO88	National Park Service - NIFA	7/6/2022			1
CO21	USDA-FS-Fed 7	7/12/2022	1		
VA24	WSP - EPA	7/12/2022			1
CO01	USGS - NIFA	7/13/2022	1		
CO00	USGS - NIFA	7/14/2022	1		
WV18	WSP - EPA	7/14/2022			1
CO10	WSP - EPA	7/15/2022	1		
NJ99	WSP - EPA	7/15/2022			1
CO02	University of Colorado	7/19/2022	1		
CO90	University of Colorado	7/19/2022	1		
CO09	National Park Service - NIFA	7/20/2022	1		
NY91	WSP - EPA	7/20/2022			1
CAN5	USGS - NIFA	7/25/2022	1		
CO96	BLM – NIFA / USDA-FS-Fed 7	7/26/2022	1	1	
NY98	USGS – NIFA / WSP - EPA	7/26/2022	1		1
CO08	WSP - EPA	7/27/2022	1		
UT95	USDA - Forest Service - NIFA	7/28/2022	1		
MT97	USDA-FS-Fed 7	8/1/2022	1		
ON07	Environment Canada	8/2/2022	1		
MT98	USGS - NIFA	8/3/2022	1		
SK31	Saskatchewan Ministry of Environment	8/3/2022			1
ME98	National Park Service - NIFA	8/4/2022	1		
SK20	Saskatchewan Ministry of Environment	8/4/2022	1		
ME94	Passamaquoddy Tribe	8/5/2022	1		
SK27	Environment Canada	8/5/2022		1	1
AB34	Wood Buffalo Environmental Association	8/8/2022	1		
AB32	Wood Buffalo Environmental Association	8/9/2022	1		
AB36	Wood Buffalo Environmental Association	8/9/2022	1		

Site ID	Sponsor	Date	NTN	MDN	AMoN
NH02	USDA - Forest Service - NIFA	8/9/2022	1		
VT01	USGS - NIFA	8/9/2022		1	
WY95	USDA - Forest Service – NIFA/ WSP - EPA	8/9/2022	1		1
NY67	NOAA – NIFA / WSP - EPA	8/16/2022	1		1
NY01	USGS - NIFA	8/17/2022	1		
WY00	USDA - Forest Service - NIFA	8/23/2022	1		
VA28	National Park Service - NIFA	8/26/2022	1	1	
CO91	USDA-FS-Fed 7	9/6/2022	1		
UT99	National Park Service - NIFA	9/9/2022	1		
IL46	WSP - EPA	9/10/2022			1
IL11	WSP - EPA	9/11/2022			1
CA67	National Park Service - NIFA	9/13/2022			1
WI31	Wisconsin Department of Natural Resources	9/13/2022	1	1	
WI35	WSP - EPA	9/14/2022	1		1
MN06	Leech Lake Band of Ojibwe	9/25/2022		1	
IA23	USGS - NIFA	9/26/2022	1		
IA08	USGS - NIFA	9/27/2022	1		
SD99	USGS - NIFA	9/29/2022	1		
WI37	USDA - Forest Service - NIFA	9/30/2022	1		

2.4 Survey Results

Site survey results are entered into a relational database. The database in turn generates Site Spot Reports which are distributed among the interested parties as soon as all the site data has been entered. Database tables with all the data collected and reviewed are then sent to the NADP Program Office and to the U.S. EPA Project Officers.

Other items gathered during the surveys (i.e., photographs, Belfort charts, etc.) are uploaded to the EPA OneDrive account where the NADP PO and the U.S. EPA POs can access them and download them as needed.

Given the volume of data generated, and the fact that data is distributed and/or is available via the internet, no survey results are included in this report.

APPENDIX A

CASTNET Audit Report Forms

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
PED108-Korey Devins-07/12/2022						
1	7/12/2022	DAS	Campbell	000406	CR3000	2511
2	7/12/2022	Ozone	ThermoElectron Inc	000732	49i A1NAA	1105347319
3	7/12/2022	Ozone Standard	ThermoElectron Inc	000214	49i A3NAA	0622717855
4	7/12/2022	Zero air pump	Werther International	06883	C 70/4	000815257

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347319

PED108

Korey Devins

07/12/2022

Ozone

000732

Slope:

1.00864

Slope:

0.00000

Intercept

0.01000

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00120

Intercept

0.25470

Cert Date

1/26/2022

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.38	0.12	0.19	ppb		0.07	
primary	2	16.57	16.24	16.46	ppb		0.22	
primary	3	36.58	36.17	36.28	ppb	0.3		
primary	4	68.34	67.80	68.46	ppb	0.97		
primary	5	111.83	111.11	112.10	ppb	0.89		

Sensor Component

Audit Pressure

Condition

745.5 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.1

Status

pass

Sensor Component

Span

Condition

1.031

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

91.7 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.6 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.64 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

701.8 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

36.0 C

Status

pass

Sensor Component

Cell B Freq.

Condition

109.1 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.6 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.56 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

702.7 mmHg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>PAR107-Korey Devins-07/14/2022</i>						
1	7/14/2022	DAS	Campbell	000333	CR3000	2112
2	7/14/2022	Ozone	ThermoElectron Inc	000624	49i A1NAA	1009241792
3	7/14/2022	Ozone Standard	ThermoElectron Inc	000436	49i A3NAA	CM08200012
4	7/14/2022	Zero air pump	Werther International	07291	C 120/TC	001071024

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241792

PAR107

Korey Devins

07/14/2022

Ozone

000624

Slope:

0.99287

Slope:

0.00000

Intercept

-0.18493

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00120

Intercept

0.25470

Cert Date

1/26/2022

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.48	0.22	0.17	ppb		-0.05	
primary	2	16.54	16.21	15.83	ppb		-0.38	
primary	3	35.96	35.55	35.10	ppb	-1.27		
primary	4	68.19	67.65	66.82	ppb	-1.23		
primary	5	108.94	108.24	107.40	ppb	-0.78		
Sensor Component	Audit Pressure		Condition	720.6 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.1		Status	pass	
Sensor Component	Span		Condition	1.006		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	93.4 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.8 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.70 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	685.8 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	37.2 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	95.3 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.8 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.70 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	686.7 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
WSP144-Korey Devins-07/15/2022						
1	7/15/2022	DAS	Campbell	000430	CR3000	2525
2	7/15/2022	Ozone	ThermoElectron Inc	000745	49i A1NAA	1105347310
3	7/15/2022	Ozone Standard	ThermoElectron Inc	000543	49i A3NAA	0929938240
4	7/15/2022	Zero air pump	Werther International	06880	C 70/4	000814273

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347310

WSP144

Korey Devins

07/15/2022

Ozone

000745

Slope:

0.98474

Slope:

0.00000

Intercept

0.12681

Intercept

0.00000

CorrCoff:

0.99996

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00120

Intercept

0.25470

Cert Date

1/26/2022

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.38	0.12	-0.27	ppb		-0.39	
primary	2	16.48	16.15	16.45	ppb		0.3	
primary	3	36.38	35.97	35.60	ppb	-1.03		
primary	4	68.61	68.07	67.46	ppb	-0.9		
primary	5	113.24	112.52	110.67	ppb	-1.66		
Sensor Component	Audit Pressure		Condition	762.5 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.000		Status	pass	
Sensor Component	Span		Condition	1.013		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	92.5 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.68 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	736.6 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	36.4 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	96.7 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.72 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	737.5 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
CAT175-Korey Devins-07/20/2022						
1	7/20/2022	DAS	Campbell	000412	CR3000	2532
2	7/20/2022	Elevation	Elevation	None	1	None
3	7/20/2022	Filter pack flow pump	Brailsford	none	TD-4X2N	1016
4	7/20/2022	Flow Rate	Apex	000603	AXMC105LPMDPCV	illegible
5	7/20/2022	Infrastructure	Infrastructure	none	none	none
6	7/20/2022	Modem	Digi	07201	LR54	Illegible
7	7/20/2022	Sample Tower	Aluma Tower	666359	B	none
8	7/20/2022	Shield (10 meter)	RM Young	none	41003	none
9	7/20/2022	Siting Criteria	Siting Criteria	None	1	None
10	7/20/2022	Temperature	RM Young	06409	41342VO	14042
11	7/20/2022	UPS	ProSine	04576	1000w	unknown

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		CAT175	Korey Devins	07/20/2022	Flow Rate	000603

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99384	Intercept	0.00125
Cert Date	2/4/2022	CorrCoff	0.99990

DAS 1:	DAS 2:	Cal Factor Zero	0.003
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
34.96%	35.24%		
		Cal Factor Full Scale	0.975
		Rotometer Reading:	2.5

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	-0.03	l/m	l/m	
primary	test pt 1	2.293	2.310	1.54	0.000	1.50	l/m	l/m	-34.98%
primary	test pt 2	2.291	2.300	1.54	0.000	1.50	l/m	l/m	-34.65%
primary	test pt 3	2.300	2.310	1.54	0.000	1.50	l/m	l/m	-35.24%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	195 cm	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14042		CAT175	Korey Devins	07/20/2022	Temperature	06409

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232734	Tfer Desc.	RTD
		Tfer ID	01227		
		Slope	1.00983	Intercept	0.15548
		Cert Date	2/10/2022	CorrCoff	1.00000

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.14	0.21		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.37	0.21	0.000	0.4	C	0.21
primary	Temp Mid Range	30.65	30.20	0.000	30.1	C	-0.09
primary	Temp High Range	42.80	42.23	0.000	42.1	C	-0.12

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID

CAT175

Technician

Korey Devins

Site Visit Date

07/20/2022

Shelter Make	Shelter Model	Shelter Size
Ekto	8810 (s/n 1977-1)	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	N/A	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Poor	Status	Fail
Sensor Component	Shelter Door	Condition	Fair	Status	pass
Sensor Component	Shelter Roof	Condition	Fair	Status	pass
Sensor Component	Shelter Floor	Condition	Poor	Status	Fail
Sensor Component	Shelter walls	Condition	Poor	Status	Fail
Sensor Component	Excessive mold present	Condition	Poor	Status	Fail
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

1 **Parameter:** DasComments

The shelter is not temperature controlled. The site is solar and DC battery powered. The met tower has been removed and the temperature is being measured from the sample tower at 10 meters above ground.

2 **Parameter:** DocumentationCo

The site copies of the SSRF are no longer kept onsite.

3 **Parameter:** ShelterCleanNotes

The shelter is seriously deteriorated with rot and mold on the walls. The vegetation has been allowed to grow. The shelter roof has been repaired.

4 **Parameter:** PollAnalyzerCom

Ozone monitoring is no longer being conducted at the site.

Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID CAT175 Technician Korey Devins Site Visit Date 07/20/2022

Site Sponsor (agency)	EPA	USGS Map	Claryville
Operating Group	private	Map Scale	
AQS #		Map Date	
Meteorological Type	R.M. Young		
Air Pollutant Analyzer	Ozone	QAPP Latitude	41.9423
Deposition Measurement	dry	QAPP Longitude	-74.5519
Land Use	woodland - mixed	QAPP Elevation Meters	765
Terrain	complex	QAPP Declination	13.5
Conforms to MLM	No	QAPP Declination Date	2/22/2006
Site Telephone	(845) 798-0947	Audit Latitude	41.942325
Site Address 1	Wildcat Mt. Road	Audit Longitude	-74.551999
Site Address 2		Audit Elevation	754
County	Ulster	Audit Declination	-13.2
City, State	Claryville, NY		
Zip Code	12725	Fire Extinguisher <input checked="" type="checkbox"/>	New in 2015
Time Zone	Eastern	First Aid Kit <input checked="" type="checkbox"/>	
Primary Operator		Safety Glasses <input type="checkbox"/>	
Primary Op. Phone #		Safety Hard Hat <input checked="" type="checkbox"/>	
Primary Op. E-mail		Climbing Belt <input type="checkbox"/>	
Backup Operator		Security Fence <input type="checkbox"/>	
Backup Op. Phone #		Secure Shelter <input checked="" type="checkbox"/>	
Backup Op. E-mail		Stable Entry Steps <input type="checkbox"/>	
Shelter Working Room <input checked="" type="checkbox"/>	Make Ekto	Model 8810 (s/n 1977-1)	Shelter Size 640 cuft
Shelter Clean <input checked="" type="checkbox"/>	Notes	The shelter is seriously deteriorated with rot and mold on the walls. The vegetation has been allowed to grow. The shelter roof has been repaired.	
Site OK <input checked="" type="checkbox"/>	Notes		
Driving Directions	From Liberty, NY go west on route 52 toward Grahamsville. Just before reaching Grahamsville, turn left onto County Road 19 to Claryville. Stay on 19 through Claryville and turn left on Wildcat Mt Road immediately after crossing the bridge at the far end of town. Bear right and follow the semi-paved road for about 0.7 miles to the fork. Go right at the fork and turn left at the first house on the left. The site is about .75 miles up the dirt road behind the house.		

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

CAT175

Technician

Korey Devins

Site Visit Date

07/20/2022

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CAT175

Technician

Korey Devins

Site Visit Date

07/20/2022

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	Natural aspiration
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	N/A
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CAT175

Technician

Korey Devins

Site Visit Date

07/20/2022

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	Ozone not measured
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		N/A
4	Describe dry dep sample tube.		3/8 teflon by 18 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input type="checkbox"/>	N/A
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input type="checkbox"/>	N/A
8	Are there moisture traps in the sample lines?	<input type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Ozone monitoring is no longer being conducted at the site.

Site ID

CAT175

Technician

Korey Devins

Site Visit Date

07/20/2022

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>	
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>	
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>	
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>	
7	Does the instrument shelter have a stable power source?	<input type="checkbox"/>	Solar power
8	Is the instrument shelter temperature controlled?	<input type="checkbox"/>	Shelter not temperature controlled
9	Is the met tower stable and grounded?	<div><div>Stable</div><div><input type="checkbox"/></div><div><input checked="" type="checkbox"/></div></div>	<div><div>Grounded</div><div><input type="checkbox"/></div><div><input checked="" type="checkbox"/></div></div>
10	Is the sample tower stable and grounded?		
11	Tower comments?		Met tower removed

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The shelter is not temperature controlled. The site is solar and DC battery powered. The met tower has been removed and the temperature is being measured from the sample tower at 10 meters above ground.

Site ID

CAT175

Technician

Korey Devins

Site Visit Date

07/20/2022

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2015	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site copies of the SSRF are no longer kept onsite.

Site ID

CAT175

Technician

Korey Devins

Site Visit Date

07/20/2022

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

N/A

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☐

N/A

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☐

N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CAT175

Technician

Korey Devins

Site Visit Date

07/20/2022

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings 95% of the time
2	Are the Site Status Report Forms being completed and filed correctly?	<input type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input type="checkbox"/>	
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

CAT175

Technician

Korey Devins

Site Visit Date

07/20/2022

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR3000	2532	000412
Elevation	Elevation	1	None	None
Filter pack flow pump	Brailsford	TD-4X2N	1016	none
Flow Rate	Apex	AXMC105LPMDPC	illegible	000603
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07201
Sample Tower	Aluma Tower	B	none	666359
Shield (10 meter)	RM Young	41003	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	14042	06409
UPS	ProSine	1000w	unknown	04576

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
CHC432-Martin Valvur-07/25/2022						
1	7/25/2022	DAS	Environmental Sys Corp	none	8832	A4871K
2	7/25/2022	Ozone	ThermoElectron Inc	none	49i A3NAA	0733726153
3	7/25/2022	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1152780006
4	7/25/2022	Zero air pump	Werther International	none	P 70/4	000756726

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

0733726153

CHC432

Martin Valvur

07/25/2022

Ozone

none

Slope:

0.96056

Slope:

0.00000

Intercept

-1.65060

Intercept

0.00000

CorrCoff:

0.99943

CorrCoff:

0.00000

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00520

Intercept

-0.00890

Cert Date

1/26/2022

CorrCoff

1.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.03	0.03	0.13	ppb		0.1	
primary	2	15.05	14.97	12.38	ppb		-2.59	
primary	3	36.60	36.39	31.33	ppb	-14.94		
primary	4	65.60	65.22	60.67	ppb	-7.23		
primary	5	110.11	109.47	104.40	ppb	-4.74		
Sensor Component	Audit Pressure			Condition	608 mmHg	Status	pass	
Sensor Component	26.6 degree unobstructed rule			Condition	True	Status	pass	
Sensor Component	Tree dewline >10m or below inlet			Condition	True	Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t			Condition	True	Status	pass	
Sensor Component	ADT <1000 vehicles further than 5			Condition	True	Status	pass	
Sensor Component	Sample Train			Condition	Good	Status	pass	
Sensor Component	Inlet Filter Condition			Condition	Clean	Status	pass	
Sensor Component	Offset			Condition	-0.1	Status	pass	
Sensor Component	Span			Condition	1.004	Status	pass	
Sensor Component	Zero Voltage			Condition	N/A	Status	pass	
Sensor Component	Fullscale Voltage			Condition	N/A	Status	pass	
Sensor Component	Cell A Freq.			Condition	119.6 kHz	Status	pass	
Sensor Component	Cell A Noise			Condition	1.5 ppb	Status	pass	
Sensor Component	Cell A Flow			Condition	0.69 lpm	Status	pass	
Sensor Component	Cell A Pressure			Condition	599.2 mmHg	Status	pass	
Sensor Component	Cell A Tmp.			Condition	39.1 C	Status	pass	
Sensor Component	Cell B Freq.			Condition	78.6 kHz	Status	pass	
Sensor Component	Cell B Noise			Condition	1.1 ppb	Status	pass	
Sensor Component	Cell B Flow			Condition	0.62 lpm	Status	pass	
Sensor Component	Cell B Pressure			Condition	598.9 mmHg	Status	pass	
Sensor Component	System Memo			Condition		Status	pass	

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
GLR468-Martin Valvur-08/02/2022						
1	8/2/2022	DAS	Environmental Sys Corp	None	8864	C2600
2	8/2/2022	Ozone	ThermoElectron Inc	none	49i A3NCA	1201477661
3	8/2/2022	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	0733726104
4	8/2/2022	Zero air pump	Werther International	none	C 120/TC	001007354

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1201477661

GLR468

Martin Valvur

08/02/2022

Ozone

none

Slope:

1.01058

Slope:

0.00000

Intercept

0.11949

Intercept

0.00000

CorrCoff:

0.99999

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00520

Intercept

-0.00890

Cert Date

1/26/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.18	-0.17	0.22	ppb		0.39	
primary	2	14.88	14.80	14.92	ppb		0.12	
primary	3	35.22	35.02	35.50	ppb	1.36		
primary	4	65.41	65.03	65.54	ppb	0.78		
primary	5	115.85	115.17	116.70	ppb	1.32		

Sensor Component

Audit Pressure

Condition

679 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

0.4

Status

pass

Sensor Component

Span

Condition

1.035

Status

pass

Sensor Component

Zero Voltage

Condition

0.0009

Status

pass

Sensor Component

Fullscale Voltage

Condition

1.0013

Status

pass

Sensor Component

Cell A Freq.

Condition

136.4 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

1.1 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.64 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

663.8 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

34.4 C

Status

pass

Sensor Component

Cell B Freq.

Condition

89.3 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.9 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.66 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

663.5 mmHg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
EGB181-Korey Devins-08/02/2022						
1	8/2/2022	Computer	Dell	07018	Inspiron 15	Unknown
2	8/2/2022	DAS	Campbell	000408	CR3000	2538
3	8/2/2022	Elevation	Elevation	None	1	None
4	8/2/2022	Filter pack flow pump	Thomas	missing	107CAB18	110400000912
5	8/2/2022	Flow Rate	Apex	000469	AXMC105LPMDPCV	illegible
6	8/2/2022	Infrastructure	Infrastructure	none	none	none
7	8/2/2022	Modem	Digi	07170	LR54	Illegible
8	8/2/2022	Sample Tower	Aluma Tower	missing	B	unknown
9	8/2/2022	Shelter Temperature	Campbell	none	107-L	none
10	8/2/2022	Siting Criteria	Siting Criteria	None	1	None
11	8/2/2022	Temperature	RM Young	05044	41342VO	9640

DAS Data Form

DAS Time Max Error: 1.25

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2538	EGB181	Korey Devins	08/02/2022	DAS	Primary

Das Date:	8 /2 /2022	Audit Date	8 /2 /2022
Das Time:	08:27:00	Audit Time	08:25:45
Das Day:	214	Audit Day	214
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0001	0.0001	0.0001

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	2/8/2022	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0001	0.0000	V	V	0.0001	
7	0.1000	0.0999	0.0999	V	V	0.0000	
7	0.3000	0.2997	0.2997	V	V	0.0000	
7	0.5000	0.4996	0.4995	V	V	-0.0001	
7	0.7000	0.6995	0.6994	V	V	-0.0001	
7	0.9000	0.8993	0.8992	V	V	-0.0001	
7	1.0000	0.9992	0.9991	V	V	-0.0001	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		EGB181	Korey Devins	08/02/2022	Flow Rate	000469

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99384	Intercept	0.00125
Cert Date	2/4/2022	CorrCoff	0.99990

DAS 1:	DAS 2:	Cal Factor Zero	-0.005
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.22%	0.40%		
		Cal Factor Full Scale	0.995
		Rotometer Reading:	1.4

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.50	0.000	-0.23	l/m	l/m	
primary	leak check	0.000	0.000	-0.01	0.000	-0.02	l/m	l/m	
primary	test pt 1	1.492	1.500	1.51	0.000	1.49	l/m	l/m	-0.40%
primary	test pt 2	1.491	1.500	1.50	0.000	1.50	l/m	l/m	0.07%
primary	test pt 3	1.495	1.500	1.50	0.000	1.50	l/m	l/m	0.20%

Sensor Component	Leak Test	Condition		Status	Fail
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	3.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	9640		EGB181	Korey Devins	08/02/2022	Temperature	05044

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00983	Intercept	0.15548
Cert Date	2/10/2022	CorrCoff	1.00000

0.19	0.21		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.44	0.28	0.000	0.1	C	-0.15	
primary	Temp Mid Range	26.55	26.14	0.000	25.9	C	-0.2	
primary	Temp High Range	44.98	44.39	0.000	44.2	C	-0.21	

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID

EGB181

Technician

Korey Devins

Site Visit Date

08/02/2022

Shelter Make

custom

Shelter Model

N/A

Shelter Size

7200 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

1 Parameter: SiteOpsProcComm

Filters are sent 4 at a time and stored in a refrigerator before and after sampling prior to shipment to the lab.

2 Parameter: DocumentationCo

The site operator does not use the logbook.

3 Parameter: ShelterCleanNotes

The shelter is provided by the Center for Atmospheric Research and is clean, organized, and spacious. The roof has been repaired.

4 Parameter: PollAnalyzerCom

Ozone concentration is not measured at EGB181 as part of CASTNET.

Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA/Envir Canada"/>	USGS Map	<input type="text"/>
Operating Group	<input type="text" value="Envir Canada"/>	Map Scale	<input type="text"/>
AQS #	<input type="text"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="SO2, NOx, NOy, More"/>	QAPP Latitude	<input type="text" value="44.2317"/>
Deposition Measurement	<input type="text" value="dry, wet, CAPMon"/>	QAPP Longitude	<input type="text" value="-79.7840"/>
Land Use	<input type="text" value="Agriculture"/>	QAPP Elevation Meters	<input type="text" value="251"/>
Terrain	<input type="text" value="gently rolling"/>	QAPP Declination	<input type="text" value="10.75"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text" value="9/16/2005"/>
Site Telephone	<input type="text" value="(705) 458-3309"/>	Audit Latitude	<input type="text" value="44.231071"/>
Site Address 1	<input type="text" value="Center for Atmospheric Research"/>	Audit Longitude	<input type="text" value="-79.783115"/>
Site Address 2	<input type="text" value="6248 Eighth Line"/>	Audit Elevation	<input type="text" value="227"/>
County	<input type="text"/>	Audit Declination	<input type="text" value="-10.4"/>
City, State	<input type="text" value="Egbert, Ontario"/>		
Zip Code	<input type="text" value="CAN L0L 1N0"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="inspected Oct 2019"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Steps <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room ☒ Make Model Shelter Size

Shelter Clean ☒ Notes

Site OK ☒ Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

EGB181

Technician

Korey Devins

Site Visit Date

08/02/2022

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

EGB181

Technician

Korey Devins

Site Visit Date

08/02/2022

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

EGB181

Technician

Korey Devins

Site Visit Date

08/02/2022

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		N/A
4	Describe dry dep sample tube.		3/8 teflon by 20 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input type="checkbox"/>	N/A
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input type="checkbox"/>	N/A
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Ozone concentration is not measured at EGB181 as part of CASTNET.

Site ID

EGB181

Technician

Korey Devins

Site Visit Date

08/02/2022

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>									
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>									
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only								
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>									
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>									
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>									
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>									
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded									
<input type="checkbox"/>		<input type="checkbox"/>									
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>									
10	Is the sample tower stable and grounded?										
11	Tower comments?										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

EGB181

Technician

Korey Devins

Site Visit Date

08/02/2022

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☐

Logbook not used

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator does not use the logbook.

Site ID

EGB181

Technician

Korey Devins

Site Visit Date

08/02/2022

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

N/A

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☐

N/A

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☐

N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

EGB181

Technician

Korey Devins

Site Visit Date

08/02/2022

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Daily	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Filters are sent 4 at a time and stored in a refrigerator before and after sampling prior to shipment to the lab.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

EGB181

Technician

Korey Devins

Site Visit Date

08/02/2022

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07018
DAS	Campbell	CR3000	2538	000408
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	110400000912	missing
Flow Rate	Apex	AXMC105LPMDPC	illegible	000469
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07170
Sample Tower	Aluma Tower	B	unknown	missing
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	9640	05044

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
CNT169-Martin Valvur-08/09/2022						
1	8/9/2022	DAS	Campbell	000427	CR3000	2526
2	8/9/2022	Ozone	ThermoElectron Inc	000620	49i A1NAA	1009241793
3	8/9/2022	Ozone Standard	ThermoElectron Inc	000687	49i A3NAA	1030244809
4	8/9/2022	Zero air pump	Werther International	06867	C 70/4	000814279

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241793

CNT169

Martin Valvur

08/09/2022

Ozone

000620

Slope:

0.98319

Slope:

0.00000

Intercept

-0.01389

Intercept

0.00000

CorrCoff:

0.99995

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00520

Intercept

-0.00890

Cert Date

1/26/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.19	-0.18	0.10	ppb		0.28	
primary	2	14.85	14.77	14.66	ppb		-0.11	
primary	3	34.80	34.60	33.85	ppb	-2.19		
primary	4	65.30	64.92	63.09	ppb	-2.86		
primary	5	115.69	115.01	113.50	ppb	-1.32		
Sensor Component	Audit Pressure		Condition	533 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.3		Status	pass	
Sensor Component	Span		Condition	1.011		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	91.9 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.4 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.60 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	511.6 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	36.4 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	96.9 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.9 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.59 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	511.3 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

CTH110-Eric Hebert-08/16/2022

1	8/16/2022	Computer	Dell	07044	Inspiron 15	Unknown
2	8/16/2022	DAS	Campbell	000415	CR3000	2510
3	8/16/2022	Elevation	Elevation	None	1	None
4	8/16/2022	Filter pack flow pump	Thomas	02664	107CA18	1092135217
5	8/16/2022	Flow Rate	Apex	000557	AXMC105LPMDPCV	unknown
6	8/16/2022	Infrastructure	Infrastructure	none	none	none
7	8/16/2022	Modem	Digi	07208	LR54	unknown
8	8/16/2022	Ozone	ThermoElectron Inc	000735	49i A1NAA	1105347308
9	8/16/2022	Ozone Standard	ThermoElectron Inc	000447	49i A3NAA	CM08200023
10	8/16/2022	Sample Tower	Aluma Tower	666363	B	AT-5107-E-4-10
11	8/16/2022	Shelter Temperature	Campbell	none	107-L	none
12	8/16/2022	Shield (10 meter)	RM Young	none	unknown	none
13	8/16/2022	Siting Criteria	Siting Criteria	None	1	None
14	8/16/2022	Temperature	RM Young	06301	41342	12540
15	8/16/2022	Zero air pump	Werther International	06864	PC70/4	000815261

DAS Data Form

DAS Time Max Error: 0.02

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2510	CTH110	Eric Hebert	08/16/2022	DAS	Primary

Das Date:	8 /16/2022	Audit Date	8 /16/2022
Das Time:	13:40:59	Audit Time	13:41:00
Das Day:	228	Audit Day	228
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0002	0.0001	0.0002

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	2/8/2022	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	0.0000	0.0000	V	V	0.0000	
7	0.1000	0.0998	0.0999	V	V	0.0001	
7	0.3000	0.2997	0.2996	V	V	-0.0001	
7	0.5000	0.4996	0.4995	V	V	-0.0001	
7	0.7000	0.6994	0.6993	V	V	-0.0001	
7	0.9000	0.8993	0.8992	V	V	-0.0001	
7	1.0000	0.9992	0.9990	V	V	-0.0002	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	unknown		CTH110	Eric Hebert	08/16/2022	Flow Rate	000557

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99384	Intercept	0.00125
Cert Date	2/4/2022	CorrCoff	0.99990

DAS 1:	DAS 2:	Cal Factor Zero	0.002
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
1.95%	1.95%		
		Cal Factor Full Scale	0.882
		Rotometer Reading:	1.55

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.01	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	test pt 1	1.535	1.540	1.71	0.000	1.51	l/m	l/m	-1.95%
primary	test pt 2	1.533	1.540	1.71	0.000	1.51	l/m	l/m	-1.95%
primary	test pt 3	1.534	1.540	1.71	0.000	1.51	l/m	l/m	-1.95%
Sensor Component	Leak Test	Condition		Status	pass				
Sensor Component	Tubing Condition	Condition	Good	Status	pass				
Sensor Component	Filter Position	Condition	Good	Status	pass				
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass				
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass				
Sensor Component	Filter Distance	Condition	2.0 cm	Status	pass				
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass				
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass				
Sensor Component	System Memo	Condition		Status	pass				

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347308

CTH110

Eric Hebert

08/16/2022

Ozone

000735

Slope:

1.00502

Slope:

0.00000

Intercept

-0.04515

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00120

Intercept

0.25470

Cert Date

1/26/2022

CorrCoff

0.99999

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.37	0.11	0.15	ppb		0.04	
primary	2	16.12	15.80	15.69	ppb		-0.11	
primary	3	35.93	35.52	35.68	ppb	0.45		
primary	4	69.86	69.32	69.68	ppb	0.52		
primary	5	110.03	109.32	109.80	ppb	0.44		

Sensor Component

Audit Pressure

Condition

721.5 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.10

Status

pass

Sensor Component

Span

Condition

1.003

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

117.5 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

1.2 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.67 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

679.7 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

33.6 C

Status

pass

Sensor Component

Cell B Freq.

Condition

101.4 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.8 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.58 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

680.0 kHz

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	12540		CTH110	Eric Hebert	08/16/2022	Temperature	06301

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232734	Tfer Desc.	RTD
		Tfer ID	01227		
		Slope	1.00983	Intercept	0.15548
		Cert Date	2/10/2022	CorrCoff	1.00000

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.08	0.17		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.25	0.09	0.000	0.3	C	0.17	
primary	Temp Mid Range	27.71	27.29	0.000	27.3	C	0.01	
primary	Temp High Range	48.15	47.53	0.000	47.6	C	0.07	

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	CTH110	Eric Hebert	08/16/2022	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.54	0.95		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00983	Intercept	0.15548
Cert Date	2/10/2022	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	27.31	26.89	0.000	26.8	C	-0.13	
primary	Temp Mid Range	25.96	25.55	0.000	26.5	C	0.95	
Sensor Component		System Memo		Condition		Status	pass	

Infrastructure Data For

Site ID

CTH110

Technician

Eric Hebert

Site Visit Date

08/16/2022

Shelter Make	Shelter Model	Shelter Size
Ekto	8810 (s/n 2116-6)	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Fair	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Fair	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Fair	Status	pass
Sensor Component	Excessive mold present	Condition	Fair	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

1 Parameter: DasComments

The meteorological tower has been removed and the temperature sensor has been moved to the east leg of the sample tower at 10 meters above the ground. The shield has been changed from aspirated to naturally aspirated.

2 Parameter: SiteOpsProcedures

The ozone inlet filter is replaced and a Z/S/P is performed every two weeks.

3 Parameter: SitingCriteriaCom

There is a point source north of Ithaca within 40 km of the site. The tree line is less than 50 m from the site. The siting is acceptable even with the noted exceptions. Trees and overgrowth have recently been removed from the site which has improved siting criteria.

4 Parameter: ShelterCleanNotes

The condition of the shelter walls are beginning to deteriorate.

5 Parameter: MetSensorComme

The temperature sensor is mounted on the east leg of the sample tower.

Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	CTH110	Technician	Eric Hebert	Site Visit Date	08/16/2022
Site Sponsor (agency)	EPA	USGS Map	Mecklenburg		
Operating Group	IES	Map Scale			
AQS #	36-109-9991	Map Date			
Meteorological Type	R.M. Young				
Air Pollutant Analyzer	Ozone, ammonia	QAPP Latitude	42.4010		
Deposition Measurement	dry, wet	QAPP Longitude	-76.6535		
Land Use	woodland - mixed	QAPP Elevation Meters	515		
Terrain	rolling	QAPP Declination	12.3		
Conforms to MLM	No	QAPP Declination Date	12/28/2004		
Site Telephone	(607) 564-7622	Audit Latitude	42.400875		
Site Address 1	CR 136 (Connecticut Hill Road)	Audit Longitude	-76.653516		
Site Address 2		Audit Elevation	511		
County	Tompkins	Audit Declination	-12.0		
City, State	Newfield, NY	Present			
Zip Code	14867	Fire Extinguisher	<input checked="" type="checkbox"/>	New in 2015	
Time Zone	Eastern	First Aid Kit	<input checked="" type="checkbox"/>		
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810 (s/n 2116-6)
		Shelter Size	640 cuft		
Shelter Clean	<input type="checkbox"/>	Notes	The condition of the shelter walls are beginning to deteriorate.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Ithaca take route 13 south to hwy 327. Bear right onto hwy 327 and go past both the lower and upper entrances for Robert Treman St Park. Turn left at the second left past the upper entrance to the park onto Trumbell Corners Road. Continue on Trumbell Corners Rd for approximately one mile to the stop sign. Turn right at the stop onto Connecticut Hill Road and continue for approximately 1/4 mile where it veers to the right. The site is up the hill on the left just after the turn in the road.				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

CTH110

Technician

Eric Hebert

Site Visit Date

08/16/2022

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	East
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature sensor is mounted on the east leg of the sample tower.

Site ID

CTH110

Technician

Eric Hebert

Site Visit Date

08/16/2022

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CTH110

Technician

Eric Hebert

Site Visit Date

08/16/2022

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CTH110

Technician

Eric Hebert

Site Visit Date

08/16/2022

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>									
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>									
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only								
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>									
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>									
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>									
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>									
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded									
<input type="checkbox"/>		<input type="checkbox"/>									
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>									
10	Is the sample tower stable and grounded?										
11	Tower comments?	Met tower removed									

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological tower has been removed and the temperature sensor has been moved to the east leg of the sample tower at 10 meters above the ground. The shield has been changed from aspirated to naturally aspirated.

Site ID

CTH110

Technician

Eric Hebert

Site Visit Date

08/16/2022

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2015	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	Oct 2015	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

Minimal information

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CTH110

Technician

Eric Hebert

Site Visit Date

08/16/2022

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Trained at ESE in 1987

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>			<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone inlet filter is replaced and a Z/S/P is performed every two weeks.

Site ID

CTH110

Technician

Eric Hebert

Site Visit Date

08/16/2022

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

CTH110

Technician

Eric Hebert

Site Visit Date

08/16/2022

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07044
DAS	Campbell	CR3000	2510	000415
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	1092135217	02664
Flow Rate	Apex	AXMC105LPMDPC	unknown	000557
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07208
Ozone	ThermoElectron Inc	49i A1NAA	1105347308	000735
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200023	000447
Sample Tower	Aluma Tower	B	AT-5107-E-4-10	666363
Shelter Temperature	Campbell	107-L	none	none
Shield (10 meter)	RM Young	unknown	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	12540	06301
Zero air pump	Werther International	PC70/4	000815261	06864

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
SHN418-Eric Hebert-08/26/2022						
1	8/26/2022	DAS	Environmental Sys Corp	90658	8816	2643
2	8/26/2022	Ozone	ThermoElectron Inc	none	49i A3NAA	0903334535
3	8/26/2022	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1030745083
4	8/26/2022	Zero air pump	Werther International	none	C 70/4	000855578

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

0903334535

SHN418

Eric Hebert

08/26/2022

Ozone

none

Slope:

1.00263

Slope:

0.00000

Intercept

0.17359

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00120

Intercept

0.25470

Cert Date

1/26/2022

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.47	0.21	0.50	ppb		0.29	
primary	2	16.84	16.51	16.67	ppb		0.16	
primary	3	37.17	36.76	36.90	ppb	0.38		
primary	4	69.84	69.30	69.71	ppb	0.59		
primary	5	114.64	113.91	114.40	ppb	0.43		

Sensor Component

Audit Pressure

Condition

681.5 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

0.1

Status

pass

Sensor Component

Span

Condition

1.008

Status

pass

Sensor Component

Zero Voltage

Condition

0.000

Status

pass

Sensor Component

Fullscale Voltage

Condition

1.0002

Status

pass

Sensor Component

Cell A Freq.

Condition

78.8 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.6 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.71 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

665.6 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

38.2 C

Status

pass

Sensor Component

Cell B Freq.

Condition

122 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.9 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.69 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

663.3 mmHg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
ZIO433-Martin Valvur-09/09/2022						
1	9/9/2022	DAS	Environmental Sys Corp	none	8816	4296
2	9/9/2022	Ozone	ThermoElectron Inc	90568	49C	49C-59348-322
3	9/9/2022	Ozone Standard	ThermoElectron Inc	90728	49C	49C-70528-366
4	9/9/2022	Zero air pump	Werther International	none	PC 70/4	000706556

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

49C-59348-322

ZIO433

Martin Valvur

09/09/2022

Ozone

90568

Slope:

0.98813

Slope:

0.00000

Intercept

-0.29081

Intercept

0.00000

CorrCoff:

0.99997

CorrCoff:

0.00000

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00520

Intercept

-0.00890

Cert Date

1/26/2022

CorrCoff

1.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.10	0.10	0.18	ppb		0.08	
primary	2	16.87	16.74	15.93	ppb		-0.81	
primary	3	38.53	38.23	37.11	ppb	-2.97		
primary	4	68.11	67.59	66.87	ppb	-1.07		
primary	5	112.84	111.97	110.30	ppb	-1.5		

Sensor Component

Audit Pressure

Condition

657 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Not tested

Status

pass

Sensor Component

Offset

Condition

0.3

Status

pass

Sensor Component

Span

Condition

1.013

Status

pass

Sensor Component

Zero Voltage

Condition

-0.1553

Status

pass

Sensor Component

Fullscale Voltage

Condition

2.5

Status

pass

Sensor Component

Cell A Freq.

Condition

63.8 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.9 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.70 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

641.0 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

35.9 C

Status

pass

Sensor Component

Cell B Freq.

Condition

63.7 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.5 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.69 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

640.9 mmHg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
BVL130-Eric Hebert-09/10/2022						
1	9/10/2022	DAS	Campbell	000332	CR3000	2111
2	9/10/2022	Ozone	ThermoElectron Inc	000738	49i A1NAA	1105347307
3	9/10/2022	Ozone Standard	ThermoElectron Inc	000219	49i A3NAA	0622717857
4	9/10/2022	Zero air pump	Werther International	06926	PC70/4	000836218

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347307

BVL130

Eric Hebert

09/10/2022

Ozone

000738

Slope:

1.00532

Slope:

0.00000

Intercept

-1.49059

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00120

Intercept

0.25470

Cert Date

1/26/2022

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.40	0.14	-1.36	ppb		-1.5	
primary	2	15.90	15.58	14.10	ppb		-1.48	
primary	3	35.25	34.85	33.56	ppb	-3.77		
primary	4	69.96	69.41	68.46	ppb	-1.38		
primary	5	108.92	108.22	107.20	ppb	-0.95		

Sensor Component

Audit Pressure

Condition

719 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

0.000

Status

pass

Sensor Component

Span

Condition

1.031

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

94.8 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

Not tested

Status

pass

Sensor Component

Cell A Flow

Condition

0.67 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

709.4 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

37.3 C

Status

pass

Sensor Component

Cell B Freq.

Condition

93.2 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

Not tested

Status

pass

Sensor Component

Cell B Flow

Condition

0.74 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

709.9 mmHg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
ALH157-Eric Hebert-09/10/2022						
1	9/10/2022	DAS	Campbell	000428	CR3000	2534
2	9/10/2022	Ozone	ThermoElectron Inc	000703	49i A1NAA	1030244805
3	9/10/2022	Ozone Standard	ThermoElectron Inc	000329	49i A3NAA	0622717853
4	9/10/2022	Zero air pump	Werther International	06925	C 70/4	000836220

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244805

ALH157

Eric Hebert

09/10/2022

Ozone

000703

Slope:

0.98810

Slope:

0.00000

Intercept

-1.31060

Intercept

0.00000

CorrCoff:

0.99999

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00120

Intercept

0.25470

Cert Date

1/26/2022

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.43	0.17	-0.81	ppb		-0.98	
primary	2	15.74	15.42	13.72	ppb		-1.7	
primary	3	34.65	34.25	32.39	ppb	-5.58		
primary	4	70.56	70.01	67.73	ppb	-3.31		
primary	5	116.68	115.94	113.40	ppb	-2.22		
Sensor Component	Audit Pressure		Condition	749.0 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Dirty		Status	Fail	
Sensor Component	Offset		Condition	0.1		Status	pass	
Sensor Component	Span		Condition	1.007		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	101.9 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.7 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.72 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	719.1 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	35.9 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	98.0 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.8 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.70 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	719.7 mmHg		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
<i>JOT403-Martin Valvur-09/13/2022</i>					
1	9/13/2022 DAS	Environmental Sys Corp	90599	8816	2271
2	9/13/2022 Elevation	Elevation	None	1	None
3	9/13/2022 Filter pack flow pump	Thomas	none	illegible	illegible
4	9/13/2022 flow rate	Tylan	03378	FC280AV	AW9403016
5	9/13/2022 Infrastructure	Infrastructure	none	none	none
6	9/13/2022 MFC power supply	Tylan	03683	RO-32	FP9403017
7	9/13/2022 Modem	Sierra wireless	none	GX450	Unknown
8	9/13/2022 Ozone	ThermoElectron Inc	none	49i A3NAA	1160770010
9	9/13/2022 Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1130950194
10	9/13/2022 Sample Tower	Aluma Tower	923310	B	none
11	9/13/2022 Shelter Temperature	ARS	none	none	none
12	9/13/2022 Siting Criteria	Siting Criteria	None	1	None
13	9/13/2022 Temperature2meter	RM Young	none	41342	14960
14	9/13/2022 Zero air pump	Werther International	none	PC70/4	606491

DAS Data Form

DAS Time Max Error: 0.5

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2271	JOT403	Martin Valvur	09/13/2022	DAS	Primary

Das Date:	9 /13/2022	Audit Date	9 /13/2022
Das Time:	12:28:00	Audit Time	12:28:30
Das Day:	256	Audit Day	256
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0002	0.0003	0.0002	0.0003

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/12/2022	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
2	0.0000	-0.0003	-0.0002	V	V	0.0001	
2	0.1000	0.1001	0.0998	V	V	-0.0003	
2	0.3000	0.3000	0.2999	V	V	-0.0001	
2	0.5000	0.4999	0.4996	V	V	-0.0003	
2	0.7000	0.7004	0.7005	V	V	0.0001	
2	0.9000	0.8999	0.9002	V	V	0.0003	
2	1.0000	1.0008	1.0007	V	V	-0.0001	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9403016		JOT403	Martin Valvur	09/13/2022	flow rate	03378

Mfg

Tylan

SN/Owner ID

FP9403017

03683

Parameter:

MFC power supply

Mfg

BIOS

Parameter

Flow Rate

Serial Number

148613

Tfer Desc.

BIOS 220-H

Tfer ID

01421

Slope

1.00789

Intercept

-0.00064

Cert Date

1/12/2022

CorrCoff

0.99990

DAS 1:	DAS 2:	Cal Factor Zero	0.072
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
1.12%	1.45%		
		Cal Factor Full Scale	5.522
		Rotometer Reading:	3.2

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.08	0.000	0.03	l/m	l/m	
primary	leak check	0.000	0.000	-0.07	0.000	0.04	l/m	l/m	
primary	test pt 1	2.996	2.970	2.95	0.000	3.01	l/m	l/m	1.45%
primary	test pt 2	3.003	2.980	2.96	0.000	3.01	l/m	l/m	1.04%
primary	test pt 3	3.001	2.980	2.94	0.000	3.01	l/m	l/m	0.87%

Sensor Component

Leak Test

Condition

Status

pass

Sensor Component

Tubing Condition

Condition

Good

Status

pass

Sensor Component

Filter Position

Condition

Good

Status

pass

Sensor Component

Rotometer Condition

Condition

Clean and dry

Status

pass

Sensor Component

Moisture Present

Condition

No moisture present

Status

pass

Sensor Component

Filter Distance

Condition

5.5 cm

Status

pass

Sensor Component

Filter Depth

Condition

0.3 cm

Status

pass

Sensor Component

Filter Azimuth

Condition

180 deg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1160770010

JOT403

Martin Valvur

09/13/2022

Ozone

none

Slope:

0.96908

Slope:

0.00000

Intercept

-0.39839

Intercept

0.00000

CorrCoff:

0.99998

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00520

Intercept

-0.00890

Cert Date

1/26/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.25	0.25	0.18	ppb		-0.07	
primary	2	15.15	15.04	14.02	ppb		-1.02	
primary	3	39.47	39.17	37.41	ppb	-4.6		
primary	4	65.00	64.50	61.85	ppb	-4.19		
primary	5	109.48	108.63	105.10	ppb	-3.3		

Sensor Component

Audit Pressure

Condition

658 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.1

Status

pass

Sensor Component

Span

Condition

0.998

Status

pass

Sensor Component

Zero Voltage

Condition

0.000

Status

pass

Sensor Component

Fullscale Voltage

Condition

1.0005

Status

pass

Sensor Component

Cell A Freq.

Condition

108.9 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.8 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.61 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

642.6 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

38.8 C

Status

pass

Sensor Component

Cell B Freq.

Condition

62.0 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.6 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.65 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

642.0 mmHg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14960		JOT403	Martin Valvur	09/13/2022	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	0.99980	Intercept	-0.01168
Cert Date	1/12/2022	CorrCoff	1.00000

0.24	0.41		
------	------	--	--

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.15	0.16	0.000	0.57C		0.41
primary	Temp Mid Range	21.88	21.90	0.000	21.72C		-0.18
primary	Temp High Rang	48.42	48.44	0.000	48.56C		0.12

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		JOT403	Martin Valvur	09/13/2022	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.55	1.14		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	0.99980	Intercept	-0.01168
Cert Date	1/12/2022	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.27	23.29	0.000	23.5	C	0.17
primary	Temp Mid Range	23.42	23.44	0.000	23.8	C	0.35
primary	Temp Mid Range	22.91	22.93	0.000	24.1	C	1.14
Sensor Component	System Memo		Condition		Status	pass	

Infrastructure Data For

Site ID

JOT403

Technician

Martin Valvur

Site Visit Date

09/13/2022

Shelter Make

ShelterOne

Shelter Model

E8129-28036

Shelter Size

768 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	Good	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Fair	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

- 1

Parameter:

DocumentationCo

Hardcopies of manuals and documentation are no longer maintained on site. All information is maintained on the internet.
- 2

Parameter:

ShelterCleanNotes

The shelter is in good condition, clean and well organized but not grounded.
- 3

Parameter:

MetOpMaintCom

The temperature sensor signal cable is in poor condition and should be replaced.

Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	JOT403	Technician	Martin Valvur	Site Visit Date	09/13/2022
Site Sponsor (agency)	NPS	USGS Map	Yucca Valley South		
Operating Group	NPS	Map Scale			
AQS #	06-071-9002	Map Date			
Meteorological Type	RM Young				
Air Pollutant Analyzer	Ozone, IMPROVE	QAPP Latitude	34.0714		
Deposition Measurement	dry, wet	QAPP Longitude	-116.3906		
Land Use	desert	QAPP Elevation Meters	1244		
Terrain	complex	QAPP Declination			
Conforms to MLM	No	QAPP Declination Date			
Site Telephone	(760) 228-1927	Audit Latitude	34.069569		
Site Address 1		Audit Longitude	-116.388933		
Site Address 2		Audit Elevation	1243		
County	San Bernardino	Audit Declination	12		
City, State	Yacca Valley, CA				
Zip Code	92284	Fire Extinguisher	Present	Inspected Sept 2022	
Time Zone	Pacific	First Aid Kit			
Primary Operator		Safety Glasses			
Primary Op. Phone #		Safety Hard Hat			
Primary Op. E-mail		Climbing Belt			
Backup Operator		Security Fence			
Backup Op. Phone #		Secure Shelter			
Backup Op. E-mail		Stable Entry Steps			
Shelter Working Room		Make	ShelterOne	Model	E8129-28036
Shelter Clean		Shelter Size	768 cuft		
Site OK		Notes	The shelter is in good condition, clean and well organized but not grounded.		
Driving Directions	At the intersection of route 62 and route 247 in Yucca Valley, take Joshua Lane south (route 247). Follow the signs for Joshua Tree National Monument. The site is up the dirt road through the locked gate (cable) toward the water tower. (gate lock = 1123 shelter lock = 5570)				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

JOT403

Technician

Martin Valvur

Site Visit Date

09/13/2022

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDJOT403

TechnicianMartin Valvur

Site Visit Date09/13/2022

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	N/A
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	N/A
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input type="checkbox"/>	Signs of wear
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature sensor signal cable is in poor condition and should be replaced.

Site IDJOT403

TechnicianMartin Valvur

Site Visit Date09/13/2022

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

JOT403

Technician

Martin Valvur

Site Visit Date

09/13/2022

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>						
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>						
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only					
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>						
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>						
6	Are the DAS, sensor translators, and shelter properly grounded?	<input type="checkbox"/>	Shelter not grounded					
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>						
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>						
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded						
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input type="checkbox"/>			
<input checked="" type="checkbox"/>		<input type="checkbox"/>						
11	Tower comments?	<div>The sample tower is bolted to the shelter</div>						

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

JOT403

Technician

Martin Valvur

Site Visit Date

09/13/2022

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	Dataview	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

Dataview

2

Are the Site Status Report Forms being completed and current?

☒

Flow & observation sections

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Hardcopies of manuals and documentation are no longer maintained on site. All information is maintained on the internet.

Site ID

JOT403

Technician

Martin Valvur

Site Visit Date

09/13/2022

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

ARS provides refresher training during maintenance visits

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by previous operator

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>		<input type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	Alarm values only	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>		<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Dataview

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

JOT403

Technician

Martin Valvur

Site Visit Date

09/13/2022

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Every 2 weeks	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

JOT403

Technician

Martin Valvur

Site Visit Date

09/13/2022

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Environmental Sys Corp	8816	2271	90599
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	illegible	illegible	none
flow rate	Tylan	FC280AV	AW9403016	03378
Infrastructure	Infrastructure	none	none	none
MFC power supply	Tylan	RO-32	FP9403017	03683
Modem	Sierra wireless	GX450	Unknown	none
Ozone	ThermoElectron Inc	49i A3NAA	1160770010	none
Ozone Standard	ThermoElectron Inc	49i A1NAA	1130950194	none
Sample Tower	Aluma Tower	B	none	923310
Shelter Temperature	ARS	none	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342	14960	none
Zero air pump	Werther International	PC70/4	606491	none

APPENDIX B

CASTNET Site Spot Report Forms

EEMS Spot Report

Data Compiled: 2/14/2023 18:30:39

Site	Visit Date	Technician
ALH157	09/10/2022	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98810	unitless	P
2	Ozone Intercept	P	0	5	4	-1.3106	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	5.5	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.98	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-1.7	ppb	Fail

EEMS Spot Report

Data Compiled: 2/14/2023 18:22:15

Site	Visit Date	Technician
BVL130	09/10/2022	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00532	unitless	P
2	Ozone Intercept	P	0	5	4	-1.49059	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	3.9	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-1.5	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-1.48	ppb	P

EEMS Spot Report

Data Compiled: 2/14/2023 20:52:48

SiteVisitDate	Site	Technician
07/20/2022	CAT175	Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	24	0.14	c	P
2	Temperature max error	P	4	0.5	24	0.21	c	P
3	Flow Rate average % difference	P	10	5	2	34.96	%	Fail
4	Flow Rate max % difference	P	10	5	2	35.24	%	Fail

SiteVisitDate	Site	Technician
07/20/2022	CAT175	Korey Devins

Field Systems Comments

- 1

Parameter:

DasComments

The shelter is not temperature controlled. The site is solar and DC battery powered. The met tower has been removed and the temperature is being measured from the sample tower at 10 meters above ground.
- 2

Parameter:

DocumentationCo

The site copies of the SSRF are no longer kept onsite.
- 3

Parameter:

ShelterCleanNotes

The shelter is seriously deteriorated with rot and mold on the walls. The vegetation has been allowed to grow. The shelter roof has been repaired.
- 4

Parameter:

PollAnalyzerCom

Ozone monitoring is no longer being conducted at the site.

EEMS Spot Report

Data Compiled: 2/14/2023 15:39:45

Site	Visit Date	Technician
CHC432	07/25/2022	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.96056	unitless	P
2	Ozone Intercept	P	0	5	4	-1.6506	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99943	unitless	P
4	Ozone % difference avg	P	7	10	4	10.7	%	Fail
5	Ozone Absolute Difference g1	P	7	3	1	0.10	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-2.59	ppb	Fail

EEMS Spot Report

Data Compiled: 2/14/2023 16:46:51

Site	Visit Date	Technician
CNT169	08/09/2022	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98319	unitless	P
2	Ozone Intercept	P	0	5	4	-0.01389	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99995	unitless	P
4	Ozone % difference avg	P	7	10	4	1.8	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.28	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.11	ppb	P

EEMS Spot Report

Data Compiled: 2/14/2023 17:17:48

SiteVisitDate	Site	Technician
08/16/2022	CTH110	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.08	c	P
2	Temperature max error	P	4	0.5	12	0.17	c	P
3	Ozone Slope	P	0	1.1	4	1.00502	unitless	P
4	Ozone Intercept	P	0	5	4	-0.04515	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	0.5	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.04	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.11	ppb	P
9	Flow Rate average % difference	P	10	5	8	1.95	%	P
10	Flow Rate max % difference	P	10	5	8	1.95	%	P
11	DAS Voltage average error	P	7	0.003	84	0.0001	V	P
12	Shelter Temperature average error	P	5	2	14	0.54	c	P
13	Shelter Temperature max error	P	5	2	14	0.95	c	P

SiteVisitDate	Site	Technician
08/16/2022	CTH110	Eric Hebert

Field Systems Comments

1 **Parameter:** DasComments

The meteorological tower has been removed and the temperature sensor has been moved to the east leg of the sample tower at 10 meters above the ground. The shield has been changed from aspirated to naturally aspirated.

2 **Parameter:** SiteOpsProcedures

The ozone inlet filter is replaced and a Z/S/P is performed every two weeks.

3 **Parameter:** SitingCriteriaCom

There is a point source north of Ithaca within 40 km of the site. The tree line is less than 50 m from the site. The siting is acceptable even with the noted exceptions. Trees and overgrowth have recently been removed from the site which has improved siting criteria.

4 **Parameter:** ShelterCleanNotes

The condition of the shelter walls are beginning to deteriorate.

5 **Parameter:** MetSensorComme

The temperature sensor is mounted on the east leg of the sample tower.

EEMS Spot Report

Data Compiled: 2/14/2023 21:20:00

Site	Visit Date	Technician
EGB181	08/02/2022	Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.19	c	P
2	Temperature max error	P	4	0.5	9	0.21	c	P
3	Flow Rate average % difference	P	10	5	3	0.22	%	P
4	Flow Rate max % difference	P	10	5	3	0.40	%	P
5	DAS Voltage average error	P	7	0.003	42	0.0001	V	P

SiteVisitDate	Site	Technician
08/02/2022	EGB181	Korey Devins

Field Systems Comments

- Parameter:** SiteOpsProcComm
Filters are sent 4 at a time and stored in a refrigerator before and after sampling prior to shipment to the lab.
- Parameter:** DocumentationCo
The site operator does not use the logbook.
- Parameter:** ShelterCleanNotes
The shelter is provided by the Center for Atmospheric Research and is clean, organized, and spacious. The roof has been repaired.
- Parameter:** PollAnalyzerCom
Ozone concentration is not measured at EGB181 as part of CASTNET.

EEMS Spot Report

Data Compiled: 2/14/2023 15:56:16

Site	Visit Date	Technician
GLR468	08/02/2022	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01058	unitless	P
2	Ozone Intercept	P	0	5	4	0.11949	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.1	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.39	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	0.12	ppb	P

EEMS Spot Report

Data Compiled: 2/14/2023 20:30:11

SiteVisitDate	Site	Technician
09/13/2022	JOT403	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.24	c	P
2	Temperature2meter max error	P	5	0.5	3	0.41	c	P
3	Ozone Slope	P	0	1.1	4	0.96908	unitless	P
4	Ozone Intercept	P	0	5	4	-0.39839	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
6	Ozone % difference avg	P	7	10	4	4.7	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.07	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-1.02	ppb	P
9	Flow Rate average % difference	P	10	5	14	1.12	%	P
10	Flow Rate max % difference	P	10	5	14	1.45	%	P
11	DAS Voltage average error	P	2	0.003	70	0.0002	V	P
12	Shelter Temperature average error	P	5	2	24	0.55	c	P
13	Shelter Temperature max error	P	5	2	24	1.14	c	P

SiteVisitDate	Site	Technician
09/13/2022	JOT403	Martin Valvur

Field Systems Comments

- 1

Parameter:

 DocumentationCo

Hardcopies of manuals and documentation are no longer maintained on site. All information is maintained on the internet.
- 2

Parameter:

 ShelterCleanNotes

The shelter is in good condition, clean and well organized but not grounded.
- 3

Parameter:

 MetOpMaintCom

The temperature sensor signal cable is in poor condition and should be replaced.

EEMS Spot Report

Data Compiled: 2/14/2023 14:58:43

Site	Visit Date	Technician
PAR107	07/14/2022	Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99287	unitless	P
2	Ozone Intercept	P	0	5	4	-0.18493	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	1.4	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.05	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.38	ppb	P

EEMS Spot Report

Data Compiled: 2/14/2023 14:33:22

Site	Visit Date	Technician
PED108	07/12/2022	Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00864	unitless	P
2	Ozone Intercept	P	0	5	4	0.01000	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	0.9	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.07	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	0.22	ppb	P

EEMS Spot Report

Data Compiled: 2/14/2023 17:41:13

Site	Visit Date	Technician
SHN418	08/26/2022	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00263	unitless	P
2	Ozone Intercept	P	0	5	4	0.17359	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	0.6	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.29	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	0.16	ppb	P

EEMS Spot Report

Data Compiled: 2/14/2023 15:12:20

Site	Visit Date	Technician
WSP144	07/15/2022	Korey Devins

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98474	unitless	P
2	Ozone Intercept	P	0	5	4	0.12681	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99996	unitless	P
4	Ozone % difference avg	P	7	10	4	1.4	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.39	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	0.30	ppb	P

EEMS Spot Report

Data Compiled: 2/14/2023 18:00:44

Site	Visit Date	Technician
ZIO433	09/09/2022	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98813	unitless	P
2	Ozone Intercept	P	0	5	4	-0.29081	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	2.6	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.08	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.81	ppb	P