

---

**2023 – 2<sup>nd</sup> Quarter Report**  
**Support for Conducting Systems &  
Performance Audits of Clean Air Status and  
Trends Network (CASTNET) Sites and  
National Atmospheric Deposition Program  
(NADP) Monitoring Stations - II**  
**EPA Contract No. EP-W-18-005**

**Prepared for:**

**U. S. Environmental Protection Agency**

**Prepared by:**



**4577E NW 6<sup>th</sup> St Ext.  
Gainesville, FL 32609**

**Report Submitted  
July 2023**

---

## Table of Contents

<b>1.0 CASTNET Quarterly Report.....</b>	<b>1</b>
1.1 Introduction.....	1
1.2 Project Objectives .....	2
1.3 CASTNET Sites Visited Second Quarter 2023.....	4
1.4 Audit Results.....	5
<b>2.0 NADP Quarterly Report .....</b>	<b>6</b>
2.1 Introduction.....	6
2.2 Project Objectives .....	6
2.3 NADP Sites Visited Second Quarter 2023.....	7
2.4 Survey Results.....	8

## List of Appendices

- Appendix A**    CASNTET Audit Report Forms
- Appendix B**    CASTNET Site Spot Report Forms

## List of Tables

Table 1. Performance Audit Challenge and Acceptance Criteria.....	2
Table 2. CASTNET Site Audit Visits .....	4
Table 3. NADP Site Survey Visits .....	7

## List of Acronyms and Abbreviations

% diff	percent difference
A/D	analog to digital converter
ARS	Air Resource Specialists, Inc.
ASTM	American Society for Testing and Materials
BLM	Bureau of Land Management
BLM-WSO	Bureau of Land Management – Wyoming State Office
CAL	Central Analytical Laboratory
CASTNET	Clean Air Status and Trends Network
CMAQ	Community Multiscale Air Quality
DAS	data acquisition system
deg	degree
DVM	digital voltmeter
ECCC	Environment and Climate Change Canada
EEMS	Environmental, Engineering & Measurement Services, Inc.
EPA	U.S. Environmental Protection Agency
ESC	Environmental Systems Corporation
FSA	Field Systems Audit
FSAD	Field Site Audit Database
GPS	geographical positioning system
HAL	Mercury Analytical Laboratory
LADCO	Lake Michigan Air Directors Consortium
lpm	liters per minute
ME DEP	Maine Department of Environmental Protection
MD DNR	Maryland Department of Natural Resources
MLM	Multilayer Model
MN PCA	Minnesota Pollution Control Agency
m/s	meters per second
mv	millivolt
NESCAUM	Northeast States for Coordinated Air Use Management
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPS	National Park Service
NYDEC	New York Department of Conservation
NYSERDA	New York State Energy Research and Development Authority
OH EPA	Ohio Environmental Protection Agency
PE	Performance Evaluation
QAPP	Quality Assurance Project Plan
SCDHEC	South Carolina Department of Health and Environmental Control
SFWMD	South Florida Water Management District
SOP	standard operating procedure
TDEP	Total Deposition
TEI	Thermo Environmental Instruments
USDA-FS	United States Department of Agriculture – Forest Service
USFS	United States Forest Service

---

USFWS	United States Fish and Wildlife Service
USGS	United States Geological Survey
USNO	United States Naval Observatory
VDC	volts direct current
WDEQ	Wyoming Department of Environmental Quality
WDNR	Wisconsin Department of Natural Resources
WRR	World Radiation Reference
WSLH	Wisconsin State Laboratory of Hygiene

## 1.0 CASTNET Quarterly Report

### 1.1 Introduction

The Clean Air Status and Trends Network (CASTNET) is a national air monitoring program established in 1988 by the US EPA. Nearly all CASTNET sites measures weekly concentrations of acidic gases and particles to provide accountability for EPA’s emission reduction programs. Most sites measure ground-level ozone as well as supplemental measurements such as meteorology and/or other trace gas concentrations.

Ambient concentrations are used to estimate deposition rates of the various pollutants with the objective of determining relationships between emissions, air quality, deposition, and ecological effects. In conjunction with other national monitoring networks, CASTNET data are used to determine the effectiveness of national emissions control programs and to assess temporal trends and spatial deposition patterns in atmospheric pollutants. CASTNET data are also used for long-range transport model evaluations and critical loads research.

Historically, CASTNET pollutant flux measurements have been reported as the aggregate product of weekly measured concentrations and model-estimated deposition velocities. The Multi-layer Model (MLM) was used to derive deposition velocity estimates from on-site meteorological parameters, land use types, and site characteristics. In 2011, EPA discontinued meteorological measurements at most EPA-sponsored CASTNET sites.

Currently, CASTNET pollutant flux estimates are calculated as the aggregate product of weekly measured chemical concentrations and gridded model-estimated deposition velocities. Total deposition is assessed using the NADP’s Total Deposition Hybrid Method (TDEP; EPA, 2015c; Schwede and Lear, 2014), which combines data from established ambient monitoring networks and chemical-transport models. To estimate dry deposition, ambient measurement data from CASTNET and other networks were merged with dry deposition rates and flux output from the Community Multiscale Air Quality (CMAQ) modeling system.

Since 2011 nearly all CASTNET ozone monitors have adhered to the requirements for State or Local Air Monitoring Stations (SLAMS) as specified by the EPA in 40 CFR Part 58. As such, the ozone data collected must meet the requirements in 40 CFR Part 58 Appendix A, which defines the quality assurance (QA) requirements for gaseous pollutant ambient air monitoring. The audits performed by EEMS under this contract fulfilled the requirement for annual performance evaluation audits of pollutant monitors in the network. The QA requirements can be found at:

<https://www.epa.gov/amtic/regulations-guidance-and-monitoring-plans>

Currently 81 CASTNET sites at 79 distinct locations measure ground-level ozone concentrations. Annual performance evaluation (PE), ozone audit data are submitted to the Air Quality System (AQS) database.

As of July 2023, the network is comprised of 87 active rural sampling sites across the United States and Canada, cooperatively operated by the Environmental Protection Agency (EPA), the National Park Service (NPS), Bureau of Land Management – Wyoming State Office (BLM-WSO) and several independent partners. WSP (formally Wood Environment and Infrastructure Solutions) is responsible for operating the EPA sponsored sites, and Air Resource Specialists, Inc. (ARS) is responsible for operating the NPS and BLM-WSO sponsored sites

## 1.2 Project Objectives

The objectives of this project are to establish an independent and unbiased program of performance and systems audits for all CASTNET sampling sites. Ongoing Quality Assurance (QA) programs are an essential part of any long-term monitoring network.

Performance audits verify that all reported variables are consistent with the accuracy goals as defined in the CASTNET Quality Assurance Project Plan (QAPP). The parameter specific accuracy goals are presented in Table 1.

**Table 1. Performance Audit Challenge and Acceptance Criteria**

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Precipitation	Response	10 manual tips	1 DAS count per tip
Precipitation	Accuracy	2 introductions of known amounts of water	$\leq \pm 10.0\%$ of input amount
Relative Humidity	Accuracy	Compared to reference instrument or standard solution	$\leq \pm 10.0\%$ RH
Solar Radiation	Accuracy	Compared to WRR traceable standard	$\leq \pm 10.0\%$ of daytime average
Surface Wetness	Response	Distilled water spray mist	Positive response
Surface Wetness	Sensitivity	1% decade resistance	N/A
Temperature	Accuracy	Comparison to 3 NIST measured baths (~ 0° C, ambient, ~ full-scale)	$\leq \pm 0.5^\circ \text{C}$
Temperature Difference	Accuracy	Comparison to station temperature sensor	$\leq \pm 0.50^\circ \text{C}$

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Shelter Temperature	Accuracy	Comparison to station temperature sensor	$\leq \pm 2.0^{\circ} \text{ C}$
Wind Direction	Orientation Accuracy	Parallel to alignment rod/crossarm, or sighted to distant point	$\leq \pm 5^{\circ}$ from degrees true
Wind Direction	Linearity	Eight cardinal points on test fixture	$\leq \pm 5^{\circ}$ mean absolute error
Wind Direction	Response Threshold	Starting torque tested with torque gauge	$< 10 \text{ g-cm}$ Climatronics; $< 20 \text{ g-cm}$ R.M. Young
Wind Speed	Accuracy	Shaft rotational speed generated and measured with certified synchronous motor	$\leq \pm 0.5 \text{ mps}$ below 5.0 mps input; $\leq \pm 5.0\%$ of input at or above 5.0 mps
Wind Speed	Starting Threshold	Starting torque tested with torque gauge	$< 0.5 \text{ g-cm}$
Mass Flow Controller	Flow Rate	Comparison with Primary Standard	$\leq \pm 5.0\%$ of designated rate
Ozone	Slope	Linear regression of multi-point test gas concentration as measured with a certified transfer standard	$0.9000 \leq m \leq 1.1000$
Ozone	Intercept		$-5.0 \text{ ppb} \leq b \leq 5.0 \text{ ppb}$
Ozone	Correlation Coefficient		$0.9950 \leq r$
Ozone	Percent Difference	Comparison with Level 2 standard concentration	$\leq \pm 15.1\%$ of test gas concentration and $\leq \pm 0.0015 \text{ ppm}$ actual difference
DAS	Accuracy	Comparison with certified standard	$\leq \pm 0.003 \text{ VDC}$

Performance audits are conducted using standards that are traceable to the National Institute of Standards and Technology (NIST), or another authoritative organization, at least annually.

Field site systems audits (FSA) are intended to provide a qualitative appraisal of the total measurement system. Site planning, organization, and operation are evaluated to ensure that good Quality Assurance/Quality Control (QA/QC) practices are being applied. At a minimum the following audit issues were addressed at each site systems audit:

- Site locations and configurations match those provided in the CASTNET QAPP.
- Meteorological instruments are in good physical and operational condition and are sited to meet EPA ambient monitoring guidelines (EPA-600/4-82-060).
- Sites are accessible, orderly, and if applicable, compliant with OSHA safety standards.
- Sampling lines are free of leaks, kinks, visible contamination, weathering, and moisture.
- Site shelters provide adequate temperature control.

- All ambient air quality instruments are functional, being operated in the appropriate range, and the zero-air supply desiccant is unsaturated.
- All instruments are in current calibration.
- Site documentation (maintenance schedules, on-site SOPs, etc.) is current and log book records are complete.
- All maintenance and on-site SOPs are performed on schedule.
- Corrective actions are documented and appropriate for required maintenance/repair activity.
- Site operators demonstrate an adequate knowledge and ability to perform required site activities, including documentation and maintenance activities.

### 1.3 CASTNET Sites Visited Second Quarter 2023

This report consists of the systems and performance, and other audit results from the CASTNET sites visited during the second quarter (April through June) of 2023. The site locations, sponsor, visit dates, and parameters audited, are included in Table 2.

**Table 2. CASTNET Site Audit Visits**

Site ID	Date	FSA	O3 PE	NOy	FLOW	Sponsor
PRK134	4/2/2023	1	1		1	EPA
GAS153	4/25/2023		1			EPA
BWR139	5/11/2023	1	1		1	EPA
PND165	5/15/2023			1		BLM-WSO
GRT434	5/16/2023		1			NPS
YEL408	5/16/2023	1	1		1	NPS
WSP144	5/17/2023	1	1		1	EPA
CRM435	5/18/2023		1			NPS
NEC602	5/24/2023	1	1		1	BLM-WSO
ARE128	6/12/2023		1			EPA
KEF112	6/13/2023		1			EPA
MKG113	6/14/2023		1			EPA
LRL117	6/15/2023		1			EPA
SEK430	6/20/2023	1	1		1	NPS
ZIO433	6/25/2023	1	1			NPS
ACA416	6/30/2023	1			1	NPS



## 1.4 Audit Results

The observations and results of the systems, performance, and Ozone PE audits are included in Appendix A, *CASTNET Audit Report Forms* by site, arranged by audit date. Photographs of site conditions are included within each system report where necessary. Copies of the spot reports that were sent following the audit of each site are included as Appendix B, *CASTNET Site Spot Report Forms*.

Results of the PE audits of the gaseous pollutant monitors other than ozone, were submitted immediately following the PE and are not included in this report. All TTP PE results of gaseous pollutant monitors are uploaded to AQS and are available there. All audit data and reports are available from the EPA CASTNET website: <https://java.epa.gov/castnet/reportPage.do>

## 2.0 NADP Quarterly Report

### 2.1 Introduction

The National Atmospheric Deposition Program (NADP) operates two precipitation chemistry networks and two atmospheric concentration networks. The National Trends Network (NTN) has been measuring acidic precipitation since 1978. The network currently has more than 250 sites. The precipitation event-based Atmospheric Integrated Research Monitoring Network (AIRMOn) began operation in 1992, and as of July 2019 is no longer in operation. The Mercury Deposition Network (MDN) measures total mercury in precipitation samples from approximately 90 stations. The MDN began operation in 1996 and includes sites throughout the US and Canada. The Atmospheric Mercury Network (AMNet) and the Ammonia Monitoring Network (AMoN) measure ambient concentrations of mercury and ammonia, respectively.

The NADP and other long-term monitoring networks provide critical information to the EPA regarding evaluating the effectiveness of emission reduction control programs from the power industry. The networks of the NADP are sponsored by several federal, state, and local agencies as well as private organizations.

The NADP Program Office (PO) operates and administers the two precipitation chemistry networks (NTN and MDN), two atmospheric concentration networks (AMNet and AMoN), and two analytical laboratories (CAL and HAL), from the Wisconsin State Lab of Hygiene (WSLH) at the University of Wisconsin in Madison. The labs have been combined and renamed as the NADP Analytical Laboratory (NAL). The network equipment depot (NED) is also located at the WSLH.

### 2.2 Project Objectives

The objective of this project is to perform independent and unbiased evaluations of the sites and their operation. These evaluations provide quality assurance pertaining to siting, sample collection and handling, equipment operation and maintenance, record keeping and field laboratory procedures.

More specifically, the surveys determine and report findings based on an established methodology consisting of completing a site questionnaire, testing the equipment and documenting with photographs the location, siting criteria, existing equipment, and any issues encountered that require such documentation.

## 2.3 NADP Sites Visited Second Quarter 2023

This report presents the NADP sites surveyed during the first quarter (April through June) of 2023. The station locations, sponsors, network, and dates of the surveys are presented in Table 3.

**Table 3. NADP Site Survey Visits**

Site ID	Date	NTN	MDN	AMoN	Site Sponsor	Site Name
WI35	4/2/2023			1	Wood - EPA	Perkinstown
BC24	4/3/2023	1			Prince Rupert Port Authority	Port Edward
IL78	4/4/2023	1			USGS	Monmouth
BC23	4/4/2023	1			Rio Tinto	Lakelse Lake
BC22	4/4/2023	1			Rio Tinto	Haul Road Station
KS97	4/5/2023	1		1	Wood - EPA	Kickapoo Tribe-Powhattan
AB14	4/6/2023		1		Intrinsik Corp	Genesee
GA41	4/25/2023			1	Wood - EPA	Georgia Station
MN01	5/8/2023	1			Minnesota Pollution Control Agency	Cedar Creek
MD15	5/8/2023	1			NOAA	Smith Island
MN27	5/9/2023	1	1		Minnesota Pollution Control Agency	Lamberton
MD18	5/9/2023	1			Maryland Department of Natural Resources	Assateague Island National Seashore-Woodcock
MD13	5/10/2023	1			University of Maryland	Wye
MD06	5/11/2023			1	Wood - EPA	Blackwater NWR
NJ00	5/12/2023	1			U.S. Fish and Wildlife Service	Edwin B. Forsythe National Wildlife Refuge
NJ39	5/15/2023	1			Wood - EPA	Cattus Island County Park
WY06	5/15/2023			1	Wood - EPA	Pinedale

Site ID	Date	NTN	MDN	AMoN	Site Sponsor	Site Name
WY94	5/15/2023			1	NPS	Grand Tetons National Park
MD08	5/16/2023	1	1	1	Maryland Department of Natural Resources	Piney Reservoir
NJ99	5/17/2023	1		1	Wood - EPA	Washington Crossing
WY08	5/17/2023	1	1		Wyoming Department of Environmental Quality / NPS	Yellowstone National Park-Tower Falls
FL41	6/1/2023	1			USGS	Verna Well Field
PA00	6/12/2023			1	Wood -EPA	Arendtsville
PA29	6/13/2023			1	Wood - EPA	Kane Experimental Forest
PA72	6/13/2023	1			USDA - Forest Service	Milford
PA56	6/14/2023			1	Wood - EPA	M. K. Goddard
PA97	6/15/2023			1	Wood - EPA	Laurel Hil
ME02	6/26/2023	1	1		Maine Department of Environmental Protection	Bridgton
ME08	6/27/2023	1			USGS	Gilead
ME04	6/28/2023	1	1		Penobscot Indian Nation / Wood - EPA	Carrabassett Valley
ME09	6/29/2023	1	1		Maine Department of Environmental Protection	Greenville Station

## 2.4 Survey Results

Site survey results are entered into a relational database. The database in turn generates Site Spot Reports which are distributed among the interested parties as soon as all the site data has been entered. Database tables with all the data collected and reviewed are then sent to the NADP Program Office and to the U.S. EPA Project Officers.

Other items gathered during the surveys (i.e., photographs, Belfort charts, etc.) are uploaded to the EPA OneDrive account where the NADP PO and the U.S. EPA POs can access them and download them as needed.

Given the volume of data generated, and the fact that data is distributed and/or is available via the internet, no survey results are included in this report.

---

## **APPENDIX A**

### **CASTNET Audit Report Forms**

---

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
PRK134-Eric Hebert-04/02/2023						
1	4/2/2023	Computer	Dell	07021	Inspiron 15	2884848822
2	4/2/2023	DAS	Campbell	000411	CR3000	2509
3	4/2/2023	Elevation	Elevation	None	1	None
4	4/2/2023	Filter pack flow pump	Thomas	04918	107CAB18	060300019989
5	4/2/2023	Flow Rate	Apex	000656	AXMC105LPMDPCV	illegible
6	4/2/2023	Infrastructure	Infrastructure	none	none	none
7	4/2/2023	Modem	Digi	07198	LR54	unknown
8	4/2/2023	Ozone	ThermoElectron Inc	000693	49i A1NAA	1030244806
9	4/2/2023	Ozone Standard	ThermoElectron Inc	000373	49i A3NAA	0726124685
10	4/2/2023	Sample Tower	Aluma Tower	000930	B	AT214072-Z-7-2
11	4/2/2023	Shelter Temperature	Campbell	none	107-L	unknown
12	4/2/2023	Siting Criteria	Siting Criteria	None	1	None
13	4/2/2023	Temperature	RM Young	06306	41342VC	12545
14	4/2/2023	Zero air pump	Werther International	06905	C 70/4	000821907

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2509	PRK134	Eric Hebert	04/02/2023	DAS	Primary

Das Date:	4 /2 /2023	Audit Date	4 /2 /2023
Das Time:	10:35:00	Audit Time	10:35:00
Das Day:	92	Audit Day	92
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0003	0.0006	0.0003	0.0006

Mfg	Date1	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0002	0.0000	V	V	0.0002	
7	0.1000	0.0997	0.0994	V	V	-0.0003	
7	0.3000	0.2995	0.2991	V	V	-0.0004	
7	0.5000	0.5000	0.5006	V	V	0.0006	
7	0.7000	0.6993	0.6990	V	V	-0.0003	
7	0.9000	0.8990	0.8990	V	V	0.0000	
7	1.0000	0.9990	0.9991	V	V	0.0001	



Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		PRK134	Eric Hebert	04/02/2023	Flow Rate	000656

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.00%	0.00%		
		Cal Factor Full Scale	0.97
		Rotometer Reading:	1.55

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.01	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.01	l/m	l/m	
primary	test pt 1	1.500	1.500	1.54	0.000	1.50	l/m	l/m	0.00%
primary	test pt 2	1.502	1.500	1.55	0.000	1.50	l/m	l/m	0.00%
primary	test pt 3	1.502	1.500	1.55	0.000	1.50	l/m	l/m	0.00%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	40 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244806

PRK134

Eric Hebert

04/02/2023

Ozone

000693

Slope:

0.99343

Slope:

0.00000

Intercept

-0.84444

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

1.00066

Intercept

0.29985

Cert Date

11/1/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.39	0.08	-0.71	ppb		-0.79	
primary	2	14.88	14.52	13.63	ppb		-0.89	
primary	3	37.13	36.69	35.39	ppb	-3.61		
primary	4	67.68	67.14	65.97	ppb	-1.76		
primary	5	110.37	109.67	108.10	ppb	-1.44		
Sensor Component	Audit Pressure		Condition	713.2 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.000		Status	pass	
Sensor Component	Span		Condition	1.008		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	100.0 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	1.0 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.73 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	692.1 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	31.8 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	99.7 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.8 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.64 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	691.5 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	12545		PRK134	Eric Hebert	04/02/2023	Temperature	06306

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232734	Tfer Desc.	RTD
		Tfer ID	01227		
		Slope	1.00945	Intercept	0.16485
		Cert Date	2/17/2023	CorrCoff	1.00000

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.19	0.40		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.23	0.06	0.000	0.2	C	0.14
primary	Temp Mid Range	17.76	17.43	0.000	17.4	C	-0.03
primary	Temp Mid Range	33.05	32.58	0.000	33.0	C	0.4

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	unknown	PRK134	Eric Hebert	04/02/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.28	0.54		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00945	Intercept	0.16485
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	23.93	23.54	0.000	23.5	C	-0.02	
primary	Temp Mid Range	25.27	24.87	0.000	24.3	C	-0.54	
Sensor Component		System Memo		Condition		Status	pass	

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition	20 m	Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Infrastructure Data For

Site ID

PRK134

Technician

Eric Hebert

Site Visit Date

04/02/2023

Shelter Make

Ekto

Shelter Model

8810 (s/n 2116-11)

Shelter Size

640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Fair	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Field Systems Comments

- 1

Parameter:

SitingCriteriaCom

Clover and Barley have been planted for hay within 20m of the site starting in 2008.
- 2

Parameter:

ShelterCleanNotes

The shelter is clean, neat, and well organized.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	PRK134	Technician	Eric Hebert	Site Visit Date	04/02/2023
Site Sponsor (agency)	EPA	USGS Map	Perkinstown		
Operating Group	Private	Map Scale			
AQS #	55-119-9991	Map Date			
Meteorological Type	R.M. Young				
Air Pollutant Analyzer	Ozone, PM2.5	QAPP Latitude	45.2066		
Deposition Measurement	dry, wet	QAPP Longitude	-90.5972		
Land Use	woodland - mixed	QAPP Elevation Meters	472		
Terrain	gently rolling	QAPP Declination	1.6		
Conforms to MLM	Yes	QAPP Declination Date	2/22/2006		
Site Telephone		Audit Latitude	45.206525		
Site Address 1	W 10776 CTH M	Audit Longitude	-90.597209		
Site Address 2		Audit Elevation	462		
County	Taylor	Audit Declination	-1.3		
City, State	Medford, WI				
Zip Code	54451	Fire Extinguisher	Present	new in 2015	
Time Zone	Central	First Aid Kit			
Primary Operator		Safety Glasses			
Primary Op. Phone #		Safety Hard Hat			
Primary Op. E-mail		Climbing Belt			
Backup Operator		Security Fence			
Backup Op. Phone #		Secure Shelter			
Backup Op. E-mail		Stable Entry Steps			
Shelter Working Room		Make	Ekto	Model	8810 (s/n 2116-11)
Shelter Clean		Shelter Size	640 cuft		
Site OK		Notes	The shelter is clean, neat, and well organized.		
Driving Directions	From Medford continue north on 13 approximately 4.5 miles and turn left (west) onto county route M. Continue approximately 13 miles. Before reaching Perkinstown, and just after crossing a small creek and two sharp curves, the site will be visible behind the landowners house on the right.				



Field Systems Data Form

F-02058-1500-S3-rev002

Site IDPRK134

TechnicianEric Hebert

Site Visit Date04/02/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	Mounted to sample tower
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDPRK134

TechnicianEric Hebert

Site Visit Date04/02/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDPRK134

TechnicianEric Hebert

Site Visit Date04/02/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 15 meters
4	Describe dry dep sample tube.		3/8 teflon by 15 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDPRK134

TechnicianEric Hebert

Site Visit Date04/02/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>							
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>							
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only						
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>							
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>							
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>							
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>							
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>							
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	
Stable		Grounded							
<input type="checkbox"/>		<input type="checkbox"/>							
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input type="checkbox"/>				
<input checked="" type="checkbox"/>		<input type="checkbox"/>							
11	Tower comments?								

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDPRK134

TechnicianEric Hebert

Site Visit Date04/02/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDPRK134

TechnicianEric Hebert

Site Visit Date04/02/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDPRK134

TechnicianEric Hebert

Site Visit Date04/02/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

PRK134

Technician

Eric Hebert

Site Visit Date

04/02/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	2884848822	07021
DAS	Campbell	CR3000	2509	000411
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	060300019989	04918
Flow Rate	Apex	AXMC105LPMDPC	illegible	000656
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07198
Ozone	ThermoElectron Inc	49i A1NAA	1030244806	000693
Ozone Standard	ThermoElectron Inc	49i A3NAA	0726124685	000373
Sample Tower	Aluma Tower	B	AT214072-Z-7-2	000930
Shelter Temperature	Campbell	107-L	unknown	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VC	12545	06306
Zero air pump	Werther International	C 70/4	000821907	06905



# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
GAS153-Eric Hebert-04/25/2023						
1	4/25/2023	DAS	Campbell	000635	CR3000	4934
2	4/25/2023	Ozone	ThermoElectron Inc	000700	49i A1NAA	1030244793
3	4/25/2023	Ozone Standard	ThermoElectron Inc	000215	49i A3NAA	0622717856
4	4/25/2023	Zero air pump	Werther International	06865	C 70/4	000814277

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244793

GAS153

Eric Hebert

04/25/2023

Ozone

000700

Slope:

0.99137

Slope:

0.00000

Intercept

-0.49234

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.53	0.23	0.06	ppb		-0.17	
primary	2	14.88	14.61	13.81	ppb		-0.8	
primary	3	34.15	33.93	32.98	ppb	-2.84		
primary	4	67.85	67.72	66.53	ppb	-1.77		
primary	5	117.27	117.27	115.90	ppb	-1.18		
Sensor Component	Audit Pressure			Condition	714.7 mmHg	Status	pass	
Sensor Component	26.6 degree unobstructed rule			Condition	True	Status	pass	
Sensor Component	Tree dewline >10m or below inlet			Condition	True	Status	pass	
Sensor Component	ADT 1000-10000 vehicles further			Condition	True	Status	pass	
Sensor Component	ADT <1000 vehicles further than			Condition	True	Status	pass	
Sensor Component	Sample Train			Condition	Good	Status	pass	
Sensor Component	Inlet Filter Condition			Condition	Moderately clean	Status	pass	
Sensor Component	Offset			Condition	-0.70	Status	pass	
Sensor Component	Span			Condition	1.032	Status	pass	
Sensor Component	Zero Voltage			Condition	N/A	Status	pass	
Sensor Component	Fullscale Voltage			Condition	N/A	Status	pass	
Sensor Component	Cell A Freq.			Condition	93.9 kHz	Status	pass	
Sensor Component	Cell A Noise			Condition	2.2 ppb	Status	pass	
Sensor Component	Cell A Flow			Condition	0.71 lpm	Status	pass	
Sensor Component	Cell A Pressure			Condition	713.9 mmHg	Status	pass	
Sensor Component	Cell A Tmp.			Condition	36.2 C	Status	pass	
Sensor Component	Cell B Freq.			Condition	90.5 kHz	Status	pass	
Sensor Component	Cell B Noise			Condition	0.7 ppb	Status	pass	
Sensor Component	Cell B Flow			Condition	0.72 lpm	Status	pass	
Sensor Component	Cell B Pressure			Condition	713.3 mmHg	Status	pass	
Sensor Component	Nafion dryer installed			Condition	True	Status	pass	
Sensor Component	System Memo			Condition		Status	pass	

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
BWR139-Martin Valvur-05/11/2023						
1	5/11/2023	Computer	Dell	07009	Inspiron 15	Unknown
2	5/11/2023	DAS	Campbell	000431	CR3000	2536
3	5/11/2023	Elevation	Elevation	None	1	None
4	5/11/2023	Flow Rate	Apex	000662	AXMC105LPMDPCV	illegible
5	5/11/2023	Infrastructure	Infrastructure	none	none	none
6	5/11/2023	Modem	Digi	07186	LR54	Illegible
7	5/11/2023	Ozone	ThermoElectron Inc	000729	49i A1NAA	1105347323
8	5/11/2023	Ozone Standard	ThermoElectron Inc	000697	49i A3NAA	1030244814
9	5/11/2023	Sample Tower	Aluma Tower	missing	B	none
10	5/11/2023	Shelter Temperature	Campbell	none	107-L	none
11	5/11/2023	Siting Criteria	Siting Criteria	None	1	None
12	5/11/2023	Temperature	RM Young	04315	41342	4012
13	5/11/2023	Zero air pump	Werther International	06877	C 70/4	000815258
14	5/11/2023	Zero air pump	Thomas	04985	107CA18	040400022190

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
<input type="text" value="Campbell"/>	<input type="text" value="2536"/>	<input type="text" value="BWR139"/>	<input type="text" value="Martin Valvur"/>	<input type="text" value="05/11/2023"/>	<input type="text" value="DAS"/>	<input type="text" value="Primary"/>

Das Date:	<input type="text" value="5 /11/2023"/>	Audit Date:	<input type="text" value="5 /11/2023"/>
Das Time:	<input type="text" value="09:10:00"/>	Audit Time:	<input type="text" value="09:10:00"/>
Das Day:	<input type="text" value="131"/>	Audit Day:	<input type="text" value="131"/>
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/25/2023"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0001	-0.0002	V	V	-0.0001	
7	0.1000	0.0998	0.0999	V	V	0.0001	
7	0.3000	0.2997	0.2997	V	V	0.0000	
7	0.5000	0.4995	0.4995	V	V	0.0000	
7	0.7000	0.6994	0.6994	V	V	0.0000	
7	0.9000	0.8992	0.8992	V	V	0.0000	
7	1.0000	0.9991	0.9991	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		BWR139	Martin Valvur	05/11/2023	Flow Rate	000662

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	0.99
0.45%	0.67%	Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference	
primary	pump off	0.000	0.000	0.01	0.000	0.00	l/m	l/m		
primary	leak check	0.000	0.000	0.01	0.000	0.01	l/m	l/m		
primary	test pt 1	1.490	1.490	1.51	0.000	1.50	l/m	l/m	0.67%	
primary	test pt 2	1.490	1.490	1.51	0.000	1.50	l/m	l/m	0.67%	
primary	test pt 3	1.500	1.500	1.51	0.000	1.50	l/m	l/m	0.00%	

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	3.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347323

BWR139

Martin Valvur

05/11/2023

Ozone

000729

Slope:

0.99917

Slope:

0.00000

Intercept

-0.51299

Intercept

0.00000

CorrCoff

0.99997

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.42	0.12	-0.06	ppb		-0.18	
primary	2	17.50	17.24	16.78	ppb		-0.46	
primary	3	35.94	35.73	34.86	ppb	-2.46		
primary	4	67.76	67.63	66.66	ppb	-1.44		
primary	5	114.69	114.68	114.40	ppb	-0.24		
Sensor Component	Audit Pressure		Condition	771 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Moderately clean		Status	pass	
Sensor Component	Offset		Condition	-0.4		Status	pass	
Sensor Component	Span		Condition	1.023		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	94.4 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.71 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	727.1 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	33.7 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	91.9 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	1.0 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.70 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	726.3 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	True		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4012		BWR139	Martin Valvur	05/11/2023	Temperature	04315

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

0.14	0.32		
------	------	--	--

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.20	0.12	0.000	0.4	C	0.32	
primary	Temp Mid Range	24.30	23.94	0.000	23.9	C	-0.03	
primary	Temp High Range	47.40	46.77	0.000	46.7	C	-0.07	

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		BWR139	Martin Valvur	05/11/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
1.94	2.21		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	24.40	24.04	0.000	26.3	C	2.21	
primary	Temp Mid Range	25.00	24.63	0.000	26.5	C	1.89	
primary	Temp Mid Range	25.20	24.83	0.000	26.5	C	1.71	
Sensor Component		System Memo		Condition		Status	pass	



# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition	10 m	Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Infrastructure Data For

Site ID

BWR139

Technician

Martin Valvur

Site Visit Date

05/11/2023

Shelter Make	Shelter Model	Shelter Size
Ekto	8810	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Field Systems Comments

**1   Parameter:**   SiteOpsProcComm

The site operator was not available during the audit visit. Data are reported from site documentation.

**2   Parameter:**   SiteOpsProcedures

The ozone sample train is leak checked every two weeks following the inlet filter change.

**3   Parameter:**   SitingCriteriaCom

Very light agriculture activities near site, not harvested, just to provide food for wildlife.

**4   Parameter:**   ShelterCleanNotes

The shelter has been repaired since the previous site audit visit.

**5   Parameter:**   PollAnalyzerCom

Ozone sample train has inline dryer.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	BWR139	Technician	Martin Valvur	Site Visit Date	05/11/2023		
Site Sponsor (agency)	EPA	USGS Map					
Operating Group	BNWR/private	Map Scale					
AQS #	24-019-9991	Map Date					
Meteorological Type	R.M. Young						
Air Pollutant Analyzer	Ozone	QAPP Latitude					
Deposition Measurement	dry	QAPP Longitude					
Land Use	woodlands - mixed, wetlands	QAPP Elevation Meters					
Terrain	flat	QAPP Declination					
Conforms to MLM	Yes	QAPP Declination Date					
Site Telephone		Audit Latitude	38.444971				
Site Address 1	Blackwater Nat Wildlife Refuge	Audit Longitude	-76.111274				
Site Address 2	2145 Key Wallace Dr.	Audit Elevation	1				
County	Dorchester	Audit Declination	-11.2				
City, State	Cambridge, MD						
Zip Code	21613	Fire Extinguisher	<input type="checkbox"/> Present				
Time Zone	Eastern	First Aid Kit	<input checked="" type="checkbox"/>				
Primary Operator		Safety Glasses	<input checked="" type="checkbox"/>				
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>				
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>				
Backup Operator		Security Fence	<input type="checkbox"/>				
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>				
Backup Op. E-mail		Stable Entry Step	<input checked="" type="checkbox"/>				
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810	Shelter Size	640 cuft
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter has been repaired since the previous site audit visit.				
Site OK	<input checked="" type="checkbox"/>	Notes					
Driving Directions	From I95 take route 50 east to Cambridge, MD. At mile marker 81 turn right on Woods Rd. Continue approximately 1 mile to the stop sign, turn right onto SR 16 west. Continue approximately 1.7 miles, past the school, and turn left onto Egypt Road. Continue approximately 7.1 miles to the stop sign. Turn right onto Key Wallace Drive towards the visitors center. Continue approximately 0.8 mile to the gate on the left. The site will be visible.						

Site ID

BWR139

Technician

Martin Valvur

Site Visit Date

05/11/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BWR139

Technician

Martin Valvur

Site Visit Date

05/11/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	Moderately clean
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BWR139

Technician

Martin Valvur

Site Visit Date

05/11/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Ozone sample train has inline dryer.

Site ID

BWR139

Technician

Martin Valvur

Site Visit Date

05/11/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Temperature only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	Met tower removed										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



Site ID

BWR139

Technician

Martin Valvur

Site Visit Date

05/11/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	March 2015	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BWR139

Technician

Martin Valvur

Site Visit Date

05/11/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone sample train is leak checked every two weeks following the inlet filter change.

Site ID

BWR139

Technician

Martin Valvur

Site Visit Date

05/11/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator was not available during the audit visit. Data are reported from site documentation.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

BWR139

Technician

Martin Valvur

Site Visit Date

05/11/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07009
DAS	Campbell	CR3000	2536	000431
Elevation	Elevation	1	None	None
Flow Rate	Apex	AXMC105LPMDPC	illegible	000662
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07186
Ozone	ThermoElectron Inc	49i A1NAA	1105347323	000729
Ozone Standard	ThermoElectron Inc	49i A3NAA	1030244814	000697
Sample Tower	Aluma Tower	B	none	missing
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	4012	04315
Zero air pump	Thomas	107CA18	040400022190	04985
Zero air pump	Werther International	C 70/4	000815258	06877

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
GRT434-Tim Mendenhall-05/16/2023						
1	5/16/2023	DAS	Environmental Sys Corp	none	8832	A3743K
2	5/16/2023	Ozone	ThermoElectron Inc	none	49i A3NAA	903334536
3	5/16/2023	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1023943899
4	5/16/2023	Zero air pump	Werther International	none	PC70/4	585590

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

903334536

GRT434

Tim Mendenhall

05/16/2023

Ozone

none

Slope:

1.04853

Slope:

0.00000

Intercept

0.07176

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.02	-0.21	-0.03	ppb		0.18	
primary	2	15.01	14.66	15.39	ppb		0.73	
primary	3	35.13	34.58	36.26	ppb	4.74		
primary	4	65.40	64.56	67.71	ppb	4.76		
primary	5	114.40	113.08	118.70	ppb	4.85		
Sensor Component	Audit Pressure			Condition	604 mmHg	Status	pass	
Sensor Component	26.6 degree unobstructed rule			Condition	True	Status	pass	
Sensor Component	Tree dewline >10m or below inlet			Condition	True	Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t			Condition	True	Status	pass	
Sensor Component	ADT <1000 vehicles further than 5			Condition	True	Status	pass	
Sensor Component	Sample Train			Condition	Good	Status	pass	
Sensor Component	Inlet Filter Condition			Condition	Clean	Status	pass	
Sensor Component	Offset			Condition	0.000	Status	pass	
Sensor Component	Span			Condition	1.000	Status	pass	
Sensor Component	Zero Voltage			Condition	N/A	Status	pass	
Sensor Component	Fullscale Voltage			Condition	N/A	Status	pass	
Sensor Component	Cell A Freq.			Condition	104 kHz	Status	pass	
Sensor Component	Cell A Noise			Condition	Not tested	Status	pass	
Sensor Component	Cell A Flow			Condition	Not tested	Status	pass	
Sensor Component	Cell A Pressure			Condition	588.9 mmHg	Status	pass	
Sensor Component	Cell A Tmp.			Condition	33.3 C	Status	pass	
Sensor Component	Cell B Freq.			Condition	80.1 kHz	Status	pass	
Sensor Component	Cell B Noise			Condition	Not tested	Status	pass	
Sensor Component	Cell B Flow			Condition	Not tested	Status	pass	
Sensor Component	Cell B Pressure			Condition	588.0 mmHg	Status	pass	
Sensor Component	Nafion dryer installed			Condition	False	Status	pass	
Sensor Component	System Memo			Condition		Status	pass	

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
YEL408-Tim Mendenhall-05/16/2023						
1	5/16/2023	DAS	Environmental Sys Corp	None	8832	A4888K
2	5/16/2023	Elevation	Elevation	None	1	None
3	5/16/2023	Flow Rate	Alicat	none	MC-10SLPM-D-PCV	Illgeible
4	5/16/2023	Infrastructure	Infrastructure	none	none	none
5	5/16/2023	Met tower	Climatronics	01362	14 inch taper	illegible
6	5/16/2023	Ozone	ThermoElectron Inc	none	49i A3NAA	1172090002
7	5/16/2023	Ozone Standard	ThermoElectron Inc	none	49i A1NAB	0926938297
8	5/16/2023	Sample Tower	Aluma Tower	illegible	B	none
9	5/16/2023	Shelter Temperature	ARS	none	none	none
10	5/16/2023	Siting Criteria	Siting Criteria	None	1	None
11	5/16/2023	Temperature2meter	RM Young	none	41342VC	029239
12	5/16/2023	Zero air pump	Werther International	none	PC 70/4	000836215

DAS Data Form

DAS Time Max Error: 2

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	A4888K	YEL408	Tim Mendenhall	05/16/2023	DAS	Primary

Das Date:	5 /16/2023	Audit Date	5 /16/2023
Das Time:	14:04:00	Audit Time	14:06:00
Das Day:	136	Audit Day	136
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0004	0.0009	0.0004	0.0009

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
16	0.0000	-0.0002	-0.0004	V	V	-0.0002	
16	0.1000	0.0999	0.0996	V	V	-0.0003	
16	0.3000	0.2999	0.2998	V	V	-0.0001	
16	0.5000	0.4996	0.4993	V	V	-0.0003	
16	0.7000	0.7000	0.7002	V	V	0.0002	
16	0.9000	0.8999	0.8994	V	V	-0.0005	
16	1.0000	0.9999	1.0008	V	V	0.0009	



Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Alicat	Illgeible		YEL408	Tim Mendenhall	05/16/2023	Flow Rate	none

Mfg	BIOS	Parameter	Flow Rate
Serial Number	152253	Tfer Desc.	BIOS 220-H
Tfer ID	15225		
Slope	1.00000	Intercept	0.00000
Cert Date	5/2/2022	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.90%	1.01%		
		Cal Factor Full Scale	0
		Rotometer Reading:	0

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.02	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.03	0.000	0.00	l/m	l/m	
primary	test pt 1	2.979	2.980	2.97	0.000	3.00	l/m	l/m	0.67%
primary	test pt 2	2.972	2.970	2.98	0.000	3.00	l/m	l/m	1.01%
primary	test pt 3	2.970	2.970	2.98	0.000	3.00	l/m	l/m	1.01%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.6 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1172090002

YEL408

Tim Mendenhall

05/16/2023

Ozone

none

Slope:

0.97086

Slope:

0.00000

Intercept

0.29844

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.06	-0.14	0.17	ppb		0.31	
primary	2	17.80	17.42	17.23	ppb		-0.19	
primary	3	37.94	37.36	36.50	ppb	-2.33		
primary	4	67.92	67.05	65.45	ppb	-2.42		
primary	5	115.78	114.45	111.40	ppb	-2.7		

Sensor Component

Audit Pressure

Condition

576 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

Not tested

Status

pass

Sensor Component

Span

Condition

Not tested

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

116.4 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

1.4 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.63 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

556.1 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

33.1 C

Status

pass

Sensor Component

Cell B Freq.

Condition

70.1 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

2.2 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.66 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

556.4 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

False

Status

pass

Sensor Component

System Memo

Condition

Status

pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	029239		YEL408	Tim Mendenhall	05/16/2023	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

0.31	0.4		
------	-----	--	--

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.10	0.10	0.000	-0.12C		-0.22
primary	Temp Mid Range	13.40	13.40	0.000	13.80C		0.4
primary	Temp High Rang	40.00	40.00	0.000	40.30C		0.3

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		YEL408	Tim Mendenhall	05/16/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.30	0.30		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	27.40	27.40	0.000	27.7	C	0.3	
primary	Temp Mid Range	28.10	28.10	0.000	28.4	C	0.3	
primary	Temp Mid Range	25.50	25.50	0.000	25.8	C	0.3	
Sensor Component	System Memo			Condition		Status	pass	

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Infrastructure Data For

Site ID

YEL408

Technician

Tim Mendenhall

Site Visit Date

05/16/2023

Shelter Make	Shelter Model	Shelter Size
Ekto	8810 (s/n 2880-1)	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	Good	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

The site operator was not able to be present during the site audit visit. Audit data are based on site documentation.

**2 Parameter:** DasComments

The shelter heat and air conditioner run simultaneously.

**3 Parameter:** SiteOpsProcedures

The ozone inlet filter is replaced and the system is leak tested every two weeks.

**4 Parameter:** SitingCriteriaCom

The site is located at the edge of a tree line. Trees as tall as 8 meters are near the sample inlet. Trees taller than 10 meters are 15 meters from the inlet.

**5 Parameter:** ShelterCleanNotes

The shelter is organized and well maintained.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	YEL408	Technician	Tim Mendenhall	Site Visit Date	05/16/2023		
Site Sponsor (agency)	NPS	USGS Map	Lake				
Operating Group	NPS	Map Scale					
AQS #	56-039-1011	Map Date					
Meteorological Type	Climatronics						
Air Pollutant Analyzer	Ozone, IMPROVE	QAPP Latitude	44.5597				
Deposition Measurement	dry	QAPP Longitude	-110.4006				
Land Use	woodland - evergreen	QAPP Elevation Meters	2400				
Terrain	complex	QAPP Declination					
Conforms to MLM	Marginally	QAPP Declination Date					
Site Telephone	(307) 242-2410	Audit Latitude	44.565356				
Site Address 1	Lake Ranger Station	Audit Longitude	-110.400338				
Site Address 2	route 14	Audit Elevation	2430				
County	Teton	Audit Declination	11.9				
City, State	Yellowstone National Park, WY	Present					
Zip Code	82190	Fire Extinguisher	<input checked="" type="checkbox"/>	New in 2017			
Time Zone	Mountain	First Aid Kit	<input checked="" type="checkbox"/>				
Primary Operator		Safety Glasses	<input type="checkbox"/>				
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>				
Primary Op. E-mail		Climbing Belt	<input checked="" type="checkbox"/>				
Backup Operator		Security Fence	<input type="checkbox"/>				
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>				
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>				
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810 (s/n 2880-1)	Shelter Size	640 cuft
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is organized and well maintained.				
Site OK	<input checked="" type="checkbox"/>	Notes					
Driving Directions	From Jackson take route 191 / 89 north to Yellowstone National Park. At Thumb Junction take 14 east around Yellowstone Lake. Turn left just past the Lake Area (and hotel) into the park residence and office compound. Continue through the compound past the housing area. The site is up the hill through the gate to the water supply tank for the compound.						



Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

YEL408

Technician

Tim Mendenhall

Site Visit Date

05/16/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

YEL408

Technician

Tim Mendenhall

Site Visit Date

05/16/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

YEL408

Technician

Tim Mendenhall

Site Visit Date

05/16/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input type="checkbox"/>	10 to 15 meters from trees

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 9 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

YEL408

Technician

Tim Mendenhall

Site Visit Date

05/16/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>	
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>	
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>	
6	Are the DAS, sensor translators, and shelter properly grounded?	<input type="checkbox"/>	Shelter not grounded
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>	
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>	
9	Is the met tower stable and grounded?	<div><div>Stable</div><div><input checked="" type="checkbox"/></div></div>	<div><div>Grounded</div><div><input checked="" type="checkbox"/></div></div>
10	Is the sample tower stable and grounded?	<div><div>Stable</div><div><input checked="" type="checkbox"/></div></div>	<div><div>Grounded</div><div><input checked="" type="checkbox"/></div></div>
11	Tower comments?		

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The shelter heat and air conditioner run simultaneously.

Site ID

YEL408

Technician

Tim Mendenhall

Site Visit Date

05/16/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	DataView2	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	July 2016	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	July 2016	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 2016	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

Dataview

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

YEL408

Technician

Tim Mendenhall

Site Visit Date

05/16/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Trained by ARS on site

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Monthly and semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>			<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Alarm values only		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>			<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Dataview

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone inlet filter is replaced and the system is leak tested every two weeks.

Site ID

YEL408

Technician

Tim Mendenhall

Site Visit Date

05/16/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	Dataview, SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input type="checkbox"/>	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator was not able to be present during the site audit visit. Audit data are based on site documentation.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

YEL408

Technician

Tim Mendenhall

Site Visit Date

05/16/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Environmental Sys Corp	8832	A4888K	None
Elevation	Elevation	1	None	None
Flow Rate	Alicat	MC-10SLPM-D-PCV	Illegible	none
Infrastructure	Infrastructure	none	none	none
Met tower	Climatronics	14 inch taper	illegible	01362
Ozone	ThermoElectron Inc	49i A3NAA	1172090002	none
Ozone Standard	ThermoElectron Inc	49i A1NAB	0926938297	none
Sample Tower	Aluma Tower	B	none	illegible
Shelter Temperature	ARS	none	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342VC	029239	none
Zero air pump	Werther International	PC 70/4	000836215	none



# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
WSP144-Martin Valvur-05/17/2023						
1	5/17/2023	Computer	Dell	07016	Inspiron 15	DK2MC12
2	5/17/2023	DAS	Campbell	000430	CR3000	2525
3	5/17/2023	Elevation	Elevation	None	1	None
4	5/17/2023	Filter pack flow pump	Thomas	06021	107CAB18B	060400022648
5	5/17/2023	Flow Rate	Apex	000872	AXMC105LPMDPCV	illegible
6	5/17/2023	Infrastructure	Infrastructure	none	none	none
7	5/17/2023	Modem	Digi	07196	LR54	unknown
8	5/17/2023	Ozone	ThermoElectron Inc	000745	49i A1NAA	1105347310
9	5/17/2023	Ozone Standard	ThermoElectron Inc	000464	49i A3NAA	0622717858
10	5/17/2023	Sample Tower	Aluma Tower	000126	B	none
11	5/17/2023	Shelter Temperature	Campbell	none	107-L	none
12	5/17/2023	Siting Criteria	Siting Criteria	None	1	None
13	5/17/2023	Temperature	RM Young	06387	41342VC	13960
14	5/17/2023	Zero air pump	Werther International	06880	C 70/4	000814273

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
<input type="text" value="Campbell"/>	<input type="text" value="2525"/>	<input type="text" value="WSP144"/>	<input type="text" value="Martin Valvur"/>	<input type="text" value="05/17/2023"/>	<input type="text" value="DAS"/>	<input type="text" value="Primary"/>

Das Date:	<input type="text" value="5 /17/2023"/>	Audit Date	<input type="text" value="5 /17/2023"/>
Das Time:	<input type="text" value="11:43:00"/>	Audit Time	<input type="text" value="11:43:00"/>
Das Day:	<input type="text" value="137"/>	Audit Day	<input type="text" value="137"/>
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0000"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0000"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/25/2023"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	0.0000	0.0000	V	V	0.0000	
7	0.1000	0.0999	0.0999	V	V	0.0000	
7	0.3000	0.2997	0.2997	V	V	0.0000	
7	0.5000	0.4995	0.4995	V	V	0.0000	
7	0.7000	0.6994	0.6994	V	V	0.0000	
7	0.9000	0.8992	0.8992	V	V	0.0000	
7	1.0000	0.9991	0.9991	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		WSP144	Martin Valvur	05/17/2023	Flow Rate	000872

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.01
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	1.01
0.89%	1.33%	Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	-0.01	0.000	-0.01	l/m	l/m	
primary	test pt 1	1.490	1.490	1.46	0.000	1.48	l/m	l/m	-0.67%
primary	test pt 2	1.490	1.490	1.47	0.000	1.48	l/m	l/m	-0.67%
primary	test pt 3	1.500	1.500	1.46	0.000	1.48	l/m	l/m	-1.33%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	4.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	225 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347310

WSP144

Martin Valvur

05/17/2023

Ozone

000745

Slope:

0.99788

Slope:

0.00000

Intercept

-0.03847

Intercept

0.00000

CorrCoff

1.00000

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.39	0.09	0.18	ppb		0.09	
primary	2	17.34	17.08	16.96	ppb		-0.12	
primary	3	35.04	34.83	34.65	ppb	-0.52		
primary	4	66.81	66.68	66.40	ppb	-0.42		
primary	5	116.00	116.00	115.80	ppb	-0.17		
Sensor Component	Audit Pressure		Condition	758.5 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.000		Status	pass	
Sensor Component	Span		Condition	1.028		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	90.3 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.9 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.65 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	731.8 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	34.3 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	99.7 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.7 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.70 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	731.2 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	13960		WSP144	Martin Valvur	05/17/2023	Temperature	06387

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

0.16	0.21		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary		0.30	0.22	0.000	0.1	C	-0.17	
primary		24.00	23.64	0.000	23.5	C	-0.1	
primary		48.40	47.76	0.000	48.0	C	0.21	

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		WSP144	Martin Valvur	05/17/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.27	0.57		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	24.90	24.53	0.000	24.6	C	0.07	
primary	Temp Mid Range	25.10	24.73	0.000	24.9	C	0.17	
primary	Temp Mid Range	25.00	24.63	0.000	25.2	C	0.57	
Sensor Component		System Memo		Condition		Status	pass	

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition	20 km	Status	Fail
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Infrastructure Data For

Site ID

WSP144

Technician

Martin Valvur

Site Visit Date

05/17/2023

Shelter Make	Shelter Model	Shelter Size
Ekto	8810	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass



# Field Systems Comments

- 1

Parameter:

SitingCriteriaCom

The city of Trenton, estimated population greater than 85,000, is within 20 km of the site.
- 2

Parameter:

ShelterCleanNotes

The shelter is in fair condition, clean, very neat, and well organized but beginning to show signs of wear.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID

WSP144

Technician

Martin Valvur

Site Visit Date

05/17/2023

Site Sponsor (agency)	EPA	USGS Map	Pennington
Operating Group	NJDEP / WCRC	Map Scale	
AQS #	34-021-9991	Map Date	
Meteorological Type	R.M. Young		
Air Pollutant Analyzer	Ozone	QAPP Latitude	
Deposition Measurement	dry, PM2.5, PM10	QAPP Longitude	
Land Use	woodland, urban agriculture	QAPP Elevation Meters	
Terrain	rolling	QAPP Declination	
Conforms to MLM	Marginally	QAPP Declination Date	
Site Telephone		Audit Latitude	40.312303
Site Address 1	WCRC-FA	Audit Longitude	-74.872663
Site Address 2	Church Rd.	Audit Elevation	59
County	Mercer	Audit Declination	-12.5
City, State	Titusville, NJ		
Zip Code	08560	Fire Extinguisher	<input checked="" type="checkbox"/> Present dated 2015
Time Zone	Eastern	First Aid Kit	<input checked="" type="checkbox"/> 
Primary Operator		Safety Glasses	<input checked="" type="checkbox"/> 
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/> 
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/> 
Backup Operator		Security Fence	<input checked="" type="checkbox"/> 
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/> 
Backup Op. E-mail		Stable Entry Step	<input checked="" type="checkbox"/> 

Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810	Shelter Size	640 cuft
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is in fair condition, clean, very neat, and well organized but beginning to show signs of wear.				
Site OK	<input checked="" type="checkbox"/>	Notes					

Driving Directions

From Philadelphia take I-95 north. Cross the Delaware River into New Jersey and take the first exit, route 29 north, just over the bridge. Continue approximately 4 miles through the traffic light at the intersection of 546 and through the park. Turn right onto Church road at the traffic light. Continue approximately 0.5 miles to the gate for the WCRC-FA on the right. The combination to the lock is 1903. Continue through the gate up the gravel road to the top of the hill and turn right along the edge of the field. Follow the gravel road to the site in the chain-link fenced area.

Site ID

WSP144

Technician

Martin Valvur

Site Visit Date

05/17/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

WSP144

Technician

Martin Valvur

Site Visit Date

05/17/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDWSP144

TechnicianMartin Valvur

Site Visit Date05/17/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

WSP144

Technician

Martin Valvur

Site Visit Date

05/17/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Temperature only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	<div>Met tower removed</div>										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

WSP144

Technician

Martin Valvur

Site Visit Date

05/17/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2011	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2011	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

WSP144

Technician

Martin Valvur

Site Visit Date

05/17/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

trained by previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



Site ID

WSP144

Technician

Martin Valvur

Site Visit Date

05/17/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

WSP144

Technician

Martin Valvur

Site Visit Date

05/17/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	DK2MC12	07016
DAS	Campbell	CR3000	2525	000430
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18B	060400022648	06021
Flow Rate	Apex	AXMC105LPMDPC	illegible	000872
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07196
Ozone	ThermoElectron Inc	49i A1NAA	1105347310	000745
Ozone Standard	ThermoElectron Inc	49i A3NAA	0622717858	000464
Sample Tower	Aluma Tower	B	none	000126
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VC	13960	06387
Zero air pump	Werther International	C 70/4	000814273	06880

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
CRM435-Tim Mendenhall-05/18/2023						
1	5/18/2023	DAS	Environmental Sys Corp	none	8816	3504
2	5/18/2023	Ozone	ThermoElectron Inc	none	49i A3NCA	1201477662
3	5/18/2023	Ozone Standard	ThermoElectron Inc	90605	49C	49C-62025-333
4	5/18/2023	Zero air pump	Werther International	none	C 70/4	000847661

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1201477662

CRM435

Tim Mendenhall

05/18/2023

Ozone

none

Slope:

0.98376

Slope:

0.00000

Intercept

0.12098

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.13	-0.07	-0.04	ppb		0.03	
primary	2	15.54	15.18	15.13	ppb		-0.05	
primary	3	34.88	34.33	33.98	ppb	-1.02		
primary	4	65.08	64.24	63.24	ppb	-1.57		
primary	5	113.30	111.99	110.30	ppb	-1.52		
Sensor Component	Audit Pressure		Condition	618.5 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	False		Status	Fail	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.4		Status	pass	
Sensor Component	Span		Condition	0.998		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	112.2 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	4.1 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.66 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	603.7 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	Not tested		Status	pass	
Sensor Component	Cell B Freq.		Condition	65.3 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	1.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.64 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	604.0 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
NEC602-Tim Mendenhall-05/24/2023						
1	5/24/2023	DAS	Campbell	none	CR1000	47758
2	5/24/2023	elevation	Elevation	none	none	none
3	5/24/2023	Filter pack flow pump	Thomas	none	107CAB18	051400047325
4	5/24/2023	Flow Rate	Omega	none	FMA6518ST-RS232	394013
5	5/24/2023	Infrastructure	Infrastructure	none	none	none
6	5/24/2023	MFC power supply	Sceptre	none	FMA65PWC	295106-8
7	5/24/2023	Ozone	ThermoElectron Inc	none	49i A1NAA	1214552974
8	5/24/2023	Ozone Standard	ThermoElectron Inc	L0534683	49i E3CAA	1214552972
9	5/24/2023	Sample Tower	Unknown	none	Unknown	None
10	5/24/2023	Shelter Temperature	ARS	none	Thermocouple	none
11	5/24/2023	siting criteria	Siting Criteria	none	none	None
12	5/24/2023	Temperature2meter	Campbell	none	unknown	missing
13	5/24/2023	Zero air pump	Thomas	none	107CAB18	082000067914

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Omega	394013		NEC602	Tim Mendenhall	05/24/2023	Flow Rate	none

Mfg	Sceptre	
SN/Owner ID	295106-8	none
Parameter:	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	152253	Tfer Desc.	BIOS 220-H
Tfer ID	15225		
Slope	1.00000	Intercept	0.00000
Cert Date	5/2/2022	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
2.74%	3.09%		
		Cal Factor Full Scale	0
		Rotometer Reading:	0

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.18	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.22	0.000	0.00	l/m	l/m	
primary	test pt 1	2.910	2.910	0.00	0.000	3.00	l/m	l/m	3.09%
primary	test pt 2	2.920	2.920	0.00	0.000	2.99	l/m	l/m	2.40%
primary	test pt 3	2.920	2.920	0.00	0.000	3.00	l/m	l/m	2.74%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Poor	Status	Fail
Sensor Component	Rotometer Condition	Condition	N/A	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	-0.75 cm	Status	Fail
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1214552974

NEC602

Tim Mendenhall

05/24/2023

Ozone

none

Slope:

0.98158

Slope:

0.00000

Intercept

-0.42016

Intercept

0.00000

CorrCoff:

0.99994

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.12	-0.08	0.13	ppb		0.21	
primary	2	14.36	14.01	13.16	ppb		-0.85	
primary	3	34.26	33.72	32.22	ppb	-4.55		
primary	4	63.45	62.63	60.69	ppb	-3.15		
primary	5	112.42	111.12	109.02	ppb	-1.91		

Sensor Component

Audit Pressure

Condition

641 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

0.1

Status

pass

Sensor Component

Span

Condition

1.041

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

93.5 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

8.2 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.66 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

627.4 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

33.4 C

Status

pass

Sensor Component

Cell B Freq.

Condition

81.9 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

8.4 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.68 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

628.0 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

False

Status

pass

Sensor Component

System Memo

Condition

Status

pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	missing		NEC602	Tim Mendenhall	05/24/2023	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

0.11	0.13		
------	------	--	--

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.28	0.28	0.000	0.15C		-0.13
primary	Temp Mid Range	19.52	19.52	0.000	19.64C		0.12
primary	Temp High Rang	37.58	37.58	0.000	37.67C		0.09

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass



# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		NEC602	Tim Mendenhall	05/24/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.18	0.30		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	24.26	24.26	0.000	24.4	C	0.1
primary	Temp Mid Range	25.02	25.02	0.000	24.9	C	-0.13
primary	Temp Mid Range	24.43	24.43	0.000	24.7	C	0.3
Sensor Component	System Memo			Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition	< 10 km	Status	Fail
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition	2 km	Status	Fail
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition	< 10 km	Status	Fail
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Infrastructure Data For

Site ID

NEC602

Technician

Tim Mendenhall

Site Visit Date

05/24/2023

Shelter Make

Shelter One

Shelter Model

AR 263648

Shelter Size

24 cuft

Sensor Component	Sample Tower Type	Condition	Other	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Not installed	Status	Fail
Sensor Component	Sample Tower	Condition	Fair	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	1/4 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

The site operator does not use gloves to handle the filter pack. Sample line leak checks are not being performed. The sample is changed on Wednesdays and not Tuesdays as described in the QAPP.

**2 Parameter:** DasComments

The dry deposition tower is visibly bent.

**3 Parameter:** SiteOpsProcedures

The site operator is new and has not yet received formal training from ARS. The site operator would benefit from training. Some of the items on the SSRF were discussed and the site operator's questions were answered regarding the correct procedures.

**4 Parameter:** DocumentationCo

The site operator is new and site documentation (QAPP and SOP) have not been provided.

**5 Parameter:** SitingCriteriaCom

The site is located approximately 2 km northeast of Newcastle WY which has a population of approximately 3500. There is an oil refinery in Newcastle. A heavily traveled road is approximately 100m west of the site.

**6 Parameter:** ShelterCleanNotes

The shelter houses the ozone, DAS, and MFC only.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	NEC602	Technician	Tim Mendenhall	Site Visit Date	05/24/2023		
Site Sponsor (agency)	BLM-WSO	USGS Map					
Operating Group	BLM	Map Scale					
AQS #	560450003	Map Date					
Meteorological Type	Met One						
Air Pollutant Analyzer	Ozone	QAPP Latitude					
Deposition Measurement	dry and wet	QAPP Longitude					
Land Use		QAPP Elevation Meters					
Terrain		QAPP Declination					
Conforms to MLM		QAPP Declination Date					
Site Telephone		Audit Latitude	43.8731				
Site Address 1		Audit Longitude	-104.192009				
Site Address 2		Audit Elevation	1469				
County	Weston	Audit Declination	8.2				
City, State	Newcastle, WY						
Zip Code	82701	Fire Extinguisher	<input type="checkbox"/> Present				
Time Zone	Mountain	First Aid Kit	<input type="checkbox"/>				
Primary Operator		Safety Glasses	<input type="checkbox"/>				
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>				
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>				
Backup Operator		Security Fence	<input type="checkbox"/>				
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>				
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>				
Shelter Working Room	<input type="checkbox"/>	Make	Shelter One	Model	AR 263648	Shelter Size	24 cuft
Shelter Clean	<input type="checkbox"/>	Notes	The shelter houses the ozone, DAS, and MFC only.				
Site OK	<input type="checkbox"/>	Notes					
Driving Directions							

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

NEC602

Technician

Tim Mendenhall

Site Visit Date

05/24/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

NEC602

Technician

Tim Mendenhall

Site Visit Date

05/24/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

NEC602

Technician

Tim Mendenhall

Site Visit Date

05/24/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 10 meters
4	Describe dry dep sample tube.		1/4 Nylon by 10 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input type="checkbox"/>	Not present

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



Site ID

NEC602

Technician

Tim Mendenhall

Site Visit Date

05/24/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>									
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>									
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input type="checkbox"/>	Not present								
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>									
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>									
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>									
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>									
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded									
<input type="checkbox"/>		<input type="checkbox"/>									
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>									
10	Is the sample tower stable and grounded?										
11	Tower comments?	sample tower bent									

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The dry deposition tower is visibly bent.

Site ID

NEC602

Technician

Tim Mendenhall

Site Visit Date

05/24/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	Not present	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	Not present	<input type="checkbox"/>
HASP	<input type="checkbox"/>	Not present	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	Not present	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	Not present	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	Not present	<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>	Not present	<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☐

No logbook

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is new and site documentation (QAPP and SOP) have not been provided.

Site ID

NEC602

Technician

Tim Mendenhall

Site Visit Date

05/24/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

no formal training received

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☐

visits on Wednesday

4

Are the standard CASTNET operational procedures being followed by the site operator?

☐

leak check not performed

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☐

would benefit from training

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input type="checkbox"/>	Not performed		<input type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>			<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>			<input type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>			<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 months		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☐

Unknown

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is new and has not yet received formal training from ARS. The site operator would benefit from training. Some of the items on the SSRF were discussed and the site operator's questions were answered regarding the correct procedures.

Site ID

NEC602

Technician

Tim Mendenhall

Site Visit Date

05/24/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input type="checkbox"/>	Filter changed mid-day on Wednesday
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input type="checkbox"/> Not performed	<input type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input type="checkbox"/> Not present	<input type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator does not use gloves to handle the filter pack. Sample line leak checks are not being performed. The sample is changed on Wednesdays and not Tuesdays as described in the QAPP.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

NEC602

Technician

Tim Mendenhall

Site Visit Date

05/24/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR1000	47758	none
elevation	Elevation	none	none	none
Filter pack flow pump	Thomas	107CAB18	051400047325	none
Flow Rate	Omega	FMA6518ST-RS232	394013	none
Infrastructure	Infrastructure	none	none	none
MFC power supply	Sceptre	FMA65PWC	295106-8	none
Ozone	ThermoElectron Inc	49i A1NAA	1214552974	none
Ozone Standard	ThermoElectron Inc	49i E3CAA	1214552972	L0534683
Sample Tower	Unknown	Unknown	None	none
Shelter Temperature	ARS	Thermocouple	none	none
siting criteria	Siting Criteria	none	None	none
Temperature2meter	Campbell	unknown	missing	none
Zero air pump	Thomas	107CAB18	082000067914	none

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
ARE128-Tim Mendenhall-06/12/2023						
1	6/12/2023	DAS	Campbell	000400	CR3000	2524
2	6/12/2023	Ozone	ThermoElectron Inc	000618	49i A1NAA	1009241789
3	6/12/2023	Ozone Standard	ThermoElectron Inc	000433	49i A3NAA	CM08200009
4	6/12/2023	Zero air pump	Werther International	06866	PC70/4	000815262

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241789

ARE128

Tim Mendenhall

06/12/2023

Ozone

000618

Slope:

1.00558

Slope:

0.00000

Intercept

-0.58735

Intercept

0.00000

CorrCoff

0.99994

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.30	0.00	-0.94	ppb		-0.94	
primary	2	14.55	14.28	13.50	ppb		-0.78	
primary	3	33.17	32.95	33.32	ppb	1.12		
primary	4	63.92	63.78	63.67	ppb	-0.17		
primary	5	108.77	108.75	108.50	ppb	-0.23		
Sensor Component	Audit Pressure		Condition	737.7 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Moderately clean		Status	pass	
Sensor Component	Offset		Condition	-0.30		Status	pass	
Sensor Component	Span		Condition	1.011		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	86.2 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	Not tested		Status	pass	
Sensor Component	Cell A Flow		Condition	0.66 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	706.3 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	37.0 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	89.6 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	Not tested		Status	pass	
Sensor Component	Cell B Flow		Condition	0.65 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	707.2 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Site Inventory by Site Visit

Site Visit Date		Parameter	Mfg	Owner ID	Model Number	Serial Number
KEF112-Tim Mendenhall-06/13/2023						
1	6/13/2023	DAS	Campbell	000414	CR3000	2537
2	6/13/2023	Ozone	ThermoElectron Inc	000682	49i A1NAA	1030244796
3	6/13/2023	Ozone Standard	ThermoElectron Inc	000432	49i A3NAA	CM08200008
4	6/13/2023	Zero air pump	Werther International	06932	C 70/4	000829174



Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244796

KEF112

Tim Mendenhall

06/13/2023

Ozone

000682

Slope:

0.96624

Slope:

0.00000

Intercept

0.83467

Intercept

0.00000

CorrCoff

0.99998

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.43	0.13	0.54	ppb		0.41	
primary	2	14.89	14.62	15.16	ppb		0.54	
primary	3	34.70	34.49	34.54	ppb	0.14		
primary	4	66.52	66.39	64.94	ppb	-2.21		
primary	5	113.42	113.41	110.30	ppb	-2.78		
Sensor Component	Audit Pressure		Condition	707.7 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.30		Status	pass	
Sensor Component	Span		Condition	1.010		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	89.2 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.9 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.58 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	660.0 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	38.4 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	101.7 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.70 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	660.6 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	True		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
MKG113-Tim Mendenhall-06/14/2023						
1	6/14/2023	DAS	Campbell	000404	CR3000	2521
2	6/14/2023	Ozone	ThermoElectron Inc	000741	49i A1NAA	1105347316
3	6/14/2023	Ozone Standard	ThermoElectron Inc	000370	49i A3NAA	0726124689
4	6/14/2023	Zero air pump	Werther International	06899	C 70/4	000821902

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347316

MKG113

Tim Mendenhall

06/14/2023

Ozone

000741

Slope:

0.98805

Slope:

0.00000

Intercept

-1.05740

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.41	0.11	-0.74	ppb		-0.85	
primary	2	14.62	14.35	13.03	ppb		-1.32	
primary	3	33.68	33.46	31.82	ppb	-5.02		
primary	4	64.87	64.73	62.89	ppb	-2.88		
primary	5	107.69	107.67	105.40	ppb	-2.13		
Sensor Component	Audit Pressure			Condition	732.9 mmHg		Status	pass
Sensor Component	26.6 degree unobstructed rule			Condition	True		Status	pass
Sensor Component	Tree dewline >10m or below inlet			Condition	True		Status	pass
Sensor Component	ADT 1000-10000 vehicles further			Condition	True		Status	pass
Sensor Component	ADT <1000 vehicles further than			Condition	True		Status	pass
Sensor Component	Sample Train			Condition	Good		Status	pass
Sensor Component	Inlet Filter Condition			Condition	Clean		Status	pass
Sensor Component	Offset			Condition	-0.10		Status	pass
Sensor Component	Span			Condition	1.004		Status	pass
Sensor Component	Zero Voltage			Condition	N/A		Status	pass
Sensor Component	Fullscale Voltage			Condition	N/A		Status	pass
Sensor Component	Cell A Freq.			Condition	85.6 kHz		Status	pass
Sensor Component	Cell A Noise			Condition	3.1 ppb		Status	pass
Sensor Component	Cell A Flow			Condition	0.69 lpm		Status	pass
Sensor Component	Cell A Pressure			Condition	684.7 mmHg		Status	pass
Sensor Component	Cell A Tmp.			Condition	36.2 C		Status	pass
Sensor Component	Cell B Freq.			Condition	99.3 kHz		Status	pass
Sensor Component	Cell B Noise			Condition	2.2 ppb		Status	pass
Sensor Component	Cell B Flow			Condition	0.74 lpm		Status	pass
Sensor Component	Cell B Pressure			Condition	685.3 mmHg		Status	pass
Sensor Component	Nafion dryer installed			Condition	True		Status	pass
Sensor Component	System Memo			Condition			Status	pass

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
LRL117-Tim Mendenhall-06/15/2023						
1	6/15/2023	DAS	Campbell	000344	CR300	2123
2	6/15/2023	Ozone	ThermoElectron Inc	000701	49i A1NAA	1030244808
3	6/15/2023	Ozone Standard	ThermoElectron Inc	000444	49i A3NAA	CM08200020
4	6/15/2023	Zero air pump	Werther International	06904	C 70/4	000821901

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244808

LRL117

Tim Mendenhall

06/15/2023

Ozone

000701

Slope:

0.98793

Slope:

0.00000

Intercept

-0.64757

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.49	0.19	-0.47	ppb		-0.66	
primary	2	14.54	14.27	13.54	ppb		-0.73	
primary	3	33.55	33.33	32.08	ppb	-3.82		
primary	4	64.34	64.20	62.95	ppb	-1.97		
primary	5	109.44	109.42	107.40	ppb	-1.86		
Sensor Component	Audit Pressure		Condition	716 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.10		Status	pass	
Sensor Component	Span		Condition	1.011		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	93.1 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	4.7 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.63 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	684.4 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	35.5 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	90.3 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	2.2 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.64 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	685.0 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

## Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
SEK430-Martin Valvur-06/20/2023						
1	6/20/2023	Computer	Hewlett Packard	none	ProBook	illegible
2	6/20/2023	DAS	Environmental Sys Corp	90649	8816	2562
3	6/20/2023	Elevation	Elevation	None	1	None
4	6/20/2023	Filter pack flow pump	Thomas	none	107CAB18	120000014367
5	6/20/2023	flow rate	Tylan	03384	FC280AV	AW9403014
6	6/20/2023	Infrastructure	Infrastructure	none	none	none
7	6/20/2023	Met tower	Aluma Tower	none	B	none
8	6/20/2023	MFC power supply	Tylan	03679	RO-32	FP9403015
9	6/20/2023	Ozone	ThermoElectron Inc	none	49i A3NCA	1200666538
10	6/20/2023	Ozone Standard	ThermoElectron Inc	90752	49C	49C-74532-376
11	6/20/2023	Shelter Temperature	ARS	none	none	none
12	6/20/2023	Shield (2 meter)	RM Young	none	Aspirated 43408	none
13	6/20/2023	Siting Criteria	Siting Criteria	None	1	None
14	6/20/2023	Temperature Translator	RM Young	00819	41406-X	063143
15	6/20/2023	Temperature2meter	RM Young	none	41342	8472
16	6/20/2023	Zero air pump	Altec	none	CDA/0	092000484

DAS Data Form

DAS Time Max Error: 1.92

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2562	SEK430	Martin Valvur	06/20/2023	DAS	Primary

Das Date:	6 /20/2023	Audit Date	6 /20/2023
Das Time:	07:06:55	Audit Time	07:05:00
Das Day:	171	Audit Day	171
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0001	0.0002	0.0001	0.0002

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0002	0.0000	V	V	0.0002	
7	0.1000	0.1000	0.0999	V	V	-0.0001	
7	0.3000	0.2997	0.2999	V	V	0.0002	
7	0.5000	0.4998	0.4999	V	V	0.0001	
7	0.7000	0.6998	0.6996	V	V	-0.0002	
7	0.9000	0.9002	0.9000	V	V	-0.0002	
7	1.0000	1.0003	1.0003	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9403014		SEK430	Martin Valvur	06/20/2023	flow rate	03384

Mfg	Tylan	
SN/Owner ID	FP9403015	03679
Parameter:	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	152253	Tfer Desc.	BIOS 220-H
Tfer ID	15225		
Slope	1.00000	Intercept	0.00000
Cert Date	5/2/2022	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.036
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
1.01%	1.36%		
		Cal Factor Full Scale	5.522
		Rotometer Reading:	3.3

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.02	0.0000	0.06	l/m	l/m	
primary	leak check	0.000	0.000	0.02	0.0000	0.07	l/m	l/m	
primary	test pt 1	2.950	2.950	2.49	0.0000	2.99	l/m	l/m	1.36%
primary	test pt 2	2.960	2.960	2.49	0.0000	2.99	l/m	l/m	1.01%
primary	test pt 3	2.970	2.970	2.50	0.0000	2.99	l/m	l/m	0.67%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Poor	Status	fail
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	-1.0 cm	Status	fail
Sensor Component	Filter Azimuth	Condition	260 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass



Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1200666538

SEK430

Martin Valvur

06/20/2023

Ozone

none

Slope:

0.99127

Slope:

0.00000

Intercept

-0.50049

Intercept

0.00000

CorrCoff:

0.99999

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.05	-0.25	-0.60	ppb		-0.35	
primary	2	16.34	15.97	15.18	ppb		-0.79	
primary	3	33.95	33.41	32.40	ppb	-3.07		
primary	4	58.43	57.66	56.93	ppb	-1.27		
primary	5	112.93	111.63	110.10	ppb	-1.38		
Sensor Component	Audit Pressure		Condition	721.5 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.40		Status	pass	
Sensor Component	Span		Condition	0.997		Status	pass	
Sensor Component	Zero Voltage		Condition	0.000		Status	pass	
Sensor Component	Fullscale Voltage		Condition	1.000		Status	pass	
Sensor Component	Cell A Freq.		Condition	60.3 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.71 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	699.6 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	28.8 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	114.0 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.9 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.72 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	699.3 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	8472		SEK430	Martin Valvur	06/20/2023	Temperature2meter	none

Mfg	RM Young		Mfg	Fluke	Parameter	Temperature	
SN/Owner ID	063143	00819	Serial Number	3275143	Tfer Desc.	RTD	
Parameter:	Temperature Translator		Tfer ID	01229			
DAS 1:		DAS 2:		Slope	1.00002	Intercept	-0.00336
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err	Cert Date	1/23/2023	CorrCoff	1.00000

0.07	0.19		
------	------	--	--

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.02	0.02	0.0000	0.03C		0.01
primary	Temp Mid Range	24.62	24.62	0.0000	24.62C		0
primary	Temp High Rang	47.35	47.35	0.0000	47.54C		0.19

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		SEK430	Martin Valvur	06/20/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.65	0.76		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	21.49	21.49	0.000	22.1	C	0.57	
primary	Temp Mid Range	21.27	21.27	0.000	22.0	C	0.76	
primary	Temp Mid Range	21.58	21.58	0.000	22.2	C	0.61	
Sensor Component	System Memo			Condition		Status	pass	

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition	40 m	Status	Fail
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Infrastructure Data For

Site ID

SEK430

Technician

Martin Valvur

Site Visit Date

06/20/2023

Shelter Make

Alan pre-fab

Shelter Model

s/n 861166 1808

Shelter Size

512 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

## Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	SEK430	Martin	06/20/2023	Filter Depth	Tylan	1414	<input type="checkbox"/>	<input type="checkbox"/>
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.								

# Field Systems Comments

**1 Parameter:** SitingCriteriaCom

The site is a wooded area with spaced trees on three sides and a steep drop in elevation on the west side. Although not strictly conforming to siting criteria it is elevated in a wide valley and representative of the area. Trees are still within 5 meters, however none are higher than the CASTNET sample inlets.

**2 Parameter:** ShelterCleanNotes

The shelter is aging but is in fair condition and kept clean, neat, and well organized.

**3 Parameter:** MetOpMaintCom

The 2 meter temperature sensor signal cable is showing signs of wear.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	SEK430	Technician	Martin Valvur	Site Visit Date	06/20/2023
Site Sponsor (agency)	NPS	USGS Map	Case Mountain		
Operating Group	NPS	Map Scale			
AQS #	06-107-0009	Map Date			
Meteorological Type	R.M. Young				
Air Pollutant Analyzer	Ozone, IMPROVE, BAM	QAPP Latitude			
Deposition Measurement	dry	QAPP Longitude			
Land Use	woodland - mixed	QAPP Elevation Meters			
Terrain	complex	QAPP Declination			
Conforms to MLM	Marginally	QAPP Declination Date			
Site Telephone		Audit Latitude	36.489469		
Site Address 1	Southern Sierra Research Center	Audit Longitude	-118.829153		
Site Address 2	Highway 198	Audit Elevation	510		
County	Tulare	Audit Declination	13.1		
City, State	Sequoia National Park, CA		Present		
Zip Code	93262	Fire Extinguisher	<input checked="" type="checkbox"/>	Inspected June 2022	
Time Zone	Pacific	First Aid Kit	<input checked="" type="checkbox"/>		
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Alan pre-fab	Model	s/n 861166 1808
		Shelter Size	512 cuft		
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is aging but is in fair condition and kept clean, neat, and well organized.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From highway 99 take 198 east through Three Rivers. Continue approximately 7 miles to the entrance to Sequoia National Park. Less than one mile past the Fee both, take the first paved road to the right at the Southern Sierra Research Center. The site is on the hill behind the center.				



Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

SEK430

Technician

Martin Valvur

Site Visit Date

06/20/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input type="checkbox"/>	2 meter temperature shield pointing south
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SEK430

Technician

Martin Valvur

Site Visit Date

06/20/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input type="checkbox"/>	Signs of wear
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The 2 meter temperature sensor signal cable is showing signs of wear.

Site ID

SEK430

Technician

Martin Valvur

Site Visit Date

06/20/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input type="checkbox"/>	Trees within 5 meters

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 16 meters
4	Describe dry dep sample tube.		3/8 teflon by 15 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SEK430

Technician

Martin Valvur

Site Visit Date

06/20/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>	
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>	
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>	
6	Are the DAS, sensor translators, and shelter properly grounded?	<input type="checkbox"/>	The shelter ground may not be adequate
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>	
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>	
9	Is the met tower stable and grounded?	<div><div>Stable</div><div><input type="checkbox"/></div><div><input checked="" type="checkbox"/></div></div>	<div><div>Grounded</div><div><input type="checkbox"/></div><div><input checked="" type="checkbox"/></div></div>
10	Is the sample tower stable and grounded?		
11	Tower comments?		The met sensors are mounted on the sample tower.

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SEK430

Technician

Martin Valvur

Site Visit Date

06/20/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	DataView2	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Jan 2006	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☒

Dataview
- 2

Are the Site Status Report Forms being completed and current?

☒

SSRFs are reviewed before sending
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SEK430

Technician

Martin Valvur

Site Visit Date

06/20/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>			<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Alarm values only		<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

DataView

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SEK430

Technician

Martin Valvur

Site Visit Date

06/20/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	Flow and observation sections only
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

SEK430

Technician

Martin Valvur

Site Visit Date

06/20/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	ProBook	illegible	none
DAS	Environmental Sys Corp	8816	2562	90649
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	120000014367	none
flow rate	Tylan	FC280AV	AW9403014	03384
Infrastructure	Infrastructure	none	none	none
Met tower	Aluma Tower	B	none	none
MFC power supply	Tylan	RO-32	FP9403015	03679
Ozone	ThermoElectron Inc	49i A3NCA	1200666538	none
Ozone Standard	ThermoElectron Inc	49C	49C-74532-376	90752
Shelter Temperature	ARS	none	none	none
Shield (2 meter)	RM Young	Aspirated 43408	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature Translator	RM Young	41406-X	063143	00819
Temperature2meter	RM Young	41342	8472	none
Zero air pump	Altec	CDA/0	092000484	none



# Site Inventory by Site Visit

Site Visit Date		Parameter	Mfg	Owner ID	Model Number	Serial Number
ZIO433-Martin Valvur-06/25/2023						
1	6/25/2023	Computer	Hewlett Packard	none	6560 b	5CB22906V0
2	6/25/2023	DAS	Environmental Sys Corp	none	8816	4296
3	6/25/2023	Modem	Sierra wireless	none	GX450	illegible
4	6/25/2023	Ozone	ThermoElectron Inc	90568	49C	49C-59348-322
5	6/25/2023	Ozone Standard	ThermoElectron Inc	90728	49C	49C-70528-366
6	6/25/2023	Shelter Temperature	ARS	none	unknown	none
7	6/25/2023	Temperature2meter	RM Young	none	41432VC	15103
8	6/25/2023	Zero air pump	Werther International	none	PC 70/4	000706556

DAS Data Form

DAS Time Max Error: 1.97

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	4296	ZIO433	Martin Valvur	06/25/2023	DAS	Primary

Das Date:	6 /25/2023	Audit Date	6 /25/2023
Das Time:	06:44:58	Audit Time	06:43:00
Das Day:	176	Audit Day	176
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0002	0.0004	0.0002	0.0004

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
16	0.0000	-0.0005	-0.0003	V	V	0.0002	
16	0.1000	0.1001	0.1002	V	V	0.0001	
16	0.3000	0.2997	0.2998	V	V	0.0001	
16	0.5000	0.5005	0.5005	V	V	0.0000	
16	0.7000	0.7014	0.7015	V	V	0.0001	
16	0.9000	0.8998	0.8994	V	V	-0.0004	
16	1.0000	1.0007	1.0009	V	V	0.0002	

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

49C-59348-322

ZIO433

Martin Valvur

06/25/2023

Ozone

90568

Slope:

1.00427

Slope:

0.00000

Intercept

-1.29029

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.06	-0.14	-1.26	ppb		-1.12	
primary	2	15.83	15.47	14.15	ppb		-1.32	
primary	3	36.01	35.45	34.25	ppb	-3.44		
primary	4	66.52	65.67	64.55	ppb	-1.72		
primary	5	114.53	113.21	112.50	ppb	-0.63		
Sensor Component	Audit Pressure		Condition	663 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	1.10		Status	pass	
Sensor Component	Span		Condition	1.030		Status	pass	
Sensor Component	Zero Voltage		Condition	-0.0016		Status	pass	
Sensor Component	Fullscale Voltage		Condition	0.9985		Status	pass	
Sensor Component	Cell A Freq.		Condition	88.6 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.7 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.68 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	697.1 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	35.3 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	87.8 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.8 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.67 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	697.0 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	15103		ZIO433	Martin Valvur	06/25/2023	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

0.25	0.3		
------	-----	--	--

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.23	0.23	0.0000	0.46C		0.23
primary	Temp Mid Range	23.63	23.63	0.0000	23.93C		0.3
primary	Temp High Rang	48.61	48.61	0.0000	48.83C		0.22

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		ZIO433	Martin Valvur	06/25/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.89	2.15		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.74	23.74	0.000	23.4	C	-0.3
primary	Temp Mid Range	23.19	23.19	0.000	23.4	C	0.21
primary	Temp Mid Range	23.40	23.40	0.000	25.6	C	2.15
Sensor Component	System Memo		Condition		Status	pass	

# Field Systems Comments

- 1

Parameter:

SiteOpsProcComm

Dry deposition samples are not collected at this CASTNET site.
- 2

Parameter:

MetOpMaintCom

The inside of the temperature shield is dirty.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	ZIO433	Technician	Martin Valvur	Site Visit Date	06/25/2023	
Site Sponsor (agency)	NPS	USGS Map				
Operating Group	NPS	Map Scale				
AQS #	49-053-0130	Map Date				
Meteorological Type	R.M. Young					
Air Pollutant Analyzer	Ozone	QAPP Latitude				
Deposition Measurement		QAPP Longitude				
Land Use		QAPP Elevation Meters				
Terrain		QAPP Declination				
Conforms to MLM		QAPP Declination Date				
Site Telephone		Audit Latitude	37.198299			
Site Address 1		Audit Longitude	-113.15072			
Site Address 2		Audit Elevation	1266			
County	Washington	Audit Declination	11.2			
City, State	Virgin, UT					
Zip Code	84779	Fire Extinguisher	<input checked="" type="checkbox"/> Present Inspected March 2022			
Time Zone	Mountain	First Aid Kit	<input checked="" type="checkbox"/> 			
Primary Operator		Safety Glasses	<input type="checkbox"/> 			
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/> 			
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/> 			
Backup Operator		Security Fence	<input checked="" type="checkbox"/> 			
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/> 			
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/> 			
Shelter Working Room	<input type="checkbox"/> Make		Model		Shelter Size	
Shelter Clean	<input type="checkbox"/> Notes					
Site OK	<input type="checkbox"/> Notes					
Driving Directions	From Hurricane UT drive north on state route 9 toward Springdale and Zion NP. Turn right at the Maverick station on the north side of La Verkin, continuing on route 9. Continue through Virgin. Once through Virgin take the second left onto the unpaved road named Dalton Wash. Take the right fork at the orchard on Dalton Wash road. Continue approximately 1/4 mile past the locked gate and then turn right. Continue approximately 1 mile to the site.					

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

ZIO433

Technician

Martin Valvur

Site Visit Date

06/25/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



Site ID

ZIO433

Technician

Martin Valvur

Site Visit Date

06/25/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input type="checkbox"/>	dirty
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The inside of the temperature shield is dirty.

Site ID

ZIO433

Technician

Martin Valvur

Site Visit Date

06/25/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		N/A
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input type="checkbox"/>	No
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ZIO433

Technician

Martin Valvur

Site Visit Date

06/25/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>							
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>							
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input type="checkbox"/>	No						
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>							
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>							
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>							
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>							
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>							
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded							
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input type="checkbox"/>				
<input checked="" type="checkbox"/>		<input type="checkbox"/>							
11	Tower comments?								

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ZIO433

Technician

Martin Valvur

Site Visit Date

06/25/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>	Not present	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☒
- 2

Are the Site Status Report Forms being completed and current?

☒
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☒

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ZIO433

Technician

Martin Valvur

Site Visit Date

06/25/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

trained onsite by ARS

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

trained by site operator

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

N/A

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>			<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>			<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>			<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Monthly		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ZIO433

Technician

Martin Valvur

Site Visit Date

06/25/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	N/A
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	N/A
3	Are data downloads and backups being performed as scheduled?	<input checked="" type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	Dataview
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	N/A
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	N/A
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	N/A
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> N/A	<input type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> N/A	<input type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> N/A	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> N/A	<input type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> N/A	<input type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> N/A	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> N/A	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Dry deposition samples are not collected at this CASTNET site.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

ZIO433

Technician

Martin Valvur

Site Visit Date

06/25/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	6560 b	5CB22906V0	none
DAS	Environmental Sys Corp	8816	4296	none
Modem	Sierra wireless	GX450	illegible	none
Ozone	ThermoElectron Inc	49C	49C-59348-322	90568
Ozone Standard	ThermoElectron Inc	49C	49C-70528-366	90728
Shelter Temperature	ARS	unknown	none	none
Temperature2meter	RM Young	41432VC	15103	none
Zero air pump	Werther International	PC 70/4	000706556	none

---

## *Site Inventory by Site Visit*

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>ACA416-Eric Hebert-06/30/2023</i>						
1	6/30/2023	Computer	Hewlett Packard	none	8460p	CNU20941M6
2	6/30/2023	DAS	Environmental Sys Corp	none	8832	A3506K
3	6/30/2023	Elevation	Elevation	None	1	None
4	6/30/2023	Flow Rate	Alicat	none	MC-10SLPM-D-PCV	Illegeible
5	6/30/2023	Infrastructure	Infrastructure	none	none	none
6	6/30/2023	Met tower	Climatronics	none	unknown	illegible
7	6/30/2023	Ozone	ThermoElectron Inc	90744	49C	49C-74536-376
8	6/30/2023	Ozone Standard	T-API	none	T-703V	71
9	6/30/2023	Sample Tower	Aluma Tower	none	B	AT-71103-7I-3
10	6/30/2023	Shelter Temperature	Agilaire	none	Unknown	None
11	6/30/2023	Shield (2 meter)	Climatronics	none	100325	illegible
12	6/30/2023	Siting Criteria	Siting Criteria	None	1	None
13	6/30/2023	Temperature2meter	Climatronics	none	100093	missing
14	6/30/2023	Zero air pump	ThermoElectron Inc	none	111	111-30215-237



Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Alicat	Illgeible		ACA416	Eric Hebert	06/30/2023	Flow Rate	none

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	-0.008
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
2.01%	2.01%		
		Cal Factor Full Scale	5.1
		Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.0000	0.04	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.0000	0.04	l/m	l/m	
primary	test pt 1	1.490	1.490	1.50	0.0000	1.52	l/m	l/m	2.01%
primary	test pt 2	1.492	1.490	1.50	0.0000	1.52	l/m	l/m	2.01%
primary	test pt 3	1.493	1.490	1.50	0.0000	1.52	l/m	l/m	2.01%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Fair	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	0.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	135 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

## 2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	missing		ACA416	Eric Hebert	06/30/2023	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.1	0.25		

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.18	0.10	0.0000	0.35C		0.25
primary	Temp Mid Range	28.40	27.99	0.0000	27.99C		0
primary	Temp High Rang	49.69	49.03	0.0000	49.07C		0.04

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
Agilaire	None	ACA416	Eric Hebert	06/30/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
1.27	1.27		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	22.78	22.44	0.000	23.7	C	1.27	
Sensor Component	System Memo		Condition		Status	pass		

Infrastructure Data For

Site ID

ACA416

Technician

Eric Hebert

Site Visit Date

06/30/2023

Shelter Make

Custom

Shelter Model

Unknown

Shelter Size

Unknown

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	Good	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

This site is operated by both the NPS and the State of Maine DEP. It is not visited by ARS for semiannual calibration and maintenance visits. The site operator does not perform many of the routine checks conducted at other CASTNET sites, such as tip checks, wetness sensor tests, and visual checks of the blowers. The state of Maine personnel maintain the meteorological systems and the ozone monitor.

**2 Parameter:** SiteOpsProcedures

The meteorological and ozone instrument checks and maintenance are performed by the State of Maine DEP.

**3 Parameter:** ShelterCleanNotes

The shelter is new, clean and well organized.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	ACA416	Technician	Eric Hebert	Site Visit Date	06/30/2023
Site Sponsor (agency)	NPS	USGS Map	Salsbury Cove		
Operating Group	NPS/MEDEP	Map Scale			
AQS #	23-009-0103	Map Date			
Meteorological Type	Climatronics				
Air Pollutant Analyzer	Ozone, SO2, NOx, NOy, PM, VOC	QAPP Latitude	44.3770		
Deposition Measurement	dry, wet, Hg	QAPP Longitude	-68.2610		
Land Use	Costal, woodland - mixed	QAPP Elevation Meters	158		
Terrain	rolling	QAPP Declination			
Conforms to MLM	No	QAPP Declination Date			
Site Telephone	(432) 288-9322	Audit Latitude	44.377086		
Site Address 1	Route 233	Audit Longitude	-68.2608		
Site Address 2		Audit Elevation	153		
County	Hancock	Audit Declination	-16.4		
City, State	Bar Harbor, ME	Present			
Zip Code	04609	Fire Extinguisher	<input checked="" type="checkbox"/>	Inspected Aug 2017	
Time Zone	Eastern	First Aid Kit	<input type="checkbox"/>		
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Custom	Model	Unknown
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is new, clean and well organized.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Bangor go east on 1A to Ellsworth. From Ellsworth take route 3 east to Bar Harbor. At the west edge of town, take Eagle Lake Rd (route 233) west toward Acadia National Park. The site is through a gate, at the end of a gravel road, across from the Park Headquarters.				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

ACA416

Technician

Eric Hebert

Site Visit Date

06/30/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



Site ID

ACA416

Technician

Eric Hebert

Site Visit Date

06/30/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ACA416

Technician

Eric Hebert

Site Visit Date

06/30/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		3/8 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ACA416

Technician

Eric Hebert

Site Visit Date

06/30/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>						
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>						
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>						
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>						
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>						
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>						
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>						
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>						
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded						
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>			
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
11	Tower comments?							

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ACA416

Technician

Eric Hebert

Site Visit Date

06/30/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	Dataview	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	June 2000	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>

1	Is the station log properly completed during every site visit?	<input checked="" type="checkbox"/>	Dataview
2	Are the Site Status Report Forms being completed and current?	<input checked="" type="checkbox"/>	
3	Are the chain-of-custody forms properly used to document sample transfer to and from lab?	<input checked="" type="checkbox"/>	
4	Are ozone z/s/p control charts properly completed and current?	<input type="checkbox"/>	Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ACA416

Technician

Eric Hebert

Site Visit Date

06/30/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Trained on-site by ARS during site installation

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

Operator procedures are very good for filter replacement

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually by MEDEP		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A		<input type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	Monthly		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	Not performed		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Monthly		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Monthly		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Results are recorded weekly on a checklist

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological and ozone instrument checks and maintenance are performed by the State of Maine DEP.

Site ID

ACA416

Technician

Eric Hebert

Site Visit Date

06/30/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings, 90%
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	Flow and general observation sections only
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/> Not performed	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/> Not performed	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

This site is operated by both the NPS and the State of Maine DEP. It is not visited by ARS for semiannual calibration and maintenance visits. The site operator does not perform many of the routine checks conducted at other CASTNET sites, such as tip checks, wetness sensor tests, and visual checks of the blowers. The state of Maine personnel maintain the meteorological systems and the ozone monitor.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

ACA416

Technician

Eric Hebert

Site Visit Date

06/30/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	8460p	CNU20941M6	none
DAS	Environmental Sys Corp	8832	A3506K	none
Elevation	Elevation	1	None	None
Flow Rate	Alicat	MC-10SLPM-D-PCV	Illgeible	none
Infrastructure	Infrastructure	none	none	none
Met tower	Climatronics	unknown	illegible	none
Ozone	ThermoElectron Inc	49C	49C-74536-376	90744
Ozone Standard	T-API	T-703V	71	none
Sample Tower	Aluma Tower	B	AT-71103-7I-3	none
Shelter Temperature	Agilaire	Unknown	None	none
Shield (2 meter)	Climatronics	100325	illegible	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	Climatronics	100093	missing	none
Zero air pump	ThermoElectron Inc	111	111-30215-237	none

---

## **APPENDIX B**

### **CASTNET Site Spot Report Forms**

---



# EEMS Spot Report

Data Compiled: 7/16/2023 14:07:19

SiteVisitDate	Site	Technician
06/30/2023	ACA416	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.10	c	P
2	Temperature2meter max error	P	5	0.5	3	0.25	c	P
3	Flow Rate average % difference	P	10	5	4	2.01	%	P
4	Flow Rate max % difference	P	10	5	4	2.01	%	P
5	Shelter Temperature average error	P	5	2	5	1.27	c	P
6	Shelter Temperature max error	P	5	2	5	1.27	c	P

SiteVisitDate	Site	Technician
06/30/2023	ACA416	Eric Hebert

# Field Systems Comments

1 **Parameter:** SiteOpsProcComm

This site is operated by both the NPS and the State of Maine DEP. It is not visited by ARS for semiannual calibration and maintenance visits. The site operator does not perform many of the routine checks conducted at other CASTNET sites, such as tip checks, wetness sensor tests, and visual checks of the blowers. The state of Maine personnel maintain the meteorological systems and the ozone monitor.

2 **Parameter:** SiteOpsProcedures

The meteorological and ozone instrument checks and maintenance are performed by the State of Maine DEP.

3 **Parameter:** ShelterCleanNotes

The shelter is new, clean and well organized.

# EEMS Spot Report

Data Compiled: 6/22/2023 10:47:31

Site	Visit Date	Technician
ARE128	06/12/2023	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00558	unitless	P
2	Ozone Intercept	P	0	5	4	-0.58735	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99994	unitless	P
4	Ozone % difference avg	P	7	10	4	1.7	%	P
5	Ozone Absolute Difference g2	P	7	1.5	1	-0.78	ppb	P

# EEMS Spot Report

Data Compiled: 5/25/2023 12:39:48

SiteVisitDate	Site	Technician
05/11/2023	BWR139	Martin Valvur

## Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	21	0.14	c	P
2	Temperature max error	P	4	0.5	21	0.32	c	P
3	Ozone Slope	P	0	1.1	4	0.99917	unitless	P
4	Ozone Intercept	P	0	5	4	-0.51299	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
6	Ozone % difference avg	P	7	10	4	1.7	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.18	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.46	ppb	P
9	Flow Rate average % difference	P	10	5	3	0.45	%	P
10	Flow Rate max % difference	P	10	5	3	0.67	%	P
11	DAS Voltage average error	P	7	0.003	91	0.0000	V	P
12	Shelter Temperature average error	P	5	2	24	1.94	c	P
13	Shelter Temperature max error	P	5	2	24	2.21	c	Fail

# Field Systems Comments

- 1

Parameter:

SiteOpsProcComm

The site operator was not available during the audit visit. Data are reported from site documentation.
- 2

Parameter:

SiteOpsProcedures

The ozone sample train is leak checked every two weeks following the inlet filter change.
- 3

Parameter:

SitingCriteriaCom

Very light agriculture activities near site, not harvested, just to provide food for wildlife.
- 4

Parameter:

ShelterCleanNotes

The shelter has been repaired since the previous site audit visit.
- 5

Parameter:

PollAnalyzerCom

Ozone sample train has inline dryer.

# EEMS Spot Report

Data Compiled: 5/28/2023 11:16:39

Site	Visit Date	Technician
CRM435	05/18/2023	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98376	unitless	P
2	Ozone Intercept	P	0	5	4	0.12098	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	1.1	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.03	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.05	ppb	P

# EEMS Spot Report

Data Compiled: 5/25/2023 16:01:54

Site	Visit Date	Technician
GAS153	04/25/2023	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99137	unitless	P
2	Ozone Intercept	P	0	5	4	-0.49234	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	2.8	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.17	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.8	ppb	P

# EEMS Spot Report

Data Compiled: 5/28/2023 11:00:31

SiteVisitDate	Site	Technician
05/16/2023	GRT434	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.04853	unitless	P
2	Ozone Intercept	P	0	5	4	0.07176	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	4.9	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.18	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	0.73	ppb	P





# EEMS Spot Report

Data Compiled: 6/22/2023 10:55:49

Site	Visit Date	Technician
KEF112	06/13/2023	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.96624	unitless	P
2	Ozone Intercept	P	0	5	4	0.83467	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	2.2	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.41	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	0.54	ppb	P

# EEMS Spot Report

Data Compiled: 6/22/2023 11:13:37

Site	Visit Date	Technician
LRL117	06/15/2023	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98793	unitless	P
2	Ozone Intercept	P	0	5	4	-0.64757	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	3.2	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.66	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.73	ppb	P

# EEMS Spot Report

Data Compiled: 6/22/2023 11:04:40

Site	Visit Date	Technician
MKG113	06/14/2023	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98805	unitless	P
2	Ozone Intercept	P	0	5	4	-1.0574	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	4.8	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.85	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-1.32	ppb	P

# EEMS Spot Report

Data Compiled: 6/9/2023 10:31:20

SiteVisitDate	Site	Technician
05/24/2023	NEC602	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.11	c	P
2	Temperature2meter max error	P	5	0.5	3	0.13	c	P
3	Ozone Slope	P	0	1.1	4	0.98158	unitless	P
4	Ozone Intercept	P	0	5	4	-0.42016	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99994	unitless	P
6	Ozone % difference avg	P	7	10	4	3.9	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.21	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.85	ppb	P
9	Flow Rate average % difference	P	10	5	3	2.74	%	P
10	Flow Rate max % difference	P	10	5	3	3.09	%	P
11	Shelter Temperature average error	P	5	2	18	0.18	c	P
12	Shelter Temperature max error	P	5	2	18	0.30	c	P

SiteVisitDate	Site	Technician
05/24/2023	NEC602	Tim Mendenhall

## Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator does not use gloves to handle the filter pack. Sample line leak checks are not being performed. The sample is changed on Wednesdays and not Tuesdays as described in the QAPP.

2 **Parameter:** DasComments

The dry deposition tower is visibly bent.

3 **Parameter:** SiteOpsProcedures

The site operator is new and has not yet received formal training from ARS. The site operator would benefit from training. Some of the items on the SSRF were discussed and the site operator's questions were answered regarding the correct procedures.

4 **Parameter:** DocumentationCo

The site operator is new and site documentation (QAPP and SOP) have not been provided.

5 **Parameter:** SitingCriteriaCom

The site is located approximately 2 km northeast of Newcastle WY which has a population of approximately 3500. There is an oil refinery in Newcastle. A heavily traveled road is approximately 100m west of the site.

6 **Parameter:** ShelterCleanNotes

The shelter houses the ozone, DAS, and MFC only.

# EEMS Spot Report

Data Compiled: 4/11/2023 08:58:43

SiteVisitDate	Site	Technician
04/02/2023	PRK134	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	18	0.19	c	P
2	Temperature max error	P	4	0.5	18	0.40	c	P
3	Ozone Slope	P	0	1.1	4	0.99343	unitless	P
4	Ozone Intercept	P	0	5	4	-0.84444	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	3.2	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.79	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.89	ppb	P
9	Flow Rate average % difference	P	10	5	8	0.00	%	P
10	Flow Rate max % difference	P	10	5	8	0.00	%	P
11	DAS Voltage average error	P	7	0.003	91	0.0003	V	P
12	Shelter Temperature average error	P	5	2	16	0.28	c	P
13	Shelter Temperature max error	P	5	2	16	0.54	c	P

SiteVisitDate	Site	Technician
04/02/2023	PRK134	Eric Hebert

# Field Systems Comments

- 1

Parameter:

SitingCriteriaCom

Clover and Barley have been planted for hay within 20m of the site starting in 2008.
- 2

Parameter:

ShelterCleanNotes

The shelter is clean, neat, and well organized.



# EEMS Spot Report

Data Compiled: 7/16/2023 13:13:38

SiteVisitDate	Site	Technician
06/20/2023	SEK430	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.07	c	P
2	Temperature2meter max error	P	5	0.5	3	0.19	c	P
3	Ozone Slope	P	0	1.1	4	0.99127	unitless	P
4	Ozone Intercept	P	0	5	4	-0.50049	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	2.7	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.35	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.79	ppb	P
9	Flow Rate average % difference	P	10	5	14	1.01	%	P
10	Flow Rate max % difference	P	10	5	14	1.36	%	P
11	DAS Voltage average error	P	7	0.003	70	0.0001	V	P
12	Shelter Temperature average error	P	5	2	24	0.65	c	P
13	Shelter Temperature max error	P	5	2	24	0.76	c	P

## Field Performance Comments

- 1

Parameter:

Flow Rate

SensorComponent:

Filter Depth

CommentCode:

71
- The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.

## Field Systems Comments

- 1

Parameter:

SitingCriteriaCom
- The site is a wooded area with spaced trees on three sides and a steep drop in elevation on the west side. Although not strictly conforming to siting criteria it is elevated in a wide valley and representative of the area. Trees are still within 5 meters, however none are higher than the CASTNET sample inlets.
- 2

Parameter:

ShelterCleanNotes
- The shelter is aging but is in fair condition and kept clean, neat, and well organized.
- 3

Parameter:

MetOpMaintCom
- The 2 meter temperature sensor signal cable is showing signs of wear.

# EEMS Spot Report

Data Compiled: 5/25/2023 13:19:40

Site	Visit Date	Technician
WSP144	05/17/2023	Martin Valvur

## Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	18	0.16	c	P
2	Temperature max error	P	4	0.5	18	0.21	c	P
3	Ozone Slope	P	0	1.1	4	0.99788	unitless	P
4	Ozone Intercept	P	0	5	4	-0.03847	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	0.5	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.09	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.12	ppb	P
9	Flow Rate average % difference	P	10	5	3	0.89	%	P
10	Flow Rate max % difference	P	10	5	3	1.33	%	P
11	DAS Voltage average error	P	7	0.003	98	0.0000	V	P
12	Shelter Temperature average error	P	5	2	24	0.27	c	P
13	Shelter Temperature max error	P	5	2	24	0.57	c	P

SiteVisitDate	Site	Technician
05/17/2023	WSP144	Martin Valvur

# Field Systems Comments

- 1

Parameter:

SitingCriteriaCom

The city of Trenton, estimated population greater than 85,000, is within 20 km of the site.
- 2

Parameter:

ShelterCleanNotes

The shelter is in fair condition, clean, very neat, and well organized but beginning to show signs of wear.

# EEMS Spot Report

Data Compiled: 6/9/2023 09:46:19

Site	Visit Date	Technician
YEL408	05/16/2023	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.31	c	P
2	Temperature2meter max error	P	5	0.5	3	0.40	c	P
3	Ozone Slope	P	0	1.1	4	0.97086	unitless	P
4	Ozone Intercept	P	0	5	4	0.29844	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	2.1	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.31	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.19	ppb	P
9	Flow Rate average % difference	P	10	5	4	0.90	%	P
10	Flow Rate max % difference	P	10	5	4	1.01	%	P
11	DAS Voltage average error	P	16	0.003	42	0.0004	V	P
12	Shelter Temperature average error	P	5	2	27	0.30	c	P
13	Shelter Temperature max error	P	5	2	27	0.30	c	P

SiteVisitDate	Site	Technician
05/16/2023	YEL408	Tim Mendenhall

# Field Systems Comments

- 1

Parameter:

SiteOpsProcComm

The site operator was not able to be present during the site audit visit. Audit data are based on site documentation.
- 2

Parameter:

DasComments

The shelter heat and air conditioner run simultaneously.
- 3

Parameter:

SiteOpsProcedures

The ozone inlet filter is replaced and the system is leak tested every two weeks.
- 4

Parameter:

SitingCriteriaCom

The site is located at the edge of a tree line. Trees as tall as 8 meters are near the sample inlet. Trees taller than 10 meters are 15 meters from the inlet.
- 5

Parameter:

ShelterCleanNotes

The shelter is organized and well maintained.

# EEMS Spot Report

Data Compiled: 7/16/2023 13:34:19

SiteVisitDate	Site	Technician
06/25/2023	ZIO433	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.25	c	P
2	Temperature2meter max error	P	5	0.5	3	0.30	c	P
3	Ozone Slope	P	0	1.1	4	1.00427	unitless	P
4	Ozone Intercept	P	0	5	4	-1.29029	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	3.6	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-1.12	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-1.32	ppb	P
9	DAS Voltage average error	P	16	0.003	35	0.0002	V	P
10	Shelter Temperature average error	P	5	2	9	0.89	c	P
11	Shelter Temperature max error	P	5	2	9	2.15	c	Fail

SiteVisitDate	Site	Technician
06/25/2023	ZIO433	Martin Valvur

# Field Systems Comments

- 1

Parameter:

SiteOpsProcComm

Dry deposition samples are not collected at this CASTNET site.
- 2

Parameter:

MetOpMaintCom

The inside of the temperature shield is dirty.