

---

**2023 – 4th Quarter Report**  
**Support for Conducting Systems &**  
**Performance Audits of Clean Air Status and**  
**Trends Network (CASTNET) Sites and**  
**National Atmospheric Deposition Program**  
**(NADP) Monitoring Stations - III**

**GSA Contract # GS-10F-075AA**  
**Blanket Purchase Agreement # 68HERH22A0026**

**Prepared for:**

**U. S. Environmental Protection Agency**

**Prepared by:**



**4577E NW 6<sup>th</sup> St Ext.**  
**Gainesville, FL 32609**

**Report Submitted**  
**January 2024**

---

## Table of Contents

<b>1.0 CASTNET Quarterly Report.....</b>	<b>1</b>
1.1 Introduction.....	1
1.2 Project Objectives .....	2
1.3 CASTNET Sites Visited Fourth Quarter 2023.....	4
1.4 CASTNET Audit Results.....	5
<b>2.0 NADP Quarterly Report .....</b>	<b>6</b>
2.1 Introduction.....	6
2.2 Project Objectives .....	6
2.3 NADP Sites Visited Fourth Quarter 2023.....	7
2.4 NADP Audit Results .....	8

### List of Appendices

- Appendix A**    CASNTET Audit Report Forms
- Appendix B**    CASTNET Site Spot Report Forms

### List of Tables

Table 1. Performance Audit Challenge and Acceptance Criteria.....	2
Table 2. CASTNET Site Audit Visits .....	4
Table 3. NADP Site Audit Visits .....	7

## List of Acronyms and Abbreviations

% diff	percent difference
A/D	analog to digital converter
ARS	Air Resource Specialists, Inc.
ASTM	American Society for Testing and Materials
BLM	Bureau of Land Management
BLM-WSO	Bureau of Land Management – Wyoming State Office
CAL	Central Analytical Laboratory
CASTNET	Clean Air Status and Trends Network
CMAQ	Community Multiscale Air Quality
DAS	data acquisition system
deg	degree
DVM	digital voltmeter
ECCC	Environment and Climate Change Canada
EEMS	Environmental, Engineering & Measurement Services, Inc.
EPA	U.S. Environmental Protection Agency
ESC	Environmental Systems Corporation
FSA	Field Systems Audit
FSAD	Field Site Audit Database
GPS	geographical positioning system
HAL	Mercury Analytical Laboratory
LADCO	Lake Michigan Air Directors Consortium
lpm	liters per minute
ME DEP	Maine Department of Environmental Protection
MD DNR	Maryland Department of Natural Resources
MLM	Multilayer Model
MN PCA	Minnesota Pollution Control Agency
m/s	meters per second
mv	millivolt
NESCAUM	Northeast States for Coordinated Air Use Management
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPS	National Park Service
NYDEC	New York Department of Conservation
NYSERDA	New York State Energy Research and Development Authority
OH EPA	Ohio Environmental Protection Agency
PE	Performance Evaluation
QAPP	Quality Assurance Project Plan
SLT	State Local and Tribal
SCDHEC	South Carolina Department of Health and Environmental Control
SFWMD	South Florida Water Management District
SOP	standard operating procedure
TDEP	Total Deposition
TEI	Thermo Environmental Instruments
USDA-FS	United States Department of Agriculture – Forest Service

USFS	United States Forest Service
USFWS	United States Fish and Wildlife Service
USGS	United States Geological Survey
USNO	United States Naval Observatory
VDC	volts direct current
WDEQ	Wyoming Department of Environmental Quality
WDNR	Wisconsin Department of Natural Resources
WRR	World Radiation Reference
WSLH	Wisconsin State Laboratory of Hygiene

## 1.0 CASTNET Quarterly Report

### 1.1 Introduction

The Clean Air Status and Trends Network (CASTNET) is a national air monitoring program established in 1988 by the US EPA. Nearly all CASTNET sites measures weekly concentrations of acidic gases and particles to provide accountability for EPA’s emission reduction programs. Most sites measure ground-level ozone as well as supplemental measurements such as meteorology and/or other trace gas concentrations.

Ambient concentrations are used to estimate deposition rates of the various pollutants with the objective of determining relationships between emissions, air quality, deposition, and ecological effects. In conjunction with other national monitoring networks, CASTNET data are used to determine the effectiveness of national emissions control programs and to assess temporal trends and spatial deposition patterns in atmospheric pollutants. CASTNET data are also used for long-range transport model evaluations and critical loads research.

Historically, CASTNET pollutant flux measurements have been reported as the aggregate product of weekly measured concentrations and model-estimated deposition velocities. The Multi-layer Model (MLM) was used to derive deposition velocity estimates from on-site meteorological parameters, land use types, and site characteristics. In 2011, EPA discontinued meteorological measurements at most EPA-sponsored CASTNET sites.

Currently, CASTNET pollutant flux estimates are calculated as the aggregate product of weekly measured chemical concentrations and gridded model-estimated deposition velocities. Total deposition is assessed using the NADP’s Total Deposition Hybrid Method (TDEP; EPA, 2015c; Schwede and Lear, 2014), which combines data from established ambient monitoring networks and chemical-transport models. To estimate dry deposition, ambient measurement data from CASTNET and other networks were merged with dry deposition rates and flux output from the Community Multiscale Air Quality (CMAQ) modeling system.

Since 2011 nearly all CASTNET ozone monitors have adhered to the requirements for State Local and Tribal (SLT) air monitoring stations as specified by the EPA in 40 CFR Part 58. As such, the ozone data collected must meet the requirements in 40 CFR Part 58 Appendix A, which defines the quality assurance (QA) requirements for gaseous pollutant ambient air monitoring. The audits performed by EEMS under this contract fulfilled the requirement for annual performance evaluation audits of pollutant monitors in the network. The QA requirements can be found at:

<https://www.epa.gov/amtic/regulations-guidance-and-monitoring-plans>

Currently more than 85 CASTNET sites measure ground-level ozone concentrations. Annual performance evaluation (PE), ozone audit data are submitted to the Air Quality System (AQS) database.

As of December 2023, the network is comprised of 92 active rural sampling sites across the United States and Canada, cooperatively operated by the Environmental Protection Agency (EPA), the National Park Service (NPS), Bureau of Land Management – Wyoming State Office (BLM-WSO) and several independent partners. WSP (formally Wood Environment and Infrastructure Solutions) is responsible for operating the EPA sponsored sites, and Air Resource Specialists, Inc. (ARS) is responsible for operating the NPS and BLM-WSO sponsored sites

## 1.2 Project Objectives

The objectives of this project are to establish an independent and unbiased program of performance and systems audits for all CASTNET sampling sites. Ongoing Quality Assurance (QA) programs are an essential part of any long-term monitoring network.

Performance audits verify that all reported variables are consistent with the accuracy goals as defined in the CASTNET Quality Assurance Project Plan (QAPP). The parameter specific accuracy goals are presented in Table 1.

**Table 1. Performance Audit Challenge and Acceptance Criteria**

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Precipitation	Response	10 manual tips	1 DAS count per tip
Precipitation	Accuracy	2 introductions of known amounts of water	$\leq \pm 10.0\%$ of input amount
Relative Humidity	Accuracy	Compared to reference instrument or standard solution	$\leq \pm 10.0\%$ RH
Solar Radiation	Accuracy	Compared to WRR traceable standard	$\leq \pm 10.0\%$ of daytime average
Surface Wetness	Response	Distilled water spray mist	Positive response
Surface Wetness	Sensitivity	1% decade resistance	N/A
Temperature	Accuracy	Comparison to 3 NIST measured baths (~ 0° C, ambient, ~ full-scale)	$\leq \pm 0.5^\circ \text{C}$
Temperature Difference	Accuracy	Comparison to station temperature sensor	$\leq \pm 0.50^\circ \text{C}$

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Shelter Temperature	Accuracy	Comparison to station temperature sensor	$\leq \pm 2.0^{\circ} \text{ C}$
Wind Direction	Orientation Accuracy	Parallel to alignment rod/crossarm, or sighted to distant point	$\leq \pm 5^{\circ}$ from degrees true
Wind Direction	Linearity	Eight cardinal points on test fixture	$\leq \pm 5^{\circ}$ mean absolute error
Wind Direction	Response Threshold	Starting torque tested with torque gauge	$< 10 \text{ g-cm}$ Climatronics; $< 20 \text{ g-cm}$ R.M. Young
Wind Speed	Accuracy	Shaft rotational speed generated and measured with certified synchronous motor	$\leq \pm 0.5 \text{ mps}$ below 5.0 mps input; $\leq \pm 5.0\%$ of input at or above 5.0 mps
Wind Speed	Starting Threshold	Starting torque tested with torque gauge	$< 0.5 \text{ g-cm}$
Mass Flow Controller	Flow Rate	Comparison with Primary Standard	$\leq \pm 5.0\%$ of designated rate
Ozone	Slope	Linear regression of multi-point test gas concentration as measured with a certified transfer standard	$0.9000 \leq m \leq 1.1000$
Ozone	Intercept		$-5.0 \text{ ppb} \leq b \leq 5.0 \text{ ppb}$
Ozone	Correlation Coefficient		$0.9950 \leq r$
Ozone	Percent Difference	Comparison with Level 2 standard concentration	$\leq \pm 15.1\%$ of test gas concentration and $\leq \pm 0.0015 \text{ ppm}$ actual difference
DAS	Accuracy	Comparison with certified standard	$\leq \pm 0.003 \text{ VDC}$

Performance audits are conducted using standards that are traceable to the National Institute of Standards and Technology (NIST), or another authoritative organization, at least annually.

Field site systems audits (FSA) are intended to provide a qualitative appraisal of the total measurement system. Site planning, organization, and operation are evaluated to ensure that good Quality Assurance/Quality Control (QA/QC) practices are being applied. At a minimum the following audit issues were addressed at each site systems audit:

- Site locations and configurations match those provided in the CASTNET QAPP.
- Meteorological instruments are in good physical and operational condition and are sited to meet EPA ambient monitoring guidelines (EPA-600/4-82-060).
- Sites are accessible, orderly, and if applicable, compliant with OSHA safety standards.
- Sampling lines are free of leaks, kinks, visible contamination, weathering, and moisture.
- Site shelters provide adequate temperature control.

- All ambient air quality instruments are functional, being operated in the appropriate range, and the zero-air supply desiccant is unsaturated.
- All instruments are in current calibration.
- Site documentation (maintenance schedules, on-site SOPs, etc.) is current and log book records are complete.
- All maintenance and on-site SOPs are performed on schedule.
- Corrective actions are documented and appropriate for required maintenance/repair activity.
- Site operators demonstrate an adequate knowledge and ability to perform required site activities, including documentation and maintenance activities.

### 1.3 CASTNET Sites Visited Fourth Quarter 2023

This report consists of the systems and performance, and other audit results from the CASTNET sites visited during the fourth quarter (October through December) of 2023. The site locations, sponsor, visit dates, and parameters audited, are included in Table 2.

**Table 2. CASTNET Site Audit Visits**

Site ID	Date	MET	FSA	O3 PE	SO2	CO	NOy	FLOW	Sponsor
KNZ184	10/10/2023		1					1	EPA
VOY413	10/10/2023		1	1				1	NPS
DEN417	10/11/2023			1					NPS
THR422	10/13/2023		1					1	NPS
GLR468	10/18/2023		1	1				1	NPS
HOX148	10/19/2023			1					EPA
UVL124	10/19/2023			1					EPA
ANA115	10/20/2023			1					EPA
CAV436	10/23/2023		1	1					NPS
CHA467	10/24/2023			1					NPS
GRC474	10/25/2023			1					NPS
PET427	10/26/2023			1					NPS
STK138	10/29/2023		1	1				1	EPA
PND165	10/31/2023		1	1				1	EPA / BLM-WSO



Site ID	Date	MET	FSA	O3 PE	SO2	CO	NOy	FLOW	Sponsor
GRB411	11/6/2023			1					NPS
SHE604	11/6/2023		1					1	BLM-WSO
BUF603	11/7/2023		1					1	BLM-WSO
CTH110	11/8/2023			1					EPA
WFM105	11/9/2023		1					1	EPA
BAS601	11/9/2023			1					BLM-WSO
NIC001	11/11/2023		1					1	EPA
DUK008	11/14/2023			1					EPA
LAV410	11/14/2023		1	1				1	NPS
BFT142	11/15/2023		1	1				1	EPA
DEV412	11/20/2023		1	1					NPS
SAN189	11/27/2023		1	1				1	EPA
KIC003	11/28/2023		1					1	EPA
SPD111	12/5/2023			1					EPA
SND152	12/6/2023			1					EPA
CND125	12/22/2023		1	1				1	EPA
COW137	12/26/2023			1					EPA

#### 1.4 CASTNET Audit Results

The observations and results of the systems, performance, and Ozone PE audits are included in Appendix A, *CASTNET Audit Report Forms* by site, arranged by audit date. Photographs of site conditions are included within each system report where necessary. Copies of the spot reports that were sent following the audit of each site are included as Appendix B, *CASTNET Site Spot Report Forms*.

Results of the PE audits of the gaseous pollutant monitors other than ozone, were submitted immediately following the PE and are not included in this report. All TTP PE results of gaseous pollutant monitors are uploaded to AQS and are available there. All audit data and reports are available from the EPA CASTNET website: <https://www.epa.gov/castnet/documents-reports#QuarterlyQualityAssuranceReports>

## 2.0 NADP Quarterly Report

### 2.1 Introduction

The National Atmospheric Deposition Program (NADP) operates two precipitation chemistry networks and two atmospheric concentration networks. The National Trends Network (NTN) has been measuring acidic precipitation since 1978. The network currently has more than 250 sites. The precipitation event-based Atmospheric Integrated Research Monitoring Network (AIRMOn) began operation in 1992, and as of July 2019 is no longer in operation. The Mercury Deposition Network (MDN) measures total mercury in precipitation samples from approximately 90 stations. The MDN began operation in 1996 and includes sites throughout the US and Canada. The Atmospheric Mercury Network (AMNet) and the Ammonia Monitoring Network (AMoN) measure ambient concentrations of mercury and ammonia, respectively.

The NADP and other long-term monitoring networks provide critical information to the EPA regarding evaluating the effectiveness of emission reduction control programs from the power industry. The networks of the NADP are sponsored by several federal, state, and local agencies as well as private organizations.

The NADP Program Office (PO) operates and administers the two precipitation chemistry networks (NTN and MDN), two atmospheric concentration networks (AMNet and AMoN), and two analytical laboratories (CAL and HAL), from the Wisconsin State Lab of Hygiene (WSLH) at the University of Wisconsin in Madison. The labs have been combined and renamed as the NADP Analytical Laboratory (NAL). The network equipment depot (NED) is also located at the WSLH.

### 2.2 Project Objectives

The objective of this project is to perform independent and unbiased evaluations of the sites and their operation. These evaluations provide quality assurance pertaining to siting, sample collection and handling, equipment operation and maintenance, record keeping and field laboratory procedures.

More specifically, the audits determine and report findings based on an established methodology consisting of completing a site questionnaire, testing the equipment and documenting with photographs the location, siting criteria, existing equipment, and any issues encountered that require such documentation.

## 2.3 NADP Sites Visited Fourth Quarter 2023

This report presents the NADP sites audited during the fourth quarter (October through December) of 2023. The station locations, sponsors, network, and dates of the surveys are presented in Table 3.

**Table 3. NADP Site Audit Visits**

Site ID	Date	NTN	MDN	AMON	Site Sponsor	Site Name
WI10	10/5/2023	1	1		Forest County Potawatomi Community	Potawatomi
MI99	10/6/2023	1			USDA-FS	Chassell
MN97	10/9/2023		1		Unknown	Grand Portage Band of Chippewa
AK01	10/10/2023	1			USDA-FS	Poker Creek
KS31	10/10/2023			1	WSP - EPA	Konza Prairie
MN32	10/10/2023	1			National Park Service - NIFA	Voyageurs National Park-Sullivan Bay
AK03	10/11/2023	1			National Park Service - NIFA	Denali National Park-Mt. McKinley
MN23	10/12/2023	1	1		USGS / Minnesota Pollution Control Agency	Camp Ripley
ND00	10/13/2023	1			National Park Service - NIFA	Theodore Roosevelt National Park-Painted Canyon
ID11	10/16/2023	1			USGS	Reynolds Creek
ID02	10/17/2023	1			USDA-FS	Priest River Experimental Forest
MT05	10/18/2023	1	1		National Park Service - NIFA	Glacier National Park-Fire Weather Station
MI51	10/19/2023			1	WSP -EPA	Unionville
MI95	10/19/2023			1	WSP -EPA	Hoxeyville
MT96	10/19/2023	1			Fort Peck Tribes	Poplar River
MI52	10/20/2023		1		Lake Michigan Air Directors Consortium (LADCO)	Ann Arbor
IL37	10/29/2023			1	WSP -EPA	Stockton
WY06	10/31/2023		1	1	Unknown / WSP-EPA	Pinedale
NY67	11/8/2023			1	WSP -EPA	Ithaca
NY98	11/9/2023			1	WSP -EPA	Whiteface Mountain
WY93	11/9/2023			1	Air Resource Specialists, Inc.	Basin - Big Horn

Site ID	Date	NTN	MDN	AMON	Site Sponsor	Site Name
NY94	11/11/2023			1	WSP -EPA	Nick's Lake
NY43	11/13/2023	1	1		New York State Department of Environmental Conservation	Rochester
NC06	11/15/2023			1	WSP -EPA	Beaufort
CA88	11/15/2023	1			USGS - NIFA	Davis
NE98	11/27/2023			1	WSP -EPA	Santee
KS97	11/28/2023			1	WSP -EPA	Kickapoo Tribe-Powhattan
TN04	12/5/2023	1		1	WSP -EPA	Speedwell
AL99	12/6/2023			1	WSP -EPA	Sand Mountain Research & Extension Center
NC26	12/22/2023		1		North Carolina Department of Environmental Quality	Candor
NC25	12/26/2023			1	WSP -EPA	Coweeta

## 2.4 NADP Audit Results

NADP site audit results are entered into a relational database. The database in turn generates Site Spot Reports which are distributed among the interested parties as soon as all the site data has been entered. Database tables with all the data collected and reviewed are then sent to the NADP Program Office and to the U.S. EPA Project Officers.

Other items gathered during the audits (i.e., photographs, Belfort charts, etc.) are uploaded to the EPA OneDrive account where the NADP PO and the U.S. EPA POs can access them and download them as needed.

Given the volume of data generated, and the fact that data is distributed and/or is available via the internet, no audit results are included in this report.

---

## **APPENDIX A**

### **CASTNET Audit Report Forms**

---

# Site Inventory by Site Visit

Site Visit Date		Parameter	Mfg	Owner ID	Model Number	Serial Number
KNZ184-Tim Mendenhall-10/10/2023						
1	10/10/2023	Computer	Dell	07014	Inspiron 15	313MC12
2	10/10/2023	DAS	Campbell	000361	CR3000	2139
3	10/10/2023	Elevation	Elevation	None	1	None
4	10/10/2023	Flow Rate	Apex	000925	AXMC105LPMDPCV	illegible
5	10/10/2023	Infrastructure	Infrastructure	none	none	none
6	10/10/2023	Modem	Digi	07182	LR54	Illegible
7	10/10/2023	Sample Tower	Aluma Tower	missing	B	none
8	10/10/2023	Shelter Temperature	Campbell	none	107-L	none
9	10/10/2023	Siting Criteria	Siting Criteria	None	1	None
10	10/10/2023	Temperature	RM Young	06541	41432VC	14082

DAS Data Form

DAS Time Max Error: 0.05

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2139	KNZ184	Tim Mendenhall	10/10/2023	DAS	Primary

Das Date:	10/10/2023	Audit Date	10/10/2023
Das Time:	07:53:23	Audit Time	07:53:26
Das Day:	284	Audit Day	284
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		KNZ184	Tim Mendenhall	10/10/2023	Flow Rate	000925

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.78%	1.35%		
		Cal Factor Full Scale	0
		Rotometer Reading:	3

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.01	l/m	l/m	
primary	test pt 1	2.961	2.960	2.97	0.000	3.00	l/m	l/m	1.35%
primary	test pt 2	2.989	2.990	2.97	0.000	3.00	l/m	l/m	0.33%
primary	test pt 3	2.993	2.990	2.96	0.000	3.01	l/m	l/m	0.67%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	4.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass



# Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14082		KNZ184	Tim Mendenhall	10/10/2023	Temperature	06541

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232679	Tfer Desc.	RTD
		Tfer ID	01228		
		Slope	1.01172	Intercept	0.08161
		Cert Date	2/17/2023	CorrCoff	1.00000

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.05	0.14		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.16	0.08	0.000	0.1	C	0
primary	Temp Mid Range	24.84	24.47	0.000	24.3	C	-0.14
primary	Temp High Range	47.92	47.28	0.000	47.3	C	0.02

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		KNZ184	Tim Mendenhall	10/10/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.13	0.38		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	23.72	23.36	0.000	23.4	C	0.01	
primary	Temp Mid Range	24.29	23.93	0.000	23.9	C	-0.01	
primary	Temp Mid Range	23.76	23.40	0.000	23.8	C	0.38	
Sensor Component	System Memo			Condition		Status	pass	

Infrastructure Data For

Site ID

KNZ184

Technician

Tim Mendenhall

Site Visit Date

10/10/2023

Shelter Make

Wells Cargo

Shelter Model

EW1211 (s/n  
1WC200E1623048028)

Shelter Size

640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Fair	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Fair	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Fair	Status	pass
Sensor Component	Shelter Floor	Condition	Poor	Status	Fail
Sensor Component	Shelter walls	Condition	Fair	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Fair	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

## Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	KNZ184	Tim Mendenhall	10/10/2023	Moisture Present	Apex	4778	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								

# Field Systems Comments

1    **Parameter:**    SitingCriteriaCom

The site is located at a Long Term Ecological Research site operated by KSU.

2    **Parameter:**    ShelterCleanNotes

The shelter is very clean, neat an well organized. Although patched, he shelter floor is deteriorated and in poor condition.

3    **Parameter:**    MetSensorComme

The temperature sensor is mounted on the north side of the sample tower.

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
VOY413-Eric Hebert-10/10/2023						
1	10/10/2023	DAS	Environmental Sys Corp	90632	8816	2505
2	10/10/2023	Elevation	Elevation	None	1	None
3	10/10/2023	Filter pack flow pump	Thomas	none	illegible	illegible
4	10/10/2023	Flow Rate	Alicat	none	MC-10SLPM-D-PCV	Unknown
5	10/10/2023	Infrastructure	Infrastructure	none	none	none
6	10/10/2023	Ozone	ThermoElectron Inc	90714	49C	49C-66828-354
7	10/10/2023	Ozone Standard	ThermoElectron Inc	90569	49C	49C-59260-322
8	10/10/2023	Sample Tower	Aluma Tower	none	B	AT-51159-11-G
9	10/10/2023	Shelter Temperature	ARS	none	none	none
10	10/10/2023	Siting Criteria	Siting Criteria	None	1	None
11	10/10/2023	Temperature2meter	RM Young	none	41342VC	029199
12	10/10/2023	Zero air pump	Twin Tower Engineering	90719	TT70/E4	526294

DAS Data Form

DAS Time Max Error: 0.75

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2505	VOY413	Eric Hebert	10/10/2023	DAS	Primary

Das Date:	10/10/2023	Audit Date	10/10/2023
Das Time:	11:00:45	Audit Time	11:00:00
Das Day:	284	Audit Day	284
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	4000392	Tfer Desc.	Source generator (D
Tfer ID	01321		
Slope	1.00000	Intercept	0.00000
Cert Date	1/22/2015	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	86590148	Tfer Desc.	DVM
Tfer ID	01310		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	



Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Alicat	Unknown		VOY413	Eric Hebert	10/10/2023	Flow Rate	none

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	-0.06
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
1.93%	2.05%		
		Cal Factor Full Scale	4.899
		Rotometer Reading:	3

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.05	l/m	l/m	
primary	leak check	0.000	0.000	0.03	0.000	0.08	l/m	l/m	
primary	test pt 1	2.932	2.930	1.45	0.000	2.99	l/m	l/m	2.05%
primary	test pt 2	2.934	2.930	1.45	0.000	2.99	l/m	l/m	2.05%
primary	test pt 3	2.935	2.940	1.45	0.000	2.99	l/m	l/m	1.70%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	6.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

49C-66828-354

VOY413

Eric Hebert

10/10/2023

Ozone

90714

Slope:

1.01225

Slope:

0.00000

Intercept

0.10569

Intercept

0.00000

CorrCoff:

0.99999

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00450

Intercept

-0.25270

Cert Date

4/24/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.49	-0.19	0.18	ppb		0.37	
primary	2	18.86	19.00	19.22	ppb		0.22	
primary	3	32.46	32.49	32.91	ppb	1.28		
primary	4	68.57	68.32	68.98	ppb	0.96		
primary	5	112.11	111.51	113.20	ppb	1.5		

Sensor Component

Audit Pressure

Condition

721 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.1

Status

pass

Sensor Component

Span

Condition

1.016

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

99.0 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

1.0 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.69 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

707.9 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

34.0 C

Status

pass

Sensor Component

Cell B Freq.

Condition

84.5 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

1.4 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.71 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

708.4 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

False

Status

pass

Sensor Component

System Memo

Condition

Status

pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	029199		VOY413	Eric Hebert	10/10/2023	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00945	Intercept	0.16485
Cert Date	2/17/2023	CorrCoff	1.00000

0.41	0.58		
------	------	--	--

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.23	0.06	0.000	0.37C		0.31
primary	Temp Mid Range	24.05	23.66	0.000	24.00C		0.34
primary	Temp High Rang	49.60	48.97	0.000	49.55C		0.58

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	VOY413	Eric Hebert	10/10/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.97	1.92		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00945	Intercept	0.16485
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	19.79	19.44	0.000	19.5	C	0.02	
primary	Temp Mid Range	19.36	19.02	0.000	20.9	C	1.92	
Sensor Component		System Memo		Condition		Status	pass	

Infrastructure Data For

Site ID

VOY413

Technician

Eric Hebert

Site Visit Date

10/10/2023

Shelter Make	Shelter Model	Shelter Size
Ekto	8810 (s/n 2880-2)	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	Good	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Fair	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Fair	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Fair	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

The site operator handles the filter barehanded.

**2 Parameter:** DasComments

The sample tower itself is not grounded, however it is bolted to the shelter which is grounded. The roof leak above the instrument rack may have been repaired, it is dry at this time.

**3 Parameter:** SitingCriteriaCom

The site is located at the top of a hill in a forest. There are trees surrounding the site which are below the tower height, but within 10 m of the inlet.

**4 Parameter:** ShelterCleanNotes

The shelter is in fair condition, and is neat and well organized.

**5 Parameter:** PollAnalyzerCom

There are no trees violating the 22.5 degree cone above the ozone sample inlet. However, there is a communication tower which is above the 22.5 degree threshold.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	KNZ184	Technician	Tim Mendenhall	Site Visit Date	10/10/2023
Site Sponsor (agency)	EPA	USGS Map	Swede Creek		
Operating Group	Kansas State University	Map Scale			
AQS #	20-161-9991	Map Date			
Meteorological Type	R.M. Young				
Air Pollutant Analyzer	Ozone	QAPP Latitude	39.1021		
Deposition Measurement	dry, wet	QAPP Longitude	-96.6096		
Land Use	range	QAPP Elevation Meters	348		
Terrain	gently rolling	QAPP Declination	4.5		
Conforms to MLM	Yes	QAPP Declination Date	01/07/2005		
Site Telephone	(785) 770-8426	Audit Latitude	39.10216		
Site Address 1	Konza Prairie Lane	Audit Longitude	-96.609583		
Site Address 2	CR 901	Audit Elevation	346		
County	Riley	Audit Declination	4.2		
City, State	Manhattan, KZ				
Zip Code	66502	Fire Extinguisher	Present	<input checked="" type="checkbox"/>	
Time Zone	central	First Aid Kit	<input checked="" type="checkbox"/>		
Primary Operator		Safety Glasses	<input checked="" type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Wells Cargo	Model	EW1211 (s/n 1WC20)
		Shelter Size	640 cuft		
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is very clean, neat an well organized. Although patched, he shelter floor is deteriorated and in poor condition.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Manhattan take route 177 south. At the east edge of town, immediately after crossing the Kansas river, turn right onto CR901 (McDowell Creek Road). Continue approximately 6.2 miles and turn left into the Konza Prairie Biological Station. The site is through the gate and up the hill past the three-story stone farm house.				



Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

KNZ184

Technician

Tim Mendenhall

Site Visit Date

10/10/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input type="checkbox"/>	south
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature sensor is mounted on the north side of the sample tower.

Site ID

KNZ184

Technician

Tim Mendenhall

Site Visit Date

10/10/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	Moderately clean
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

KNZ184

Technician

Tim Mendenhall

Site Visit Date

10/10/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	N/A
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	N/A
3	Describe ozone sample tube.		N/A
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	N/A
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	N/A
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

KNZ184

Technician

Tim Mendenhall

Site Visit Date

10/10/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>									
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>									
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	N/A								
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>									
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>									
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>									
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>									
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded									
<input type="checkbox"/>		<input type="checkbox"/>									
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>									
10	Is the sample tower stable and grounded?										
11	Tower comments?										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

KNZ184

Technician

Tim Mendenhall

Site Visit Date

10/10/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2014	<input type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☒
- 2

Are the Site Status Report Forms being completed and current?

☒
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☒
- N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

KNZ184

Technician

Tim Mendenhall

Site Visit Date

10/10/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by site operator

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

N/A

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

N/A

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

KNZ184

Technician

Tim Mendenhall

Site Visit Date

10/10/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

KNZ184

Technician

Tim Mendenhall

Site Visit Date

10/10/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	313MC12	07014
DAS	Campbell	CR3000	2139	000361
Elevation	Elevation	1	None	None
Flow Rate	Apex	AXMC105LPMDPC	illegible	000925
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07182
Sample Tower	Aluma Tower	B	none	missing
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41432VC	14082	06541



Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	VOY413	Technician	Eric Hebert	Site Visit Date	10/10/2023
Site Sponsor (agency)	NPS	USGS Map	Ash River NE		
Operating Group	NPS	Map Scale			
AQS #	27-137-0034	Map Date			
Meteorological Type	Climatronics				
Air Pollutant Analyzer	Ozone, IMPROVE	QAPP Latitude	48.4128		
Deposition Measurement	dry, wet	QAPP Longitude	-92.8292		
Land Use	woodland - mixed	QAPP Elevation Meters	429		
Terrain	rolling	QAPP Declination			
Conforms to MLM	Marginally	QAPP Declination Date			
Site Telephone		Audit Latitude	48.412518		
Site Address 1	CR 129	Audit Longitude	-92.829225		
Site Address 2	Ash River Visitor Center Rd.	Audit Elevation	427		
County	St. Louis	Audit Declination	0.5		
City, State	Orr, MN				
Zip Code	55771	Fire Extinguisher	<input type="checkbox"/>	Present	
Time Zone	Central	First Aid Kit	<input type="checkbox"/>		
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input checked="" type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810 (s/n 2880-2)
		Shelter Size	640 cuft		
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is in fair condition, and is neat and well organized.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Duluth take route 53 north towards International Falls. Approximately 20 miles south of International Falls and just north of Orr, turn right (east) on County Road 129. Continue approximately 9.5 miles and turn left toward the Ash River Visitor Center. Continue approximately 1.5 miles and look for a closed gate on the right. The site is approximately 1 mile up the trail from the road.				

Site ID

VOY413

Technician

Eric Hebert

Site Visit Date

10/10/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

VOY413

Technician

Eric Hebert

Site Visit Date

10/10/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

VOY413

Technician

Eric Hebert

Site Visit Date

10/10/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	Trees have been cut

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 9 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There are no trees violating the 22.5 degree cone above the ozone sample inlet. However, there is a communication tower which is above the 22.5 degree threshold.

Site ID

VOY413

Technician

Eric Hebert

Site Visit Date

10/10/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>						
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>						
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only					
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>						
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>						
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>						
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>						
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>						
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded						
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input type="checkbox"/>			
<input checked="" type="checkbox"/>		<input type="checkbox"/>						
11	Tower comments?							

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The sample tower itself is not grounded, however it is bolted to the shelter which is grounded. The roof leak above the instrument rack may have been repaired, it is dry at this time.

Site ID

VOY413

Technician

Eric Hebert

Site Visit Date

10/10/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	Dataview	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Jan 2006	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

Dataview

2

Are the Site Status Report Forms being completed and current?

☒

Flow section only

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

VOY413

Technician

Eric Hebert

Site Visit Date

10/10/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	Weekly		<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Alarm values only		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 3 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Dataview

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

VOY413

Technician

Eric Hebert

Site Visit Date

10/10/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	gloves not used
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator handles the filter barehanded.



Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

VOY413

Technician

Eric Hebert

Site Visit Date

10/10/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Environmental Sys Corp	8816	2505	90632
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	illegible	illegible	none
Flow Rate	Alicat	MC-10SLPM-D-PCV	Unknown	none
Infrastructure	Infrastructure	none	none	none
Ozone	ThermoElectron Inc	49C	49C-66828-354	90714
Ozone Standard	ThermoElectron Inc	49C	49C-59260-322	90569
Sample Tower	Aluma Tower	B	AT-51159-11-G	none
Shelter Temperature	ARS	none	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342VC	029199	none
Zero air pump	Twin Tower Engineering	TT70/E4	526294	90719

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
DEN417-Martin Valvur-10/11/2023						
1	10/11/2023	DAS	Environmental Sys Corp	90600	8816	2274
2	10/11/2023	Ozone	ThermoElectron Inc	90835	49C	0520012327
3	10/11/2023	Ozone Standard	ThermoElectron Inc	none	49C	49C-71310-368
4	10/11/2023	Zero air pump	Werther International	none	PC70/4	526281

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

0520012327

DEN417

Martin Valvur

10/11/2023

Ozone

90835

Slope:

1.02530

Slope:

0.00000

Intercept

0.11634

Intercept

0.00000

CorrCoff:

0.99998

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.20	-0.40	-0.06	ppb		0.34	
primary	2	14.81	14.49	14.98	ppb		0.49	
primary	3	34.79	34.95	35.42	ppb	1.34		
primary	4	65.18	64.48	66.52	ppb	3.11		
primary	5	114.78	113.71	116.70	ppb	2.6		

Sensor Component

Audit Pressure

Condition

699 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.2

Status

pass

Sensor Component

Span

Condition

1.029

Status

pass

Sensor Component

Zero Voltage

Condition

-0.0007

Status

pass

Sensor Component

Fullscale Voltage

Condition

0.9998

Status

pass

Sensor Component

Cell A Freq.

Condition

92.9 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.5 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.61 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

691.1 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

29.6 C

Status

pass

Sensor Component

Cell B Freq.

Condition

80.6 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.5 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.64 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

690.6 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

False

Status

pass

Sensor Component

System Memo

Condition

Status

pass

# Site Inventory by Site Visit

Site Visit Date		Parameter	Mfg	Owner ID	Model Number	Serial Number
THR422-Tim Mendenhall-10/13/2023						
1	10/13/2023	Computer	Hewlett Packard	none	65606	5CB1520H68
2	10/13/2023	DAS	Environmental Sys Corp	90656	8816	2600
3	10/13/2023	Elevation	Elevation	None	1	None
4	10/13/2023	Filter pack flow pump	Thomas	none	107CAB18	Illegible
5	10/13/2023	Flow Rate	Alicat	none	MC-10SLPM-D-PCV	301232
6	10/13/2023	Infrastructure	Infrastructure	none	none	none
7	10/13/2023	Met tower	Rohn	none	unknown	none
8	10/13/2023	Sample Tower	Aluma Tower	none	B	AT-81077-J5
9	10/13/2023	Shelter Temperature	ARS	none	none	none
10	10/13/2023	Siting Criteria	Siting Criteria	None	1	None
11	10/13/2023	Temperature2meter	RM Young	none	41342VC	29200

DAS Data Form

DAS Time Max Error: 1.92

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2600	THR422	Tim Mendenhall	10/13/2023	DAS	Primary

Das Date:	10/13/2023	Audit Date	10/13/2023
Das Time:	10:29:04	Audit Time	10:27:09
Das Day:	286	Audit Day	286
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Alicat	301232		THR422	Tim Mendenhall	10/13/2023	Flow Rate	none

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
50.33%	50.50%		
		Cal Factor Full Scale	5
		Rotometer Reading:	3

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.02	0.000	0.01	l/m	l/m	
primary	test pt 1	2.990	2.990	1.68	0.000	1.49	l/m	l/m	-50.17%
primary	test pt 2	3.002	3.000	1.68	0.000	1.49	l/m	l/m	-50.33%
primary	test pt 3	3.012	3.010	1.68	0.000	1.49	l/m	l/m	-50.50%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	3.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

## 2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	29200		THR422	Tim Mendenhall	10/13/2023	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.27	0.39		

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.34	0.26	0.000	0.65C		0.39
primary	Temp Mid Range	27.71	27.31	0.000	27.65C		0.34
primary	Temp High Rang	49.47	48.82	0.000	48.90C		0.08

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		THR422	Tim Mendenhall	10/13/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.59	0.80		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	20.81	20.49	0.000	20.7	C	0.19	
primary	Temp Mid Range	19.73	19.42	0.000	20.2	C	0.79	
primary	Temp Mid Range	23.59	23.24	0.000	22.4	C	-0.8	
Sensor Component	System Memo			Condition		Status	pass	



Infrastructure Data For

Site ID

THR422

Technician

Tim Mendenhall

Site Visit Date

10/13/2023

Shelter Make	Shelter Model	Shelter Size
Ekto	8814 (s/n 3028-1)	896 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Fair	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition	200 m	Status	Fail
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition	300 m	Status	Fail
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

Gloves are not used to handle the filter pack. The filter bag is used as a glove.

**2 Parameter:** DasComments

The met tower is no longer in use.

**3 Parameter:** SiteOpsProcedures

The ozone sample train does not have a means to introduce test gas at the sample inlet. Results of routine zero, span, precision, and any multipoint calibration checks are maintained by the state personnel who perform the tests. The two inlet filters in the sample train are creating a large pressure drop.

**4 Parameter:** SitingCriteriaCom

The site is located 200 meters from an interstate rest area, and 300 meters from interstate 94. The rest area can have parked and idling vehicles for extended periods.

**5 Parameter:** ShelterCleanNotes

The shelter is in good condition, clean and well organized.

**6 Parameter:** PollAnalyzerCom

The ozone monitor is operated by the state of North Dakota. There is approximately 1.5 meters of tygon tubing attached to the 3/8 filter pack flow tubing. The data logger was recording the flow rate as 1.5 lpm while the rotometer and the audit standard device were measuring approximately 3 lpm.

**7 Parameter:** MetSensorComme

The 2-meter temperature sensor is mounted on south side of the sample tower, which is attached to the site shelter. The sensor is 4.1 meters above ground and close to the shelter.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	THR422	Technician	Tim Mendenhall	Site Visit Date	10/13/2023
Site Sponsor (agency)	NPS	USGS Map	Fryburg NW		
Operating Group	NPS and state of ND	Map Scale			
AQS #	38-007-0002	Map Date			
Meteorological Type	Climatronics				
Air Pollutant Analyzer	Ozone, SO2, IMPROVE, PM2.5	QAPP Latitude	46.8947		
Deposition Measurement	dry, wet	QAPP Longitude	-103.3778		
Land Use	prairie	QAPP Elevation Meters	850		
Terrain	rolling - complex	QAPP Declination			
Conforms to MLM	Marginally	QAPP Declination Date			
Site Telephone		Audit Latitude	46.894844		
Site Address 1	Painted Canyon Visitor Center	Audit Longitude	-103.377719		
Site Address 2	Exit 32 Interstate 94	Audit Elevation	840		
County	Billings	Audit Declination	8.2		
City, State	Medora, ND				
Zip Code	58645	Fire Extinguisher	<input type="checkbox"/>	Present	
Time Zone	Mountain	First Aid Kit	<input checked="" type="checkbox"/>		
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input checked="" type="checkbox"/>		
Backup Operator		Security Fence	<input checked="" type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8814 (s/n 3028-1)
		Shelter Size	896 cuft		
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is in good condition, clean and well organized.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Interstate 94 take exit 32 to the Painted Canyon rest area and visitor center. The site is just east of the parking lot on a gravel road.				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

THR422

Technician

Tim Mendenhall

Site Visit Date

10/13/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The 2-meter temperature sensor is mounted on south side of the sample tower, which is attached to the site shelter. The sensor is 4.1 meters above ground and close to the shelter.

Site ID

THR422

Technician

Tim Mendenhall

Site Visit Date

10/13/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input type="checkbox"/>	Moderately clean
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

THR422

Technician

Tim Mendenhall

Site Visit Date

10/13/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		3/8 teflon by 10 meters and glass manifold
4	Describe dry dep sample tube.		3/8 teflon by 12 meters and 1.5 meters of tygon
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet and analyzer
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone monitor is operated by the state of North Dakota. There is approximately 1.5 meters of tygon tubing attached to the 3/8 filter pack flow tubing. The data logger was recording the flow rate as 1.5 lpm while the rotometer and the audit standard device were measuring approximately 3 lpm.

Site ID

THR422

Technician

Tim Mendenhall

Site Visit Date

10/13/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?											

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The met tower is no longer in use.



Site ID

THR422

Technician

Tim Mendenhall

Site Visit Date

10/13/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☐

not used

2

Are the Site Status Report Forms being completed and current?

☒

Flow section only

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

THR422

Technician

Tim Mendenhall

Site Visit Date

10/13/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by previous site operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by current operator

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	every 2 months	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input checked="" type="checkbox"/>	every 2 months	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>		<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

not tested

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☐

Not tested

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☐

Unknown

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone sample train does not have a means to introduce test gas at the sample inlet. Results of routine zero, span, precision, and any multipoint calibration checks are maintained by the state personnel who perform the tests. The two inlet filters in the sample train are creating a large pressure drop.

Site ID

THR422

Technician

Tim Mendenhall

Site Visit Date

10/13/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Gloves are not used to handle the filter pack. The filter bag is used as a glove.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

THR422

Technician

Tim Mendenhall

Site Visit Date

10/13/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	65606	5CB1520H68	none
DAS	Environmental Sys Corp	8816	2600	90656
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	Illegible	none
Flow Rate	Alicat	MC-10SLPM-D-PCV	301232	none
Infrastructure	Infrastructure	none	none	none
Met tower	Rohn	unknown	none	none
Sample Tower	Aluma Tower	B	AT-81077-J5	none
Shelter Temperature	ARS	none	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342VC	29200	none

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
GLR468-Tim Mendenhall-10/18/2023						
1	10/18/2023	Computer	Hewlett Packard	ACAD	6730b	CNU9335F7W
2	10/18/2023	Elevation	Elevation	None	1	None
3	10/18/2023	Filter pack flow pump	Thomas	none	107CAB18	Illegible
4	10/18/2023	Flow Rate	Tylan	none	FC280	AW9710138
5	10/18/2023	Infrastructure	Infrastructure	none	none	none
6	10/18/2023	MFC power supply	Tylan	03944	RO-32	FP9605010
7	10/18/2023	Ozone	ThermoElectron Inc	none	49i A3NCA	1201477661
8	10/18/2023	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	0733726104
9	10/18/2023	Sample Tower	Aluma Tower	none	B	none
10	10/18/2023	Shelter Temperature	ARS	77	none	none
11	10/18/2023	Siting Criteria	Siting Criteria	None	1	None
12	10/18/2023	Temperature2meter	RM Young	none	41342	17625
13	10/18/2023	Zero air pump	Werther International	none	C 120/TC	001007354

DAS Data Form

DAS Time Max Error: 0.17

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	C2600	GLR468	Tim Mendenhall	10/18/2023	DAS	Primary

Das Date:	10/18/2023	Audit Date	10/18/2023
Das Time:	09:55:05	Audit Time	09:55:15
Das Day:	291	Audit Day	291
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9710138		GLR468	Tim Mendenhall	10/18/2023	Flow Rate	none

Mfg	Tylan			Mfg	BIOS	Parameter	Flow Rate
SN/Owner ID	FP9605010	03944		Serial Number	148613	Tfer Desc.	BIOS 220-H
Parameter:	MFC power supply			Tfer ID	01421		
				Slope	1.00000	Intercept	0.00000
				Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.094
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.22%	0.33%		
		Cal Factor Full Scale	5.441
		Rotometer Reading:	3.1

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.04	0.000	0.08	l/m	l/m	
primary	leak check	0.000	0.000	-0.01	0.000	0.12	l/m	l/m	
primary	test pt 1	3.009	3.010	2.72	0.000	3.00	l/m	l/m	-0.33%
primary	test pt 2	3.008	3.010	2.71	0.000	3.00	l/m	l/m	-0.33%
primary	test pt 3	3.008	3.010	2.72	0.000	3.01	l/m	l/m	0.00%
Sensor Component	Leak Test			Condition		Status	pass		
Sensor Component	Tubing Condition			Condition	Good	Status	pass		
Sensor Component	Filter Position			Condition	Good	Status	pass		
Sensor Component	Rotometer Condition			Condition	Clean and dry	Status	pass		
Sensor Component	Moisture Present			Condition	No moisture present	Status	pass		
Sensor Component	Filter Distance			Condition	4.5 cm	Status	pass		
Sensor Component	Filter Depth			Condition	2.0 cm	Status	pass		
Sensor Component	Filter Azimuth			Condition	360 deg	Status	pass		
Sensor Component	System Memo			Condition		Status	pass		

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1201477661

GLR468

Tim Mendenhall

10/18/2023

Ozone

none

Slope:

0.99776

Slope:

0.00000

Intercept

-0.82253

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.45	0.15	-0.54	ppb		-0.69	
primary	2	16.06	15.80	14.90	ppb		-0.9	
primary	3	34.46	34.24	33.22	ppb	-3.02		
primary	4	63.59	63.45	62.45	ppb	-1.59		
primary	5	107.98	107.96	106.96	ppb	-0.93		
Sensor Component	Audit Pressure		Condition	704 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.4		Status	pass	
Sensor Component	Span		Condition	1.013		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	123.7 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	2.3 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.68 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	673.9 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	31.5 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	80.8 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	1.1 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.70 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	674.2 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	



## 2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	17625		GLR468	Tim Mendenhall	10/18/2023	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.21	0.24		

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.31	0.23	0.000	0.06C		-0.17
primary	Temp Mid Range	22.91	22.56	0.000	22.34C		-0.22
primary	Temp High Rang	50.45	49.78	0.000	49.54C		-0.24

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		GLR468	Tim Mendenhall	10/18/2023	Shelter Temperature	77

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.63	0.70		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.11	22.76	0.000	23.3	C	0.5
primary	Temp Mid Range	21.37	21.04	0.000	21.7	C	0.7
primary	Temp Mid Range	21.80	21.47	0.000	22.2	C	0.69
Sensor Component	System Memo			Condition		Status	pass

Infrastructure Data For

Site ID

GLR468

Technician

Tim Mendenhall

Site Visit Date

10/18/2023

Shelter Make

Ekto

Shelter Model

8810 (s/n 2149-20)

Shelter Size

640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Fair	Status	pass
Sensor Component	Met Tower	Condition	Poor	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Fair	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Fair	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Fair	Status	pass
Sensor Component	Excessive mold present	Condition	Fair	Status	pass
Sensor Component	Signal Cable	Condition	Poor	Status	Fail
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition	20 km	Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

- 1

Parameter:

SiteOpsProcComm

The site operator uses the filter bad as a glove.
- 2

Parameter:

SitingCriteriaCom

The site is located in a small clearing within 100 meters of a horse stable. There is a plywood and aluminum processing plant within 20 km of the site.
- 3

Parameter:

ShelterCleanNotes

The shelter is in fair condition. Evidence of repairs to roof leaks attempted. The floor has been repaired since the previous audit visit.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	GLR468	Technician	Tim Mendenhall	Site Visit Date	10/18/2023		
Site Sponsor (agency)	NPS	USGS Map	Lake McDonald West				
Operating Group	NPS	Map Scale					
AQS #	30-029-8001	Map Date					
Meteorological Type	R.M. Young						
Air Pollutant Analyzer	Ozone, IMPROVE	QAPP Latitude	48.5103				
Deposition Measurement	dry, wet, Hg	QAPP Longitude	-113.9956				
Land Use	woodland - mixed	QAPP Elevation Meters	976				
Terrain	complex	QAPP Declination	18				
Conforms to MLM	No	QAPP Declination Date	12/27/2004				
Site Telephone	(406) 888-7983	Audit Latitude	48.510301				
Site Address 1	Horse Stables	Audit Longitude	-113.996807				
Site Address 2	Quarter Circle Bridge Rd	Audit Elevation	964				
County	Flathead	Audit Declination	14.1				
City, State	West Glacier, MT						
Zip Code	59936	Fire Extinguisher	Present	Inspected June 2011			
Time Zone	Mountain	First Aid Kit					
Primary Operator		Safety Glasses					
Primary Op. Phone #		Safety Hard Hat					
Primary Op. E-mail		Climbing Belt					
Backup Operator		Security Fence					
Backup Op. Phone #		Secure Shelter					
Backup Op. E-mail		Stable Entry Steps					
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810 (s/n 2149-20)	Shelter Size	640 cuft
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is in fair condition. Evidence of repairs to roof leaks attempted. The floor has been repaired since the previous audit visit.				
Site OK	<input checked="" type="checkbox"/>	Notes					
Driving Directions	From Kalispell proceed north on route 2 to West Glacier. Turn left onto Going To The Sun Road into Glacier National Park. Proceed approximately 0.2 miles past the entrance and fee station, and turn left toward the horse stables. Bear right at the fork and continue through the gate past the stables. The site is visible in the clearing on the left.						

Field Systems Data Form

F-02058-1500-S3-rev002

Site IDGLR468

TechnicianTim Mendenhall

Site Visit Date10/18/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	Temperature now at 2 meters
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDGLR468

TechnicianTim Mendenhall

Site Visit Date10/18/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input type="checkbox"/>	Signs of wear
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



Site IDGLR468

TechnicianTim Mendenhall

Site Visit Date10/18/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 15 meters
4	Describe dry dep sample tube.		3/8 Teflon by 12 meters and 0.5 meters tygon
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

GLR468

Technician

Tim Mendenhall

Site Visit Date

10/18/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>						
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>						
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only					
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>						
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>						
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>						
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>						
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>						
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded						
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input type="checkbox"/>			
<input checked="" type="checkbox"/>		<input type="checkbox"/>						
11	Tower comments?							

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

GLR468

Technician

Tim Mendenhall

Site Visit Date

10/18/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	Dataview	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2016	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	April 2004	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	April 2004	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☒

Dataview
- 2

Are the Site Status Report Forms being completed and current?

☒
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

GLR468

Technician

Tim Mendenhall

Site Visit Date

10/18/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by previous site operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>			<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Alarm values only		<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>			<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Dataview

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDGLR468

TechnicianTim Mendenhall

Site Visit Date10/18/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed various times
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	Dataview
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator uses the filter bad as a glove.

Field Systems Data Form

F-02058-1500-S10-rev002

Site IDGLR468

TechnicianTim Mendenhall

Site Visit Date10/18/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	6730b	CNU9335F7W	ACAD
DAS	Environmental Sys Corp	8864	C2600	None
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	Illegible	none
Flow Rate	Tylan	FC280	AW9710138	none
Infrastructure	Infrastructure	none	none	none
MFC power supply	Tylan	RO-32	FP9605010	03944
Ozone	ThermoElectron Inc	49i A3NCA	1201477661	none
Ozone Standard	ThermoElectron Inc	49i A1NAA	0733726104	none
Sample Tower	Aluma Tower	B	none	none
Shelter Temperature	ARS	none	none	77
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342	17625	none
Zero air pump	Werther International	C 120/TC	001007354	none

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
UVL124-Eric Hebert-10/19/2023						
1	10/19/2023	DAS	Campbell	000347	CR3000	2126
2	10/19/2023	Ozone	ThermoElectron Inc	000680	49i A1NAA	1030244792
3	10/19/2023	Ozone Standard	ThermoElectron Inc	000438	49i A3NAA	CM08200014
4	10/19/2023	Zero air pump	Werther International	06936	C 70/4	000829169

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244792

UVL124

Eric Hebert

10/19/2023

Ozone

000680

Slope:

1.00788

Slope:

0.00000

Intercept

-0.41443

Intercept

0.00000

CorrCoff:

0.99998

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00450

Intercept

-0.25270

Cert Date

4/24/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.41	-0.11	-0.13	ppb		-0.02	
primary	2	16.44	16.60	16.07	ppb		-0.53	
primary	3	32.45	32.48	32.09	ppb	-1.21		
primary	4	66.61	66.37	66.43	ppb	0.09		
primary	5	113.90	113.29	113.90	ppb	0.54		

Sensor Component

Audit Pressure

Condition

732 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

0.40

Status

pass

Sensor Component

Span

Condition

1.030

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

115.1 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.6 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.68 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

713.5 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

33.5 C

Status

pass

Sensor Component

Cell B Freq.

Condition

100.7 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

1.1 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.68 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

714.4 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

False

Status

pass

Sensor Component

System Memo

Condition

Status

pass



# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
HOX148-Eric Hebert-10/19/2023						
1	10/19/2023	DAS	Campbell	000426	CR3000	2533
2	10/19/2023	Ozone	ThermoElectron Inc	000734	49i A1NAA	1105347317
3	10/19/2023	Ozone Standard	ThermoElectron Inc	000544	49i A3NAA	0929938242
4	10/19/2023	Zero air pump	Werther International	06938	C 70/4	000829164

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347317

HOX148

Eric Hebert

10/19/2023

Ozone

000734

Slope:

1.01508

Slope:

0.00000

Intercept

0.46876

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00450

Intercept

-0.25270

Cert Date

4/24/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.57	-0.27	0.19	ppb		0.46	
primary	2	15.43	15.59	16.45	ppb		0.86	
primary	3	35.17	35.18	36.04	ppb	2.42		
primary	4	64.95	64.72	66.09	ppb	2.09		
primary	5	117.25	116.61	118.90	ppb	1.94		

Sensor Component

Audit Pressure

Condition

738 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

0.000

Status

pass

Sensor Component

Span

Condition

1.023

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

100.3 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

1.6 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.72 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

695.8 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

37.0 C

Status

pass

Sensor Component

Cell B Freq.

Condition

104.8 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

1.3 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.68 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

696.7 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

True

Status

pass

Sensor Component

System Memo

Condition

Status

pass

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
ANA115-Eric Hebert-10/20/2023						
1	10/20/2023	DAS	Campbell	000339	CR3000	2118
2	10/20/2023	Ozone	ThermoElectron Inc	000699	49i A1NAA	1030244804
3	10/20/2023	Ozone Standard	ThermoElectron Inc	000513	49i A3NAA	0922236889
4	10/20/2023	Zero air pump	Werther International	06933	C 70/4	000836202

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244804

ANA115

Eric Hebert

10/20/2023

Ozone

000699

Slope:

0.99806

Slope:

0.00000

Intercept

-0.18415

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00450

Intercept

-0.25270

Cert Date

4/24/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.18	0.46	0.34	ppb		-0.12	
primary	2	16.03	16.19	16.06	ppb		-0.13	
primary	3	33.02	33.04	32.62	ppb	-1.28		
primary	4	69.12	68.86	68.50	ppb	-0.52		
primary	5	113.65	113.04	112.70	ppb	-0.3		

Sensor Component

Audit Pressure

Condition

723 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.20

Status

pass

Sensor Component

Span

Condition

1.014

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

99.5 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

Not tested

Status

pass

Sensor Component

Cell A Flow

Condition

0.70 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

690.1 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

34.3 C

Status

pass

Sensor Component

Cell B Freq.

Condition

102.8 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

Not tested

Status

pass

Sensor Component

Cell B Flow

Condition

0.65 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

689.4 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

True

Status

pass

Sensor Component

System Memo

Condition

Status

pass

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
CAV436-Martin Valvur-10/23/2023					
1 10/23/2023	Computer	Hewlett Packard	none	ProBook	5CD01715DB
2 10/23/2023	DAS	Environmental Sys Corp	None	8864	C2602
3 10/23/2023	Modem	Sierra wireless	none	GX450	Unknown
4 10/23/2023	Ozone	ThermoElectron Inc	none	49i A3NAA	0733726103
5 10/23/2023	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	CM08460009
6 10/23/2023	Shelter Temperature	ARS	none	none	none
7 10/23/2023	Temperature2meter	RM Young	none	41432VC	31823
8 10/23/2023	Zero air pump	Werther International	none	C 70/4	000915011

DAS Data Form

DAS Time Max Error: 1.57

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	C2602	CAV436	Martin Valvur	10/23/2023	DAS	Primary

Das Date:	10/23/2023	Audit Date:	10/23/2023
Das Time:	07:57:26	Audit Time:	07:59:00
Das Day:	296	Audit Day:	296
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

0733726103

CAV436

Martin Valvur

10/23/2023

Ozone

none

Slope:

0.97980

Slope:

0.00000

Intercept

-0.77048

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.02	-0.22	-1.00	ppb		-0.78	
primary	2	14.45	14.13	12.91	ppb		-1.22	
primary	3	33.86	33.40	32.09	ppb	-4		
primary	4	64.00	63.31	61.40	ppb	-3.06		
primary	5	115.04	113.97	110.80	ppb	-2.82		

Sensor Component

Audit Pressure

Condition

648 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.2

Status

pass

Sensor Component

Span

Condition

1.004

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

124.5 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

1.1 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.70 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

633.4 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

37.9 C

Status

pass

Sensor Component

Cell B Freq.

Condition

71.8 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.6 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.69 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

632.8 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

False

Status

pass

Sensor Component

System Memo

Condition

Status

pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	31823		CAV436	Martin Valvur	10/23/2023	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

0.69	0.74		
------	------	--	--

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.14	0.14	0.000	0.88	C	0.74
primary	Temp Mid Range	24.40	24.40	0.000	25.11	C	0.71
primary	Temp High Rang	48.09	48.09	0.000	48.71	C	0.62

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass



# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		CAV436	Martin Valvur	10/23/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.32	0.69		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	20.51	20.51	0.000	21.2	C	0.69	
primary	Temp Mid Range	21.06	21.06	0.000	21.3	C	0.26	
primary	Temp Mid Range	24.12	24.12	0.000	24.1	C	-0.02	
Sensor Component	System Memo			Condition		Status	pass	

# Field Systems Comments

- 1

Parameter:

SiteOpsProcComm

Dry deposition samples are not collected at this site.
- 2

Parameter:

DocumentationCo

The site is visited every other Tuesday.
- 3

Parameter:

MetSensorComme

The 2-meter temperature sensor is mounted one meter above the building roof and facing south. The building is likely to impact the accuracy of the measurements.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	CAV436	Technician	Martin Valvur	Site Visit Date	10/23/2023		
Site Sponsor (agency)	NPS	USGS Map					
Operating Group	NPS	Map Scale					
AQS #	35-151-0745	Map Date					
Meteorological Type							
Air Pollutant Analyzer	Ozone	QAPP Latitude					
Deposition Measurement		QAPP Longitude					
Land Use		QAPP Elevation Meters					
Terrain		QAPP Declination					
Conforms to MLM		QAPP Declination Date					
Site Telephone		Audit Latitude	32.178141				
Site Address 1		Audit Longitude	-104.443206				
Site Address 2		Audit Elevation	1358				
County		Audit Declination	7				
City, State	Carlsbad, NM						
Zip Code	88220	Fire Extinguisher	<input checked="" type="checkbox"/> Inspected March 2023				
Time Zone	Mountain	First Aid Kit	<input type="checkbox"/> in vehicle				
Primary Operator		Safety Glasses	<input type="checkbox"/>				
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>				
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>				
Backup Operator		Security Fence	<input type="checkbox"/>				
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>				
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>				
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Shelter One	Model	E8129-29034	Shelter Size	768 cutt
Shelter Clean	<input checked="" type="checkbox"/>	Notes					
Site OK	<input checked="" type="checkbox"/>	Notes					
Driving Directions							

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

10/23/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input type="checkbox"/>	south
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input type="checkbox"/>	Attached to roof railing
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The 2-meter temperature sensor is mounted one meter above the building roof and facing south. The building is likely to impact the accuracy of the measurements.

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

10/23/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

10/23/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 10 meters
4	Describe dry dep sample tube.		N/A
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

10/23/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>									
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>									
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only								
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>									
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>									
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>									
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>									
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded									
<input type="checkbox"/>		<input type="checkbox"/>									
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>									
10	Is the sample tower stable and grounded?										
11	Tower comments?										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

10/23/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input type="checkbox"/>		<input type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☒

Dataview
- 2

Are the Site Status Report Forms being completed and current?

☐
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☐
- 4

Are ozone z/s/p control charts properly completed and current?

☐

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site is visited every other Tuesday.



Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

10/23/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

N/A

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

N/A

3

Is the site visited regularly on the required Tuesday schedule?

☐

every other Tuesday

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Bi-monthly	<input type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>		<input type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	Bi-monthly	<input type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Bi-monthly	<input type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>		<input type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Bi-monthly	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Bi-monthly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Bi-monthly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Bi-monthly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Bi-monthly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

10/23/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	N/A
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	N/A
3	Are data downloads and backups being performed as scheduled?	<input checked="" type="checkbox"/>	N/A
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	N/A
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	N/A
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	N/A
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	N/A
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	N/A
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Dry deposition samples are not collected at this site.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

10/23/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	ProBook	5CD01715DB	none
DAS	Environmental Sys Corp	8864	C2602	None
Modem	Sierra wireless	GX450	Unknown	none
Ozone	ThermoElectron Inc	49i A3NAA	0733726103	none
Ozone Standard	ThermoElectron Inc	49i A1NAA	CM08460009	none
Shelter Temperature	ARS	none	none	none
Temperature2meter	RM Young	41432VC	31823	none
Zero air pump	Werther International	C 70/4	000915011	none

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
CHA467-Martin Valvur-10/24/2023						
1	10/24/2023	DAS	Environmental Sys Corp	90611	8816	2613
2	10/24/2023	Ozone	ThermoElectron Inc	none	49i A3NAA	CM08460007
3	10/24/2023	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	CM08460051
4	10/24/2023	Zero air pump	Werther International	none	PC70/4	531392

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

CM08460007

CHA467

Martin Valvur

10/24/2023

Ozone

none

Slope:

0.98591

Slope:

0.00000

Intercept

0.08656

Intercept

0.00000

CorrCoff:

0.99990

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.09	-0.11	0.84	ppb		0.95	
primary	2	15.10	14.78	14.04	ppb		-0.74	
primary	3	34.97	34.50	33.95	ppb	-1.61		
primary	4	64.57	63.88	62.57	ppb	-2.07		
primary	5	115.40	114.32	113.20	ppb	-0.98		

Sensor Component

Audit Pressure

Condition

633 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.4

Status

pass

Sensor Component

Span

Condition

1.025

Status

pass

Sensor Component

Zero Voltage

Condition

0.000

Status

pass

Sensor Component

Fullscale Voltage

Condition

1.000

Status

pass

Sensor Component

Cell A Freq.

Condition

110.3 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

1.4 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.71 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

625.4 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

33.3 C

Status

pass

Sensor Component

Cell B Freq.

Condition

103.7 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

1.8 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.67 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

624.5 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

False

Status

pass

Sensor Component

System Memo

Condition

Status

pass

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
GRC474-Martin Valvur-10/25/2023						
1	10/25/2023	DAS	Environmental Sys Corp	90602	8816	2270
2	10/25/2023	Ozone	ThermoElectron Inc	none	49i A3NAA	1023943902
3	10/25/2023	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1130450191
4	10/25/2023	Zero air pump	Werther International	none	PC70/4	531380

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1023943902

GRC474

Martin Valvur

10/25/2023

Ozone

none

Slope:

0.97456

Slope:

0.00000

Intercept

-0.76120

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.07	-0.13	-1.01	ppb		-0.88	
primary	2	14.33	14.01	13.02	ppb		-0.99	
primary	3	35.51	35.04	33.49	ppb	-4.52		
primary	4	65.15	64.45	61.91	ppb	-4.02		
primary	5	116.24	115.16	111.50	ppb	-3.23		
Sensor Component	Audit Pressure		Condition	597 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.1		Status	pass	
Sensor Component	Span		Condition	1.021		Status	pass	
Sensor Component	Zero Voltage		Condition	0.0002		Status	pass	
Sensor Component	Fullscale Voltage		Condition	1.0001		Status	pass	
Sensor Component	Cell A Freq.		Condition	87.3 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.9 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.68 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	592.7 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	34.1 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	80.5 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.69 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	592.1 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
PET427-Martin Valvur-10/26/2023						
1	10/26/2023	DAS	Environmental Sys Corp	90641	8816	2526
2	10/26/2023	Ozone	ThermoElectron Inc	none	49i A3NAA	1023943901
3	10/26/2023	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1211052489
4	10/26/2023	Zero air pump	Werther International	none	PC 70/4	531382



Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1023943901

PET427

Martin Valvur

10/26/2023

Ozone

none

Slope:

0.95667

Slope:

0.00000

Intercept

0.46781

Intercept

0.00000

CorrCoff:

0.99977

CorrCoff:

0.00000

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.14	-0.06	1.77	ppb		1.83	
primary	2	15.38	15.06	13.75	ppb		-1.31	
primary	3	34.30	33.83	32.41	ppb	-4.29		
primary	4	58.46	57.81	55.60	ppb	-3.9		
primary	5	115.72	114.64	110.50	ppb	-3.68		
Sensor Component	Audit Pressure		Condition	622 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Not tested		Status	pass	
Sensor Component	Offset		Condition	0.000		Status	pass	
Sensor Component	Span		Condition	1.004		Status	pass	
Sensor Component	Zero Voltage		Condition	0.0001		Status	pass	
Sensor Component	Fullscale Voltage		Condition	1.0001		Status	pass	
Sensor Component	Cell A Freq.		Condition	87.5 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.4 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.52 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	615.5 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	33.6 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	87.1 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.51 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	614.9 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
STK138-Eric Hebert-10/29/2023						
1	10/29/2023	Computer	Dell	07065	Inspiron 15	1Y3MC12
2	10/29/2023	DAS	Campbell	000349	CR3000	2128
3	10/29/2023	Elevation	Elevation	None	1	None
4	10/29/2023	Filter pack flow pump	Thomas	04923	107CAB18	060300019959
5	10/29/2023	Flow Rate	Apex	000461	AXMC105LPMDPCV	illegible
6	10/29/2023	Infrastructure	Infrastructure	none	none	none
7	10/29/2023	Modem	Digi	07179	LR54	unknown
8	10/29/2023	Ozone	ThermoElectron Inc	000625	49i A1NAA	1009241797
9	10/29/2023	Ozone Standard	ThermoElectron Inc	000445	49i A3NAA	CM08200021
10	10/29/2023	Sample Tower	Aluma Tower	03554	A	none
11	10/29/2023	Shelter Temperature	Campbell	none	107-L	unknown
12	10/29/2023	Siting Criteria	Siting Criteria	None	1	None
13	10/29/2023	Temperature	RM Young	06407	41342VC	14040
14	10/29/2023	Zero air pump	Werther International	06897	C 70/4	000821893

DAS Data Form

DAS Time Max Error: 0.02

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2128	STK138	Eric Hebert	10/29/2023	DAS	Primary

Das Date:	10/29/2023	Audit Date	10/29/2023
Das Time:	06:15:31	Audit Time	06:15:30
Das Day:	302	Audit Day	302
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	4000392	Tfer Desc.	Source generator (D
Tfer ID	01321		
Slope	1.00000	Intercept	0.00000
Cert Date	1/22/2015	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	86590148	Tfer Desc.	DVM
Tfer ID	01310		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		STK138	Eric Hebert	10/29/2023	Flow Rate	000461

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.01
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.90%	1.35%		
		Cal Factor Full Scale	1.02
		Rotometer Reading:	1.45

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.01	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.02	l/m	l/m	
primary	test pt 1	1.483	1.480	1.47	0.000	1.50	l/m	l/m	1.35%
primary	test pt 2	1.483	1.480	1.47	0.000	1.50	l/m	l/m	1.35%
primary	test pt 3	1.500	1.500	1.47	0.000	1.50	l/m	l/m	0.00%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	6.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.2 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241797

STK138

Eric Hebert

10/29/2023

Ozone

000625

Slope:

1.01627

Slope:

0.00000

Intercept

0.16439

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00450

Intercept

-0.25270

Cert Date

4/24/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.22	0.07	0.38	ppb		0.31	
primary	2	16.50	16.65	17.03	ppb		0.38	
primary	3	36.35	36.35	37.00	ppb	1.77		
primary	4	69.71	69.45	70.68	ppb	1.76		
primary	5	114.62	114.00	116.10	ppb	1.83		

Sensor Component

Audit Pressure

Condition

Not tested

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.20

Status

pass

Sensor Component

Span

Condition

1.032

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

100.4 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.9 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.63 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

699.3 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

34.1 C

Status

pass

Sensor Component

Cell B Freq.

Condition

101.7 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

1.0 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.57 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

698.7 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

True

Status

pass

Sensor Component

System Memo

Condition

Status

pass

# Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14040		STK138	Eric Hebert	10/29/2023	Temperature	06407

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00945	Intercept	0.16485
Cert Date	2/17/2023	CorrCoff	1.00000

0.08	0.11		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.19	0.02	0.000	0.1	C	0.11
primary	Temp Mid Range	28.50	28.07	0.000	28.0	C	-0.11
primary	Temp High Range	48.89	48.27	0.000	48.3	C	-0.02

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	unknown		STK138	Eric Hebert	10/29/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.65	1.54		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00945	Intercept	0.16485
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	25.82	25.42	0.000	25.2	C	-0.21
primary	Temp Mid Range	23.14	22.76	0.000	24.3	C	1.54
primary	Temp Mid Range	28.48	28.05	0.000	27.9	C	-0.2
Sensor Component	System Memo		Condition		Status	pass	





Infrastructure Data For

Site ID

STK138

Technician

Eric Hebert

Site Visit Date

10/29/2023

Shelter Make	Shelter Model	Shelter Size
Ekto	8810 (s/n 2149-21)	640 cuft

Sensor Component	Sample Tower Type	Condition	Type A	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Poor	Status	Fail
Sensor Component	Shelter Condition	Condition	Poor	Status	Fail
Sensor Component	Shelter Door	Condition	Fair	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Poor	Status	Fail
Sensor Component	Shelter walls	Condition	Fair	Status	pass
Sensor Component	Excessive mold present	Condition	Fair	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition	20 m	Status	Fail
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

The site operator is completing the SSRF information on the day the filter is removed rather than when installed. He is also indicating on the form that the ozone inlet filter is changed every week.

**2 Parameter:** DasComments

The sample tower is original and is in poor condition. The lower section has been cut to allow the upper section to fold down completely.

**3 Parameter:** SiteOpsProcedures

The ozone sample train is leak tested every 2 weeks.

**4 Parameter:** SitingCriteriaCom

The site is located in a corn field on a cattle farm. Corn is planted within 10 meters.

**5 Parameter:** ShelterCleanNotes

There are signs of leaks on the walls and floor rot. The shelter has continued to deteriorate since the previous audit visit.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	STK138	Technician	Eric Hebert	Site Visit Date	10/29/2023		
Site Sponsor (agency)	EPA	USGS Map	Kent				
Operating Group	Private	Map Scale					
AQS #	17-085-9991	Map Date					
Meteorological Type	R.M. Young						
Air Pollutant Analyzer	Ozone	QAPP Latitude	42.2872				
Deposition Measurement	dry	QAPP Longitude	-89.9998				
Land Use	agricultural	QAPP Elevation Meters	274				
Terrain	rolling	QAPP Declination	1.3				
Conforms to MLM	Yes	QAPP Declination Date	2/22/2006				
Site Telephone		Audit Latitude	42.287216				
Site Address 1	10939 E. Parker Road	Audit Longitude	-89.99995				
Site Address 2		Audit Elevation	281				
County	Jo Daviess	Audit Declination	-1.3				
City, State	Stockton, IL						
Zip Code	61085	Fire Extinguisher	<input checked="" type="checkbox"/> Present	new in 2015			
Time Zone	Central	First Aid Kit	<input checked="" type="checkbox"/>				
Primary Operator		Safety Glasses	<input type="checkbox"/>				
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>				
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>				
Backup Operator		Security Fence	<input type="checkbox"/>				
Backup Op. Phone #		Secure Shelter	<input type="checkbox"/>				
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>				
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810 (s/n 2149-21)	Shelter Size	640 cuft
Shelter Clean	<input type="checkbox"/>	Notes	There are signs of leaks on the walls and floor rot. The shelter has continued to deteriorate since the previous audit visit.				
Site OK	<input checked="" type="checkbox"/>	Notes					
Driving Directions	From Stockton go south on 78 (Main Street) for approximately 2.5 miles. As the road turns sharply to the right, continue straight onto a dirt road. There will be a stop sign at another dirt road intersection within 100 yards. Continue through that intersection, the site will be visible in the distance on a hill-side to the left. Continue another 1.5 miles bearing to the left on dirt roads to the Evans farm. The site is past both houses in the hay field.						

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

STK138

Technician

Eric Hebert

Site Visit Date

10/29/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	Mounted to sample tower
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

STK138

Technician

Eric Hebert

Site Visit Date

10/29/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

STK138

Technician

Eric Hebert

Site Visit Date

10/29/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 18 meters
4	Describe dry dep sample tube.		3/8 teflon by 18 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

STK138

Technician

Eric Hebert

Site Visit Date

10/29/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>									
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>									
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only								
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>									
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>									
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>									
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>									
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded									
<input type="checkbox"/>		<input type="checkbox"/>									
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>									
10	Is the sample tower stable and grounded?										
11	Tower comments?										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The sample tower is original and is in poor condition. The lower section has been cut to allow the upper section to fold down completely.



Site ID

STK138

Technician

Eric Hebert

Site Visit Date

10/29/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

STK138

Technician

Eric Hebert

Site Visit Date

10/29/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Trained by previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Call-in only

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone sample train is leak tested every 2 weeks.

Site ID

STK138

Technician

Eric Hebert

Site Visit Date

10/29/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is completing the SSRF information on the day the filter is removed rather than when installed. He is also indicating on the form that the ozone inlet filter is changed every week.

**F-02058-1500-S10-rev002**

**Site Visit Date** 10/29/2023

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	1Y3MC12	07065
DAS	Campbell	CR3000	2128	000349
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	060300019959	04923
Flow Rate	Apex	AXMC105LPMDPC	illegible	000461
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07179
Ozone	ThermoElectron Inc	49i A1NAA	1009241797	000625
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200021	000445
Sample Tower	Aluma Tower	A	none	03554
Shelter Temperature	Campbell	107-L	unknown	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VC	14040	06407
Zero air pump	Werther International	C 70/4	000821893	06897

# Site Inventory by Site Visit

Site Visit Date		Parameter	Mfg	Owner ID	Model Number	Serial Number
PND165-Martin Valvur-10/31/2023						
1	10/31/2023	DAS	Campbell	000403	CR3000	2516
2	10/31/2023	Elevation	Elevation	None	1	None
3	10/31/2023	Filter pack flow pump	Thomas	00534	107CA18	0000162757
4	10/31/2023	Flow Rate	Apex	000871	AXMC105LPMDPCV	illegible
5	10/31/2023	Infrastructure	Infrastructure	none	none	none
6	10/31/2023	Modem	Digi	07123	LR54	Illegible
7	10/31/2023	Noy	Teledyne	000807	T200U	112
8	10/31/2023	Ozone	ThermoElectron Inc	000676	49i A1NAA	1030244794
9	10/31/2023	Ozone Standard	ThermoElectron Inc	000694	49i A3NAA	1030244815
10	10/31/2023	Sample Tower	Aluma Tower	000055	B	AT-81213-J12
11	10/31/2023	Shelter Temperature	Campbell	none	107-L	none
12	10/31/2023	Siting Criteria	Siting Criteria	None	1	None
13	10/31/2023	Temperature	RM Young	06539	41342	14800
14	10/31/2023	Zero air pump	Werther International	06881	C 70/4	000815264

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2516	PND165	Martin Valvur	10/31/2023	DAS	Primary

Das Date:	10/31/2023	Audit Date:	10/31/2023
Das Time:	12:36:00	Audit Time:	12:36:00
Das Day:	304	Audit Day:	304
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		PND165	Martin Valvur	10/31/2023	Flow Rate	000871

Mfg	BIOS	Parameter	Flow Rate
Serial Number	152253	Tfer Desc.	BIOS 220-H
Tfer ID	15225		
Slope	1.00000	Intercept	0.00000
Cert Date	5/2/2022	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.01
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.29%	0.33%		
		Cal Factor Full Scale	1
		Rotometer Reading:	3.6

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.02	l/m	l/m	
primary	test pt 1	3.011	3.010	3.01	0.000	3.02	l/m	l/m	0.33%
primary	test pt 2	3.016	3.020	3.02	0.000	3.01	l/m	l/m	-0.33%
primary	test pt 3	3.004	3.000	3.02	0.000	3.01	l/m	l/m	0.20%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244794

PND165

Martin Valvur

10/31/2023

Ozone

000676

Slope:

1.00609

Slope:

0.00000

Intercept

-2.68838

Intercept

0.00000

CorrCoff:

0.99974

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

49CPS-70008-364

Tfer Desc.

Ozone primary stan

Tfer ID

01110

Slope

1.00426

Intercept

0.20413

Cert Date

10/31/2022

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.14	-0.06	-4.20	ppb		-4.14	
primary	2	16.32	15.99	14.65	ppb		-1.34	
primary	3	36.12	35.64	33.92	ppb	-4.95		
primary	4	66.12	65.41	62.78	ppb	-4.1		
primary	5	117.68	116.59	114.40	ppb	-1.9		

Sensor Component

Audit Pressure

Condition

578 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

1.9

Status

pass

Sensor Component

Span

Condition

1.068

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

76.0 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.6 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.65 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

561.0 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

29.3 C

Status

pass

Sensor Component

Cell B Freq.

Condition

84.7 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.6 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.62 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

560.7 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

False

Status

pass

Sensor Component

System Memo

Condition

Status

pass



# Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14800		PND165	Martin Valvur	10/31/2023	Temperature	06539

DAS 1:	DAS 2:	Mfg	Fluke	Parameter	Temperature
		Serial Number	3275143	Tfer Desc.	RTD
		Tfer ID	01229		
		Slope	1.00002	Intercept	-0.00336
		Cert Date	1/23/2023	CorrCoff	1.00000

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.06	0.08		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.12	0.12	0.000	0.2	C	0.07
primary	Temp Mid Range	21.62	21.62	0.000	21.6	C	-0.03
primary	Temp High Range	47.14	47.14	0.000	47.1	C	-0.08

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		PND165	Martin Valvur	10/31/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.43	0.82		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	21.16	21.16	0.000	20.3	C	-0.82	
primary	Temp Mid Range	21.29	21.29	0.000	21.6	C	0.33	
primary	Temp Mid Range	21.16	21.16	0.000	21.3	C	0.15	
Sensor Component	System Memo			Condition		Status	pass	

Infrastructure Data For

Site ID

PND165

Technician

Martin Valvur

Site Visit Date

10/31/2023

Shelter Make	Shelter Model	Shelter Size
Ekto	8810 (s/n 2149-22)	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	Good	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Poor	Status	Fail
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

- 1

Parameter:

SitingCriteriaCom

Construction at the bottom of the hill and entrance to the site access road has been completed.
- 2

Parameter:

ShelterCleanNotes

The floor tiles are loose and breaking into pieces.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	PND165	Technician	Martin Valvur	Site Visit Date	10/31/2023
Site Sponsor (agency)	BLM-WSO	USGS Map	Fremont Lake South		
Operating Group	Private / BLM	Map Scale			
AQS #	56-035-9991	Map Date			
Meteorological Type	R.M. Young				
Air Pollutant Analyzer	Ozone	QAPP Latitude	42.9214		
Deposition Measurement	dry, wet	QAPP Longitude	-109.7900		
Land Use	range	QAPP Elevation Meters	2388		
Terrain	complex	QAPP Declination	12.75		
Conforms to MLM	Marginally	QAPP Declination Date	2/22/2006		
Site Telephone	(307) 367-6584	Audit Latitude	42.929031		
Site Address 1	Skyline Drive	Audit Longitude	-109.787796		
Site Address 2	Fremont Lake Rd.	Audit Elevation	2386		
County	Sublette	Audit Declination	10.9		
City, State	Pinedale, WY				
Zip Code	82941	Fire Extinguisher	<input checked="" type="checkbox"/> Present	New in 2015	
Time Zone	Mountain	First Aid Kit	<input checked="" type="checkbox"/>		
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input checked="" type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810 (s/n 2149-22)
		Shelter Size	640 cuft		
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The floor tiles are loose and breaking into pieces.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Rock Springs take route 191 north to Pinedale. At the south edge of town turn right onto Fremont Lake Rd. Continue approximately 6.5 miles on the main road, past Fremont Lake. The road changes to Skyline Drive. The site is visible on a ridge on the right. There is a dirt access road to the site in the summer.				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

PND165

Technician

Martin Valvur

Site Visit Date

10/31/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	Over shelter
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	Over shelter
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PND165

Technician

Martin Valvur

Site Visit Date

10/31/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	N/A
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



Site ID

PND165

Technician

Martin Valvur

Site Visit Date

10/31/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PND165

Technician

Martin Valvur

Site Visit Date

10/31/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>							
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>							
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only						
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>							
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>							
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>							
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>							
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>							
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
Stable		Grounded							
<input checked="" type="checkbox"/>		<input type="checkbox"/>							
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>				
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
11	Tower comments?								

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PND165

Technician

Martin Valvur

Site Visit Date

10/31/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☒
- 2

Are the Site Status Report Forms being completed and current?

☒
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PND165

Technician

Martin Valvur

Site Visit Date

10/31/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

trained by current operator

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PND165

Technician

Martin Valvur

Site Visit Date

10/31/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons approximately 80%
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

PND165

Technician

Martin Valvur

Site Visit Date

10/31/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR3000	2516	000403
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	0000162757	00534
Flow Rate	Apex	AXMC105LPMDPC	illegible	000871
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07123
Noy	Teledyne	T200U	112	000807
Ozone	ThermoElectron Inc	49i A1NAA	1030244794	000676
Ozone Standard	ThermoElectron Inc	49i A3NAA	1030244815	000694
Sample Tower	Aluma Tower	B	AT-81213-J12	000055
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	14800	06539
Zero air pump	Werther International	C 70/4	000815264	06881

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
GRB411-Martin Valvur-11/06/2023						
1	11/6/2023	DAS	Environmental Sys Corp	90635	8816	2507
2	11/6/2023	Ozone	ThermoElectron Inc	none	49i A3NAA	1200666539
3	11/6/2023	Ozone Standard	ThermoElectron Inc	none	49C	0330302753
4	11/6/2023	Zero air pump	Werther International	90722	TT70/4E	507782

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1200666539

GRB411

Martin Valvur

11/06/2023

Ozone

none

Slope:

1.01129

Slope:

0.00000

Intercept

-0.87381

Intercept

0.00000

CorrCoff:

0.99998

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

CM23147126

Tfer Desc.

Ozone primary stan

Tfer ID

01116

Slope

1.00654

Intercept

-0.03885

Cert Date

9/19/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.19	0.22	-0.79	ppb		-1.01	
primary	2	16.13	16.00	15.42	ppb		-0.58	
primary	3	35.15	34.83	34.66	ppb	-0.49		
primary	4	64.95	64.32	63.77	ppb	-0.86		
primary	5	114.11	112.98	113.50	ppb	0.46		

Sensor Component

Audit Pressure

Condition

588 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

0.000

Status

pass

Sensor Component

Span

Condition

1.005

Status

pass

Sensor Component

Zero Voltage

Condition

-0.0002

Status

pass

Sensor Component

Fullscale Voltage

Condition

1.0002

Status

pass

Sensor Component

Cell A Freq.

Condition

78.8 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.9 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.62 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

582.3 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

32.5 C

Status

pass

Sensor Component

Cell B Freq.

Condition

63.9 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.7 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.60 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

582.0 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

False

Status

pass

Sensor Component

System Memo

Condition

Status

pass



# Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>SHE604-Tim Mendenhall-11/06/2023</i>						
1	11/6/2023	DAS	Campbell	none	CR1000	49923
2	11/6/2023	elevation	Elevation	none	none	none
3	11/6/2023	Flow Rate	AALBORG	none	GFC-17	illegibile
4	11/6/2023	Infrastructure	Infrastructure	none	none	none
5	11/6/2023	Sample Tower	Unknown	none	Unknown	None
6	11/6/2023	siting criteria	Siting Criteria	none	none	None
7	11/6/2023	Temperature2meter	Campbell	none	10755	Illegible

DAS Data Form

DAS Time Max Error: 0.03

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	49923	SHE604	Tim Mendenhall	11/06/2023	DAS	Primary

Das Date:	11/6 /2023	Audit Date	11/6 /2023
Das Time:	8:02:57	Audit Time	8:02:59
Das Day:	310	Audit Day	310
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
AALBORG	illegibile		SHE604	Tim Mendenhall	11/06/2023	Flow Rate	none

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.26
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	0.987
0.89%	1.64%	Rotometer Reading:	0

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.26	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.26	l/m	l/m	
primary	test pt 1	2.933	2.930	2.70	0.000	2.96	l/m	l/m	1.02%
primary	test pt 2	3.045	3.040	2.75	0.000	2.99	l/m	l/m	-1.64%
primary	test pt 3	2.975	2.980	2.75	0.000	2.98	l/m	l/m	0.00%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	N/A	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	2.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# 2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	Illegible		SHE604	Tim Mendenhall	11/06/2023	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.11	0.17		

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.17	0.09	0.000	0.14	C	0.05
primary	Temp Mid Rang	25.76	25.38	0.000	25.21	C	-0.17
primary	Temp High Rang	40.51	39.96	0.000	40.08	C	0.12

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID

SHE604

Technician

Tim Mendenhall

Site Visit Date

11/06/2023

Shelter Make	Shelter Model	Shelter Size

Sensor Component	Sample Tower Type	Condition	Other	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	Fair	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Not installed	Status	pass
Sensor Component	Sample Tower	Condition	Fair	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Fair	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

**1 Parameter:** DasComments

The site power source is solar and wind with battery storage. The NEMA enclosure has a cooling fan and heat for the 2B ozone monitor.

**2 Parameter:** SiteOpsProcedures

observations of current meteorological measurements are recorded on a hardcopy checklist for ARS and not on the SSRF.

**3 Parameter:** DocumentationCo

The site operator is supplied with a disc containing the QAPP, operating procedures, and HASP which is kept at his office. A hard copy BLM check list developed by ARS is completed and sent to ARS each week. Standard CASTNET SSRF forms are being used now.

**4 Parameter:** SitingCriteriaCom

The site is located in range land. There is an active rail line with coal trains within one kilometer of the site.

**5 Parameter:** ShelterCleanNotes

NEMA enclosure, wind and solar power

**6 Parameter:** PollAnalyzerCom

The dry deposition filter pack enclosure is not the standard "pot" size as at the other CASTNET sites. The diameter is much smaller. It is not clear if this will impact particle collection efficiency. The filter is not plumb inside the enclosure and there is a section of tygon tubing between the pump and MFC.

**7 Parameter:** MetSensorComme

The site is a small footprint solar powered site that has been operating as part of the WARMS network for more than 10 years. Objects violate the 45 degree rule for the tipping bucket rain gage. The temperature and RH are being measured at 2.5 meters above the ground. The upper section of the tower is not plumb. The guy wires could be adjusted to correct.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID

SHE604

Technician

Tim Mendenhall

Site Visit Date

11/06/2023

Site Sponsor (agency)	BLM-WSO	USGS Map	
Operating Group	BLM	Map Scale	
AQS #		Map Date	
Meteorological Type	Met One		
Air Pollutant Analyzer		QAPP Latitude	
Deposition Measurement		QAPP Longitude	
Land Use		QAPP Elevation Meters	
Terrain		QAPP Declination	
Conforms to MLM		QAPP Declination Date	
Site Telephone		Audit Latitude	44.933601
Site Address 1		Audit Longitude	-106.847161
Site Address 2		Audit Elevation	1141
County	Sheridan	Audit Declination	9.8
City, State	Sheridan, WY		
Zip Code	82801	Fire Extinguisher	<input type="checkbox"/> Present
Time Zone	Mountain	First Aid Kit	<input type="checkbox"/>
Primary Operator		Safety Glasses	<input type="checkbox"/>
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>
Backup Operator		Security Fence	<input type="checkbox"/>
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>
Backup Op. E-mail		Stable Entry Step	<input checked="" type="checkbox"/>
Shelter Working Room	<input type="checkbox"/>	Make	
		Model	
		Shelter Size	
Shelter Clean	<input checked="" type="checkbox"/>	Notes	NEMA enclosure, wind and solar power
Site OK	<input type="checkbox"/>	Notes	
Driving Directions			



# Field Systems Data Form

F-02058-1500-S3-rev002

Site ID  Technician  Site Visit Date

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	<input type="text"/>
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	<input type="text"/>
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	tower upper section not plumb
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	<input type="text"/>
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	<input type="text"/>
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	<input type="text"/>
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	<input type="text"/>
8	Is the rain gauge plumb?	<input type="checkbox"/>	<input type="text"/>
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input type="checkbox"/>	45 degree rule violation
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site is a small footprint solar powered site that has been operating as part of the WARMS network for more than 10 years. Objects violate the 45 degree rule for the tipping bucket rain gage. The temperature and RH are being measured at 2.5 meters above the ground. The upper section of the tower is not plumb. The guy wires could be adjusted to correct.

Site ID

SHE604

Technician

Tim Mendenhall

Site Visit Date

11/06/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SHE604

Technician

Tim Mendenhall

Site Visit Date

11/06/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		N/A
4	Describe dry dep sample tube.		3/8 teflon by 10 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	N/A
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	in-line filter
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input type="checkbox"/>	Not present

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The dry deposition filter pack enclosure is not the standard "pot" size as at the other CASTNET sites. The diameter is much smaller. It is not clear if this will impact particle collection efficiency. The filter is not plumb inside the enclosure and there is a section of tygon tubing between the pump and MFC.

Site ID

SHE604

Technician

Tim Mendenhall

Site Visit Date

11/06/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>								
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>								
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input type="checkbox"/>	Not present							
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>								
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>								
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>								
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>								
8	Is the instrument shelter temperature controlled?	<input type="checkbox"/>	Marginally							
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td><td></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td><td></td></tr></table>	Stable		Grounded		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded								
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>								
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td><td></td></tr></table>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>					
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>								
11	Tower comments?									

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site power source is solar and wind with battery storage. The NEMA enclosure has a cooling fan and heat for the 2B ozone monitor.

# Field Systems Data Form

F-02058-1500-S7-rev002

Site ID  Technician  Site Visit Date

## Documentation

### Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

### Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	2013	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	2013	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	2013	<input checked="" type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	Not present	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- Is the station log properly completed during every site visit? ☒
- Are the Site Status Report Forms being completed and current? ☒
- Are the chain-of-custody forms properly used to document sample transfer to and from lab? ☒
- Are ozone z/s/p control charts properly completed and current? ☒ N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is supplied with a disc containing the QAPP, operating procedures, and HASP which is kept at his office. A hard copy BLM check list developed by ARS is completed and sent to ARS each week. Standard CASTNET SSRF forms are being used now.

Site ID

SHE604

Technician

Tim Mendenhall

Site Visit Date

11/06/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Training provided by ARS

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	Monthly		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	N/A		<input type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

N/A

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

N/A

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

observations of current meteorological measurements are recorded on a hardcopy checklist for ARS and not on the SSRF.

Site ID

SHE604

Technician

Tim Mendenhall

Site Visit Date

11/06/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	One set of gloves only
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input type="checkbox"/> Not present	<input type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

SHE604

Technician

Tim Mendenhall

Site Visit Date

11/06/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR1000	49923	none
elevation	Elevation	none	none	none
Flow Rate	AALBORG	GFC-17	illegible	none
Infrastructure	Infrastructure	none	none	none
Sample Tower	Unknown	Unknown	None	none
siting criteria	Siting Criteria	none	None	none
Temperature2meter	Campbell	10755	Illegible	none



# Site Inventory by Site Visit

Site Visit Date		Parameter	Mfg	Owner ID	Model Number	Serial Number
BUF603-Tim Mendenhall-11/07/2023						
1	11/7/2023	DAS	Campbell	49917	CR1000	49917
2	11/7/2023	elevation	Elevation	none	none	none
3	11/7/2023	Filter pack flow pump	Thomas	02980	107CA18	608102A
4	11/7/2023	Flow Rate	Omega	none	FMA6518ST-RS232	315688-1
5	11/7/2023	Infrastructure	Infrastructure	none	none	none
6	11/7/2023	Sample Tower	Unknown	none	Unknown	None
7	11/7/2023	siting criteria	Siting Criteria	none	none	None
8	11/7/2023	Temperature2meter	Campbell	none	10755	Missing

DAS Data Form

DAS Time Max Error: 0.02

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	49917	BUF603	Tim Mendenhall	11/07/2023	DAS	Primary

Das Date:	11/7 /2023	Audit Date	11/7 /2023
Das Time:	9:42:42	Audit Time	9:42:41
Das Day:	311	Audit Day	311
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Omega	315688-1		BUF603	Tim Mendenhall	11/07/2023	Flow Rate	none

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.417
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	0.978
1.24%	1.35%	Rotometer Reading:	0

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference	
primary	pump off	0.000	0.000	0.00	0.000	0.42	l/m	l/m		
primary	leak check	0.000	0.000	0.00	0.000	0.42	l/m	l/m		
primary	test pt 1	2.956	2.960	0.00	0.000	3.00	l/m	l/m	1.35%	
primary	test pt 2	2.957	2.960	0.00	0.000	3.00	l/m	l/m	1.35%	
primary	test pt 3	2.980	2.980	0.00	0.000	3.01	l/m	l/m	1.01%	

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Not installed	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	3.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	9.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	Missing		BUF603	Tim Mendenhall	11/07/2023	Temperature2meter	none

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

0.28	0.42		
------	------	--	--

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.24	0.16	0.000	0.58	C	0.42
primary	Temp Mid Rang	25.59	25.21	0.000	25.06	C	-0.15
primary	Temp High Rang	42.06	41.49	0.000	41.76	C	0.27

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID

BUF603

Technician

Tim Mendenhall

Site Visit Date

11/07/2023

Shelter Make

Shelter Model

Shelter Size

Sensor Component	Sample Tower Type	Condition	Other	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	Good	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Not tested	Status	pass
Sensor Component	Shelter Temp Control	Condition	N/A	Status	pass
Sensor Component	Rotometer	Condition	Not installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

The site operator does not use gloves, however, he uses the filter bag when handling the filter.

**2 Parameter:** DasComments

The NEMA enclosure has a cooling fan.

**3 Parameter:** DocumentationCo

A disc with the current QAPP has been received and is kept at the site operator's office. The site operator completes and files a hardcopy checklist and logbook developed by ARS for BLM each week.

**4 Parameter:** ShelterCleanNotes

NEMA enclosure, 120 VAC power

**5 Parameter:** PollAnalyzerCom

The dry deposition filter pack enclosure is not the standard "pot" size that is used at the other CASTNET sites. The diameter of the enclosure is much smaller and the filter is mounted much deeper inside the opening. The geometry of the filter pack and enclosure is likely to impact particle collection efficiency.

**6 Parameter:** MetSensorComme

The temperature is measured at 2.5 meters above the ground. The top section of the tower is not perfectly plumb and guy wire tension could be applied to improve position.

**7 Parameter:** MetOpMaintCom

Some signal cables are showing signs of wear.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID

BUF603

Technician

Tim Mendenhall

Site Visit Date

11/07/2023

Site Sponsor (agency)	BLM-WSO	USGS Map	
Operating Group	BLM	Map Scale	
AQS #		Map Date	
Meteorological Type			
Air Pollutant Analyzer		QAPP Latitude	
Deposition Measurement		QAPP Longitude	
Land Use		QAPP Elevation Meters	
Terrain		QAPP Declination	
Conforms to MLM		QAPP Declination Date	
Site Telephone		Audit Latitude	44.144135
Site Address 1		Audit Longitude	-106.108771
Site Address 2		Audit Elevation	1320
County	Johnson	Audit Declination	9.3
City, State	Buffalo, WY		
Zip Code	82834	Fire Extinguisher	<input type="checkbox"/> Present
Time Zone	Mountain	First Aid Kit	<input type="checkbox"/>
Primary Operator		Safety Glasses	<input type="checkbox"/>
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>
Backup Operator		Security Fence	<input type="checkbox"/>
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>
Backup Op. E-mail		Stable Entry Step	<input checked="" type="checkbox"/>
Shelter Working Room	<input type="checkbox"/>	Make	
		Model	
		Shelter Size	
Shelter Clean	<input type="checkbox"/>	Notes	NEMA enclosure, 120 VAC power
Site OK	<input type="checkbox"/>	Notes	
Driving Directions			



Site ID

BUF603

Technician

Tim Mendenhall

Site Visit Date

11/07/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input type="checkbox"/>	45 degree rule violation
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature is measured at 2.5 meters above the ground. The top section of the tower is not perfectly plumb and guy wire tension could be applied to improve position.

Site ID

BUF603

Technician

Tim Mendenhall

Site Visit Date

11/07/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Some signal cables are showing signs of wear.

Site ID

BUF603

Technician

Tim Mendenhall

Site Visit Date

11/07/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	N/A
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	N/A
3	Describe ozone sample tube.		N/A
4	Describe dry dep sample tube.		3/8 teflon by 10 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	N/A
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	N/A
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input type="checkbox"/>	Not present

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The dry deposition filter pack enclosure is not the standard "pot" size that is used at the other CASTNET sites. The diameter of the enclosure is much smaller and the filter is mounted much deeper inside the opening. The geometry of the filter pack and enclosure is likely to impact particle collection efficiency.

Site ID

BUF603

Technician

Tim Mendenhall

Site Visit Date

11/07/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>							
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>							
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input type="checkbox"/>	Not present						
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>							
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>							
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>							
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>							
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>	cooling fan only						
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded							
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>				
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
11	Tower comments?								

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The NEMA enclosure has a cooling fan.

Site ID

BUF603

Technician

Tim Mendenhall

Site Visit Date

11/07/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	Not present	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	2013	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	2013	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	2013	<input checked="" type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	Not present	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>	Not present	<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☒
- 2

Are the Site Status Report Forms being completed and current?

☒
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☒

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

A disc with the current QAPP has been received and is kept at the site operator's office. The site operator completes and files a hardcopy checklist and logbook developed by ARS for BLM each week.

Site ID

BUF603

Technician

Tim Mendenhall

Site Visit Date

11/07/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	Monthly		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

N/A

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

N/A

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BUF603

Technician

Tim Mendenhall

Site Visit Date

11/07/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input type="checkbox"/> Not present	<input type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator does not use gloves, however, he uses the filter bag when handling the filter.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

BUF603

Technician

Tim Mendenhall

Site Visit Date

11/07/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR1000	49917	49917
elevation	Elevation	none	none	none
Filter pack flow pump	Thomas	107CA18	608102A	02980
Flow Rate	Omega	FMA6518ST-RS232	315688-1	none
Infrastructure	Infrastructure	none	none	none
Sample Tower	Unknown	Unknown	None	none
siting criteria	Siting Criteria	none	None	none
Temperature2meter	Campbell	10755	Missing	none



# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
CTH110-Eric Hebert-11/08/2023						
1	11/8/2023	DAS	Campbell	000415	CR3000	2510
2	11/8/2023	Ozone	ThermoElectron Inc	000735	49i A1NAA	1105347308
3	11/8/2023	Ozone Standard	ThermoElectron Inc	000447	49i A3NAA	CM08200023
4	11/8/2023	Zero air pump	Werther International	06864	PC70/4	000815261

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347308

CTH110

Eric Hebert

11/08/2023

Ozone

000735

Slope:

0.98097

Slope:

0.00000

Intercept

0.09209

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00450

Intercept

-0.25270

Cert Date

4/24/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.42	-0.12	0.00	ppb		0.12	
primary	2	17.41	17.56	17.17	ppb		-0.39	
primary	3	33.36	33.38	32.91	ppb	-1.42		
primary	4	67.87	67.62	66.54	ppb	-1.61		
primary	5	116.00	115.37	113.20	ppb	-1.9		
Sensor Component	Audit Pressure		Condition	716.5 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Moderately clean		Status	pass	
Sensor Component	Offset		Condition	-0.10		Status	pass	
Sensor Component	Span		Condition	1.003		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	110.3 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	Not tested		Status	pass	
Sensor Component	Cell A Flow		Condition	0.69 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	685.1 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	34.3 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	89.4 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	Not tested		Status	pass	
Sensor Component	Cell B Flow		Condition	0.68 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	684.8 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	True		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
BAS601-Tim Mendenhall-11/09/2023						
1	11/9/2023	DAS	Campbell	none	CR1000	47759
2	11/9/2023	Filter pack flow pump	Thomas	02980	107CA18	608102A
3	11/9/2023	Ozone	ThermoElectron Inc	L0534684	49i A1NAA	1214552973
4	11/9/2023	Ozone Standard	ThermoElectron Inc	none	49i E3CAA	1214552971

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1214552973

BAS601

Tim Mendenhall

11/09/2023

Ozone

L0534684

Slope:

0.97330

Slope:

0.00000

Intercept

-1.05805

Intercept

0.00000

CorrCoff

0.99991

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.43	0.13	-0.78	ppb		-0.91	
primary	2	16.98	16.72	15.47	ppb		-1.25	
primary	3	36.32	36.11	34.16	ppb	-5.55		
primary	4	67.51	67.38	63.52	ppb	-5.9		
primary	5	115.63	115.63	112.01	ppb	-3.18		
Sensor Component	Audit Pressure		Condition	662 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	0.1		Status	pass	
Sensor Component	Span		Condition	1.017		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	79.7 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.9 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.63 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	656.0 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	31.3 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	57.6 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.65 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	655.4 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Site Inventory by Site Visit

Site Visit Date		Parameter	Mfg	Owner ID	Model Number	Serial Number
WFM105-Eric Hebert-11/09/2023						
1	11/9/2023	DAS	Campbell	000803	CR850	23270
2	11/9/2023	elevation	Elevation	none	none	none
3	11/9/2023	Filter pack flow pump	Permotec	none	BL30EB	Illegible
4	11/9/2023	Flow Rate	Apex	000900	AXMC105LPMDPCV	illegible
5	11/9/2023	Infrastructure	Infrastructure	none	none	none
6	11/9/2023	Modem	Sierra wireless	06983	unknown	unknown
7	11/9/2023	siting criteria	Siting Criteria	none	none	None
8	11/9/2023	Temperature	RM Young	04683	41342VC	6697

DAS Data Form

DAS Time Max Error: 0.03

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	23270	WFM105	Eric Hebert	11/09/2023	DAS	Primary

Das Date:	11/10/2023	Audit Date	11/10/2023
Das Time:	11:42:00	Audit Time	11:41:58
Das Day:	314	Audit Day	314
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	4000392	Tfer Desc.	Source generator (D
Tfer ID	01321		
Slope	1.00000	Intercept	0.00000
Cert Date	1/22/2015	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	86590148	Tfer Desc.	DVM
Tfer ID	01310		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		WFM105	Eric Hebert	11/09/2023	Flow Rate	000900

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.047
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
1.12%	1.35%		
		Cal Factor Full Scale	1.049
		Rotometer Reading:	2.95

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference	
primary	pump off	0.000	0.000	0.00	0.000	0.05	l/m	l/m		
primary	leak check	0.000	0.000	0.01	0.000	0.06	l/m	l/m		
primary	test pt 1	2.965	2.960	2.95	0.000	3.00	l/m	l/m	1.35%	
primary	test pt 2	2.963	2.960	2.95	0.000	3.00	l/m	l/m	1.35%	
primary	test pt 3	2.980	2.980	2.95	0.000	3.00	l/m	l/m	0.67%	

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	3.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	6697		WFM105	Eric Hebert	11/09/2023	Temperature	04683

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature		
		Serial Number	H232734	Tfer Desc.	RTD		
		Tfer ID	01227				
		Slope	1.00945	Intercept	0.16485		
		Cert Date	2/17/2023	CorrCoff	1.00000		
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err				

0.10	0.25		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.10	-0.06	0.000	0.0	C	0.04	
primary	Temp Mid Range	26.56	26.15	0.000	25.9	C	-0.25	
primary	Temp High Range	47.40	46.79	0.000	46.8	C	-0.01	

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass



Infrastructure Data For

Site ID

WFM105

Technician

Eric Hebert

Site Visit Date

11/09/2023

Shelter Make

Shelter Model

Shelter Size

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	N/A	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	N/A	Status	pass
Sensor Component	Shelter Door	Condition	N/A	Status	pass
Sensor Component	Shelter Roof	Condition	N/A	Status	pass
Sensor Component	Shelter Floor	Condition	N/A	Status	pass
Sensor Component	Shelter walls	Condition	N/A	Status	pass
Sensor Component	Excessive mold present	Condition	N/A	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

The observation section of the SSRF is completed the day the filer is removed and not the day of installation.

**2 Parameter:** DasComments

Single tower, with filter pack at 10 meters and temperature at 9 meters.

**3 Parameter:** DocumentationCo

The site operator takes notes in his own field notebook, there is no site logbook.

**4 Parameter:** SitingCriteriaCom

The site is located at the Atmospheric Science Research Center (ASRC) operated by the NY University (SUNY) system.

**5 Parameter:** ShelterCleanNotes

Small footprint site with no shelter. Equipment housed in enclosure on sample tower.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	WFM105	Technician	Eric Hebert	Site Visit Date	11/09/2023		
Site Sponsor (agency)	EPA	USGS Map					
Operating Group	SUNY	Map Scale					
AQS #		Map Date					
Meteorological Type							
Air Pollutant Analyzer		QAPP Latitude					
Deposition Measurement	dry, wet	QAPP Longitude					
Land Use	Woodland - mixed	QAPP Elevation Meters					
Terrain	Complex	QAPP Declination					
Conforms to MLM	No	QAPP Declination Date					
Site Telephone		Audit Latitude	44.39322				
Site Address 1		Audit Longitude	-73.85874				
Site Address 2		Audit Elevation	608				
County		Audit Declination					
City, State	Wilmington, NY						
Zip Code	12997	Fire Extinguisher	<input checked="" type="checkbox"/> Present				
Time Zone	Eastern	First Aid Kit	<input checked="" type="checkbox"/>				
Primary Operator		Safety Glasses	<input type="checkbox"/>				
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>				
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>				
Backup Operator		Security Fence	<input type="checkbox"/>				
Backup Op. Phone #		Secure Shelter	<input type="checkbox"/>				
Backup Op. E-mail		Stable Entry Steps	<input type="checkbox"/>				
Shelter Working Room	<input type="checkbox"/>	Make		Model		Shelter Size	
Shelter Clean	<input type="checkbox"/>	Notes	Small footprint site with no shelter. Equipment housed in enclosure on sample tower.				
Site OK	<input checked="" type="checkbox"/>	Notes					
Driving Directions							

Site ID

WFM105

Technician

Eric Hebert

Site Visit Date

11/09/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

WFM105

Technician

Eric Hebert

Site Visit Date

11/09/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

WFM105

Technician

Eric Hebert

Site Visit Date

11/09/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		N/A
4	Describe dry dep sample tube.		3/8 Teflon by 10 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	N/A
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	N/A
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	inline filter
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

WFM105

Technician

Eric Hebert

Site Visit Date

11/09/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>										
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input type="checkbox"/>	N/A									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?											

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Single tower, with filter pack at 10 meters and temperature at 9 meters.



Site ID

WFM105

Technician

Eric Hebert

Site Visit Date

11/09/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☐

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☒

N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator takes notes in his own field notebook, there is no site logbook.

Site ID

WFM105

Technician

Eric Hebert

Site Visit Date

11/09/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained onsite by AMEC personnel

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

N/A

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

N/A

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

WFM105

Technician

Eric Hebert

Site Visit Date

11/09/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input checked="" type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	One set of gloves only
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The observation section of the SSRF is completed the day the filter is removed and not the day of installation.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

WFM105

Technician

Eric Hebert

Site Visit Date

11/09/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR850	23270	000803
elevation	Elevation	none	none	none
Filter pack flow pump	Permotec	BL30EB	Illegible	none
Flow Rate	Apex	AXMC105LPMDPC	illegible	000900
Infrastructure	Infrastructure	none	none	none
Modem	Sierra wireless	unknown	unknown	06983
siting criteria	Siting Criteria	none	None	none
Temperature	RM Young	41342VC	6697	04683

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
NIC001-Eric Hebert-11/11/2023					
1 11/11/2023	DAS	Campbell	000801	CR850	23268
2 11/11/2023	elevation	Elevation	none	none	none
3 11/11/2023	Filter pack flow pump	Permotec	none	BL30EB	Illegible
4 11/11/2023	Flow Rate	Apex	000595	AXMC105LPMDPCV	illegible
5 11/11/2023	Infrastructure	Infrastructure	none	none	none
6 11/11/2023	Modem	Sierra wireless	06989	GX440	Unknown
7 11/11/2023	Sample Tower	Aluma Tower	000785	B	AT-212125X73
8 11/11/2023	siting criteria	Siting Criteria	none	none	None
9 11/11/2023	Temperature	RM Young	04943	41342	none

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	23268	NIC001	Eric Hebert	11/11/2023	DAS	Primary

Das Date:	11/11/2023	Audit Date	11/11/2023
Das Time:	12:12:20	Audit Time	12:12:20
Das Day:	315	Audit Day	315
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	4000392	Tfer Desc.	Source generator (D
Tfer ID	01321		
Slope	1.00000	Intercept	0.00000
Cert Date	1/22/2015	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	86590148	Tfer Desc.	DVM
Tfer ID	01310		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		NIC001	Eric Hebert	11/11/2023	Flow Rate	000595

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.028
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.00%	0.00%		
		Cal Factor Full Scale	1.024
		Rotometer Reading:	2.75

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.03	l/m	l/m	
primary	leak check	0.000	0.000	0.08	0.000	0.11	l/m	l/m	
primary	test pt 1	2.998	3.000	2.98	0.000	3.00	l/m	l/m	0.00%
primary	test pt 2	3.001	3.000	2.98	0.000	3.00	l/m	l/m	0.00%
primary	test pt 3	3.004	3.000	2.98	0.000	3.00	l/m	l/m	0.00%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Fair	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	0.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	none		NIC001	Eric Hebert	11/11/2023	Temperature	04943

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00945	Intercept	0.16485
Cert Date	2/17/2023	CorrCoff	1.00000

0.06	0.09		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.16	0.00	0.000	0.0	C	0.01	
primary	Temp Mid Range	25.40	25.00	0.000	24.9	C	-0.09	
primary	Temp High Range	46.14	45.54	0.000	45.5	C	-0.08	

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass



Infrastructure Data For

Site ID

NIC001

Technician

Eric Hebert

Site Visit Date

11/11/2023

Shelter Make

Shelter Model

Shelter Size

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	N/A	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	N/A	Status	pass
Sensor Component	Shelter Door	Condition	N/A	Status	pass
Sensor Component	Shelter Roof	Condition	N/A	Status	pass
Sensor Component	Shelter Floor	Condition	N/A	Status	pass
Sensor Component	Shelter walls	Condition	N/A	Status	pass
Sensor Component	Excessive mold present	Condition	N/A	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

**1 Parameter:** DasComments

Single tower with filter pack mounted at 10 meters and temperature mounted at 9 meters. The tower is difficult to lower due to the lower section contacting the chain-link fence. This could be a potential safety hazard. It is recommended that a solution be investigated.

**2 Parameter:** DocumentationCo

There is no logbook onsite to record information regarding site status or filter information.

**3 Parameter:** ShelterCleanNotes

Small footprint site with no shelter. Equipment housed in enclosure on sample tower.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	NIC001	Technician	Eric Hebert	Site Visit Date	11/11/2023		
Site Sponsor (agency)	EPA	USGS Map					
Operating Group	NY DEC	Map Scale					
AQS #		Map Date					
Meteorological Type							
Air Pollutant Analyzer		QAPP Latitude					
Deposition Measurement	dry	QAPP Longitude					
Land Use	Woodland - mixed	QAPP Elevation Meters					
Terrain	Complex	QAPP Declination					
Conforms to MLM	No	QAPP Declination Date					
Site Telephone		Audit Latitude	43.68596				
Site Address 1		Audit Longitude	-74.9857				
Site Address 2		Audit Elevation	526				
County	Herkimer	Audit Declination					
City, State	Old Forge, NY						
Zip Code	13420	Fire Extinguisher	<input checked="" type="checkbox"/> Present				
Time Zone	Eastern	First Aid Kit	<input checked="" type="checkbox"/>				
Primary Operator		Safety Glasses	<input checked="" type="checkbox"/>				
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>				
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>				
Backup Operator		Security Fence	<input checked="" type="checkbox"/>				
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>				
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>				
Shelter Working Room	<input type="checkbox"/>	Make		Model		Shelter Size	
Shelter Clean	<input type="checkbox"/>	Notes	Small footprint site with no shelter. Equipment housed in enclosure on sample tower.				
Site OK	<input type="checkbox"/>	Notes					
Driving Directions							

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

NIC001

Technician

Eric Hebert

Site Visit Date

11/11/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

NIC001

Technician

Eric Hebert

Site Visit Date

11/11/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

NIC001

Technician

Eric Hebert

Site Visit Date

11/11/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		N/A
4	Describe dry dep sample tube.		3/8 Teflon by 10 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	N/A
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	N/A
8	Are there moisture traps in the sample lines?	<input type="checkbox"/>	Flow line only (balston filter)
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

NIC001

Technician

Eric Hebert

Site Visit Date

11/11/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>										
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>	N/A									
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?											

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Single tower with filter pack mounted at 10 meters and temperature mounted at 9 meters. The tower is difficult to lower due to the lower section contacting the chain-link fence. This could be a potential safety hazard. It is recommended that a solution be investigated.



Site ID

NIC001

Technician

Eric Hebert

Site Visit Date

11/11/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	No logbook	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☐

No logbook
- 2

Are the Site Status Report Forms being completed and current?

☒
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☒

N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There is no logbook onsite to record information regarding site status or filter information.

Site ID

NIC001

Technician

Eric Hebert

Site Visit Date

11/11/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

N/A

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

N/A

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

NIC001

Technician

Eric Hebert

Site Visit Date

11/11/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input checked="" type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

NIC001

Technician

Eric Hebert

Site Visit Date

11/11/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR850	23268	000801
elevation	Elevation	none	none	none
Filter pack flow pump	Permotec	BL30EB	Illegible	none
Flow Rate	Apex	AXMC105LPMDPC	illegible	000595
Infrastructure	Infrastructure	none	none	none
Modem	Sierra wireless	GX440	Unknown	06989
Sample Tower	Aluma Tower	B	AT-212125X73	000785
siting criteria	Siting Criteria	none	None	none
Temperature	RM Young	41342	none	04943

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
DUK008-Eric Hebert-11/14/2023						
1	11/14/2023	DAS	Campbell	000420	CR3000	2520
2	11/14/2023	Ozone	ThermoElectron Inc	000616	49i A1NAA	1009241781
3	11/14/2023	Ozone Standard	ThermoElectron Inc	000369	49i A3NAA	0726124690

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241781

DUK008

Eric Hebert

11/14/2023

Ozone

000616

Slope:

1.01197

Slope:

0.00000

Intercept

-0.03930

Intercept

0.00000

CorrCoff

1.00000

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00450

Intercept

-0.25270

Cert Date

4/24/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.05	0.23	0.35	ppb		0.12	
primary	2	17.66	17.81	17.94	ppb		0.13	
primary	3	37.19	37.18	37.48	ppb	0.8		
primary	4	69.03	68.77	69.44	ppb	0.97		
primary	5	117.87	117.23	118.70	ppb	1.25		
Sensor Component	Audit Pressure		Condition	752.8 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.10		Status	pass	
Sensor Component	Span		Condition	1.020		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	84.8 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	Not tested		Status	pass	
Sensor Component	Cell A Flow		Condition	0.66 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	682.4 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	34.1 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	91.4 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	Not tested		Status	pass	
Sensor Component	Cell B Flow		Condition	0.61 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	682.7 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
LAV410-Martin Valvur-11/14/2023						
1	11/14/2023	Computer	Hewlett Packard	none	EliteBook	CNU3389G02
2	11/14/2023	DAS	Environmental Sys Corp	90535	8816	2026
3	11/14/2023	Elevation	Elevation	None	1	None
4	11/14/2023	Filter pack flow pump	Thomas	none	107CAB18	Illegible
5	11/14/2023	flow rate	Tylan	none	FC280SAV	AW02213004
6	11/14/2023	Infrastructure	Infrastructure	none	none	none
7	11/14/2023	Met tower	Rohn	none	unknown	none
8	11/14/2023	MFC power supply	Tylan	00042	RO-32	FP902022
9	11/14/2023	Ozone	ThermoElectron Inc	none	49i A3NAA	1152780007
10	11/14/2023	Ozone Standard	ThermoElectron Inc	90567	49C	49C-59283-322
11	11/14/2023	Sample Tower	Aluma Tower	923314	B	AT-5324-F6-O
12	11/14/2023	Shelter Temperature	ARS	none	unknown	none
13	11/14/2023	Siting Criteria	Siting Criteria	None	1	None
14	11/14/2023	Temperature2meter	RM Young	none	41342VC	029458
15	11/14/2023	Zero air pump	Twin Tower Engineering	none	TT70/4E	526292

DAS Data Form

DAS Time Max Error: 0.67

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2026	LAV410	Martin Valvur	11/14/2023	DAS	Primary

Das Date:	11/14/2023	Audit Date:	11/14/2023
Das Time:	9:01:20	Audit Time:	9:02:00
Das Day:	318	Audit Day:	318
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	



Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW02213004		LAV410	Martin Valvur	11/14/2023	flow rate	none

Mfg	Tylan	
SN/Owner ID	FP902022	00042
Parameter:	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	152253	Tfer Desc.	BIOS 220-H
Tfer ID	15225		
Slope	1.00000	Intercept	0.00000
Cert Date	5/2/2022	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.41
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
1.28%	1.60%		
		Cal Factor Full Scale	10.42
		Rotometer Reading:	2

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.30	0.0000	0.14	l/m	l/m	
primary	leak check	0.000	0.000	-0.29	0.0000	0.16	l/m	l/m	
primary	test pt 1	3.067	3.070	2.56	0.0000	3.02	l/m	l/m	-1.60%
primary	test pt 2	3.063	3.060	2.57	0.0000	3.02	l/m	l/m	-1.27%
primary	test pt 3	3.053	3.050	2.57	0.0000	3.02	l/m	l/m	-0.98%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	165 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1152780007

LAV410

Martin Valvur

11/14/2023

Ozone

none

Slope:

0.97678

Slope:

0.00000

Intercept

0.41499

Intercept

0.00000

CorrCoff:

0.99998

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

CM23147126

Tfer Desc.

Ozone primary stan

Tfer ID

01116

Slope

1.00654

Intercept

-0.03885

Cert Date

9/19/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.24	-0.19	0.53	ppb		0.72	
primary	2	14.36	14.25	14.42	ppb		0.17	
primary	3	34.09	33.78	32.97	ppb	-2.43		
primary	4	63.60	62.99	61.79	ppb	-1.92		
primary	5	114.03	112.90	110.90	ppb	-1.79		
Sensor Component	Audit Pressure		Condition	611.5 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	Not tested		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	6.8 m		Status	Fail	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.1		Status	pass	
Sensor Component	Span		Condition	1.008		Status	pass	
Sensor Component	Zero Voltage		Condition	-0.0001		Status	pass	
Sensor Component	Fullscale Voltage		Condition	1.0002		Status	pass	
Sensor Component	Cell A Freq.		Condition	87.5 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	1.0 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.64 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	606.0 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	37.3 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	76.6 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	1.0 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.66 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	605.3 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# 2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	029458		LAV410	Martin Valvur	11/14/2023	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

0.22	0.33		
------	------	--	--

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.25	0.25	0.0000	0.34C		0.09
primary	Temp Mid Range	21.71	21.71	0.0000	21.96C		0.25
primary	Temp High Rang	46.91	46.91	0.0000	47.24C		0.33

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		LAV410	Martin Valvur	11/14/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.59	0.62		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.67	23.67	0.000	23.1	C	-0.55
primary	Temp Mid Range	24.39	24.39	0.000	23.8	C	-0.62
primary	Temp Mid Range	25.71	25.71	0.000	25.1	C	-0.59
Sensor Component	System Memo			Condition		Status	pass

Infrastructure Data For

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/14/2023

Shelter Make

Shelter Model

Shelter Size

1150 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	Good	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition	25 m	Status	Fail
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

**1 Parameter:** SiteOpsProcedures

The ozone inlet filter is changed and the sample line conditioned every two weeks or as needed.

**2 Parameter:** SitingCriteriaCom

The site is located at the end of a park service facility parking lot, in a fire station. The tree line is near the building, but the prevailing wind direction is from the clearing. Tree height above the sample inlet is not twice as far away as it is high above the inlet.

**3 Parameter:** ShelterCleanNotes

The inside equipment is located in room within the fire station, clean, neat, and organized.

**4 Parameter:** PollAnalyzerCom

Trees violate the ozone sample inlet siting criteria.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	LAV410	Technician	Martin Valvur	Site Visit Date	11/14/2023
Site Sponsor (agency)	NPS	USGS Map	Manzanita Lake		
Operating Group	NPS	Map Scale			
AQS #	06-065-1004	Map Date			
Meteorological Type	Climatronics				
Air Pollutant Analyzer	Ozone, IMPROVE	QAPP Latitude	40.5403		
Deposition Measurement	dry, wet	QAPP Longitude	-121.5764		
Land Use	woodland - evergreen	QAPP Elevation Meters	1756		
Terrain	complex	QAPP Declination			
Conforms to MLM	Marginally	QAPP Declination Date			
Site Telephone	(530) 335-7214	Audit Latitude	40.539991		
Site Address 1	38050 Hwy 36E	Audit Longitude	-121.576462		
Site Address 2		Audit Elevation	1755		
County	Shasta	Audit Declination	14.5		
City, State	Mineral, CA				
Zip Code	96063	Fire Extinguisher	<input checked="" type="checkbox"/> Present	Inspected Oct 2023	
Time Zone	Pacific	First Aid Kit	<input checked="" type="checkbox"/>		
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make		Model	
				Shelter Size	1150 cuft
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The inside equipment is located in room within the fire station, clean, neat, and organized.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Redding take route 44 east for approximately 45 miles. At the park, and intersection of 44 and 89, turn right onto route 89. Turn right at the first road into the fire station and maintenance area. Take the first left, the site is behind the fire station at the end of the parking lot. One room in the fire station houses the climate controlled equipment.				



Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/14/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/14/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site IDLAV410

TechnicianMartin Valvur

Site Visit Date11/14/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input type="checkbox"/>	< 10 meters

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 10 meters
4	Describe dry dep sample tube.		3/8 teflon by 10 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Trees violate the ozone sample inlet siting criteria.

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/14/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>						
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>						
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only					
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>						
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>						
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>						
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>						
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>						
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded						
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
10	Is the sample tower stable and grounded?	<table><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>			
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>						
11	Tower comments?							

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/14/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	DataView2	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	July 2012	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/14/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Informal training provided by ARS during maintenance visits, and trained by previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Not performed		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	Not performed		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Alarm values only		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Dataview

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone inlet filter is changed and the sample line conditioned every two weeks or as needed.

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/14/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed between 11:00 and 13:00
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, dataview
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

LAV410

Technician

Martin Valvur

Site Visit Date

11/14/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	EliteBook	CNU3389G02	none
DAS	Environmental Sys Corp	8816	2026	90535
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	Illegible	none
flow rate	Tylan	FC280SAV	AW02213004	none
Infrastructure	Infrastructure	none	none	none
Met tower	Rohn	unknown	none	none
MFC power supply	Tylan	RO-32	FP902022	00042
Ozone	ThermoElectron Inc	49i A3NAA	1152780007	none
Ozone Standard	ThermoElectron Inc	49C	49C-59283-322	90567
Sample Tower	Aluma Tower	B	AT-5324-F6-O	923314
Shelter Temperature	ARS	unknown	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342VC	029458	none
Zero air pump	Twin Tower Engineering	TT70/4E	526292	none



# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
BFT142-Eric Hebert-11/15/2023						
1	11/15/2023	Computer	Dell	07212	Inspiron 15	Unknown
2	11/15/2023	DAS	Campbell	000498	CR3000	3815
3	11/15/2023	Elevation	Elevation	None	1	None
4	11/15/2023	Filter pack flow pump	Thomas	04279	107CA18	129800010158
5	11/15/2023	Flow Rate	Apex	000593	AXMC105LPMDPCV	illegible
6	11/15/2023	Infrastructure	Infrastructure	none	none	none
7	11/15/2023	Modem	Digi	07135	LR54	Illegible
8	11/15/2023	Ozone	ThermoElectron Inc	000746	49i A1NAA	1105347315
9	11/15/2023	Ozone Standard	ThermoElectron Inc	000330	49i A3NAA	0622717854
10	11/15/2023	Sample Tower	Aluma Tower	000863	B	unknown
11	11/15/2023	Shelter Temperature	Campbell	none	107-L	none
12	11/15/2023	Siting Criteria	Siting Criteria	None	1	None
13	11/15/2023	Temperature	RM Young	04444	41342VO	4542
14	11/15/2023	Zero air pump	Werther International	07291	C 120/TC	001071024

DAS Data Form

DAS Time Max Error: 0.02

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	3815	BFT142	Eric Hebert	11/15/2023	DAS	Primary

Das Date:	11/15/2023	Audit Date	11/15/2023
Das Time:	9:22:15	Audit Time	9:22:14
Das Day:	319	Audit Day	319
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	4000392	Tfer Desc.	Source generator (D
Tfer ID	01321		
Slope	1.00000	Intercept	0.00000
Cert Date	1/22/2015	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	86590148	Tfer Desc.	DVM
Tfer ID	01310		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible	BFT142	Eric Hebert	11/15/2023	Flow Rate	000593

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	-0.01
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.00%	0.00%		
		Cal Factor Full Scale	0.99
		Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	-0.01	l/m	l/m	
primary	test pt 1	1.502	1.500	1.51	0.000	1.50	l/m	l/m	0.00%
primary	test pt 2	1.502	1.500	1.51	0.000	1.50	l/m	l/m	0.00%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347315

BFT142

Eric Hebert

11/15/2023

Ozone

000746

Slope:

0.97877

Slope:

0.00000

Intercept

-0.06249

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180930075

Tfer Desc.

Ozone primary stan

Tfer ID

01115

Slope

1.00450

Intercept

-0.25270

Cert Date

4/24/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.00	0.28	0.28	ppb		0	
primary	2	16.54	16.69	16.25	ppb		-0.44	
primary	3	36.27	36.27	35.40	ppb	-2.43		
primary	4	66.86	66.62	65.09	ppb	-2.32		
primary	5	117.54	116.90	114.40	ppb	-2.16		

Sensor Component

Audit Pressure

Condition

755 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Moderately clean

Status

pass

Sensor Component

Offset

Condition

-0.20

Status

pass

Sensor Component

Span

Condition

0.989

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

89.9 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

Not tested

Status

pass

Sensor Component

Cell A Flow

Condition

0.70 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

701.8 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

31.6 C

Status

pass

Sensor Component

Cell B Freq.

Condition

114.3 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

Not tested

Status

pass

Sensor Component

Cell B Flow

Condition

0.69 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

702.1 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

True

Status

pass

Sensor Component

System Memo

Condition

Status

pass

# Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4542		BFT142	Eric Hebert	11/15/2023	Temperature	04444

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature		
		Serial Number	H232734	Tfer Desc.	RTD		
		Tfer ID	01227				
		Slope	1.00945	Intercept	0.16485		
		Cert Date	2/17/2023	CorrCoff	1.00000		
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err				

0.41	0.70		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.24	0.07	0.000	0.2	C	0.16	
primary	Temp Mid Range	24.51	24.12	0.000	24.5	C	0.38	
primary	Temp High Range	46.76	46.16	0.000	46.9	C	0.7	

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		BFT142	Eric Hebert	11/15/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.17	0.28		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00945	Intercept	0.16485
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	21.00	20.64	0.000	20.9	C	0.28	
primary	Temp Mid Range	20.95	20.59	0.000	20.7	C	0.13	
primary	Temp Mid Range	21.27	20.91	0.000	21.0	C	0.11	
Sensor Component	System Memo			Condition		Status	pass	

Infrastructure Data For

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

11/15/2023

Shelter Make	Shelter Model	Shelter Size
Ekto	8810	640 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Poor	Status	Fail
Sensor Component	Shelter Roof	Condition	Fair	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Shelter walls	Condition	Poor	Status	Fail
Sensor Component	Excessive mold present	Condition	Poor	Status	Fail
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass



## Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	BFT142	Eric Hebert	11/15/2023	Moisture Present	Apex	4169	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								

# Field Systems Comments

**1 Parameter:** SiteOpsProcComm

The SSRF forms are not completed on the day of filter installation. The logbook entries are not up to date.

**2 Parameter:** DasComments

The new sample tower is not attached to the shelter. The sample tower is not grounded.

**3 Parameter:** SitingCriteriaCom

The site is surrounded by a corn/soy bean field, within a large-scale commercial agriculture operation.

**4 Parameter:** ShelterCleanNotes

One shelter light is functioning properly. The shelter is in poor condition due to being flooded during hurricanes. The floor has been repaired.

**5 Parameter:** MetOpMaintCom

The meteorological tower has been removed and the temperature sensor is installed in a naturally aspirated shield on the sample tower.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

11/15/2023

Site Sponsor (agency)	EPA	USGS Map	Williston
Operating Group	UNC-IMS	Map Scale	
AQS #	37-031-9991	Map Date	
Meteorological Type	R.M. Young		
Air Pollutant Analyzer	Ozone	QAPP Latitude	
Deposition Measurement	dry, wet	QAPP Longitude	
Land Use	agriculture	QAPP Elevation Meters	
Terrain	flat	QAPP Declination	
Conforms to MLM	Yes	QAPP Declination Date	
Site Telephone		Audit Latitude	34.884668
Site Address 1	Open Grounds Farm	Audit Longitude	-76.620666
Site Address 2	100 Nelson Bay Rd.	Audit Elevation	5.3
County	Carteret	Audit Declination	-9.9
City, State	Beaufort, NC		
Zip Code	28516	Fire Extinguisher	<input checked="" type="checkbox"/> Present New in 2015
Time Zone	Eastern	First Aid Kit	<input checked="" type="checkbox"/> 
Primary Operator		Safety Glasses	<input checked="" type="checkbox"/> 
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/> 
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/> 
Backup Operator		Security Fence	<input type="checkbox"/> 
Backup Op. Phone #		Secure Shelter	<input type="checkbox"/> 
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/> 

Shelter Working Room	<input checked="" type="checkbox"/>	Make	Ekto	Model	8810	Shelter Size	640 cuft
Shelter Clean	<input checked="" type="checkbox"/>	Notes	One shelter light is functioning properly. The shelter is in poor condition due to being flooded during hurricanes. The floor has been repaired.				
Site OK	<input checked="" type="checkbox"/>	Notes					

Driving Directions

From I-95 take highway 70 east through Morehead City and over the bridge. Continue through Beaufort staying on route 70 east. At East Carteret High School, route 70 turns to the right at a traffic light. Continue straight through the light on Merrimon Rd. (SR 1300), do not follow 70 to the right. Open Grounds Farm will be on the right approximately 6 miles on Merrimon Rd. Sign in at the guard house. Continue on the dirt road into the farm. Turn left at the first dirt road. The site will be visible in the corner of the field. Follow the dirt road around the field to the site.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

11/15/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

11/15/2023

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological tower has been removed and the temperature sensor is installed in a naturally aspirated shield on the sample tower.

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

11/15/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 10 meters
4	Describe dry dep sample tube.		3/8 teflon by 10 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

11/15/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Temperature only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	Met tower removed.										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The new sample tower is not attached to the shelter. The sample tower is not grounded.

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

11/15/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	2019	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	2019	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	2019	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☒
- 2

Are the Site Status Report Forms being completed and current?

☒
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☐
- Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

11/15/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BFT142

Technician

Eric Hebert

Site Visit Date

11/15/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The SSRF forms are not competed on the day of filter installation. The logbook entries are not up to date.

**F-02058-1500-S10-rev002**

**Site Visit Date** 11/15/2023

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07212
DAS	Campbell	CR3000	3815	000498
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	129800010158	04279
Flow Rate	Apex	AXMC105LPMDPC	illegible	000593
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07135
Ozone	ThermoElectron Inc	49i A1NAA	1105347315	000746
Ozone Standard	ThermoElectron Inc	49i A3NAA	0622717854	000330
Sample Tower	Aluma Tower	B	unknown	000863
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	4542	04444
Zero air pump	Werther International	C 120/TC	001071024	07291

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
DEV412-Martin Valvur-11/20/2023					
1 11/20/2023	Computer	panasonic	none	CF-53	2ULCUTM
2 11/20/2023	DAS	Environmental Sys Corp	None	8864	C2950
3 11/20/2023	Met tower	Glen Martin Engineering	none	unknown	none
4 11/20/2023	Modem	Hughesnet	none	HN9000	unknown
5 11/20/2023	Ozone	ThermoElectron Inc	none	49i A3NAA	1201557776
6 11/20/2023	Ozone Standard	ThermoElectron Inc	90716	49CPS	66830-354
7 11/20/2023	Sample Tower	Aluma Tower	none	FOT-10	218298EE3
8 11/20/2023	Shelter Temperature	ARS	none	unknown	none
9 11/20/2023	Temperature	Vaisala	none	HMP45AC	F0940121
10 11/20/2023	Zero air pump	Werther International	none	C 70/4	000915005

DAS Data Form

DAS Time Max Error: 3.97

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	C2950	DEV412	Martin Valvur	11/20/2023	DAS	Primary

Das Date:	11/20/2023	Audit Date:	11/20/2023
Das Time:	9:09:58	Audit Time:	9:06:00
Das Day:	324	Audit Day:	324
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1201557776

DEV412

Martin Valvur

11/20/2023

Ozone

none

Slope:

1.00126

Slope:

0.00000

Intercept

-1.02788

Intercept

0.00000

CorrCoff:

0.99999

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

CM23147126

Tfer Desc.

Ozone primary stan

Tfer ID

01116

Slope

1.00654

Intercept

-0.03885

Cert Date

9/19/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.08	-0.04	-0.90	ppb		-0.86	
primary	2	14.01	13.90	12.86	ppb		-1.04	
primary	3	33.21	32.91	31.88	ppb	-3.18		
primary	4	63.33	62.72	61.52	ppb	-1.93		
primary	5	113.75	112.63	111.90	ppb	-0.65		
Sensor Component	Audit Pressure		Condition	752 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Not tested		Status	pass	
Sensor Component	Offset		Condition	-0.5		Status	pass	
Sensor Component	Span		Condition	0.999		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	72.0 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.4 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.70 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	746.2 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	30.8 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	125.6 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.9 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.71 lpm		Status	Pass	
Sensor Component	Cell B Pressure		Condition	745.6 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	F0940121		DEV412	Martin Valvur	11/20/2023	Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

0.58	0.83		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	19.43	19.43	0.0000	20.3	C	0.83	
primary	Temp Mid Range	20.27	20.27	0.0000	19.9	C	-0.34	

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Not properly sited	Status	Fail
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		DEV412	Martin Valvur	11/20/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
1.03	1.32		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00002	Intercept	-0.00336
Cert Date	1/23/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	21.98	21.98	0.000	21.1	C	-0.85
primary	Temp Mid Range	21.54	21.54	0.000	20.6	C	-0.93
primary	Temp Mid Range	22.75	22.75	0.000	21.4	C	-1.32
Sensor Component	System Memo		Condition		Status	pass	



# Field Systems Comments

**1   Parameter:**   SiteOpsProcComm

Dry deposition samples are not collected at this site.

**2   Parameter:**   MetSensorComme

The temperature and humidity combination sensor is mounted in a non-aspirated shield on the south side of the tower. The sensor cannot be submerged and therefore was only challenged in air side-by-side with the RTD standard. Audit results are not comparable with other submergible sensors.

**3   Parameter:**   PollAnalyzerCom

The sample tubing is not secured to the sample tower.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	DEV412	Technician	Martin Valvur	Site Visit Date	11/20/2023
Site Sponsor (agency)	NPS	USGS Map			
Operating Group	NPS	Map Scale			
AQS #		Map Date			
Meteorological Type	Climatronics				
Air Pollutant Analyzer		QAPP Latitude			
Deposition Measurement		QAPP Longitude			
Land Use		QAPP Elevation Meters			
Terrain		QAPP Declination			
Conforms to MLM		QAPP Declination Date			
Site Telephone	(760) 786-2497	Audit Latitude	36.508819		
Site Address 1	PO Box 579	Audit Longitude	-116.847697		
Site Address 2	Hwy 190	Audit Elevation	131		
County	Inyo	Audit Declination	13.3		
City, State	Death Valley, CA				
Zip Code	92328	Fire Extinguisher	<input checked="" type="checkbox"/>	Present	New July 2010
Time Zone	Pacific	First Aid Kit	<input type="checkbox"/>		
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make		Model	
Shelter Clean	<input checked="" type="checkbox"/>	Notes			
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Las Vegas take route 160 west to Pahrump. Turn onto 178 to Shoshone. At the stop sign in Shoshone turn right onto route 127 toward Death Valley. In Death Valley Junction, just past the Amargosa Theater, turn left onto Highway 190. Continue to the park. Approximately 3 miles past the Furnace Creek Ranch, turn right at the sign for Cow Creek and the park administratin offices. Take the first left and continue up the hill past the park housing, bearing left and continuing uphill. The site is past the locked gate on the service road to the water supply facilities.				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

DEV412

Technician

Martin Valvur

Site Visit Date

11/20/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input type="checkbox"/>	south
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature and humidity combination sensor is mounted in a non-aspirated shield on the south side of the tower. The sensor cannot be submerged and therefore was only challenged in air side-by-side with the RTD standard. Audit results are not comparable with other submergible sensors.

Site ID

DEV412

Technician

Martin Valvur

Site Visit Date

11/20/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

DEV412

Technician

Martin Valvur

Site Visit Date

11/20/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		N/A
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	N/A
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The sample tubing is not secured to the sample tower.

Site ID

DEV412

Technician

Martin Valvur

Site Visit Date

11/20/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>	
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>	
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>	
6	Are the DAS, sensor translators, and shelter properly grounded?	<input type="checkbox"/>	shelter not grounded
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>	
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>	
9	Is the met tower stable and grounded?	<div><div>Stable</div><div><input checked="" type="checkbox"/></div></div>	<div><div>Grounded</div><div><input checked="" type="checkbox"/></div></div>
10	Is the sample tower stable and grounded?	<div><div><input checked="" type="checkbox"/></div></div>	<div><div><input type="checkbox"/></div></div>
11	Tower comments?	sample tower not grounded	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

DEV412

Technician

Martin Valvur

Site Visit Date

11/20/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	Dataview	<input checked="" type="checkbox"/>
SSRF	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☒
- 2

Are the Site Status Report Forms being completed and current?

☒
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☐

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

DEV412

Technician

Martin Valvur

Site Visit Date

11/20/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

N/A

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

N/A

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

N/A

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>		<input type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Dataview

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



Site ID

DEV412

Technician

Martin Valvur

Site Visit Date

11/20/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	N/A
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	N/A
3	Are data downloads and backups being performed as scheduled?	<input checked="" type="checkbox"/>	N/A
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	Dataview
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	N/A
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	N/A
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	N/A
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Dry deposition samples are not collected at this site.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

DEV412

Technician

Martin Valvur

Site Visit Date

11/20/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	panasonic	CF-53	2ULCUTM	none
DAS	Environmental Sys Corp	8864	C2950	None
Met tower	Glen Martin Engineering	unknown	none	none
Modem	Hughesnet	HN9000	unknown	none
Ozone	ThermoElectron Inc	49i A3NAA	1201557776	none
Ozone Standard	ThermoElectron Inc	49CPS	66830-354	90716
Sample Tower	Aluma Tower	FOT-10	218298EE3	none
Shelter Temperature	ARS	unknown	none	none
Temperature	Vaisala	HMP45AC	F0940121	none
Zero air pump	Werther International	C 70/4	000915005	none

## Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
SAN189-Tim Mendenhall-11/27/2023					
1 11/27/2023	Computer	Dell	07019	Inspiron 15	GK2MC12
2 11/27/2023	DAS	Campbell	000360	CR3000	2138
3 11/27/2023	Elevation	Elevation	None	1	None
4 11/27/2023	Filter pack flow pump	Thomas	06019	107CAB18	050400022576
5 11/27/2023	Flow Rate	Apex	000861	AXMC105LPMDPCV	illegible
6 11/27/2023	Flow Rate	Apex	000527	AXMC105LPMDPCV	48100
7 11/27/2023	Infrastructure	Infrastructure	none	none	none
8 11/27/2023	Modem	Digi	07133	LR54	unknown
9 11/27/2023	Ozone	ThermoElectron Inc	000685	49i A1NAA	1030244789
10 11/27/2023	Ozone Standard	ThermoElectron Inc	000434	49i A3NAA	CM08200010
11 11/27/2023	Sample Tower	Aluma Tower	000207	B	none
12 11/27/2023	Shelter Temperature	Campbell	none	107-L	223461
13 11/27/2023	Temperature	RM Young	06537	41342VC	14798
14 11/27/2023	Zero air pump	Werther International	06875	C 70/4	000814272

DAS Data Form

DAS Time Max Error: 0.03

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2138	SAN189	Tim Mendenhall	11/27/2023	DAS	Primary

Das Date:	11/27/2023	Audit Date	11/27/2023
Das Time:	11:31:02	Audit Time	11:31:04
Das Day:	331	Audit Day	331
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg

Serial Number Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

Apex

48100

SAN189

Tim Mendenhall

11/27/2023

Flow Rate

000527

Mfg

BIOS

Parameter

Flow Rate

Serial Number

148613

Tfer Desc.

BIOS 220-H

Tfer ID

01421

Slope

1.00000

Intercept

0.00000

Cert Date

2/23/2023

CorrCoff

1.00000

DAS 1:

DAS 2:

Cal Factor Zero

0

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

Cal Factor Full Scale

1

0.99%

1.32%

Rotometer Reading:

3.1

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference	
primary	pump off	0.000	0.000	0.00	0.000	0.00	l/m	l/m		
primary	leak check	0.000	0.000	0.02	0.000	0.03	l/m	l/m		
primary	test pt 1	3.011	3.010	2.99	0.000	3.00	l/m	l/m	-0.33%	
primary	test pt 2	3.039	3.040	2.99	0.000	3.00	l/m	l/m	-1.32%	
primary	test pt 3	3.040	3.040	2.99	0.000	3.00	l/m	l/m	-1.32%	

Sensor Component

Leak Test

Condition

Status

pass

Sensor Component

Tubing Condition

Condition

Good

Status

pass

Sensor Component

Filter Position

Condition

Good

Status

pass

Sensor Component

Rotometer Condition

Condition

Clean and dry

Status

pass

Sensor Component

Moisture Present

Condition

No moisture present

Status

pass

Sensor Component

Filter Distance

Condition

3.0 cm

Status

pass

Sensor Component

Filter Depth

Condition

4.0 cm

Status

pass

Sensor Component

Filter Azimuth

Condition

270 deg

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Apex

illegible

SAN189

Tim Mendenhall

11/27/2023

Flow Rate

000861

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1030244789

SAN189

Tim Mendenhall

11/27/2023

Ozone

000685

Slope:

1.00318

Slope:

0.00000

Intercept

-0.01756

Intercept

0.00000

CorrCoff:

0.99999

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.49	0.19	0.36	ppb		0.17	
primary	2	16.28	16.02	15.95	ppb		-0.07	
primary	3	35.51	35.30	35.15	ppb	-0.43		
primary	4	65.82	65.69	66.05	ppb	0.55		
primary	5	111.48	111.47	111.80	ppb	0.3		

Sensor Component

Audit Pressure

Condition

724.5 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.5

Status

pass

Sensor Component

Span

Condition

1.052

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

78.4 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.8 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.72 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

698.6 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

34.3 C

Status

pass

Sensor Component

Cell B Freq.

Condition

107.8 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

1.1 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.72 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

698.0 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

False

Status

pass

Sensor Component

System Memo

Condition

Status

pass

# Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14798		SAN189	Tim Mendenhall	11/27/2023	Temperature	06537

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232679	Tfer Desc.	RTD
		Tfer ID	01228		
		Slope	1.01172	Intercept	0.08161
		Cert Date	2/17/2023	CorrCoff	1.00000

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.28	0.50		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.16	0.08	0.000	0.2	C	0.12
primary	Temp Mid Range	25.64	25.26	0.000	25.1	C	-0.21
primary	Temp High Range	42.34	41.77	0.000	41.3	C	-0.5

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	223461		SAN189	Tim Mendenhall	11/27/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.64	0.80		

Mfg	Extech	Parameter	Shelter Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	21.00	20.68	0.000	21.4	C	0.76
primary	Temp Mid Range	26.88	26.49	0.000	25.7	C	-0.8
primary	Temp Mid Range	26.09	25.71	0.000	25.3	C	-0.37
Sensor Component	System Memo			Condition		Status	pass



Infrastructure Data For

Site ID

SAN189

Technician

Tim Mendenhall

Site Visit Date

11/27/2023

Shelter Make

Shelter One

Shelter Model

E8109-26012

Shelter Size

720 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Fair	Status	pass
Sensor Component	Tubing Type	Condition	1/4 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

## Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Temperature	SAN189	Tim Mendenhall	11/27/2023	System Memo	RM Young	2887	<input type="checkbox"/>	<input type="checkbox"/>
The sensor signal cables are showing signs of wear.								

# Field Systems Comments

- 1

Parameter:

DasComments

The met tower is not currently in use and it is somewhat unstable.
- 2

Parameter:

SiteOpsProcedures

The site operator was not available during the audit visit due to illness.
- 3

Parameter:

DocumentationCo

The site operator reported that all instrument manuals are kept at the office.
- 4

Parameter:

ShelterCleanNotes

The shelter is in very good condition.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	SAN189	Technician	Tim Mendenhall	Site Visit Date	11/27/2023
Site Sponsor (agency)	EPA	USGS Map	Santee		
Operating Group	Santee Sioux Nation	Map Scale			
AQS #	31-107-9991	Map Date			
Meteorological Type	R.M. Young				
Air Pollutant Analyzer	Ozone, SO2, NOx, CO	QAPP Latitude			
Deposition Measurement	dry	QAPP Longitude			
Land Use	range	QAPP Elevation Meters	429		
Terrain	rolling	QAPP Declination			
Conforms to MLM	Yes	QAPP Declination Date	6/21/2018		
Site Telephone	(402) 857-2546	Audit Latitude	42.829154		
Site Address 1	SR S54D	Audit Longitude	-97.854128		
Site Address 2	Santee Sioux Indian Reservation	Audit Elevation	434		
County	Knox	Audit Declination	5.0		
City, State	Niobrara, NE				
Zip Code	68760	Fire Extinguisher	Present	<input checked="" type="checkbox"/>	
Time Zone	Central	First Aid Kit	<input checked="" type="checkbox"/>	No inspection date	
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>		
Backup Operator		Security Fence	<input type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Shelter One	Model	E8109-26012
		Shelter Size	720 cuft		
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is in very good condition.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Yankton, South Dakota go south on route 81. Turn right (south) at the intersection of route 12 and continue approximately 26 miles. Just past the casino and gas station, turn right (north) onto SR 54 toward Santee. Continue approximately 6.5 miles. The site will be visible through the farm gate on the left at the top of a hill just before reaching Santee.				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

SAN189

Technician

Tim Mendenhall

Site Visit Date

11/27/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	sensor mounted on south side of tower
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SAN189

Technician

Tim Mendenhall

Site Visit Date

11/27/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Signs of wear
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SAN189

Technician

Tim Mendenhall

Site Visit Date

11/27/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 16 meters
4	Describe dry dep sample tube.		1/4 teflon by 16 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

SAN189

Technician

Tim Mendenhall

Site Visit Date

11/27/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input type="checkbox"/>	Temperature only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input checked="" type="checkbox"/>										
<input checked="" type="checkbox"/>		<input type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	sample tower not grounded										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The met tower is not currently in use and it is somewhat unstable.



Site ID

SAN189

Technician

Tim Mendenhall

Site Visit Date

11/27/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	2018	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	2018	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator reported that all instrument manuals are kept at the office.

Site ID

SAN189

Technician

Tim Mendenhall

Site Visit Date

11/27/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by the previous operator / and DEP staff

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by the current operator

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>		<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>		<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>		<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator was not available during the audit visit due to illness.

Site ID

SAN189

Technician

Tim Mendenhall

Site Visit Date

11/27/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	One set of gloves only
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

SAN189

Technician

Tim Mendenhall

Site Visit Date

11/27/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	GK2MC12	07019
DAS	Campbell	CR3000	2138	000360
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	050400022576	06019
Flow Rate	Apex	AXMC105LPMDPC	48100	000527
Flow Rate	Apex	AXMC105LPMDPC	illegible	000861
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	unknown	07133
Ozone	ThermoElectron Inc	49i A1NAA	1030244789	000685
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200010	000434
Sample Tower	Aluma Tower	B	none	000207
Shelter Temperature	Campbell	107-L	223461	none
Temperature	RM Young	41342VC	14798	06537
Zero air pump	Werther International	C 70/4	000814272	06875

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
KIC003-Tim Mendenhall-11/29/2023						
1	11/29/2023	DAS	Campbell	000816	CR850	28382
2	11/29/2023	Flow Rate	Apex	000668	MC-5SLPM-D	54765
3	11/29/2023	Modem	Sierra wireless	06996	unknown	unknown
4	11/29/2023	Sample Tower	Aluma Tower	000814	B	none
5	11/29/2023	Temperature	RM Young	06112	41342	10176

DAS Data Form

DAS Time Max Error: 0.05

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	28382	KIC003	Tim Mendenhall	11/29/2023	DAS	Primary

Das Date:	11/29/2023	Audit Date	11/29/2023
Das Time:	7:52:25	Audit Time	7:52:28
Das Day:	333	Audit Day	333
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	54765		KIC003	Tim Mendenhall	11/29/2023	Flow Rate	000668

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	-0.012
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
2.28%	2.74%		
Cal Factor Full Scale		0.992	
Rotometer Reading:		0	

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.32	0.000	0.31	l/m	l/m	
primary	test pt 1	2.925	2.920	3.00	0.000	2.99	l/m	l/m	2.40%
primary	test pt 2	2.922	2.920	3.00	0.000	3.00	l/m	l/m	2.74%
primary	test pt 3	2.948	2.950	3.00	0.000	3.00	l/m	l/m	1.69%

Sensor Component	Leak Test	Condition	0.30 lpm	Status	Fail
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Dirty	Status	Fail
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	10176		KIC003	Tim Mendenhall	11/29/2023	Temperature	06112

DAS 1:	DAS 2:	Mfg	Extech	Parameter	Temperature
		Serial Number	H232679	Tfer Desc.	RTD
		Tfer ID	01228		
		Slope	1.01172	Intercept	0.08161
		Cert Date	2/17/2023	CorrCoff	1.00000

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.08	0.21		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.05	-0.03	0.000	0.0	C	-0.01
primary	Temp Mid Range	24.41	24.05	0.000	24.0	C	-0.02
primary	Temp High Range	45.01	44.41	0.000	44.2	C	-0.21

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass



## Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	KIC003	Tim Mendenhall	11/29/2023	Rotometer Condit	Apex	4793	<input type="checkbox"/>	<input type="checkbox"/>
The rotometer ball is stuck and not floating due to either dirt or moisture inside the rotometer.								

# Field Systems Comments

**1   Parameter:**   SiteOpsProcComm

The site operation is currently suspended until funding is available.

**2   Parameter:**   DocumentationCo

Currently there is no logbook provided by WSP but that maybe due to suspension of site operation since July.

**3   Parameter:**   SitingCriteriaCom

The site is located across the street from the community school in the town of Powhattan.

**4   Parameter:**   ShelterCleanNotes

Small footprint site with no shelter.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	KIC003	Technician	Tim Mendenhall	Site Visit Date	11/29/2023		
Site Sponsor (agency)	EPA	USGS Map					
Operating Group	Kickapoo Tribe	Map Scale					
AQS #		Map Date					
Meteorological Type	R.M. Young						
Air Pollutant Analyzer		QAPP Latitude					
Deposition Measurement		QAPP Longitude					
Land Use		QAPP Elevation Meters					
Terrain		QAPP Declination					
Conforms to MLM		QAPP Declination Date					
Site Telephone		Audit Latitude	39.76102				
Site Address 1		Audit Longitude	-95.63599				
Site Address 2		Audit Elevation	367				
County	Brown	Audit Declination					
City, State	Powhattan, KS						
Zip Code	66527	Fire Extinguisher	<input type="checkbox"/> Present				
Time Zone	Central	First Aid Kit	<input checked="" type="checkbox"/>				
Primary Operator		Safety Glasses	<input checked="" type="checkbox"/>				
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>				
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>				
Backup Operator		Security Fence	<input checked="" type="checkbox"/>				
Backup Op. Phone #		Secure Shelter	<input type="checkbox"/>				
Backup Op. E-mail		Stable Entry Steps	<input type="checkbox"/>				
Shelter Working Room	<input type="checkbox"/>	Make		Model		Shelter Size	
Shelter Clean	<input type="checkbox"/>	Notes	Small footprint site with no shelter.				
Site OK	<input checked="" type="checkbox"/>	Notes					
Driving Directions							

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

KIC003

Technician

Tim Mendenhall

Site Visit Date

11/29/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	sensor on south side of tower
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

KIC003

Technician

Tim Mendenhall

Site Visit Date

11/29/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	Moderately clean
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

KIC003

Technician

Tim Mendenhall

Site Visit Date

11/29/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	N/A
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	N/A
3	Describe ozone sample tube.		N/A
4	Describe dry dep sample tube.		3/8 teflon by 10 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	N/A
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	N/A
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	rotometer is stuck at 0.0 lpm

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

KIC003

Technician

Tim Mendenhall

Site Visit Date

11/29/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>	
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>	
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>	
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>	
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>	GFI breaker tripped
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>	N/A
9	Is the met tower stable and grounded?	<div><div>Stable</div><div><input type="checkbox"/></div><div><input checked="" type="checkbox"/></div></div>	<div><div>Grounded</div><div><input type="checkbox"/></div><div><input checked="" type="checkbox"/></div></div>
10	Is the sample tower stable and grounded?		
11	Tower comments?		

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

KIC003

Technician

Tim Mendenhall

Site Visit Date

11/29/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	Not present	<input type="checkbox"/>
SSRF	<input type="checkbox"/>		<input type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2018	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2018	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

- 1

Is the station log properly completed during every site visit?

☐
- 2

Are the Site Status Report Forms being completed and current?

☒
- 3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒
- 4

Are ozone z/s/p control charts properly completed and current?

☒
- 
- 
- N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Currently there is no logbook provided by WSP but that maybe due to suspension of site operation since July.



Site ID

KIC003

Technician

Tim Mendenhall

Site Visit Date

11/29/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

no current site operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☒

N/A

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

N/A

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

KIC003

Technician

Tim Mendenhall

Site Visit Date

11/29/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input type="checkbox"/>	not operational
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operation is currently suspended until funding is available.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

KIC003

Technician

Tim Mendenhall

Site Visit Date

11/29/2023

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR850	28382	000816
Flow Rate	Apex	MC-5SLPM-D	54765	000668
Modem	Sierra wireless	unknown	unknown	06996
Sample Tower	Aluma Tower	B	none	000814
Temperature	RM Young	41342	10176	06112

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
SPD111-Martin Valvur-12/05/2023						
1	12/5/2023	DAS	Campbell	000405	CR3000	2622
2	12/5/2023	Ozone	ThermoElectron Inc	000615	49i A1NAA	1009241787
3	12/5/2023	Ozone Standard	ThermoElectron Inc	000435	49i A3NAA	CM08200011
4	12/5/2023	Zero air pump	Werther International	06912	C 70/4	000829177

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241787

SPD111

Martin Valvur

12/05/2023

Ozone

000615

Slope:

0.99728

Slope:

0.00000

Intercept

-0.63396

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

CM23147126

Tfer Desc.

Ozone primary stan

Tfer ID

01116

Slope

1.00654

Intercept

-0.03885

Cert Date

9/19/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.25	0.34	-0.34	ppb		-0.68	
primary	2	14.14	14.05	13.45	ppb		-0.6	
primary	3	34.11	33.76	33.22	ppb	-1.61		
primary	4	62.01	61.29	60.16	ppb	-1.86		
primary	5	112.41	111.02	110.20	ppb	-0.74		
Sensor Component	Audit Pressure		Condition	722 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.1		Status	pass	
Sensor Component	Span		Condition	1.002		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	93.9 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	1.0 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.69 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	705.4 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	30.8 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	91.0 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.8 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.70 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	705.1 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
SND152-Martin Valvur-12/06/2023						
1	12/6/2023	DAS	Campbell	000357	CR3000	2135
2	12/6/2023	Ozone	ThermoElectron Inc	000743	49i A1NAA	1105347321
3	12/6/2023	Ozone Standard	ThermoElectron Inc	000704	49i A3NAA	1030244816
4	12/6/2023	Zero air pump	Werther International	06878	C 70/4	000815254

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347321

SND152

Martin Valvur

12/06/2023

Ozone

000743

Slope:

1.02085

Slope:

0.00000

Intercept

-0.74215

Intercept

0.00000

CorrCoff:

0.99996

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

CM23147126

Tfer Desc.

Ozone primary stan

Tfer ID

01116

Slope

1.00654

Intercept

-0.03885

Cert Date

9/19/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.06	0.15	-0.25	ppb		-0.4	
primary	2	14.87	14.77	13.69	ppb		-1.08	
primary	3	32.83	32.49	32.56	ppb	0.22		
primary	4	61.74	61.02	61.83	ppb	1.32		
primary	5	112.62	111.23	112.70	ppb	1.31		

Sensor Component

Audit Pressure

Condition

730 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.5

Status

pass

Sensor Component

Span

Condition

1.034

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

96.2 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

0.4 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.65 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

708.8 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

35.2 C

Status

pass

Sensor Component

Cell B Freq.

Condition

91.8 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.6 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.66 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

708.5 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

True

Status

pass

Sensor Component

System Memo

Condition

Status

pass

# Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
CND125-Eric Hebert-12/22/2023						
1	12/22/2023	Computer	Dell	07015	Inspiron 15	BQ3MC12
2	12/22/2023	DAS	Campbell	000499	CR3000	3816
3	12/22/2023	Elevation	Elevation	None	1	None
4	12/22/2023	Filter pack flow pump	Thomas	01235	107CA18	illegible
5	12/22/2023	Flow Rate	Apex	000859	AXMC105LPMDPCV	illegible
6	12/22/2023	Infrastructure	Infrastructure	none	none	none
7	12/22/2023	Modem	Digi	07122	LR54	Illegible
8	12/22/2023	Ozone	ThermoElectron Inc	000614	49i A1NAA	1009241794
9	12/22/2023	Ozone Standard	ThermoElectron Inc	000376	49i A3NAA	0726124693
10	12/22/2023	Sample Tower	Aluma Tower	03495	A	none
11	12/22/2023	Shelter Temperature	Campbell	none	107-L	none
12	12/22/2023	Siting Criteria	Siting Criteria	None	1	None
13	12/22/2023	Temperature	RM Young	06402	41342VC	14035
14	12/22/2023	Zero air pump	Werther International	06868	C 70/4	000814284



DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	3816	CND125	Eric Hebert	12/22/2023	DAS	Primary

Das Date:	12/22/2023	Audit Date:	12/22/2023
Das Time:	10:07:00	Audit Time:	10:07:00
Das Day:	356	Audit Day:	356
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Datel	Parameter	DAS
Serial Number	15510194	Tfer Desc.	Source generator (D
Tfer ID	01320		
Slope	1.00000	Intercept	0.00000
Cert Date	2/13/2012	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740135	Tfer Desc.	DVM
Tfer ID	01311		
Slope	1.00000	Intercept	0.00000
Cert Date	1/25/2023	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		CND125	Eric Hebert	12/22/2023	Flow Rate	000859

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00000	Intercept	0.00000
Cert Date	2/23/2023	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.01
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	0.98
4.26%	4.46%	Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	-0.04	0.000	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	-0.02	0.000	-0.18	l/m	l/m	
primary	test pt 1	1.566	1.570	1.54	0.000	1.50	l/m	l/m	-4.46%
primary	test pt 2	1.565	1.560	1.54	0.000	1.50	l/m	l/m	-3.85%
primary	test pt 3	1.566	1.570	1.54	0.000	1.50	l/m	l/m	-4.46%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	100 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1009241794

CND125

Eric Hebert

12/22/2023

Ozone

000614

Slope:

1.01683

Slope:

0.00000

Intercept

-0.04086

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.46	0.16	0.23	ppb		0.07	
primary	2	15.72	15.46	15.58	ppb		0.12	
primary	3	37.15	36.94	37.39	ppb	1.21		
primary	4	68.87	68.74	70.03	ppb	1.86		
primary	5	108.29	108.27	110.00	ppb	1.59		
Sensor Component	Audit Pressure		Condition	753.7 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further t		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than 5		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Dirty		Status	Fail	
Sensor Component	Offset		Condition	-0.20		Status	pass	
Sensor Component	Span		Condition	1.038		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	107.8 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	1.0 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.72 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	722.2 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	36.5 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	94.6 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.8 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.71 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	721.6 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	True		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

# Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14035		CND125	Eric Hebert	12/22/2023	Temperature	06402

Mfg

Extech

Parameter

Temperature

Serial Number

H232679

Tfer Desc.

RTD

Tfer ID

01228

Slope

1.01172

Intercept

0.08161

Cert Date

2/17/2023

CorrCoff

1.00000

DAS 1:

Abs Avg Err

0.04

Abs Max Err

0.05

DAS 2:

Abs Avg Err

Abs Max Err

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.23	0.15	0.000	0.2	C	0.05	
primary	Temp Mid Range	21.97	21.63	0.000	21.7	C	0.03	
primary	Temp High Range	46.85	46.23	0.000	46.2	C	-0.03	

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Shelter Temperature Data For

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none		CND125	Eric Hebert	12/22/2023	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.12	0.23		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.01172	Intercept	0.08161
Cert Date	2/17/2023	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	27.51	27.11	0.000	27.0	C	-0.07	
primary	Temp Mid Range	29.18	28.76	0.000	28.5	C	-0.23	
primary	Temp Mid Range	28.51	28.10	0.000	28.1	C	-0.05	
Sensor Component		System Memo		Condition		Status	pass	

Infrastructure Data For

Site ID

CND125

Technician

Eric Hebert

Site Visit Date

12/22/2023

Shelter Make	Shelter Model	Shelter Size
Ekto	8810	640 cuft

Sensor Component	Sample Tower Type	Condition	Type A	Status	pass
Sensor Component	Conduit	Condition	N/A	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Fair	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Fair	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

# Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

# Field Systems Comments

**1   Parameter:**   SitingCriteriaCom

The land owner maintains a pine tree forest on the property within 50 meters of the site. The trees were planted just before the site was installed in 1990 and may or may not be harvested in the future.

**2   Parameter:**   ShelterCleanNotes

The shelter is well clean and well organized. There are signs of insect infestation on floor.

**3   Parameter:**   PollAnalyzerCom

Ozone sample train has inline dryer.

**4   Parameter:**   MetOpMaintCom

The temperature sensor is mounted on the sample tower in a naturally aspirated shield.



# Field Systems Data Form

F-02058-1500-S1-rev002

Site ID CND125 Technician Eric Hebert Site Visit Date 12/22/2023

Site Sponsor (agency)	EPA	USGS Map	
Operating Group	private	Map Scale	
AQS #	37-123-9991	Map Date	
Meteorological Type	Claytronic		
Air Pollutant Analyzer	Ozone	QAPP Latitude	
Deposition Measurement	dry, Hg, PM2.5, PM10	QAPP Longitude	
Land Use	woodland	QAPP Elevation Meters	
Terrain	rolling	QAPP Declination	
Conforms to MLM	Marginally	QAPP Declination Date	
Site Telephone		Audit Latitude	35.26333
Site Address 1	136 Perry Drive	Audit Longitude	-79.83754
Site Address 2		Audit Elevation	172
County	Montgomery	Audit Declination	-8
City, State	Candor, NC		
Zip Code	27229	Fire Extinguisher <input checked="" type="checkbox"/>	New in 2015
Time Zone	Eastern	First Aid Kit <input checked="" type="checkbox"/>	
Primary Operator		Safety Glasses <input checked="" type="checkbox"/>	
Primary Op. Phone #		Safety Hard Hat <input checked="" type="checkbox"/>	
Primary Op. E-mail		Climbing Belt <input type="checkbox"/>	
Backup Operator		Security Fence <input type="checkbox"/>	
Backup Op. Phone #		Secure Shelter <input checked="" type="checkbox"/>	
Backup Op. E-mail		Stable Entry Step <input checked="" type="checkbox"/>	
Shelter Working Room <input checked="" type="checkbox"/>	Make Ekto	Model 8810	Shelter Size 640 cuft
Shelter Clean <input checked="" type="checkbox"/>	Notes	The shelter is well clean and well organized. There are signs of insect infestation on floor.	
Site OK <input checked="" type="checkbox"/>	Notes		

**Driving Directions** From Greensboro take Hwy 220 (future I-73) south to Candor. Exit at 211 west to Candor. At the traffic light turn left (south) onto 220 south and 731 west. Continue approximately 1.3 miles which will take you out of town. Bear right onto 731 west at the split. Take an immediate right onto McCallum Rd. (there is a sign for E-KU-SUMEE at the intersection). Continue approximately 5.4 miles to Perry Drive which is on the left. Turn left onto the gravel road and follow it to the end. The site is behind the house, drive around the grapevines on the left.

Site ID

CND125

Technician

Eric Hebert

Site Visit Date

12/22/2023

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CND125

Technician

Eric Hebert

Site Visit Date

12/22/2023

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	N/A
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature sensor is mounted on the sample tower in a naturally aspirated shield.

Site ID

CND125

Technician

Eric Hebert

Site Visit Date

12/22/2023

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Ozone sample train has inline dryer.

Site ID

CND125

Technician

Eric Hebert

Site Visit Date

12/22/2023

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Temperature only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?											

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CND125

Technician

Eric Hebert

Site Visit Date

12/22/2023

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	May 2019	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CND125

Technician

Eric Hebert

Site Visit Date

12/22/2023

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CND125

Technician

Eric Hebert

Site Visit Date

12/22/2023

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:



**F-02058-1500-S10-rev002**

**Site Visit Date** 12/22/2023

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	BQ3MC12	07015
DAS	Campbell	CR3000	3816	000499
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	illegible	01235
Flow Rate	Apex	AXMC105LPMDPC	illegible	000859
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07122
Ozone	ThermoElectron Inc	49i A1NAA	1009241794	000614
Ozone Standard	ThermoElectron Inc	49i A3NAA	0726124693	000376
Sample Tower	Aluma Tower	A	none	03495
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VC	14035	06402
Zero air pump	Werther International	C 70/4	000814284	06868

# Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
COW137-Eric Hebert-12/26/2023						
1	12/26/2023	DAS	Campbell	000401	CR3000	2529
2	12/26/2023	Ozone	ThermoElectron Inc	000684	49i A1NAA	103244795
3	12/26/2023	Ozone Standard	ThermoElectron Inc	000441	49i A3NAA	CM08200017
4	12/26/2023	Zero air pump	Werther International	06940	C 70/4	000821897

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

103244795

COW137

Eric Hebert

12/26/2023

Ozone

000684

Slope:

0.97363

Slope:

0.00000

Intercept

-0.54646

Intercept

0.00000

CorrCoff:

1.00000

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

1180030022

Tfer Desc.

Ozone primary stan

Tfer ID

01114

Slope

0.99730

Intercept

0.29920

Cert Date

4/25/2023

CorrCoff

1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.36	0.06	-0.54	ppb		-0.6	
primary	2	14.96	14.69	13.74	ppb		-0.95	
primary	3	35.95	35.74	34.44	ppb	-3.7		
primary	4	70.08	69.96	67.40	ppb	-3.73		
primary	5	110.43	110.41	107.00	ppb	-3.14		

Sensor Component

Audit Pressure

Condition

678.4 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

True

Status

pass

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.30

Status

pass

Sensor Component

Span

Condition

1.015

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

101.6 kHz

Status

pass

Sensor Component

Cell A Noise

Condition

Not tested

Status

pass

Sensor Component

Cell A Flow

Condition

0.68 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

637.4 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

33.4 C

Status

pass

Sensor Component

Cell B Freq.

Condition

95.2 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

Not tested

Status

pass

Sensor Component

Cell B Flow

Condition

0.67 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

638.0 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

True

Status

pass

Sensor Component

System Memo

Condition

Status

pass

---

## **APPENDIX B**

### **CASTNET Site Spot Report Forms**

---

# EEMS Spot Report

Data Compiled: 11/5/2023 19:04:30

Site	Visit Date	Technician
ANA115	10/20/2023	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99806	unitless	P
2	Ozone Intercept	P	0	5	4	-0.18415	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	0.7	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.12	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.13	ppb	P

# EEMS Spot Report

Data Compiled: 1/16/2024 11:28:00 AM

Site	Visit Date	Technician
BAS601	11/09/2023	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97330	unitless	P
2	Ozone Intercept	P	0	5	4	-1.05805	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99991	unitless	P
4	Ozone % difference avg	P	7	10	4	5.4	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.91	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-1.25	ppb	P

# EEMS Spot Report

Data Compiled: 1/15/2024 6:12:10 PM

SiteVisitDate	Site	Technician
11/15/2023	BFT142	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	18	0.41	c	P
2	Temperature max error	P	4	0.5	18	0.70	c	Fail
3	Ozone Slope	P	0	1.1	4	0.97877	unitless	P
4	Ozone Intercept	P	0	5	4	-0.06249	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	2.4	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.00	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.44	ppb	P
9	Flow Rate average % difference	P	10	5	5	0.00	%	P
10	Flow Rate max % difference	P	10	5	5	0.00	%	P
11	DAS Voltage average error	P	4	0.003	13	0.0000	V	P
12	Shelter Temperature average error	P	5	2	24	0.17	c	P
13	Shelter Temperature max error	P	5	2	24	0.28	c	P

## Field Performance Comments

- 1

Parameter:

Flow Rate

SensorComponent:

Moisture Present

CommentCode:

72
- The filter sample tubing has drops of moisture in low sections outside the shelter.

## Field Systems Comments

- 1

Parameter:

SiteOpsProcComm
- The SSRF forms are not completed on the day of filter installation. The logbook entries are not up to date.
- 2

Parameter:

DasComments
- The new sample tower is not attached to the shelter. The sample tower is not grounded.
- 3

Parameter:

SitingCriteriaCom
- The site is surrounded by a corn/soy bean field, within a large-scale commercial agriculture operation.
- 4

Parameter:

ShelterCleanNotes
- One shelter light is functioning properly. The shelter is in poor condition due to being flooded during hurricanes. The floor has been repaired.
- 5

Parameter:

MetOpMaintCom
- The meteorological tower has been removed and the temperature sensor is installed in a naturally aspirated shield on the sample tower.



# EEMS Spot Report

Data Compiled: 1/12/2024 12:03:32 PM

Site	Visit Date	Technician
BUF603	11/07/2023	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.28	c	P
2	Temperature2meter max error	P	5	0.5	3	0.42	c	P
3	Flow Rate average % difference	P	10	5	9	1.24	%	P
4	Flow Rate max % difference	P	10	5	9	1.35	%	P
5	DAS Voltage average error	P	4	0.003	1	0.0000	V	P

SiteVisitDate	Site	Technician
11/07/2023	BUF603	Tim Mendenhall

## Field Systems Comments

- 1 **Parameter:** SiteOpsProcComm  
The site operator does not use gloves, however, he uses the filter bag when handling the filter.
- 2 **Parameter:** DasComments  
The NEMA enclosure has a cooling fan.
- 3 **Parameter:** DocumentationCo  
A disc with the current QAPP has been received and is kept at the site operator's office. The site operator completes and files a hardcopy checklist and logbook developed by ARS for BLM each week.
- 4 **Parameter:** ShelterCleanNotes  
NEMA enclosure, 120 VAC power
- 5 **Parameter:** PollAnalyzerCom  
The dry deposition filter pack enclosure is not the standard "pot" size that is used at the other CASTNET sites. The diameter of the enclosure is much smaller and the filter is mounted much deeper inside the opening. The geometry of the filter pack and enclosure is likely to impact particle collection efficiency.
- 6 **Parameter:** MetSensorComme  
The temperature is measured at 2.5 meters above the ground. The top section of the tower is not perfectly plumb and guy wire tension could be applied to improve position.
- 7 **Parameter:** MetOpMaintCom  
Some signal cables are showing signs of wear.

# EEMS Spot Report

Data Compiled: 11/5/2023 20:03:18

SiteVisitDate	Site	Technician
10/23/2023	CAV436	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.69	c	Fail
2	Temperature2meter max error	P	5	0.5	3	0.74	c	Fail
3	Ozone Slope	P	0	1.1	4	0.97980	unitless	P
4	Ozone Intercept	P	0	5	4	-0.77048	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	4.6	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.78	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-1.22	ppb	P
9	DAS Voltage average error	P	4	0.003	3	0.0000	V	P
10	Shelter Temperature average error	P	5	2	9	0.32	c	P
11	Shelter Temperature max error	P	5	2	9	0.69	c	P

SiteVisitDate	Site	Technician
10/23/2023	CAV436	Martin Valvur

# Field Systems Comments

- 1

Parameter:

SiteOpsProcComm

Dry deposition samples are not collected at this site.
- 2

Parameter:

DocumentationCo

The site is visited every other Tuesday.
- 3

Parameter:

MetSensorComme

The 2-meter temperature sensor is mounted one meter above the building roof and facing south. The building is likely to impact the accuracy of the measurements.

# EEMS Spot Report

Data Compiled: 11/5/2023 20:13:22

Site	Visit Date	Technician
CHA467	10/24/2023	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98591	unitless	P
2	Ozone Intercept	P	0	5	4	0.08656	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99990	unitless	P
4	Ozone % difference avg	P	7	10	4	2.4	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.95	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.74	ppb	P

# EEMS Spot Report

Data Compiled: 1/16/2024 11:20:34 AM

Site	Visit Date	Technician
CND125	12/22/2023	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	18	0.04	c	P
2	Temperature max error	P	4	0.5	18	0.05	c	P
3	Ozone Slope	P	0	1.1	4	1.01683	unitless	P
4	Ozone Intercept	P	0	5	4	-0.04086	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	1.4	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.07	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	0.12	ppb	P
9	Flow Rate average % difference	P	10	5	3	4.25	%	P
10	Flow Rate max % difference	P	10	5	3	4.46	%	P
11	DAS Voltage average error	P	4	0.003	14	0.0000	V	P
12	Shelter Temperature average error	P	5	2	24	0.12	c	P
13	Shelter Temperature max error	P	5	2	24	0.23	c	P

# Field Systems Comments

- 1

Parameter:

SitingCriteriaCom

The land owner maintains a pine tree forest on the property within 50 meters of the site. The trees were planted just before the site was installed in 1990 and may or may not be harvested in the future.
- 2

Parameter:

ShelterCleanNotes

The shelter is well clean and well organized. There are signs of insect infestation on floor.
- 3

Parameter:

PollAnalyzerCom

Ozone sample train has inline dryer.
- 4

Parameter:

MetOpMaintCom

The temperature sensor is mounted on the sample tower in a naturally aspirated shield.

# EEMS Spot Report

Data Compiled: 1/16/2024 11:29:17 AM

Site	Visit Date	Technician
COW137	12/26/2023	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97363	unitless	P
2	Ozone Intercept	P	0	5	4	-0.54646	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	4.2	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.6	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.95	ppb	P



# EEMS Spot Report

Data Compiled: 1/16/2024 11:30:22 AM

Site	Visit Date	Technician
CTH110	11/08/2023	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98097	unitless	P
2	Ozone Intercept	P	0	5	4	0.09209	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	1.8	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.12	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.39	ppb	P

# EEMS Spot Report

Data Compiled: 11/5/2023 15:47:42

Site	Visit Date	Technician
DEN417	10/11/2023	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.0253	unitless	P
2	Ozone Intercept	P	0	5	4	0.11634	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	2.6	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.34	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	0.49	ppb	P

# EEMS Spot Report

Data Compiled: 1/16/2024 8:13:43 AM

SiteVisitDate	Site	Technician
11/20/2023	DEV412	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	2	0.59	c	Fail
2	Temperature max error	P	4	0.5	2	0.83	c	Fail
3	Ozone Slope	P	0	1.1	4	1.00126	unitless	P
4	Ozone Intercept	P	0	5	4	-1.02788	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	3.3	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.86	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-1.04	ppb	P
9	DAS Voltage average error	P	4	0.003	1	0.0000	V	P
10	Shelter Temperature average error	P	5	2	6	1.03	c	P
11	Shelter Temperature max error	P	5	2	6	1.32	c	P

SiteVisitDate	Site	Technician
11/20/2023	DEV412	Martin Valvur

# Field Systems Comments

- 1

Parameter:

SiteOpsProcComm

Dry deposition samples are not collected at this site.
- 2

Parameter:

PollAnalyzerCom

The sample tubing is not secured to the sample tower.
- 3

Parameter:

MetSensorComme

The temperature and humidity combination sensor is mounted in a non-aspirated shield on the south side of the tower. The sensor cannot be submerged and therefore was only challenged in air side-by-side with the RTD standard. Audit results are not comparable with other submergible sensors.

# EEMS Spot Report

Data Compiled: 1/16/2024 11:31:48 AM

Site	Visit Date	Technician
DUK008	11/14/2023	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01197	unitless	P
2	Ozone Intercept	P	0	5	4	-0.0393	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	0.9	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.12	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	0.13	ppb	P

# EEMS Spot Report

Data Compiled: 11/5/2023 17:22:52

SiteVisitDate	Site	Technician
10/18/2023	GLR468	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.21	c	P
2	Temperature2meter max error	P	5	0.5	3	0.24	c	P
3	Ozone Slope	P	0	1.1	4	0.99776	unitless	P
4	Ozone Intercept	P	0	5	4	-0.82253	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	2.8	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.69	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.9	ppb	P
9	Flow Rate average % difference	P	10	5	8	0.22	%	P
10	Flow Rate max % difference	P	10	5	8	0.33	%	P
11	DAS Voltage average error	P	4	0.003	4	0.0000	V	P
12	Shelter Temperature average error	P	5	2	24	0.63	c	P
13	Shelter Temperature max error	P	5	2	24	0.70	c	P

SiteVisitDate	Site	Technician
10/18/2023	GLR468	Tim Mendenhall

# Field Systems Comments

- 1

Parameter:

SiteOpsProcComm

The site operator uses the filter bad as a glove.
- 2

Parameter:

SitingCriteriaCom

The site is located in a small clearing within 100 meters of a horse stable. There is a plywood and aluminum processing plant within 20 km of the site.
- 3

Parameter:

ShelterCleanNotes

The shelter is in fair condition. Evidence of repairs to roof leaks attempted. The floor has been repaired since the previous audit visit.

# EEMS Spot Report

Data Compiled: 1/16/2024 11:32:52 AM

Site	Visit Date	Technician
GRB411	11/06/2023	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01129	unitless	P
2	Ozone Intercept	P	0	5	4	-0.87381	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	1.4	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-1.01	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.58	ppb	P



# EEMS Spot Report

Data Compiled: 11/5/2023 20:21:26

Site	Visit Date	Technician
GRC474	10/25/2023	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97456	unitless	P
2	Ozone Intercept	P	0	5	4	-0.7612	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	4.7	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.88	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.99	ppb	P

# EEMS Spot Report

Data Compiled: 11/5/2023 18:51:44

Site	Visit Date	Technician
HOX148	10/19/2023	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01508	unitless	P
2	Ozone Intercept	P	0	5	4	0.46876	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	3.0	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.46	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	0.86	ppb	P

# EEMS Spot Report

Data Compiled: 1/16/2024 9:07:23 AM

Site	Visit Date	Technician
KIC003	11/29/2023	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	15	0.08	c	P
2	Temperature max error	P	4	0.5	15	0.21	c	P
3	Flow Rate average % difference	P	10	5	2	2.28	%	P
4	Flow Rate max % difference	P	10	5	2	2.74	%	P
5	DAS Voltage average error	P	4	0.003	5	0.0000	V	P

SiteVisitDate	Site	Technician
11/29/2023	KIC003	Tim Mendenhall

# Field Performance Comments

- 1

**Parameter:** Flow Rate

**SensorComponent:** Rotometer Condi

**CommentCode:** 203
- The rotometer ball is stuck and not floating due to either dirt or moisture inside the rotometer.

# Field Systems Comments

- 1

**Parameter:** SiteOpsProcComm
- The site operation is currently suspended until funding is available.
- 2

**Parameter:** DocumentationCo
- Currently there is no logbook provided by WSP but that maybe due to suspension of site operation since July.
- 3

**Parameter:** SitingCriteriaCom
- The site is located across the street from the community school in the town of Powhattan.
- 4

**Parameter:** ShelterCleanNotes
- Small footprint site with no shelter.

# EEMS Spot Report

Data Compiled: 11/5/2023 12:25:01

SiteVisitDate	Site	Technician
10/10/2023	KNZ184	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.05	c	P
2	Temperature max error	P	4	0.5	9	0.14	c	P
3	Flow Rate average % difference	P	10	5	2	0.78	%	P
4	Flow Rate max % difference	P	10	5	2	1.35	%	P
5	DAS Voltage average error	P	4	0.003	9	0.0000	V	P
6	Shelter Temperature average error	P	5	2	24	0.13	c	P
7	Shelter Temperature max error	P	5	2	24	0.38	c	P

SiteVisitDate	Site	Technician
10/10/2023	KNZ184	Tim Mendenhall

## Field Performance Comments

- 1

**Parameter:** Flow Rate

**SensorComponent:** Moisture Present

**CommentCode:** 72
- The filter sample tubing has drops of moisture in low sections outside the shelter.

## Field Systems Comments

- 1

**Parameter:** SitingCriteriaCom
- The site is located at a Long Term Ecological Research site operated by KSU.
- 2

**Parameter:** ShelterCleanNotes
- The shelter is very clean, neat an well organized. Although patched, he shelter floor is deteriorated and in poor condition.
- 3

**Parameter:** MetSensorComme
- The temperature sensor is mounted on the north side of the sample tower.

# EEMS Spot Report

Data Compiled: 1/15/2024 5:43:43 PM

SiteVisitDate	Site	Technician
11/14/2023	LAV410	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.22	c	P
2	Temperature2meter max error	P	5	0.5	3	0.33	c	P
3	Ozone Slope	P	0	1.1	4	0.97678	unitless	P
4	Ozone Intercept	P	0	5	4	0.41499	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
6	Ozone % difference avg	P	7	10	4	1.8	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.72	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	0.17	ppb	P
9	Flow Rate average % difference	P	10	5	12	1.28	%	P
10	Flow Rate max % difference	P	10	5	12	1.6	%	P
11	DAS Voltage average error	P	4	0.003	10	0.0000	V	P
12	Shelter Temperature average error	P	5	2	6	0.59	c	P
13	Shelter Temperature max error	P	5	2	6	0.62	c	P

SiteVisitDate	Site	Technician
11/14/2023	LAV410	Martin Valvur

# Field Systems Comments

- 1

Parameter:

SiteOpsProcedures

The ozone inlet filter is changed and the sample line conditioned every two weeks or as needed.
- 2

Parameter:

SitingCriteriaCom

The site is located at the end of a park service facility parking lot, in a fire station. The tree line is near the building, but the prevailing wind direction is from the clearing. Tree height above the sample inlet is not twice as far away as it is high above the inlet.
- 3

Parameter:

ShelterCleanNotes

The inside equipment is located in room within the fire station, clean, neat, and organized.
- 4

Parameter:

PollAnalyzerCom

Trees violate the ozone sample inlet siting criteria.



# EEMS Spot Report

Data Compiled: 1/15/2024 5:19:11 PM

SiteVisitDate	Site	Technician
11/11/2023	NIC001	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	18	0.06	c	P
2	Temperature max error	P	4	0.5	18	0.09	c	P
3	Flow Rate average % difference	P	10	5	8	0.00	%	P
4	Flow Rate max % difference	P	10	5	8	0.00	%	P
5	DAS Voltage average error	P	4	0.003	6	0.0000	V	P

SiteVisitDate	Site	Technician
11/11/2023	NIC001	Eric Hebert

# Field Systems Comments

- 1

Parameter:

DasComments

Single tower with filter pack mounted at 10 meters and temperature mounted at 9 meters. The tower is difficult to lower due to the lower section contacting the chain-link fence. This could be a potential safety hazard. It is recommended that a solution be investigated.
- 2

Parameter:

DocumentationCo

There is no logbook onsite to record information regarding site status or filter information.
- 3

Parameter:

ShelterCleanNotes

Small footprint site with no shelter. Equipment housed in enclosure on sample tower.

# EEMS Spot Report

Data Compiled: 11/5/2023 20:29:07

Site	Visit Date	Technician
PET427	10/26/2023	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.95667	unitless	P
2	Ozone Intercept	P	0	5	4	0.46781	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99977	unitless	P
4	Ozone % difference avg	P	7	10	4	5.1	%	P
5	Ozone Absolute Difference g1	P	7	3	1	1.83	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-1.31	ppb	P

# EEMS Spot Report

Data Compiled: 11/5/2023 21:40:57

SiteVisitDate	Site	Technician
10/31/2023	PND165	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	21	0.06	c	P
2	Temperature max error	P	4	0.5	21	0.08	c	P
3	Ozone Slope	P	0	1.1	4	1.00609	unitless	P
4	Ozone Intercept	P	0	5	4	-2.68838	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99974	unitless	P
6	Ozone % difference avg	P	7	10	4	4.8	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-4.14	ppb	Fail
8	Ozone Absolute Difference g2	P	7	1.5	1	-1.34	ppb	P
9	Flow Rate average % difference	P	10	5	3	0.29	%	P
10	Flow Rate max % difference	P	10	5	3	0.33	%	P
11	DAS Voltage average error	P	4	0.003	14	0.0000	V	P
12	Shelter Temperature average error	P	5	2	24	0.43	c	P
13	Shelter Temperature max error	P	5	2	24	0.82	c	P

SiteVisitDate	Site	Technician
10/31/2023	PND165	Martin Valvur

# Field Systems Comments

- 1

Parameter:

SitingCriteriaCom

Construction at the bottom of the hill and entrance to the site access road has been completed.
- 2

Parameter:

ShelterCleanNotes

The floor tiles are loose and breaking into pieces.

# EEMS Spot Report

Data Compiled: 1/16/2024 8:40:18 AM

SiteVisitDate	Site	Technician
11/27/2023	SAN189	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	21	0.28	c	P
2	Temperature max error	P	4	0.5	21	0.50	c	P
3	Ozone Slope	P	0	1.1	4	1.00318	unitless	P
4	Ozone Intercept	P	0	5	4	-0.01756	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	0.4	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.17	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.07	ppb	P
9	Flow Rate average % difference	P	10	5	6	0.99	%	P
10	Flow Rate max % difference	P	10	5	6	1.32	%	P
11	DAS Voltage average error	P	4	0.003	13	0.0000	V	P
12	Shelter Temperature average error	P	5	2	24	0.64	c	P
13	Shelter Temperature max error	P	5	2	24	0.80	c	P

## Field Performance Comments

1    **Parameter:**    Temperature                      **SensorComponent:**    System Memo                      **CommentCode:** 4

         The sensor signal cables are showing signs of wear.

## Field Systems Comments

- 1    **Parameter:**    DasComments
- The met tower is not currently in use and it is somewhat unstable.
- 2    **Parameter:**    SiteOpsProcedures
- The site operator was not available during the audit visit due to illness.
- 3    **Parameter:**    DocumentationCo
- The site operator reported that all instrument manuals are kept at the office.
- 4    **Parameter:**    ShelterCleanNotes
- The shelter is in very good condition.

# EEMS Spot Report

Data Compiled: 1/15/2024 2:02:24 PM

Site	Visit Date	Technician
SHE604	11/06/2023	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.11	c	P
2	Temperature2meter max error	P	5	0.5	3	0.17	c	P
3	Flow Rate average % difference	P	10	5	2	0.89	%	P
4	Flow Rate max % difference	P	10	5	2	1.64	%	P
5	DAS Voltage average error	P	4	0.003	1	0.0000	V	P



SiteVisitDate	Site	Technician
11/06/2023	SHE604	Tim Mendenhall

## Field Systems Comments

1 **Parameter:** DasComments

The site power source is solar and wind with battery storage. The NEMA enclosure has a cooling fan and heat for the 2B ozone monitor.

2 **Parameter:** SiteOpsProcedures

observations of current meteorological measurements are recorded on a hardcopy checklist for ARS and not on the SSRF.

3 **Parameter:** DocumentationCo

The site operator is supplied with a disc containing the QAPP, operating procedures, and HASP which is kept at his office. A hard copy BLM check list developed by ARS is completed and sent to ARS each week. Standard CASTNET SSRF forms are being used now.

4 **Parameter:** SitingCriteriaCom

The site is located in range land. There is an active rail line with coal trains within one kilometer of the site.

5 **Parameter:** ShelterCleanNotes

NEMA enclosure, wind and solar power

6 **Parameter:** PollAnalyzerCom

The dry deposition filter pack enclosure is not the standard "pot" size as at the other CASTNET sites. The diameter is much smaller. It is not clear if this will impact particle collection efficiency. The filter is not plumb inside the enclosure and there is a section of tygon tubing between the pump and MFC.

7 **Parameter:** MetSensorComme

The site is a small footprint solar powered site that has been operating as part of the WARMS network for more than 10 years. Objects violate the 45 degree rule for the tipping bucket rain gage. The temperature and RH are being measured at 2.5 meters above the ground. The upper section of the tower is not plumb. The guy wires could be adjusted to correct.

# EEMS Spot Report

Data Compiled: 1/16/2024 11:34:04 AM

Site	Visit Date	Technician
SND152	12/06/2023	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.02085	unitless	P
2	Ozone Intercept	P	0	5	4	-0.74215	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99996	unitless	P
4	Ozone % difference avg	P	7	10	4	2.5	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.4	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-1.08	ppb	P

# EEMS Spot Report

Data Compiled: 1/16/2024 11:35:10 AM

Site	Visit Date	Technician
SPD111	12/05/2023	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99728	unitless	P
2	Ozone Intercept	P	0	5	4	-0.63396	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	2.1	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.68	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.6	ppb	P

# EEMS Spot Report

Data Compiled: 11/5/2023 21:12:10

SiteVisitDate	Site	Technician
10/29/2023	STK138	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	21	0.08	c	P
2	Temperature max error	P	4	0.5	21	0.11	c	P
3	Ozone Slope	P	0	1.1	4	1.01627	unitless	P
4	Ozone Intercept	P	0	5	4	0.16439	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	1.9	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.31	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	0.38	ppb	P
9	Flow Rate average % difference	P	10	5	6	0.90	%	P
10	Flow Rate max % difference	P	10	5	6	1.35	%	P
11	DAS Voltage average error	P	4	0.003	14	0.0000	V	P
12	Shelter Temperature average error	P	5	2	24	0.65	c	P
13	Shelter Temperature max error	P	5	2	24	1.54	c	P

SiteVisitDate	Site	Technician
10/29/2023	STK138	Eric Hebert

# Field Systems Comments

- 1

**Parameter:** SiteOpsProcComm

The site operator is completing the SSRF information on the day the filter is removed rather than when installed. He is also indicating on the form that the ozone inlet filter is changed every week.
- 2

**Parameter:** DasComments

The sample tower is original and is in poor condition. The lower section has been cut to allow the upper section to fold down completely.
- 3

**Parameter:** SiteOpsProcedures

The ozone sample train is leak tested every 2 weeks.
- 4

**Parameter:** SitingCriteriaCom

The site is located in a corn field on a cattle farm. Corn is planted within 10 meters.
- 5

**Parameter:** ShelterCleanNotes

There are signs of leaks on the walls and floor rot. The shelter has continued to deteriorate since the previous audit visit.



# EEMS Spot Report

Data Compiled: 11/5/2023 22:26:11

SiteVisitDate	Site	Technician
10/13/2023	THR422	Tim Mendenhall

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.27	c	P
2	Temperature2meter max error	P	5	0.5	3	0.39	c	P
3	Flow Rate average % difference	P	10	5	2	50.33	%	Fail
4	Flow Rate max % difference	P	10	5	2	50.5	%	Fail
5	DAS Voltage average error	P	4	0.003	11	0.0000	V	P
6	Shelter Temperature average error	P	5	2	27	0.59	c	P
7	Shelter Temperature max error	P	5	2	27	0.80	c	P

## Field Systems Comments

1 **Parameter:** SiteOpsProcComm

Gloves are not used to handle the filter pack. The filter bag is used as a glove.

2 **Parameter:** DasComments

The met tower is no longer in use.

3 **Parameter:** SiteOpsProcedures

The ozone sample train does not have a means to introduce test gas at the sample inlet. Results of routine zero, span, precision, and any multipoint calibration checks are maintained by the state personnel who perform the tests. The two inlet filters in the sample train are creating a large pressure drop.

4 **Parameter:** SitingCriteriaCom

The site is located 200 meters from an interstate rest area, and 300 meters from interstate 94. The rest area can have parked and idling vehicles for extended periods.

5 **Parameter:** ShelterCleanNotes

The shelter is in good condition, clean and well organized.

6 **Parameter:** PollAnalyzerCom

The ozone monitor is operated by the state of North Dakota. There is approximately 1.5 meters of tygon tubing attached to the 3/8 filter pack flow tubing. The data logger was recording the flow rate as 1.5 lpm while the rotometer and the audit standard device were measuring approximately 3 lpm.

7 **Parameter:** MetSensorComme

The 2-meter temperature sensor is mounted on south side of the sample tower, which is attached to the site shelter. The sensor is 4.1 meters above ground and close to the shelter.



# EEMS Spot Report

Data Compiled: 11/5/2023 18:37:20

Site	Visit Date	Technician
UVL124	10/19/2023	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00788	unitless	P
2	Ozone Intercept	P	0	5	4	-0.41443	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	1.3	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.02	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.53	ppb	P

# EEMS Spot Report

Data Compiled: 11/5/2023 13:07:28

SiteVisitDate	Site	Technician
10/10/2023	VOY413	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.41	c	P
2	Temperature2meter max error	P	5	0.5	3	0.58	c	Fail
3	Ozone Slope	P	0	1.1	4	1.01225	unitless	P
4	Ozone Intercept	P	0	5	4	0.10569	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	1.2	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.37	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	0.22	ppb	P
9	Flow Rate average % difference	P	10	5	4	1.93	%	P
10	Flow Rate max % difference	P	10	5	4	2.05	%	P
11	DAS Voltage average error	P	4	0.003	13	0.0000	V	P
12	Shelter Temperature average error	P	5	2	18	0.97	c	P
13	Shelter Temperature max error	P	5	2	18	1.92	c	P

SiteVisitDate	Site	Technician
10/10/2023	VOY413	Eric Hebert

## Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator handles the filter barehanded.

2 **Parameter:** DasComments

The sample tower itself is not grounded, however it is bolted to the shelter which is grounded. The roof leak above the instrument rack may have been repaired, it is dry at this time.

3 **Parameter:** SitingCriteriaCom

The site is located at the top of a hill in a forest. There are trees surrounding the site which are below the tower height, but within 10 m of the inlet.

4 **Parameter:** ShelterCleanNotes

The shelter is in fair condition, and is neat and well organized.

5 **Parameter:** PollAnalyzerCom

There are no trees violating the 22.5 degree cone above the ozone sample inlet. However, there is a communication tower which is above the 22.5 degree threshold.

# EEMS Spot Report

Data Compiled: 1/15/2024 4:50:43 PM

Site	Visit Date	Technician
WFM105	11/09/2023	Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	21	0.10	c	P
2	Temperature max error	P	4	0.5	21	0.25	c	P
3	Flow Rate average % difference	P	10	5	2	1.12	%	P
4	Flow Rate max % difference	P	10	5	2	1.35	%	P
5	DAS Voltage average error	P	4	0.003	6	0.0000	V	P

SiteVisitDate	Site	Technician
11/09/2023	WFM105	Eric Hebert

# Field Systems Comments

- 1

Parameter:

SiteOpsProcComm

The observation section of the SSRF is completed the day the filer is removed and not the day of installation.
- 2

Parameter:

DasComments

Single tower, with filter pack at 10 meters and temperature at 9 meters.
- 3

Parameter:

DocumentationCo

The site operator takes notes in his own field notebook, there is no site logbook.
- 4

Parameter:

SitingCriteriaCom

The site is located at the Atmospheric Science Research Center (ASRC) operated by the NY University (SUNY) system.
- 5

Parameter:

ShelterCleanNotes

Small footprint site with no shelter. Equipment housed in enclosure on sample tower.