
2025 – 1st Quarter Report
**Support for Conducting Systems &
Performance Audits of Clean Air Status and
Trends Network (CASTNET) Sites and
National Atmospheric Deposition Program
(NADP) Monitoring Stations - III**

GSA Contract # GS-10F-075AA
Blanket Purchase Agreement # 68HERH22A0026

Prepared for:

**U.S. Environmental Protection Agency
Office of Atmospheric Protection
Clean Air and Power Division**

Prepared by:



**4577E NW 6th St Ext.
Gainesville, FL 32609**

**Report Submitted
April 2025**

Table of Contents

1.0 CASTNET Quarterly Report.....	1
1.1 Introduction.....	1
1.2 Project Objectives	2
1.3 CASTNET Sites Visited First Quarter 2025	4
1.4 CASTNET Audit Results.....	4
2.0 NADP Quarterly Report	6
2.1 Introduction.....	6
2.2 Project Objectives	6
2.3 NADP Sites Visited First Quarter 2025	7
2.4 NADP Audit Results	7

List of Appendices

- Appendix A** CASTNET Audit Report Forms
- Appendix B** CASTNET Site Spot Report Forms

List of Tables

Table 1. Performance Audit Challenge and Acceptance Criteria.....	2
Table 2. CASTNET Site Audit Visits	4
Table 3. NADP Site Audit Visits	7

List of Acronyms and Abbreviations

% diff	percent difference
A/D	analog to digital converter
ARS	Air Resource Specialists, Inc.
ASTM	American Society for Testing and Materials
BLM	Bureau of Land Management
BLM-WSO	Bureau of Land Management – Wyoming State Office
CAL	Central Analytical Laboratory
CASTNET	Clean Air Status and Trends Network
CMAQ	Community Multiscale Air Quality
DAS	data acquisition system
deg	degree
DVM	digital voltmeter
ECCC	Environment and Climate Change Canada
EEMS	Environmental, Engineering & Measurement Services, Inc.
EPA	U.S. Environmental Protection Agency
ESC	Environmental Systems Corporation
FSA	Field Systems Audit
FSAD	Field Site Audit Database
GPS	geographical positioning system
HAL	Mercury Analytical Laboratory
LADCO	Lake Michigan Air Directors Consortium
lpm	liters per minute
ME DEP	Maine Department of Environmental Protection
MD DNR	Maryland Department of Natural Resources
MLM	Multilayer Model
MN PCA	Minnesota Pollution Control Agency
m/s	meters per second
mv	millivolt
NESCAUM	Northeast States for Coordinated Air Use Management
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPS	National Park Service
NYDEC	New York Department of Conservation
NYSERDA	New York State Energy Research and Development Authority
OH EPA	Ohio Environmental Protection Agency
PE	Performance Evaluation
QAPP	Quality Assurance Project Plan
SLT	State, Local, and Tribal
SCDHEC	South Carolina Department of Health and Environmental Control
SFWMD	South Florida Water Management District
SOP	standard operating procedure
TDEP	Total Deposition
TEI	Thermo Environmental Instruments
USDA-FS	United States Department of Agriculture – Forest Service

USFS	United States Forest Service
USFWS	United States Fish and Wildlife Service
USGS	United States Geological Survey
USNO	United States Naval Observatory
VDC	volts direct current
WDEQ	Wyoming Department of Environmental Quality
WDNR	Wisconsin Department of Natural Resources
WRR	World Radiation Reference
WSLH	Wisconsin State Laboratory of Hygiene

1.0 CASTNET Quarterly Report

1.1 Introduction

The Clean Air Status and Trends Network (CASTNET) is a national air monitoring program established in 1988 by the US EPA. Nearly all CASTNET sites measures weekly concentrations of acidic gases and particles to provide accountability for EPA’s emission reduction programs. Most sites measure ground-level ozone as well as supplemental measurements such as meteorology and/or other trace gas concentrations.

Ambient concentrations are used to estimate deposition rates of the various pollutants with the objective of determining relationships between emissions, air quality, deposition, and ecological effects. In conjunction with other national monitoring networks, CASTNET data are used to determine the effectiveness of national emissions control programs and to assess temporal trends and spatial deposition patterns in atmospheric pollutants. CASTNET data are also used for long-range transport model evaluations and critical loads research.

Historically, CASTNET pollutant flux measurements have been reported as the aggregate product of weekly measured concentrations and model-estimated deposition velocities. The Multi-layer Model (MLM) was used to derive deposition velocity estimates from on-site meteorological parameters, land use types, and site characteristics. In 2011, EPA discontinued meteorological measurements at most EPA-sponsored CASTNET sites.

Currently, CASTNET pollutant flux estimates are calculated as the aggregate product of weekly measured chemical concentrations and gridded model-estimated deposition velocities. Total deposition is assessed using the NADP’s Total Deposition Hybrid Method (TDEP; EPA, 2015c; Schwede and Lear, 2014), which combines data from established ambient monitoring networks and chemical-transport models. To estimate dry deposition, ambient measurement data from CASTNET and other networks were merged with dry deposition rates and flux output from the Community Multiscale Air Quality (CMAQ) modeling system.

Since 2011 nearly all CASTNET ozone monitors have adhered to the requirements for State, Local, and Tribal (SLT) air monitoring stations as specified by the EPA in 40 CFR Part 58. As such, the ozone data collected must meet the requirements in 40 CFR Part 58 Appendix A, which defines the quality assurance (QA) requirements for gaseous pollutant ambient air monitoring. The audits performed by EEMS under this contract fulfilled the requirement for annual performance evaluation audits of pollutant monitors in the network. The QA requirements can be found at:

<https://www.epa.gov/amtic/regulations-guidance-and-monitoring-plans>

Currently more than 85 CASTNET sites measure ground-level ozone concentrations. Annual performance evaluation (PE), ozone audit data are submitted to the Air Quality System (AQS) database.

As of January 2025, the network is comprised of 91 active rural sampling sites across the United States and Canada, cooperatively operated by the Environmental Protection Agency (EPA), the National Park Service (NPS), Bureau of Land Management – Wyoming State Office (BLM-WSO) and several independent partners. WSP is responsible for operating the EPA sponsored sites, and Air Resource Specialists, Inc. (ARS) is responsible for operating the NPS and BLM-WSO sponsored sites

1.2 Project Objectives

The objectives of this project are to establish an independent and unbiased program of performance and systems audits for all CASTNET sampling sites. Ongoing Quality Assurance (QA) programs are an essential part of any long-term monitoring network.

Performance audits verify that all reported variables are consistent with the accuracy goals as defined in the CASTNET Quality Assurance Project Plan (QAPP). The parameter specific accuracy goals are presented in Table 1.

Table 1. Performance Audit Challenge and Acceptance Criteria

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Precipitation	Response	10 manual tips	1 DAS count per tip
Precipitation	Accuracy	2 introductions of known amounts of water	$\leq \pm 10.0\%$ of input amount
Relative Humidity	Accuracy	Compared to reference instrument or standard solution	$\leq \pm 10.0\%$ RH
Solar Radiation	Accuracy	Compared to WRR traceable standard	$\leq \pm 10.0\%$ of daytime average
Surface Wetness	Response	Distilled water spray mist	Positive response
Surface Wetness	Sensitivity	1% decade resistance	N/A
Temperature	Accuracy	Comparison to 3 NIST measured baths (~ 0° C, ambient, ~ full-scale)	$\leq \pm 0.5^\circ \text{ C}$
Temperature Difference	Accuracy	Comparison to station temperature sensor	$\leq \pm 0.50^\circ \text{ C}$

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Shelter Temperature	Accuracy	Comparison to station temperature sensor	$\leq \pm 2.0^{\circ} \text{ C}$
Wind Direction	Orientation Accuracy	Parallel to alignment rod/crossarm, or sighted to distant point	$\leq \pm 5^{\circ}$ from degrees true
Wind Direction	Linearity	Eight cardinal points on test fixture	$\leq \pm 5^{\circ}$ mean absolute error
Wind Direction	Response Threshold	Starting torque tested with torque gauge	< 10 g-cm Climatronics; < 20 g-cm R.M. Young
Wind Speed	Accuracy	Shaft rotational speed generated and measured with certified synchronous motor	$\leq \pm 0.5 \text{ mps}$ below 5.0 mps input; $\leq \pm 5.0\%$ of input at or above 5.0 mps
Wind Speed	Starting Threshold	Starting torque tested with torque gauge	< 0.5 g-cm
Mass Flow Controller	Flow Rate	Comparison with Primary Standard	$\leq \pm 5.0\%$ of designated rate
Ozone	Slope	Linear regression of multi-point test gas concentration as measured with a certified transfer standard	$0.9000 \leq m \leq 1.1000$
Ozone	Intercept		$-5.0 \text{ ppb} \leq b \leq 5.0 \text{ ppb}$
Ozone	Correlation Coefficient		$0.9950 \leq r$
Ozone	Percent Difference	Comparison with Level 2 standard concentration	$\leq \pm 15.1\%$ of test gas concentration and $\leq \pm 0.0015 \text{ ppm}$ actual difference
DAS	Accuracy	Comparison with certified standard	$\leq \pm 0.003 \text{ VDC}$

Performance audits are conducted using standards that are traceable to the National Institute of Standards and Technology (NIST), or another authoritative organization, at least annually.

Field site systems audits (FSA) are intended to provide a qualitative appraisal of the total measurement system. Site planning, organization, and operation are evaluated to ensure that good Quality Assurance/Quality Control (QA/QC) practices are being applied. At a minimum the following audit issues were addressed at each site systems audit:

- Site locations and configurations match those provided in the CASTNET QAPP.
- Meteorological instruments are in good physical and operational condition and are sited to meet EPA ambient monitoring guidelines (EPA-600/4-82-060).
- Sites are accessible, orderly, and if applicable, compliant with OSHA safety standards.
- Sampling lines are free of leaks, kinks, visible contamination, weathering, and moisture.

- Site shelters provide adequate temperature control.
- All ambient air quality instruments are functional, being operated in the appropriate range, and the zero-air supply desiccant is unsaturated.
- All instruments are in current calibration.
- Site documentation (maintenance schedules, on-site SOPs, etc.) is current and log book records are complete.
- All maintenance and on-site SOPs are performed on schedule.
- Corrective actions are documented and appropriate for required maintenance/repair activity.
- Site operators demonstrate an adequate knowledge and ability to perform required site activities, including documentation and maintenance activities.

1.3 CASTNET Sites Visited First Quarter 2025

This report consists of the systems and performance, and other audit results from the CASTNET sites visited during the first quarter (January through March) of 2025. The site locations, sponsor, visit dates, and parameters audited, are included in Table 2.

Table 2. CASTNET Site Audit Visits

Site ID	Date	MET	FSA	O3 PE	SO2	CO	NOy	FLOW	Sponsor
SUM156	2/7/2025			1					EPA
ALC188	2/10/2025		1	1				1	EPA
BBE401	2/12/2025		1	1				1	NPS
CAV436	2/14/2025		1	1					NPS
PAL190	2/17/2025		1	1				1	EPA
CHA467	3/31/2025			1					NPS

1.4 CASTNET Audit Results

The observations and results of the systems, performance, and Ozone PE audits are included in Appendix A, *CASTNET Audit Report Forms* by site, arranged by audit date. Photographs of site conditions are included within each system report where necessary. Copies of the spot reports that were sent following the audit of each site are included as Appendix B, *CASTNET Site Spot Report Forms*.

Results of the PE audits of the gaseous pollutant monitors other than ozone, were submitted immediately following the PE and are not included in this report. All TTP PE results of gaseous pollutant monitors are uploaded to AQS and are available there. All audit data and reports are available from the EPA CASTNET website: <https://www.epa.gov/castnet/documents-reports#QuarterlyQualityAssuranceReports>

2.0 NADP Quarterly Report

2.1 Introduction

The National Atmospheric Deposition Program (NADP) operates two precipitation chemistry networks and two atmospheric concentration networks. The National Trends Network (NTN) has been measuring acidic precipitation since 1978. The network currently has more than 250 sites. The precipitation event-based Atmospheric Integrated Research Monitoring Network (AIRMOn) began operation in 1992, and as of July 2019 is no longer in operation. The Mercury Deposition Network (MDN) measures total mercury in precipitation samples from approximately 90 stations. The MDN began operation in 1996 and includes sites throughout the US and Canada. The Atmospheric Mercury Network (AMNet) and the Ammonia Monitoring Network (AMoN) measure ambient concentrations of mercury and ammonia, respectively.

The NADP and other long-term monitoring networks provide critical information to the EPA regarding evaluating the effectiveness of emission reduction control programs from the power industry. The networks of the NADP are sponsored by several federal, state, and local agencies as well as private organizations.

The NADP Program Office (PO) operates and administers the two precipitation chemistry networks (NTN and MDN), two atmospheric concentration networks (AMNet and AMoN), and the NADP analytical laboratory (NAL) from the Wisconsin State Lab of Hygiene (WSLH) at the University of Wisconsin in Madison. The network equipment depot (NED) is also located at the WSLH.

2.2 Project Objectives

The objective of this project is to perform independent and unbiased evaluations of the sites and their operation. These evaluations provide quality assurance pertaining to siting, sample collection and handling, equipment operation and maintenance, record keeping and field laboratory procedures.

More specifically, the audits determine and report findings based on an established methodology consisting of completing a site questionnaire, testing the equipment and documenting with photographs the location, siting criteria, existing equipment, and any issues encountered that require such documentation.

2.3 NADP Sites Visited First Quarter 2025

This report presents the NADP sites audited during the first quarter (January through March) of 2025. The station locations, sponsors, network, and dates of the surveys are presented in Table 3.

Table 3. NADP Site Audit Visits

Site ID	Date	NTN	MDN	AMoN	Site Sponsor	Site Name
FL23	2/7/2025			1	WSP - EPA	Sumatra
TX41	2/10/2025			1	WSP - EPA	Alabama-Coushatta
TX22	2/13/2025	1			USGS - NIFA	Guadalupe Mountains National Park Frijole Ranger Station
TX43	2/17/2025	1		1	Texas A&M University / WSP - EPA	Cañonceta
CO81	3/25/2025	1		1	Weld County	Missile Site Park
CO82	3/25/2025	1		1	Weld County	Orchard
CO01	3/26/2025	1			USGS - NIFA	Las Animas Fish Hatchery
AZ98	3/31/2025	1		1	NPS / WSP -EPA	Chiricahua

2.4 NADP Audit Results

NADP site audit results are entered into a relational database. The database in turn generates Site Spot Reports which are distributed among the interested parties as soon as all the site data has been entered. Database tables with all the data and photos collected, are available for download by the NADP Program Office and the U.S. EPA Project Officers, following the QA process, usually the month following site audits.

Given the volume of data generated, and the fact that data is distributed and/or is available via the internet, no audit results are included in this report.

APPENDIX A

CASTNET Audit Report Forms

Site Inventory by Site Visit

Site Visit	Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
SUM156-Martin Valvur-02/07/2025						
1	2/7/2025	DAS	Campbell	000352	CR3000	2130
2	2/7/2025	Ozone	ThermoElectron Inc	000724	49i A1NAA	1105347328
3	2/7/2025	Ozone Standard	ThermoElectron Inc	000511	49i A3NAA	0922236888
4	2/7/2025	Zero air pump	Werther International	06882	C 70/4	000815255

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347328

SUM156

Martin Valvur

02/07/2025

Ozone

000724

Slope:

0.98252

Slope:

0.00000

Intercept

-0.15045

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

CM23147126

Tfer Desc.

Ozone primary stan

Tfer ID

01116

Slope

0.99260

Intercept

0.04790

Cert Date

4/10/2024

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	-0.06	-0.10	0.09	ppb		0.19	
primary	2	12.45	12.34	11.76	ppb		-0.58	
primary	3	32.48	32.27	31.31	ppb	-3.02		
primary	4	62.71	62.35	61.17	ppb	-1.91		
primary	5	113.87	113.27	111.20	ppb	-1.84		
Sensor Component	Audit Pressure		Condition	755 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.2		Status	pass	
Sensor Component	Span		Condition	1.006		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	98.6 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	1.9 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.72 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	726.2 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	37.4 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	97.1 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	1.9 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.71 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	725.9 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	True		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
ALC188-Martin Valvur-02/10/2025						
1	2/10/2025	Computer	Dell	07006	Inspiron 15	373MC12
2	2/10/2025	DAS	Campbell	000335	CR3000	2114
3	2/10/2025	Elevation	Elevation	None	1	None
4	2/10/2025	Filter pack flow pump	Thomas	02980	107CA18	608102A
5	2/10/2025	Flow Rate	Apex	000886	AXMC105LPMDPCV	illegible
6	2/10/2025	Infrastructure	Infrastructure	none	none	none
7	2/10/2025	Modem	Digi	07202	LR54	Illegible
8	2/10/2025	Ozone	ThermoElectron Inc	000742	49i A1NAA	1105347313
9	2/10/2025	Ozone Standard	ThermoElectron Inc	000512	49i A3NAA	0922236890
10	2/10/2025	Sample Tower	Aluma Tower	000136	B	none
11	2/10/2025	Shelter Temperature	Campbell	none	107-L	none
12	2/10/2025	Siting Criteria	Siting Criteria	None	1	None
13	2/10/2025	Temperature	RM Young	07289	41342	032128
14	2/10/2025	Zero air pump	Werther International	06899	C 70/4	000821902

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2114	ALC188	Martin Valvur	02/10/2025	DAS	Primary

Das Date:	2 /10/2025	Audit Date	2 /10/2025
Das Time:	8:34:00	Audit Time	8:34:00
Das Day:	41	Audit Day	41
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/5/2025	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		ALC188	Martin Valvur	02/10/2025	Flow Rate	000886

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99266	Intercept	0.00014
Cert Date	4/6/2024	CorrCoff	0.99986

DAS 1:	DAS 2:	Cal Factor Zero	0.02
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	1
2.76%	3.47%	Rotometer Reading:	1.4

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference	
primary	pump off	0.000	0.000	0.00	0.000	0.02	l/m	l/m		
primary	leak check	0.000	0.000	0.02	0.000	0.02	l/m	l/m		
primary	test pt 1	1.430	1.440	1.50	0.000	1.49	l/m	l/m	3.47%	
primary	test pt 2	1.438	1.450	1.50	0.000	1.50	l/m	l/m	3.45%	
primary	test pt 3	1.465	1.480	1.50	0.000	1.50	l/m	l/m	1.35%	

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	3.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347313

ALC188

Martin Valvur

02/10/2025

Ozone

000742

Slope:

0.96984

Slope:

0.00000

Intercept

-0.07461

Intercept

0.00000

CorrCoff

0.99999

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

CM23147126

Tfer Desc.

Ozone primary stan

Tfer ID

01116

Slope

0.99260

Intercept

0.04790

Cert Date

4/10/2024

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.23	0.18	0.22	ppb		0.04	
primary	2	11.83	11.72	11.08	ppb		-0.64	
primary	3	32.00	31.79	30.97	ppb	-2.61		
primary	4	63.03	62.67	60.52	ppb	-3.49		
primary	5	114.97	114.36	110.90	ppb	-3.07		
Sensor Component	Audit Pressure		Condition	750 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.4		Status	pass	
Sensor Component	Span		Condition	1.107		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	88.3 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	1.0 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.65 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	732.5 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	31.6 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	92.7 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	1.0 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.67 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	732.5 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	True		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	032128		ALC188	Martin Valvur	02/10/2025	Temperature	07289

				Mfg	Fluke	Parameter	Temperature
				Serial Number	2085085	Tfer Desc.	RTD
				Tfer ID	01226		
				Slope	1.00031	Intercept	-0.04252
				Cert Date	1/8/2025	CorrCoff	0.99999

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

0.10	0.17		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.00	0.04	0.000	0.2	C	0.17	
primary	Temp Mid Range	22.78	22.82	0.000	22.9	C	0.09	
primary	Temp High Range	46.97	47.00	0.000	47.0	C	-0.05	

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	ALC188	Martin Valvur	02/10/2025	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.63	0.68		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	2085085	Tfer Desc.	RTD
Tfer ID	01226		
Slope	1.00031	Intercept	-0.04252
Cert Date	1/8/2025	CorrCoff	0.99999

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	21.84	21.88	0.000	22.5	C	0.63	
primary	Temp Mid Range	22.18	22.22	0.000	22.8	C	0.58	
primary	Temp Mid Range	22.04	22.08	0.000	22.8	C	0.68	
Sensor Component		System Memo	Condition		Status	pass		

Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Infrastructure Data For

Site ID

ALC188

Technician

Martin Valvur

Site Visit Date

02/10/2025

Shelter Make

Shelter One

Shelter Model

8128-2311

Shelter Size

1024 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	ALC188	Martin Valvur	02/10/2025	Moisture Present	Apex	4735	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								

Field Systems Comments

1 Parameter: DocumentationCo

WIFI available at site and manuals and documents maintained on the site computer.

2 Parameter: SitingCriteriaCom

The site is well located with respect to CASTNET siting criteria, however there is a small campground 0.5 km to the northwest which may be a source of smoke.

3 Parameter: ShelterCleanNotes

The site is clean and neat.

4 Parameter: PollAnalyzerCom

There are moisture traps in both the flow and ozone sample lines.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	ALC188	Technician	Martin Valvur	Site Visit Date	02/10/2025
Site Sponsor (agency)	EPA	USGS Map	Dallardsville		
Operating Group	Alabama-Coushatta Environmental Gr	Map Scale			
AQS #	48-373-9991	Map Date			
Meteorological Type	R.M. Young				
Air Pollutant Analyzer	Ozone	QAPP Latitude	30.4210		
Deposition Measurement	dry	QAPP Longitude	-94.4045		
Land Use	woodland - mixed	QAPP Elevation Meters	101		
Terrain	gently rolling	QAPP Declination	3.8		
Conforms to MLM	Yes	QAPP Declination Date	9/16/2005		
Site Telephone	(936) 563-2973	Audit Latitude	30.701577		
Site Address 1	Poncho Rd.	Audit Longitude	-94.674011		
Site Address 2	571 Park Rd. 56	Audit Elevation	105		
County	Polk	Audit Declination	2.5		
City, State	Livingston, TX				
Zip Code	77351	Fire Extinguisher	Present	New in 2015	
Time Zone	Central	First Aid Kit			
Primary Operator		Safety Glasses			
Primary Op. Phone #		Safety Hard Hat			
Primary Op. E-mail		Climbing Belt			
Backup Operator		Security Fence			
Backup Op. Phone #		Secure Shelter			
Backup Op. E-mail		Stable Entry Step			
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Shelter One	Model	8128-2311
		Shelter Size	1024 cuft		
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The site is clean and neat.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From Livingston proceed east on route 190 approximately 16 miles. Turn right (south) onto Park Road 56 at the sign for Alabama-Coushatta Tribe and the Indian Village. Continue past the facility and campground by the small lake on the left. Just past the campground entrance, turn left onto a dirt road. Continue approximately 0.6 miles bearing right at the first fork and left at the second. You will see the site in the clearing.				

Site ID

ALC188

Technician

Martin Valvur

Site Visit Date

02/10/2025

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input type="checkbox"/>	Temperature sensor facing west
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ALC188

Technician

Martin Valvur

Site Visit Date

02/10/2025

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ALC188

Technician

Martin Valvur

Site Visit Date

02/10/2025

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There are moisture traps in both the flow and ozone sample lines.

Site ID

ALC188

Technician

Martin Valvur

Site Visit Date

02/10/2025

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Temperature only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	<div>Met tower removed</div>										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ALC188

Technician

Martin Valvur

Site Visit Date

02/10/2025

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2011	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input checked="" type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

Minimal information

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☒

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

WIFI available at site and manuals and documents maintained on the site computer.

Site ID

ALC188

Technician

Martin Valvur

Site Visit Date

02/10/2025

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by previous site operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually		<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	As needed		<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily		<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	As needed		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks		<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input checked="" type="checkbox"/>	N/A		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly		<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

ALC188

Technician

Martin Valvur

Site Visit Date

02/10/2025

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

ALC188

Technician

Martin Valvur

Site Visit Date

02/10/2025

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	373MC12	07006
DAS	Campbell	CR3000	2114	000335
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	608102A	02980
Flow Rate	Apex	AXMC105LPMDPC	illegible	000886
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07202
Ozone	ThermoElectron Inc	49i A1NAA	1105347313	000742
Ozone Standard	ThermoElectron Inc	49i A3NAA	0922236890	000512
Sample Tower	Aluma Tower	B	none	000136
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	032128	07289
Zero air pump	Werther International	C 70/4	000821902	06899

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
BBE401-Martin Valvur-02/12/2025						
1	2/12/2025	Computer	panasonic	none	Tough Book	CF-532BL28CM
2	2/12/2025	DAS	Campbell	None	CR1000X	12388
3	2/12/2025	Elevation	Elevation	None	1	None
4	2/12/2025	Filter pack flow pump	Thomas	none	107CA18A	608102A
5	2/12/2025	Flow Rate	Alicat	none	MC-10SLPM-D-PCV	134657
6	2/12/2025	Infrastructure	Infrastructure	none	none	none
7	2/12/2025	Ozone	Teledyne	none	T400	7455
8	2/12/2025	Ozone Standard	ThermoElectron Inc	none	49i A3NAA	1023943901
9	2/12/2025	Sample Tower	Aluma Tower	none	B	AT-5381-F9-1
10	2/12/2025	Shelter Temperature	ARS	none	none	none
11	2/12/2025	Siting Criteria	Siting Criteria	None	1	None
12	2/12/2025	Temperature2meter	Vaisala	none	WXT536	V4920649
13	2/12/2025	Zero air pump	Werther International	none	PC 70/4	000855581

DAS Data Form

DAS Time Max Error: 0.2

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	12388	BBE401	Martin Valvur	02/12/2025	DAS	Primary

Das Date:	2 /12/2025	Audit Date	2 /12/2025
Das Time:	8:25:00	Audit Time	8:25:12
Das Day:	43	Audit Day	43
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/5/2025	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
<input type="text" value="Alicat"/>	<input type="text" value="134657"/>		<input type="text" value="BBE401"/>	<input type="text" value="Martin Valvur"/>	<input type="text" value="02/12/2025"/>	<input type="text" value="Flow Rate"/>	<input type="text" value="none"/>

Mfg

Parameter

Serial Number

Tfer Desc.

Tfer ID

Slope

Intercept

Cert Date

CorrCoff

DAS 1:

DAS 2:

Cal Factor Zero

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

Cal Factor Full Scale

Rotometer Reading:

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.04	0.000	0.00	l/m	l/m	
primary	test pt 1	2.983	3.000	2.98	0.000	2.98	l/m	l/m	-0.67%
primary	test pt 2	2.980	3.000	2.98	0.000	2.98	l/m	l/m	-0.77%
primary	test pt 3	2.980	3.000	2.98	0.000	2.98	l/m	l/m	-0.67%

Sensor Component

Condition

Status

Sensor Component

Condition

Status

Sensor Component

Condition

Status

Sensor Component

Condition

Status

Sensor Component

Condition

Status

Sensor Component

Condition

Status

Sensor Component

Condition

Status

Sensor Component

Condition

Status

Sensor Component

Condition

Status

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

Teledyne

7455

BBE401

Martin Valvur

02/12/2025

Ozone

none

Slope:

0.99424

Slope:

0.00000

Intercept

-0.34373

Intercept

0.00000

CorrCoff

0.99994

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

CM23147126

Tfer Desc.

Ozone primary stan

Tfer ID

01116

Slope

0.99260

Intercept

0.04790

Cert Date

4/10/2024

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.12	0.07	0.40	ppb		0.33	
primary	2	13.25	13.13	12.27	ppb		-0.86	
primary	3	33.42	33.21	32.14	ppb	-3.27		
primary	4	63.62	63.26	62.77	ppb	-0.78		
primary	5	116.93	116.31	115.38	ppb	-0.8		
Sensor Component	Audit Pressure			Condition	659 mmHg	Status	pass	
Sensor Component	26.6 degree unobstructed rule			Condition	True	Status	pass	
Sensor Component	Tree dewline >10m or below inlet			Condition	True	Status	pass	
Sensor Component	ADT 1000-10000 vehicles further			Condition	True	Status	pass	
Sensor Component	ADT <1000 vehicles further than			Condition	True	Status	pass	
Sensor Component	Sample Train			Condition	Good	Status	pass	
Sensor Component	Inlet Filter Condition			Condition	Clean	Status	pass	
Sensor Component	Offset			Condition	0.9	Status	pass	
Sensor Component	Span			Condition	4850.5	Status	pass	
Sensor Component	Zero Voltage			Condition	N/A	Status	pass	
Sensor Component	Fullscale Voltage			Condition	N/A	Status	pass	
Sensor Component	Cell A Freq.			Condition	N/A	Status	pass	
Sensor Component	Cell A Noise			Condition	N/A	Status	pass	
Sensor Component	Cell A Flow			Condition	0.89 lpm	Status	pass	
Sensor Component	Cell A Pressure			Condition	24.1 inHg	Status	pass	
Sensor Component	Cell A Tmp.			Condition	25.4 C	Status	pass	
Sensor Component	Cell B Freq.			Condition	N/A	Status	pass	
Sensor Component	Cell B Noise			Condition	N/A	Status	pass	
Sensor Component	Cell B Flow			Condition	N/A	Status	pass	
Sensor Component	Cell B Pressure			Condition	N/A	Status	pass	
Sensor Component	Nafion dryer installed			Condition	False	Status	pass	
Sensor Component	System Memo			Condition		Status	pass	

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	V4920649		BBE401	Martin Valvur	02/12/2025	Temperature2meter	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	2085085	Tfer Desc.	RTD
Tfer ID	01226		
Slope	1.00031	Intercept	-0.04252
Cert Date	1/8/2025	CorrCoff	0.99999

0	0	0	0
---	---	---	---

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary		0.00	0.00	0.000	0.00	C	0

Sensor Component	Shield	Condition		Status	pass
Sensor Component	Properly Sited	Condition		Status	pass
Sensor Component	Blower	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		BBE401	Martin Valvur	02/12/2025	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.14	0.20		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	2085085	Tfer Desc.	RTD
Tfer ID	01226		
Slope	1.00031	Intercept	-0.04252
Cert Date	1/8/2025	CorrCoff	0.99999

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	22.28	22.32	0.000	22.5	C	0.2	
primary	Temp Mid Range	22.59	22.63	0.000	22.8	C	0.19	
primary	Temp Mid Range	23.40	23.44	0.000	23.4	C	-0.04	
Sensor Component		System Memo		Condition		Status	pass	

Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Infrastructure Data For

Site ID

BBE401

Technician

Martin Valvur

Site Visit Date

02/12/2025

Shelter Make	Shelter Model	Shelter Size
Ekto	8814	896 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	Pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Temperature2meter	BBE401	Martin Valvur	02/12/2025	System Memo	Vaisala	4852	<input type="checkbox"/>	<input type="checkbox"/>
Temperature and relative humidity are being measured using a combination sensor which cannot be submerged in a water bath for audits.								

Field Systems Comments

- 1 **Parameter:** DasComments

Met tower no longer in use.

- 2 **Parameter:** SiteOpsProcedures

The ozone sample line is leak tested every two weeks when the inlet filter is replaced.

- 3 **Parameter:** ShelterCleanNotes

The shelter is clean, neat, and well organized.

- 4 **Parameter:** MetSensorComme

Meteorological parameters are being measured with an "all-in-one" sensor which is not submergible. Temperature data were not available for display on the site DAS and it was not tested.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID

BBE401

Technician

Martin Valvur

Site Visit Date

02/12/2025

Site Sponsor (agency)	NPS	USGS Map	Panther Junction
Operating Group	NPS	Map Scale	
AQS #	48-043-0101	Map Date	
Meteorological Type	Climatronics		
Air Pollutant Analyzer	Ozone, IMPROVE, PM2.5	QAPP Latitude	29.3022
Deposition Measurement	dry, wet	QAPP Longitude	-103.1772
Land Use	desert	QAPP Elevation Meters	1052
Terrain	complex	QAPP Declination	
Conforms to MLM	Marginally	QAPP Declination Date	
Site Telephone	(432) 477-2258	Audit Latitude	29.302651
Site Address 1	K-Bar Ranch	Audit Longitude	-103.177813
Site Address 2	Big Bend National Park	Audit Elevation	1057
County	Brewster	Audit Declination	7.0
City, State	Big Bend National Park, TX		
Zip Code	79834	Fire Extinguisher	<div>Present<input type="checkbox"/></div>
Time Zone	Central	First Aid Kit	<div><input checked="" type="checkbox"/></div>
Primary Operator		Safety Glasses	<div><input type="checkbox"/></div>
Primary Op. Phone #		Safety Hard Hat	<div><input type="checkbox"/></div>
Primary Op. E-mail		Climbing Belt	<div><input type="checkbox"/></div>
Backup Operator		Security Fence	<div><input type="checkbox"/></div>
Backup Op. Phone #		Secure Shelter	<div><input checked="" type="checkbox"/></div>
Backup Op. E-mail		Stable Entry Step	<div><input checked="" type="checkbox"/></div>
Shelter Working Room	<div><input checked="" type="checkbox"/></div>	Make	<div>Ekto</div>
		Model	<div>8814</div>
		Shelter Size	<div>896 cuft</div>
Shelter Clean	<div><input checked="" type="checkbox"/></div>	Notes	<div>The shelter is clean, neat, and well organized.</div>
Site OK	<div><input checked="" type="checkbox"/></div>	Notes	<div></div>

Driving Directions

From interstate 10 in Fort Stockton, turn south on highway 385 and drive approximately 120 miles to Big Bend National Park. Continue on the park road past the entrance station 26 miles to the stop sign at Panther Junction near the visitor center. Turn left (east) and continue approximately 2.5 miles. Turn left on the dirt road marked K-Bar and continue approximately 0.5 miles. Turn right on the service road just past the Chihuahuan Desert Research Station (old house) on the right. The site is 400 meters at the end of the road.

Site ID

BBE401

Technician

Martin Valvur

Site Visit Date

02/12/2025

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Meteorological parameters are being measured with an "all-in-one" sensor which is not submergible. Temperature data were not available for display on the site DAS and it was not tested.

Site ID

BBE401

Technician

Martin Valvur

Site Visit Date

02/12/2025

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	Temperature only
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BBE401

Technician

Martin Valvur

Site Visit Date

02/12/2025

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BBE401

Technician

Martin Valvur

Site Visit Date

02/12/2025

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Temperature only									
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?											

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Met tower no longer in use.

Site ID

BBE401

Technician

Martin Valvur

Site Visit Date

02/12/2025

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	Dataview	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	outdated	<input type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	missing	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1	Is the station log properly completed during every site visit?	<input checked="" type="checkbox"/>	Dataview
2	Are the Site Status Report Forms being completed and current?	<input checked="" type="checkbox"/>	Flow section only
3	Are the chain-of-custody forms properly used to document sample transfer to and from lab?	<input checked="" type="checkbox"/>	
4	Are ozone z/s/p control charts properly completed and current?	<input type="checkbox"/>	Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

BBE401

Technician

Martin Valvur

Site Visit Date

02/12/2025

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Monthly	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	Monthly	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	Alarm values only	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Dataview

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone sample line is leak tested every two weeks when the inlet filter is replaced.

Site ID

BBE401

Technician

Martin Valvur

Site Visit Date

02/12/2025

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	Dataview
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

BBE401

Technician

Martin Valvur

Site Visit Date

02/12/2025

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	panasonic	Tough Book	CF-532BL28CM	none
DAS	Campbell	CR1000X	12388	None
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18A	608102A	none
Flow Rate	Alicat	MC-10SLPM-D-PC	134657	none
Infrastructure	Infrastructure	none	none	none
Ozone	Teledyne	T400	7455	none
Ozone Standard	ThermoElectron Inc	49i A3NAA	1023943901	none
Sample Tower	Aluma Tower	B	AT-5381-F9-1	none
Shelter Temperature	ARS	none	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	Vaisala	WXT536	V4920649	none
Zero air pump	Werther International	PC 70/4	000855581	none

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
CAV436-Martin Valvur-02/14/2025						
1	2/14/2025	Computer	Hewlett Packard	none	ProBook	5CD01715DB
2	2/14/2025	DAS	Environmental Sys Corp	None	8864	C2602
3	2/14/2025	Modem	Sierra wireless	none	GX450	Unknown
4	2/14/2025	Ozone	ThermoElectron Inc	none	49i A3NAA	0733726103
5	2/14/2025	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	CM08460009
6	2/14/2025	Shelter Temperature	ARS	none	none	none
7	2/14/2025	Temperature	Vaisala	none	WTX536	V5010145
8	2/14/2025	Zero air pump	Werther International	none	C 70/4	000915011

DAS Data Form

DAS Time Max Error: 1.5

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	C2602	CAV436	Martin Valvur	02/14/2025	DAS	Primary

Das Date:	2 /14/2025	Audit Date	2 /14/2025
Das Time:	8:45:30	Audit Time	8:47:00
Das Day:	45	Audit Day	45
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/5/2025	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

0733726103

CAV436

Martin Valvur

02/14/2025

Ozone

none

Slope:

0.98395

Slope:

0.00000

Intercept

-0.09027

Intercept

0.00000

CorrCoff

1.00000

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

CM23147126

Tfer Desc.

Ozone primary stan

Tfer ID

01116

Slope

0.99260

Intercept

0.04790

Cert Date

4/10/2024

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.38	0.33	0.41	ppb		0.08	
primary	2	14.03	13.91	13.49	ppb		-0.42	
primary	3	34.84	34.62	33.81	ppb	-2.37		
primary	4	65.57	65.20	64.14	ppb	-1.64		
primary	5	116.96	116.34	114.40	ppb	-1.68		
Sensor Component	Audit Pressure		Condition	642 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Moderately clean		Status	pass	
Sensor Component	Offset		Condition	-0.2		Status	pass	
Sensor Component	Span		Condition	1.004		Status	pass	
Sensor Component	Zero Voltage		Condition	N/A		Status	pass	
Sensor Component	Fullscale Voltage		Condition	N/A		Status	pass	
Sensor Component	Cell A Freq.		Condition	112.7 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	0.9 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.71 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	638.7 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	34.3 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	64.8 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	0.6 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.73 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	639.1 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	V5010145		CAV436	Martin Valvur	02/14/2025	Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err

Mfg	Fluke	Parameter	Temperature
Serial Number	2085085	Tfer Desc.	RTD
Tfer ID	01226		
Slope	1.00031	Intercept	-0.04252
Cert Date	1/8/2025	CorrCoff	0.99999

0.39	0.97		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	9.04	9.08	0.000	9.1	C	0.02	
primary	Temp Mid Range	10.13	10.17	0.000	10.0	C	-0.17	
primary	Temp Mid Range	13.03	13.07	0.000	12.1	C	-0.97	

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none		CAV436	Martin Valvur	02/14/2025	Shelter Temperature	none

DAS 1:		DAS 2:		Mfg	Fluke	Parameter	Shelter Temperatur
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err	Serial Number	2085085	Tfer Desc.	RTD
0.29	0.59			Tfer ID	01226		
				Slope	1.00031	Intercept	-0.04252
				Cert Date	1/8/2025	CorrCoff	0.99999

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Mid Range	21.04	21.08	0.000	21.7	C	0.59	
primary	Temp Mid Range	21.19	21.23	0.000	21.4	C	0.16	
primary	Temp Mid Range	20.07	20.11	0.000	20.0	C	-0.13	

Sensor Component	System Memo	Condition		Status	pass
------------------	-------------	-----------	--	--------	------

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Temperature	CAV436	Martin Valvur	02/14/2025	System Memo	Vaisala	4853	<input type="checkbox"/>	<input type="checkbox"/>
Temperature and relative humidity are being measured using a combination sensor which cannot be submerged in a water bath for audits.								

Field Systems Comments

1 Parameter: SiteOpsProcComm

Dry deposition samples are not collected at this site.

2 Parameter: DocumentationCo

The site is visited every other Tuesday. WIFI is available at the station and manuals and documents can be obtained online.

3 Parameter: MetSensorComme

The 2-meter temperature sensor has been replaced with an "all-in-one" meteorological sensor mounted at 10m on the sample tower. The sensor cannot be submerged and was tested by placing the RTD standard inside the naturally aspirated shield next to the site sensor.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	CAV436	Technician	Martin Valvur	Site Visit Date	02/14/2025		
Site Sponsor (agency)	NPS	USGS Map					
Operating Group	NPS	Map Scale					
AQS #	35-151-0745	Map Date					
Meteorological Type							
Air Pollutant Analyzer	Ozone	QAPP Latitude					
Deposition Measurement		QAPP Longitude					
Land Use		QAPP Elevation Meters					
Terrain		QAPP Declination					
Conforms to MLM		QAPP Declination Date					
Site Telephone		Audit Latitude	32.178141				
Site Address 1		Audit Longitude	-104.443206				
Site Address 2		Audit Elevation	1358				
County		Audit Declination	7				
City, State	Carlsbad, NM						
Zip Code	88220	Fire Extinguisher	<input checked="" type="checkbox"/> Inspected June 2024				
Time Zone	Mountain	First Aid Kit	<input type="checkbox"/> in vehicle				
Primary Operator		Safety Glasses	<input type="checkbox"/>				
Primary Op. Phone #		Safety Hard Hat	<input type="checkbox"/>				
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>				
Backup Operator		Security Fence	<input type="checkbox"/>				
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>				
Backup Op. E-mail		Stable Entry Step	<input checked="" type="checkbox"/>				
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Shelter One	Model	E8129-29034	Shelter Size	768 cutt
Shelter Clean	<input checked="" type="checkbox"/>	Notes					
Site OK	<input checked="" type="checkbox"/>	Notes					
Driving Directions							

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

02/14/2025

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The 2-meter temperature sensor has been replaced with an "all-in-one" meteorological sensor mounted at 10m on the sample tower. The sensor cannot be submerged and was tested by placing the RTD standard inside the naturally aspirated shield next to the site sensor.

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

02/14/2025

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

02/14/2025

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 10 meters
4	Describe dry dep sample tube.		N/A
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input type="checkbox"/>	
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

02/14/2025

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>												
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>												
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only											
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>												
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>												
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>												
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>												
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>												
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td><td></td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td><td></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td><td></td></tr></table>	Stable		Grounded		<input type="checkbox"/>		<input type="checkbox"/>		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded												
<input type="checkbox"/>		<input type="checkbox"/>												
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>												
10	Is the sample tower stable and grounded?													
11	Tower comments?													

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

02/14/2025

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input type="checkbox"/>		<input type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☐

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☐

4

Are ozone z/s/p control charts properly completed and current?

☐

Dataview

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site is visited every other Tuesday. WIFI is available at the station and manuals and documents can be obtained online.

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

02/14/2025

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

N/A

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

N/A

3

Is the site visited regularly on the required Tuesday schedule?

☐

every other Tuesday

4

Are the standard CASTNET operational procedures being flollowed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Bi-monthly	<input type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>		<input type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	Bi-monthly	<input type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Bi-monthly	<input type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>		<input type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Bi-monthly	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Bi-monthly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Monthly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Bi-monthly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Bi-monthly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

02/14/2025

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	N/A
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	N/A
3	Are data downloads and backups being performed as scheduled?	<input checked="" type="checkbox"/>	N/A
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	N/A
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	N/A
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	N/A
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	N/A
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	N/A
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Dry deposition samples are not collected at this site.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

CAV436

Technician

Martin Valvur

Site Visit Date

02/14/2025

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	ProBook	5CD01715DB	none
DAS	Environmental Sys Corp	8864	C2602	None
Modem	Sierra wireless	GX450	Unknown	none
Ozone	ThermoElectron Inc	49i A3NAA	0733726103	none
Ozone Standard	ThermoElectron Inc	49i A1NAA	CM08460009	none
Shelter Temperature	ARS	none	none	none
Temperature	Vaisala	WTX536	V5010145	none
Zero air pump	Werther International	C 70/4	000915011	none

Site Inventory by Site Visit

Site Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number	
PAL190-Martin Valvur-02/17/2025						
1	2/17/2025	Computer	Dell	07056	Inspiron 15	FF3MC12
2	2/17/2025	DAS	Campbell	000343	CR3000	2122
3	2/17/2025	Elevation	Elevation	None	1	None
4	2/17/2025	Filter pack flow pump	Thomas	02752	107CA110	11920011905
5	2/17/2025	Flow Rate	Apex	000858	AXMC105LPMDPCV	illegible
6	2/17/2025	Infrastructure	Infrastructure	none	none	none
7	2/17/2025	Modem	Digi	07175	LR54	Illegible
8	2/17/2025	Ozone	ThermoElectron Inc	000726	49i A1NAA	1105347314
9	2/17/2025	Ozone Standard	ThermoElectron Inc	000375	49i A3NAA	0726124696
10	2/17/2025	Sample Tower	Aluma Tower	missing	B	AT-7200-582
11	2/17/2025	Shelter Temperature	Campbell	none	107-L	10755-148
12	2/17/2025	Siting Criteria	Siting Criteria	None	1	None
13	2/17/2025	Temperature	RM Young	06303	41342VO	12542
14	2/17/2025	Zero air pump	Werther International	06922	C 70/4	000836217

DAS Data Form

DAS Time Max Error: 0

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2122	PAL190	Martin Valvur	02/17/2025	DAS	Primary

Das Date:	2 /17/2025	Audit Date	2 /17/2025
Das Time:	8:28:20	Audit Time	8:28:20
Das Day:	48	Audit Day	48
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
0.0000	0.0000	0.0000	0.0000

Mfg	HY	Parameter	DAS
Serial Number	12010039329	Tfer Desc.	Source generator (D
Tfer ID	01322		
Slope	1.00000	Intercept	0.00000
Cert Date	6/15/2014	CorrCoff	1.00000
Mfg	Fluke	Parameter	DAS
Serial Number	95740243	Tfer Desc.	DVM
Tfer ID	01312		
Slope	1.00000	Intercept	0.00000
Cert Date	1/5/2025	CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
4	0.0000	0.0000	0.0000	V	V	0.0000	

Flow Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		PAL190	Martin Valvur	02/17/2025	Flow Rate	000858

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	0.99266	Intercept	0.00014
Cert Date	4/6/2024	CorrCoff	0.99986

DAS 1:	DAS 2:	Cal Factor Zero	0.03
A Avg % Diff:	A Max % Dif	A Avg %Diff	A Max % Dif
0.11%	0.33%		
		Cal Factor Full Scale	0.95
		Rotometer Reading:	3.1

Desc.	Test type	Input l/m	Input Corr	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.03	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.03	l/m	l/m	
primary	test pt 1	2.982	3.000	3.22	0.000	3.00	l/m	l/m	0.00%
primary	test pt 2	2.975	3.000	3.22	0.000	3.00	l/m	l/m	0.00%
primary	test pt 3	2.974	3.000	3.22	0.000	2.99	l/m	l/m	-0.33%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	6.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	0.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	135 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg

Serial Number

Tag

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

1105347314

PAL190

Martin Valvur

02/17/2025

Ozone

000726

Slope:

0.92999

Slope:

0.00000

Intercept

0.19685

Intercept

0.00000

CorrCoff:

0.99998

CorrCoff:

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Dif

A Avg %Diff

A Max % Dif

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

CM23147126

Tfer Desc.

Ozone primary stan

Tfer ID

01116

Slope

0.99260

Intercept

0.04790

Cert Date

4/10/2024

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.36	0.31	0.26	ppb		-0.05	
primary	2	13.97	13.85	12.93	ppb		-0.92	
primary	3	34.35	34.13	32.25	ppb	-5.66		
primary	4	64.90	64.53	60.51	ppb	-6.43		
primary	5	116.69	116.07	107.90	ppb	-7.3		

Sensor Component

Audit Pressure

Condition

661 mmHg

Status

pass

Sensor Component

26.6 degree unobstructed rule

Condition

False

Status

Fail

Sensor Component

Tree dewline >10m or below inlet

Condition

True

Status

pass

Sensor Component

ADT 1000-10000 vehicles further t

Condition

True

Status

pass

Sensor Component

ADT <1000 vehicles further than 5

Condition

True

Status

pass

Sensor Component

Sample Train

Condition

Good

Status

pass

Sensor Component

Inlet Filter Condition

Condition

Clean

Status

pass

Sensor Component

Offset

Condition

-0.4

Status

pass

Sensor Component

Span

Condition

1.016

Status

pass

Sensor Component

Zero Voltage

Condition

N/A

Status

pass

Sensor Component

Fullscale Voltage

Condition

N/A

Status

pass

Sensor Component

Cell A Freq.

Condition

88.8 khz

Status

pass

Sensor Component

Cell A Noise

Condition

0.9 ppb

Status

pass

Sensor Component

Cell A Flow

Condition

0.68 lpm

Status

pass

Sensor Component

Cell A Pressure

Condition

649.8 mmHg

Status

pass

Sensor Component

Cell A Tmp.

Condition

30.1 C

Status

pass

Sensor Component

Cell B Freq.

Condition

102.5 kHz

Status

pass

Sensor Component

Cell B Noise

Condition

0.8 ppb

Status

pass

Sensor Component

Cell B Flow

Condition

0.69 lpm

Status

pass

Sensor Component

Cell B Pressure

Condition

649.5 mmHg

Status

pass

Sensor Component

Nafion dryer installed

Condition

False

Status

pass

Sensor Component

System Memo

Condition

Status

pass

Temperature Data Form

Mfg	Serial Number	Tag	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	12542		PAL190	Martin Valvur	02/17/2025	Temperature	06303

DAS 1:	DAS 2:	Mfg	Fluke	Parameter	Temperature
		Serial Number	2085085	Tfer Desc.	RTD
		Tfer ID	01226		
		Slope	1.00031	Intercept	-0.04252
		Cert Date	1/8/2025	CorrCoff	0.99999

Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.12	0.27		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference	
primary	Temp Low Range	0.00	0.04	0.000	0.1	C	0.01	
primary	Temp Mid Range	23.17	23.21	0.000	23.1	C	-0.09	
primary	Temp High Range	47.80	47.83	0.000	47.6	C	-0.27	

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	10755-148	PAL190	Martin Valvur	02/17/2025	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Err	Abs Avg Err	Abs Max Err
0.19	0.28		

Mfg	Fluke	Parameter	Shelter Temperature
Serial Number	2085085	Tfer Desc.	RTD
Tfer ID	01226		
Slope	1.00031	Intercept	-0.04252
Cert Date	1/8/2025	CorrCoff	0.99999

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.16	23.20	0.000	23.0	C	-0.19
primary	Temp Mid Range	22.24	22.28	0.000	22.4	C	0.1
primary	Temp Mid Range	20.66	20.70	0.000	21.0	C	0.28
Sensor Component	System Memo		Condition		Status	pass	

Siting Criteria Form

Sensor Component	Large point source of So2 or Nox	Condition		Status	pass
Sensor Component	City > 50,000	Condition		Status	pass
Sensor Component	City 1,000 to 10,000	Condition		Status	pass
Sensor Component	City 10,000 to 50,000	Condition		Status	pass
Sensor Component	Feedlot operations	Condition		Status	pass
Sensor Component	Large parking lot	Condition		Status	pass
Sensor Component	Limited agriculture operations	Condition		Status	pass
Sensor Component	Major industrial source	Condition		Status	pass
Sensor Component	Secondary road < or = 100 per da	Condition		Status	pass
Sensor Component	Secondary road >100 vehicles/da	Condition		Status	pass
Sensor Component	Small parking lot	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Major highway, airport, or rail yard	Condition		Status	pass
Sensor Component	Intensive agriculture operations	Condition		Status	pass

Infrastructure Data For

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

02/17/2025

Shelter Make

Shelter One

Shelter Model

E-8109-26012-2

Shelter Size

720 cuft

Sensor Component	Sample Tower Type	Condition	Type B	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Moisture Trap Type	Condition	Glass bottle and filter	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Shelter walls	Condition	Good	Status	pass
Sensor Component	Excessive mold present	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample train is leak tested every two weeks.

2 Parameter: SitingCriteriaCom

The site is located 40 km southeast of Amarillo TX which has a population of approximately 178,000.

3 Parameter: ShelterCleanNotes

The shelter is in good condition.

4 Parameter: MetSensorComme

The meteorological tower and sensors have been removed.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID	PAL190	Technician	Martin Valvur	Site Visit Date	02/17/2025
Site Sponsor (agency)	EPA	USGS Map	Fortress Cliff		
Operating Group	TX A&M University	Map Scale			
AQS #	48-381-9991	Map Date			
Meteorological Type	R.M. Young				
Air Pollutant Analyzer	Ozone	QAPP Latitude			
Deposition Measurement	dry, wet	QAPP Longitude			
Land Use	agriculture	QAPP Elevation Meters			
Terrain	Complex	QAPP Declination			
Conforms to MLM	Marginally	QAPP Declination Date			
Site Telephone		Audit Latitude	34.88061		
Site Address 1		Audit Longitude	-101.664703		
Site Address 2		Audit Elevation	1053		
County	Randall	Audit Declination	6.6		
City, State	Canyon, TX				
Zip Code	79015	Fire Extinguisher	<input checked="" type="checkbox"/>	Present	No inspection date
Time Zone	Central	First Aid Kit	<input checked="" type="checkbox"/>		
Primary Operator		Safety Glasses	<input type="checkbox"/>		
Primary Op. Phone #		Safety Hard Hat	<input checked="" type="checkbox"/>		
Primary Op. E-mail		Climbing Belt	<input type="checkbox"/>		
Backup Operator		Security Fence	<input checked="" type="checkbox"/>		
Backup Op. Phone #		Secure Shelter	<input checked="" type="checkbox"/>		
Backup Op. E-mail		Stable Entry Steps	<input checked="" type="checkbox"/>		
Shelter Working Room	<input checked="" type="checkbox"/>	Make	Shelter One	Model	E-8109-26012-2
		Shelter Size	720 cuft		
Shelter Clean	<input checked="" type="checkbox"/>	Notes	The shelter is in good condition.		
Site OK	<input checked="" type="checkbox"/>	Notes			
Driving Directions	From I27 take exit 99 and go east on Hungate road to the first stop sign. Turn right (south) onto Eastern which is a dirt road. At the next intersection turn left (east) on Lawrence (also dirt). Continue and follow sharp left turn onto Pullman. Continue and follow sharp right turn onto game lands. Continue through two gates and past storage building. Site will be visible on the left.				

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

02/17/2025

1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	<input checked="" type="checkbox"/>	N/A
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	<input checked="" type="checkbox"/>	N/A
3	Are the tower and sensors plumb?	<input checked="" type="checkbox"/>	N/A
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	<input checked="" type="checkbox"/>	
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)	<input checked="" type="checkbox"/>	
6	Is the solar radiation sensor plumb?	<input checked="" type="checkbox"/>	N/A
7	Is it sited to avoid shading, or any artificial or reflected light?	<input checked="" type="checkbox"/>	N/A
8	Is the rain gauge plumb?	<input checked="" type="checkbox"/>	N/A
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	<input checked="" type="checkbox"/>	N/A
10	Is the surface wetness sensor sited with the grid surface facing north?	<input checked="" type="checkbox"/>	N/A
11	Is it inclined approximately 30 degrees?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological tower and sensors have been removed.

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

02/17/2025

1	Do all the meterological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

02/17/2025

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	<input checked="" type="checkbox"/>	
2	Are the sample inlets 3 - 15 meters above the ground?	<input checked="" type="checkbox"/>	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	<input checked="" type="checkbox"/>	

Pollutant analyzers and deposition equipment operations and maintenance

1	Do the analyzers and equipment appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>	
2	Are the analyzers and monitors operational, on-line, and reporting data?	<input checked="" type="checkbox"/>	
3	Describe ozone sample tube.		1/4 teflon by 15 meters
4	Describe dry dep sample tube.		3/8 teflon by 15 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	<input checked="" type="checkbox"/>	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	<input checked="" type="checkbox"/>	
7	Is the zero air supply desiccant unsaturated?	<input checked="" type="checkbox"/>	
8	Are there moisture traps in the sample lines?	<input checked="" type="checkbox"/>	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	<input checked="" type="checkbox"/>	Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

02/17/2025

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>										
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>										
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>										
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>										
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>										
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>										
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>										
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>										
9	Is the met tower stable and grounded?	<table><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input type="checkbox"/>		<input type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	
Stable		Grounded										
<input type="checkbox"/>		<input type="checkbox"/>										
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>										
10	Is the sample tower stable and grounded?											
11	Tower comments?	<div>met tower removed</div>										

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

02/17/2025

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2014	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	Oct 2014	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	Electronic copy	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>		<input type="checkbox"/>

1

Is the station log properly completed during every site visit?

☒

2

Are the Site Status Report Forms being completed and current?

☒

3

Are the chain-of-custody forms properly used to document sample transfer to and from lab?

☒

4

Are ozone z/s/p control charts properly completed and current?

☐

Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

02/17/2025

Site operation procedures

1

Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?

☐

Trained by previous operator

2

Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?

☒

Trained on site by current operator

3

Is the site visited regularly on the required Tuesday schedule?

☒

4

Are the standard CASTNET operational procedures being followed by the site operator?

☒

5

Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

☒

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze	<input type="checkbox"/>	N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>

1

Do multi-point calibration gases go through the complete sample train including all filters?

☐

Unknown

2

Do automatic and manual z/s/p gasses go through the complete sample train including all filters?

☒

3

Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

☒

SSRF

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone sample train is leak tested every two weeks.

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

02/17/2025

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

PAL190

Technician

Martin Valvur

Site Visit Date

02/17/2025

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	FF3MC12	07056
DAS	Campbell	CR3000	2122	000343
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA110	11920011905	02752
Flow Rate	Apex	AXMC105LPMDPC	illegible	000858
Infrastructure	Infrastructure	none	none	none
Modem	Digi	LR54	Illegible	07175
Ozone	ThermoElectron Inc	49i A1NAA	1105347314	000726
Ozone Standard	ThermoElectron Inc	49i A3NAA	0726124696	000375
Sample Tower	Aluma Tower	B	AT-7200-582	missing
Shelter Temperature	Campbell	107-L	10755-148	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	12542	06303
Zero air pump	Werther International	C 70/4	000836217	06922

Site Inventory by Site Visit

Site Visit Date		Parameter	Mfg	Owner ID	Model Number	Serial Number
CHA467-Martin Valvur-03/31/2025						
1	3/31/2025	DAS	Environmental Sys Corp	90611	8816	2613
2	3/31/2025	Ozone	ThermoElectron Inc	none	49i A3NAA	CM08460007
3	3/31/2025	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	CM08460051
4	3/31/2025	Zero air pump	Werther International	none	PC70/4	531392

Ozone Data Form

Mfg

Serial Number

Ta

Site

Technician

Site Visit Date

Parameter

Owner ID

ThermoElectron Inc

CM08460007

CHA467

Martin Valvur

03/31/2025

Ozone

none

Slope:

1.00226

Slope:

0.00000

Intercept

-0.19243

Intercept

0.00000

CorrCoff

1.00000

CorrCoff

0.00000

DAS 1:

DAS 2:

A Avg % Diff:

A Max % Di

A Avg %Diff

A Max % Di

0.0%

0.0%

Mfg

ThermoElectron Inc

Parameter

ozone

Serial Number

CM23147126

Tfer Desc.

Ozone primary stan

Tfer ID

01116

Slope

0.99260

Intercept

0.04790

Cert Date

4/10/2024

CorrCoff

0.99999

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif	
primary	1	0.26	0.21	0.05	ppb		-0.16	
primary	2	14.37	14.25	13.97	ppb		-0.28	
primary	3	32.19	31.98	31.96	ppb	-0.06		
primary	4	62.82	62.46	62.41	ppb	-0.08		
primary	5	114.36	113.75	113.80	ppb	0.04		
Sensor Component	Audit Pressure		Condition	628 mmHg		Status	pass	
Sensor Component	26.6 degree unobstructed rule		Condition	True		Status	pass	
Sensor Component	Tree dewline >10m or below inlet		Condition	True		Status	pass	
Sensor Component	ADT 1000-10000 vehicles further		Condition	True		Status	pass	
Sensor Component	ADT <1000 vehicles further than		Condition	True		Status	pass	
Sensor Component	Sample Train		Condition	Good		Status	pass	
Sensor Component	Inlet Filter Condition		Condition	Clean		Status	pass	
Sensor Component	Offset		Condition	-0.1		Status	pass	
Sensor Component	Span		Condition	1.025		Status	pass	
Sensor Component	Zero Voltage		Condition	0.000		Status	pass	
Sensor Component	Fullscale Voltage		Condition	0.9999		Status	pass	
Sensor Component	Cell A Freq.		Condition	101.2 kHz		Status	pass	
Sensor Component	Cell A Noise		Condition	1.8 ppb		Status	pass	
Sensor Component	Cell A Flow		Condition	0.70 lpm		Status	pass	
Sensor Component	Cell A Pressure		Condition	631.5 mmHg		Status	pass	
Sensor Component	Cell A Tmp.		Condition	35.0 C		Status	pass	
Sensor Component	Cell B Freq.		Condition	85.1 kHz		Status	pass	
Sensor Component	Cell B Noise		Condition	1.4 ppb		Status	pass	
Sensor Component	Cell B Flow		Condition	0.67 lpm		Status	pass	
Sensor Component	Cell B Pressure		Condition	631.2 mmHg		Status	pass	
Sensor Component	Nafion dryer installed		Condition	False		Status	pass	
Sensor Component	System Memo		Condition			Status	pass	

APPENDIX B

CASTNET Site Spot Report Forms

EEMS Spot Report

Data Compiled: 2/18/2025 3:12:07 PM

SiteVisitDate	Site	Technician
02/10/2025	ALC188	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.10	c	P
2	Temperature max error	P	4	0.5	6	0.17	c	P
3	Ozone Slope	P	0	1.1	4	0.96984	unitless	P
4	Ozone Intercept	P	0	5	4	-0.07461	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	3.6	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.04	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.64	ppb	P
9	Flow Rate average % difference	P	10	5	3	2.76	%	P
10	Flow Rate max % difference	P	10	5	3	3.47	%	P
11	DAS Voltage average error	P	4	0.003	16	0.0000	V	P
12	Shelter Temperature average error	P	5	2	21	0.63	c	P
13	Shelter Temperature max error	P	5	2	21	0.68	c	P

Field Performance Comments

- 1

Parameter:

Flow Rate

SensorComponent:

Moisture Present

CommentCode:

72
- The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

- 1

Parameter:

DocumentationCo
- WIFI available at site and manuals and documents maintained on the site computer.
- 2

Parameter:

SitingCriteriaCom
- The site is well located with respect to CASTNET siting criteria, however there is a small campground 0.5 km to the northwest which may be a source of smoke.
- 3

Parameter:

ShelterCleanNotes
- The site is clean and neat.
- 4

Parameter:

PollAnalyzerCom
- There are moisture traps in both the flow and ozone sample lines.

EEMS Spot Report

Data Compiled: 2/18/2025 3:15:10 PM

SiteVisitDate	Site	Technician
02/12/2025	BBE401	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99424	unitless	P
2	Ozone Intercept	P	0	5	4	-0.34373	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99994	unitless	P
4	Ozone % difference avg	P	7	10	4	2.8	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.33	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.86	ppb	P
7	Flow Rate average % difference	P	10	5	3	0.70	%	P
8	Flow Rate max % difference	P	10	5	3	0.77	%	P
9	DAS Voltage average error	P	4	0.003	1	0.0000	V	P
10	Shelter Temperature average error	P	5	2	24	0.14	c	P
11	Shelter Temperature max error	P	5	2	24	0.20	c	P

Field Performance Comments

- 1

Parameter:

Temperature2mete

SensorComponent:

System Memo

CommentCode:

217
- Temperature and relative humidity are being measured using a combination sensor which cannot be submerged in a water bath for audits.

Field Systems Comments

- 1

Parameter:

DasComments

Met tower no longer in use.
- 2

Parameter:

SiteOpsProcedures

The ozone sample line is leak tested every two weeks when the inlet filter is replaced.
- 3

Parameter:

ShelterCleanNotes

The shelter is clean, neat, and well organized.
- 4

Parameter:

MetSensorComme

Meteorological parameters are being measured with an "all-in-one" sensor which is not submergible. Temperature data were not available for display on the site DAS and it was not tested.

EEMS Spot Report

Data Compiled: 2/18/2025 3:46:54 PM

SiteVisitDate	Site	Technician
02/14/2025	CAV436	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.39	c	P
2	Temperature max error	P	4	0.5	3	0.97	c	Fail
3	Ozone Slope	P	0	1.1	4	0.98395	unitless	P
4	Ozone Intercept	P	0	5	4	-0.09027	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	2.2	%	P
7	Ozone Absolute Difference g1	P	7	3	1	0.08	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.42	ppb	P
9	DAS Voltage average error	P	4	0.003	5	0.0000	V	P
10	Shelter Temperature average error	P	5	2	12	0.29	c	P
11	Shelter Temperature max error	P	5	2	12	0.59	c	P

Field Performance Comments

- 1

Parameter:

Temperature

SensorComponent:

System Memo

CommentCode:

217
- Temperature and relative humidity are being measured using a combination sensor which cannot be submerged in a water bath for audits.

Field Systems Comments

- 1

Parameter:

SiteOpsProcComm
- Dry deposition samples are not collected at this site.
- 2

Parameter:

DocumentationCo
- The site is visited every other Tuesday. WIFI is available at the station and manuals and documents can be obtained online.
- 3

Parameter:

MetSensorComme
- The 2-meter temperature sensor has been replaced with an "all-in-one" meteorological sensor mounted at 10m on the sample tower. The sensor cannot be submerged and was tested by placing the RTD standard inside the naturally aspirated shield next to the site sensor.

EEMS Spot Report

Data Compiled: 4/8/2025 12:33:56 PM

Site	Visit Date	Technician
CHA467	03/31/2025	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00226	unitless	P
2	Ozone Intercept	P	0	5	4	-0.19243	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	0.5	%	P
5	Ozone Absolute Difference g1	P	7	3	1	-0.16	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.28	ppb	P

EEMS Spot Report

Data Compiled: 3/2/2025 8:54:24 PM

SiteVisitDate	Site	Technician
02/17/2025	PAL190	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	27	0.12	c	P
2	Temperature max error	P	4	0.5	27	0.27	c	P
3	Ozone Slope	P	0	1.1	4	0.92999	unitless	P
4	Ozone Intercept	P	0	5	4	0.19685	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
6	Ozone % difference avg	P	7	10	4	6.4	%	P
7	Ozone Absolute Difference g1	P	7	3	1	-0.05	ppb	P
8	Ozone Absolute Difference g2	P	7	1.5	1	-0.92	ppb	P
9	Flow Rate average % difference	P	10	5	3	0.11	%	P
10	Flow Rate max % difference	P	10	5	3	0.33	%	P
11	DAS Voltage average error	P	4	0.003	15	0.0000	V	P
12	Shelter Temperature average error	P	5	2	27	0.19	c	P
13	Shelter Temperature max error	P	5	2	27	0.28	c	P

SiteVisitDate	Site	Technician
02/17/2025	PAL190	Martin Valvur

Field Systems Comments

- 1

Parameter:

SiteOpsProcedures

The ozone sample train is leak tested every two weeks.
- 2

Parameter:

SitingCriteriaCom

The site is located 40 km southeast of Amarillo TX which has a population of approximately 178,000.
- 3

Parameter:

ShelterCleanNotes

The shelter is in good condition.
- 4

Parameter:

MetSensorComme

The meteorological tower and sensors have been removed.

EEMS Spot Report

Data Compiled: 4/8/2025 12:08:38 PM

Site	Visit Date	Technician
SUM156	02/07/2025	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98252	unitless	P
2	Ozone Intercept	P	0	5	4	-0.15045	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	2.8	%	P
5	Ozone Absolute Difference g1	P	7	3	1	0.19	ppb	P
6	Ozone Absolute Difference g2	P	7	1.5	1	-0.58	ppb	P