

NPDES PERMIT NO. NM0031178
RESPONSE TO COMMENTS

RECEIVED ON THE SUBJECT DRAFT NATIONAL POLLUTANT DISCHARGE
ELIMINATION SYSTEM (NPDES) PERMIT IN ACCORDANCE WITH REGULATIONS
LISTED AT 40 CFR 124.17

APPLICANT: Camino Real Regional Utility Authority
North Wastewater Treatment Plant
P.O. Box 429
Sunland Park, NM 88063

ISSUING OFFICE: U.S. Environmental Protection Agency
Region 6
1201 Elm Street
Dallas, Texas 75270

PREPARED BY: Quang Nguyen
Environmental Engineer
Permitting and Water Quality Branch
Water Division
VOICE: 214-665-7238
FAX: 214-665-2191
EMAIL: Nguyen.Quang@epa.gov

PERMIT ACTION: Final permit decision and response to comments received on the proposed NPDES permit publicly noticed on April 12, 2025.

DATE PREPARED: June 9, 2025

Unless otherwise stated, citations to 40 CFR refer to promulgated regulations listed at Title 40, Code of Federal Regulations, revised as of June 6, 2025.

DOCUMENT ABBREVIATIONS

In the document that follows, various abbreviations are used. They are as follows:

4Q3	Lowest four-day average flow rate expected to occur once every three years
BAT	Best available technology economically achievable
BCT	Best conventional pollutant control technology
BPT	Best practicable control technology currently available
BMP	Best management plan
BOD	Biochemical oxygen demand (five-day unless noted otherwise)
BPJ	Best professional judgment
CBOD	Carbonaceous biochemical oxygen demand (five-day unless noted otherwise)
CD	Critical dilution
CFR	Code of Federal Regulations
Cfs	Cubic feet per second
COD	Chemical oxygen demand
COE	United States Corp of Engineers
CWA	Clean Water Act
DMR	Discharge monitoring report
ELG	Effluent limitations guidelines
EPA	United States Environmental Protection Agency
ESA	Endangered Species Act
FCB	Fecal coliform bacteria
F&WS	United States Fish and Wildlife Service
mg/L	Milligrams per liter
µg/L	Micrograms per liter
MGD	million gallons per day
NMAC	New Mexico Administrative Code
NMED	New Mexico Environment Department
NMIP	New Mexico NPDES Permit Implementation Procedures
NMWQS	New Mexico State Standards for Interstate and Intrastate Surface Waters
NPDES	National Pollutant Discharge Elimination System
ML	Minimum quantification level
O&G	Oil and grease
PCB	Polychlorinated Biphenyl
PFAS	Per- and Polyfluoroalkyl Substances
POTW	Publically owned treatment works
RP	Reasonable potential
SIC	Standard industrial classification
s.u.	Standard units (for parameter pH)
SWQB	Surface Water Quality Bureau
TDS	Total dissolved solids
TMDL	Total maximum daily load
TRC	Total residual chlorine
TSS	Total suspended solids
UAA	Use attainability analysis
USGS	United States Geological Service
WLA	Wasteload allocation
WET	Whole effluent toxicity
WQCC	New Mexico Water Quality Control Commission
WQMP	Water Quality Management Plan
WWTP	Wastewater treatment plant

SUBSTANTIAL CHANGES FROM DRAFT PERMIT

1. Included the reporting requirements for the 30-day average concentration and 30-day average loading as well as the effluent limits for the daily maximum concentration and daily maximum loading for dissolved Boron to the final permit.
2. Revised effluent limits for Arsenic (Total), Selenium (Total), Bis(2-ethylhexyl) Phthalate, and Butyl Benzyl Phthalate and included these limits to the final permit.

STATE CERTIFICATION

In a letter from Ms. Shelly Lemon, Bureau Chief, SWQB, to Mr. Scott Mason IV, Regional Administrator dated May 20, 2025, the NMED certified that the discharge will comply with the applicable provisions of Section 208(e), 301, 301, 303, 306 and 307 of the Clean Water Act and with appropriate requirements of State law.

The NMED stated that to meet the requirements of State law, including water quality standards and appropriate basin plan as may be amended by the water quality management plan, each of the conditions cited in the draft permit and the State certification shall not be made less stringent.

The State also stated that it reserves the right to amend or revoke this certification if such action is necessary to ensure compliance with the State's water quality standards and water quality management plan.

Condition of Certification

Condition No. 1: Effluent Limitation for Dissolved Boron

The draft permit did not contain the loading limitation from the waste load allocation (WLA) for boron in the Lower Rio Grande in the effluent limits. To protect and maintain existing and downstream water quality and to prevent further degradation of water quality in the Rio Grande Basin, the final permit must be corrected to add the following 30-day average loading effluent limitation and daily maximum for dissolved boron in Part I, Requirements for NPDES permits, Section A. Limitation and Monitoring Requirements.

Pollutant	30-day avg.	7-day avg.	Daily Max	30-day avg.	7-day avg.	Daily Max	Measurement Frequency	Sample Type
Boron, Dissolved	Report (lbs/day)	***	6.26 lbs/day	Report (mg/L)	***	0.75 mg/L	2/week	Grab

[20.6.4(H) NMAC – General Criteria; 20.6.4.101 NMAC – Rio Grande Basin; State of New Mexico Water Quality Management Plan and Continuing Planning Process (WQMP/CPP), including Appendix A; 2024-2026 State of New Mexico CWA §303(d) / §305(b) Integrated Report; State of New Mexico Total Maximum Daily Loads for the Gila/Mimbres/San Francisco and Lower Rio Grande Basins; EPA Region VI Procedures for Implementing National Pollutant Discharge Elimination System Permits in New Mexico (NMIP)]
(Please see Appendix 1 for the detail of this condition)

Background for Condition #1: Effluent Limitation for Dissolved Boron

Regulatory Citations/ Guidance:

New Mexico Administrative Code (NMAC), available at <https://www.srca.nm.gov/nmac-home/nmac-titles/title-20-environmental-protection/chapter-6-water-quality/>

20.6.4.13 GENERAL CRITERIA

H. Pathogens: Surface waters of the state shall be free of pathogens from other than natural causes in sufficient quantity to impair public health or the designated, existing or attainable uses of a surface water of the state.

20.6.4.101 RIO GRANDE BASIN: The main stem of the Rio Grande from the international boundary with Mexico upstream to one mile downstream of Percha Dam.

A. Designated uses: irrigation, marginal warmwater aquatic life, livestock watering, wildlife habitat and primary contact.

B. Criteria: The use-specific numeric criteria set forth in 20.6.4.900 NMAC are applicable to the designated uses except that the following segment-specific criterion applies: temperature 34°C (93.2°F) or less. At mean monthly flows above 350 cfs, the monthly average concentration for: TDS 2,000 mg/L or less, sulfate 500 mg/L or less and chloride 400 mg/L or less.

Statewide Water Quality Management Plan and Continuing Planning Process (2020 WQMP/CPP), available at <https://www.env.nm.gov/surface-water-quality/wqmp-cpp/>

Part IV – Total Maximum Daily Load (TMDL)

D. TMDL Implementation: As TMDLs are developed and approved, they are incorporated into Appendix B-1 of this WQMP/CPP and used as the basis for implementation of water pollution control activities. For point sources, TMDLs are implemented through NPDES permits (see Section V), whereas for nonpoint sources, TMDLs are implemented through the Nonpoint Source Management Program (NPSMP; see Section VII).

Part V – Effluent Limitations

A. Introduction

If a WLA has been developed in a TMDL, the permitting authority is required to incorporate it into the NPDES permit. A TMDL details the assumptions and processes used to develop the WLA. EPA's Technical Support Document (TSD) procedures should be used by the permitting authority to incorporate the WLA into the NPDES permit. However, if no TMDL has been established, the permitting authority reviews effluent discharge data to ensure that NPDES permits are protective of WQS. For all pollutants that have a reasonable potential to cause or contribute to a violation of a water quality standard, the permitting authority performs calculations or modeling to determine effluent limitations for those pollutants. This review is done in accordance with applicable federal regulations and guidance. Specific evaluations for NPDES permits issued in New Mexico are discussed in the EPA Region 6 document Procedures for

Implementing NPDES Permits in New Mexico (NMIP) developed by EPA in consultation with NMED.

2024-2026 State of New Mexico CWA §303(d) / §305(b) Integrated Report, available at <https://www.env.nm.gov/surface-water-quality/303d-305b/>

Rio Grande (International Mexico bnd to TX border)			AU IR CATEGORY	LOCATION DESCRIPTION	
			5/5A	HUC: 13030102	El Paso-Las Cruces
AU ID	WQS REF	WATER TYPE	SIZE	ASSESSED	MONITORING SCHEDULE
NM-2101_00	20.6.4.101	RIVER	7.95 MILES	2022	2029
USE	ATTAINMENT	CAUSE(S)	FIRST LISTED	TMDL DATE	PARAMETER IR CATEGORY
IRR	Not Supporting	Boron, Dissolved	2014	2023 (est.)	5/5A
LW	Fully Supporting				
MWWAL	Fully Supporting				
PC	Fully Supporting				
WH	Fully Supporting				

AU Comment: TMDL for E. coli. 2023 TMDL pending WQCC approval

Total Maximum Daily Loads for Gila/Mimbres/San Francisco and Lower Rio Grande Basins, available at https://www-q.env.nm.gov/surface-water-quality/wp-content/uploads/sites/18/2024/08/EPA-Approved-Gila-LRG-TMDL_082024.pdf

A dissolved boron waste load allocation for the Rio Grande (International Mexico bnd to TX border), assessment unit in the Lower Rio Grande Basin was included in the 2024 Total Maximum Daily Loads for the Gila/Mimbres/San Francisco and Lower Rio Grande Basins). The 2024 Total Maximum Daily Load for the Gila/Mimbres/San Francisco and Lower Rio Grande Basins was approved by the Water Quality Control Commission (WQCC) on July 9, 2024, and the EPA on August 20, 2024. The TMDL assigned a WLA of 6.26 lbs/day for dissolved boron to CRRUA's Sunland Park North WWTP.

EPA Region VI's Procedures for Implementing NPDES Permits in New Mexico (2012 NMIP), available at <https://www.epa.gov/tx/procedures-implementing-national-pollutant-discharge-elimination-system-permits-new-mexico-nmip>

Part IV – Establishing Water Quality – Based Toxic Effluent Limitations

M. TMDL Strategy

40 CFR 122.44(d)(1) requires the permitting authority to establish permit conditions which achieve water quality standards. In addition, 40 CFR 130.7(c) requires TMDLs to be established at levels necessary to attain and maintain the applicable narrative and numerical water quality standards. Lastly, 40 CFR 122.44(d)(1)(vii)(B) requires that NPDES permit conditions must be consistent with the assumptions and requirements of an available waste load allocation (WLA) in a TMDL. These, approved loads are then incorporated into the State's WQMPs and NPDES permits. To meet the Federal requirements and meet State water quality requirements, permits

must meet those conditions of TMDLs that can be implemented in permits. Facilities that discharge the parameter of concern addressed in an approved or established TMDL generally fall into two groups and will need to be permitted in specific ways. Where the approved or established TMDL assigns an individual WLA to a specific discharger, the permit writer will permit per the TMDL condition. Where the approved or established TMDL does not include a specific WLA for a discharger, the WQMP will need to be revised to include the facility with a specific WLA or reference a specific WLA for that facility (which may require a revision of the TMDL). In either case, specific WLAs or conditions of the TMDL, which can include target parameter concentrations, in lieu of specific WLAs, will need to be included in permits. Pollutants with a specific numeric standard can be implemented at the point of discharge. Narrative or general water quality standards that cannot be implemented through a point of discharge limit will require additional modeling, as determined acceptable by EPA, to demonstrate compliance with the TMDL. Effluent trading, to allow new dischargers or allow expansion for existing discharges, will need to be verifiable and in all affected permits, consistent with EPA policy. Incorporation of conditions of the TMDL may occur at reissuance of the permit, or the permit may be reopened to incorporate those conditions if they are of an immediate health and safety concern.

N. Determining Compliance with Water Quality Objectives and Water Quality Based Effluent Limitations

1. Water Quality Management Plan Compliance

Federal regulations state that NPDES permit limitations must reflect water quality standards and State requirements per WQMP (40 CFR 122.44 (d)(6)). This regulation requires that permits be at least consistent with State WQMP, which means that permit writers must incorporate at least the requirements of WQMP, any WLAs or specified statewide or basin specific parameter concentration target but may include more stringent water quality standards in permits.

Regulation Rationale:

The Camino Real Regional Utility Authority (CRRUA) Sunland Park North Wastewater Treatment Plant (WWTP) discharges treated effluent into the Rio Grande in Water Quality Segment 20.6.4.101 NMAC of the Rio Grande Basin. The designated uses for the stream are irrigation, marginal warmwater aquatic life, livestock watering, wildlife habitat and primary contact.

State water quality standards consist of various components such as designated uses, water quality criteria, and the WQMP/CPP. The primary purpose of the WQMP/CPP is to provide a concise summary of the water quality management system in New Mexico. The WQMP is used to direct implementation of New Mexico water quality programs intended to provide a consistent approach to preserve, protect, and improve the water quality by ensuring that water quality standards are established to protect designated uses, the quality of water, and point (and nonpoint

sources) that may impact water quality. The WQMP/CPP requires that approved TMDLs and WLAs be incorporated in point source NPDES permits.

The NMIP also requires the incorporation of TMDLs and WLAs into point source NPDES permits.

The approved WLA described in the Total Maximum Daily Loads for the Gila/Mimbres/San Francisco and Lower Rio Grande Basins must be implemented in the CRRUA Sunland Park North NPDES permit to protect designated uses and prevent further degradation of the Rio Grande.

Response: The EPA concurs and has included the recommended reporting requirements for 30-day average concentration and 30-day average loading, as well as the effluent limits for the daily maximum concentration of 0.75 mg/L and daily maximum loading of 6.26 lbs/day for dissolved Boron to the final permit.

Comments that are not Conditions of Certification

Comment No. 1:

Doña Ana County voted to terminate its Joint Powers Agreement with the City on Sunland Park for the Camino Real Regional Utility Authority (CRRUA) on May 13, 2025. (See <https://www.donaanacounty.org/Home/Components/News/News/878/>.) This dissolution will result in a change in wastewater treatment plant operator during the permit term. NMED requests that EPA include the process that CRRUA, Doña Ana County (DAC), and the City of Sunland Park should follow to notify EPA on the change in operator. NMED should be copied on the change in operator notification submittals.

Response: The EPA agrees with NMED and modified PART III Section D.3 of the final permit (TRANSFERS) with the following languages.

This permit is not transferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act.

As an alternative to transfers described above, under 40 CFR 122.61(b) any NPDES permit may be automatically transferred to a new permittee if:

- (1) The current permittee notifies the Director at least 30 days in advance of the proposed transfer.
- (2) The notice includes a written agreement between the existing and new permittees containing a specific date for transfer of permit responsibility, coverage, and liability between them; and
- (3) The Director does not notify the existing permittee and the proposed new permittee of his or her intent to modify or revoke and reissue the permit. A modification under this

subparagraph may also be a minor modification under 40 CFR 122.63. If this notice is not received, the transfer is effective on the date specified in the agreement mentioned in item 2 of this section.

A copy of any transfer request must also be provided to NMED.

Comment No. 2:

Part I. Requirements for NPDES Permits, Section A. Limitation and Monitoring Requirements, Subsection 1. Final Effluent Limits – 1.0 MGD Design Flow

The standard loading equation, using a conversion factor for liters to gallons is:

$$\text{Loading [lbs/day]} = \text{concentration [mg/L]} \times \text{flow [MGD]} \times 8.34$$

The effluent loading limitations (lbs/day) for daily maximum and monthly average for the following pollutants are calculated incorrectly in the draft permit and draft fact sheet.

- a. Arsenic, dissolved
- b. Selenium, total recoverable
- c. Bis(2-ethylhexyl) Phthalate
- d. Butyl Benzyl Phthalate Please see the table below which outlines the effluent loading limitations calculated using the standard conversion.

Fact Sheet. Table 5: Effluent limits

Parameters	Daily Max. (µg/L)	Monthly Avg. (µg/L)	Daily Max Loading (lbs/day)	Monthly Avg. Loading (lbs/day)
Arsenic, Dissolved	9	9.69	0.07511	0.08086
Selenium, Total Recoverable	5	5	0.04173	0.04173
Bis(2-ethylhexyl) Phthalate	4.182	3.7	0.03490	0.03088
Butyl Benzyl Phthalate	1.115	1	0.00930	0.00835

NMED requests that EPA review and revise the loading limitations in the permit accordingly.

Response: The EPA agrees with NMED, reviewed the previously conducted water quality based reasonable potential screening (RP) analysis and made corrections to the effluent limits for Arsenic (Total), Selenium (Total), Bis(2-ethylhexyl) Phthalate, and Butyl Benzyl Phthalate in the final permit. Reviewing the previously conducted RP analysis, EPA found a typo in the input. The EPA reran a RP analysis with correction. Like the results of the previously conducted RP analysis, Arsenic (Total), Selenium (Total), Bis(2-ethylhexyl) Phthalate, and Butyl Benzyl Phthalate in the revised RP analysis are found to have reasonable potential to violate New Mexico WQS consistent with the designated uses for the receiving waterbody (see Appendix 1). Based on the revised RP analysis, EPA revised effluent limits for the mentioned pollutants in the final permit (see table below).

Parameters	Daily Max. (µg/L)	Monthly Avg. (µg/L)	Daily Max Loading (lbs/day)	Monthly Avg. Loading (lbs/day)
Arsenic, Total	32.616	28.269	0.272	0.236
Selenium, Total	5	5	0.0417	0.0417
Bis(2-ethylhexyl) Phthalate	4.663	3.7	0.0389	0.0308
Butyl Benzyl Phthalate	1.23	1	0.0102	0.00834

Comment No. 3:

Part 1. Requirements for NPDES Permits, Section B. Compliance Schedules

NMED requests EPA incorporate a compliance schedule to address the new effluent limitation for dissolved boron. NMED recommends a 36-month compliance schedule with quarterly updates to EPA and NMED.

Response: The EPA agrees and added a 36-month compliance schedule for dissolved Boron in the final permit.

Comment No. 4:

Part I. Requirements for NPDES Permits, Section D. Overflow Reporting

Overflows that endanger health or the environment are required to be reported to EPA and NMED. There is no public notification requirement for overflows that reach a water body and endanger human health of downstream users. NMED requests that EPA add a paragraph that requires permittees to coordinate with downstream users and stakeholders to develop a communications procedure or communication plan to notify the public of any overflows that reach a water body. Permittees should provide a copy of the public notification to NMED.

Response: The EPA agrees and added the following paragraph to the Part I (Requirements for NPDES Permits, Section D. Overflow Reporting) of the final permit.

The permittee shall coordinate with downstream users and stakeholders (i.e., TCEQ Border and Permian Area Director, TCEQ El Paso Regional Director, TCEQ El Paso Air/Water/Waste Section Manager, TCEQ Border Affair, etc.) to develop a communication procedure/plan to notify the public of any sewer overflows and bypass events. Permittees shall provide a copy of the developed communication procedure/plan to NMED.

Comment No. 5:

Part I. Requirements for NPDES Permits, Section D. Overflow Reporting

Texas is a downstream State on the Rio Grande. NMED requests EPA include notification to the Texas Commission on Environmental Quality (TCEQ) for any overflows that reach the Rio Grande. The TCEQ points of contact that should be notified are:

Ryan Slocum, TCEQ El Paso Regional Director, via email at ryan.slocum@tceq.texas.gov
Kent Waggoner, TCEQ El Paso Air/Water/Waste Section Manager, via email at kent.waggoner@tceq.texas.gov

Response: The draft permit has included 4 TCEQ contacts, 2 of whom are Ryan Slocum and Kent Waggoner, for any overflows that reach the Rio Grande. The EPA made no changes to the final permit.

Comment No. 6:

Part II. Other Conditions, Section B. 24-hour Oral Reporting: Daily Maximum Limitation Violations

The permittee is required to submit oral reports of daily maximum limitations to NMED and EPA. NMED requests to receive notifications via email to SWQ.Reporting@env.nm.gov.

Response: Comment noted. EPA added the email address to the final permit.

Comment No. 7:

Fact Sheet

The approval date for the most recent EPA-approved New Mexico water quality standards (NMWQS) in 20.6.4 NMAC is incorrect. NMED requests EPA update the Fact Sheet to reflect the most recent EPA-approval date of April 10, 2025, for NMWQS in 20.6.4 NMAC. For reference, see: <https://www.env.nm.gov/surface-water-quality/wqs-amendments/>.

Response: Comment noted for the record. No changes were made in the final permit.

Comment No. 8:

Fact Sheet

References to the State of New Mexico Clean Water Act §303(d)/§305(b) Integrated Report are outdated. The 2024–2026 Integrated Report was approved on May 17, 2024. NMED requests that EPA update the references to cite the current §303(d)/§305(b) Integrated Report. For reference, see: <https://www.env.nm.gov/surface-water-quality/303d-305b/>.

Response: Comment noted for the record. No changes were made in the final permit

Comment No. 9:

Fact Sheet. Section C. Water Quality Based Limitations, Subparagraph 5. Permit Action – Water Quality-Based Limits, Paragraph g. Boron

The Total Maximum Daily Load (TMDL) for the Gila/Mimbres/San Francisco and Lower Rio Grande Basins was approved by the Water Quality Control Commission on July 9, 2024, and approved by the EPA on August 20, 2024. The TMDL, available at https://www-q.env.nm.gov/surface-water-quality/wp-content/uploads/sites/18/2024/08/EPA-Approved-Gila-LRG-TMDL_082024.pdf, included a wasteload allocation for CRRUA North Wastewater Treatment Plant of 6.26 lbs/day of boron of CRRUA North for boron. NMED requests EPA update the fact sheet with this information.

Response: Comment noted for the record. The EPA has included the recommended reporting requirements for the 30-day average concentration and 30-day average loading, as well as the effluent limits for the daily maximum concentration of 0.75 mg/L and daily maximum loading of 6.26 lbs/day for dissolved Boron to the final permit.

CALCULATIONS OF NEW MEXICO WATER QUALITY-BASED EFFLUENT LIMITATIONS									
NMAC 20.6.4. NMWQS as of 2023 (EPA Approved January 19, 2023)									
Calculations Specifications:		Excel Revised (in red text) as of February 2023							
Prepared By:	Quang Nguyen	5-Jun-25		2:07 PM					
STEP 1:		REFERENCE IMPLEMENTATION PROCEDURES		APPENDIX 1					
		INPUT FACILITY AND RECEIVING STREAM DATA		of FACT SHEET					
		LIST SOURCE OF DATA INPUT							
IMPLEMENTATION PROCEDURES									
The State of New Mexico Standards for Interstate and Intrastate Surface Waters are implemented in this spread sheet by using procedures established in the current "Procedures for Implementing NPDES Permits in New Mexico"									
FACILITY				DATA INPUT					
Permittee				Camino RUA					
NPDES Permit No.				NMO031178					
Outfall No.(s)				1					
Plant Effluent Flow (MGD)				1		For industrial and federal facility, use the highest monthly average flow			
Plant Effluent Flow (cfs)				1.55		for the past 24 months. For POTWs, use the design flow.			
RECEIVING STREAM				DATA INPUT					
Receiving Stream Name				Rio Grande					
Basin Name				Rio Grande Basin					
Waterbody Segment Code No.				20.6.4.101					
Is a publicly owned lake or reservoir (enter "1" if it's a lake, "0" if not)				0					
Are acute aquatic life criteria considered (1=yes, 0=no)				1					
Are chronic aquatic life criteria considered (1=yes, 0=no)				1					
Are domestic water supply criteria considered (1=yes, 0=no)				0					
Are irrigation water supply criteria considered (1=yes, 0=no)				1					
Livestock watering and wildlife habitat criteria applied to all streams									
USGS Flow Station				USGS					
WQ Monitoring Station No.				SJR					
Receiving Stream TSS (mg/l)				254.16		For intermittent stream, enter effluent TSS			
Receiving Stream Hardness (mg/l as CaCO ₃)				RANGE 0 - 400 20		For intermittent stream, enter effluent Hardness (If no data, 20 mg/l is used)			
Receiving Stream Critical Low Flow (4Q3) (cfs)				0		Enter "0" for intermittent stream and lake.			
Receiving Stream Harmonic Mean Flow (cfs)				0.429		Enter harmonic mean or modified harmonic mean flow data or 0.001 if no data is available			
Avg. Receiving Water Temperature (C)				27.67					
pH (Avg), Receiving Stream				8.63					
Fraction of stream allowed for mixing (F)				1		Enter 1, if stream morphology data is not available or for intermittent streams.			
Fraction of Critical Low Flow				0					

STEP 2: INPUT AMBIENT AND EFFLUENT DATA																																																																																																																								
CALCULATE IN-STREAM WASTE CONCENTRATIONS																																																																																																																								
DATA INPUT		Input pollutant geometric mean concentration as micro-gram per liter (ug/l or ppb) unless other unit is specified for the parameter. Effluent value reported as "< detection level" (DL) but the DL is greater than MQL, input "1/2 DL" for calculation. Effluent value reported as "< detection level" (DL) and the DL is smaller than MQL, no data is inputted. If a less than MQL value is reported, input either the reported value or "0" for calculation. The following formula is used to calculate the Instream Waste Concentration (Cd) See the current "Procedures for Implementing NPDES Permits in New Mexico" $Cd = [(FQa * Ca) + (Qe * 2.13 * Ce)] / (FQa + Qe)$ Where: Cd = Instream Waste Concentration F = Fraction of stream allowed for mixing (see "Procedures for Implementing NPDES Permits in New Mexico") Ce = Reported concentration in effluent Ca = Ambient stream concentration upstream of discharge Qe = Plant effluent flow Qa = Critical low flow of stream at discharge point expressed as the 4Q3 or harmonic mean flow for human health criteria																																																																																																																						
The following formula convert metals reported in total form to dissolved form if criteria are in dissolved form See the current "Procedures for Implementing NPDES Permits in New Mexico" $Kp = Kpo * (TSS^a)$ $C/Ci = 1 / (1 + Kp * TSS * 10^{-6})$ Total Metal Criteria (Ci) = Cr / (C/Ci) Kp = Linear partition coefficient; Kpo and a can be found in table below TSS = Total suspended solids concentration found in receiving stream (or in effluent for intermittent stream) C/Ci = Fraction of metal dissolved; and Cr = Dissolved criteria value																																																																																																																								
<table border="1"> <thead> <tr> <th colspan="6">Stream Linear Partition Coefficient</th> <th colspan="6">Lake Linear Partition Coefficient</th> </tr> <tr> <th>Total Metals</th> <th>Total Value</th> <th>Kpo</th> <th>alpha (a)</th> <th>Kp</th> <th>C/Ci</th> <th>Dissolved Value in Stream</th> <th>Kpo</th> <th>alpha (a)</th> <th>Kp</th> <th>C/Ci</th> <th>Dissolved Value in Lake</th> </tr> </thead> <tbody> <tr> <td>Arsenic</td> <td></td> <td>480000</td> <td>-0.73</td> <td>8423.895681</td> <td>0.31836819</td> <td>#VALUE!</td> <td>480000</td> <td>-0.73</td> <td>8423.895681</td> <td>0.31836819</td> <td>#VALUE!</td> </tr> <tr> <td>Chromium III</td> <td>0.82</td> <td>3360000</td> <td>-0.93</td> <td>19480.02813</td> <td>0.168037744</td> <td>0.13779095</td> <td>2170000</td> <td>-0.27</td> <td>486497.6977</td> <td>0.008022575</td> <td>0.0065785</td> </tr> <tr> <td>Copper</td> <td>4.66</td> <td>1040000</td> <td>-0.74</td> <td>17268.47594</td> <td>0.185564705</td> <td>0.86473152</td> <td>2850000</td> <td>-0.9</td> <td>19509.60059</td> <td>0.167825781</td> <td>0.7820681</td> </tr> <tr> <td>Lead</td> <td>0</td> <td>2800000</td> <td>-0.8</td> <td>33348.19021</td> <td>0.105532254</td> <td>0</td> <td>2040000</td> <td>-0.53</td> <td>108373.5626</td> <td>0.035033357</td> <td>0</td> </tr> <tr> <td>Nickel</td> <td>2.35</td> <td>490000</td> <td>-0.57</td> <td>20858.59131</td> <td>0.1586944</td> <td>0.37293184</td> <td>2210000</td> <td>-0.76</td> <td>32848.14131</td> <td>0.106966932</td> <td>0.2513723</td> </tr> <tr> <td>Silver</td> <td></td> <td>2390000</td> <td>-1.03</td> <td>7964.114277</td> <td>0.330670413</td> <td>0</td> <td>2390000</td> <td>-1.03</td> <td>7964.114277</td> <td>0.330670413</td> <td>0</td> </tr> <tr> <td>Zinc</td> <td>54.3</td> <td>1250000</td> <td>-0.7</td> <td>25902.09976</td> <td>0.1318691</td> <td>7.16049211</td> <td>3340000</td> <td>-0.68</td> <td>77316.74632</td> <td>0.048424217</td> <td>2.629435</td> </tr> </tbody> </table>													Stream Linear Partition Coefficient						Lake Linear Partition Coefficient						Total Metals	Total Value	Kpo	alpha (a)	Kp	C/Ci	Dissolved Value in Stream	Kpo	alpha (a)	Kp	C/Ci	Dissolved Value in Lake	Arsenic		480000	-0.73	8423.895681	0.31836819	#VALUE!	480000	-0.73	8423.895681	0.31836819	#VALUE!	Chromium III	0.82	3360000	-0.93	19480.02813	0.168037744	0.13779095	2170000	-0.27	486497.6977	0.008022575	0.0065785	Copper	4.66	1040000	-0.74	17268.47594	0.185564705	0.86473152	2850000	-0.9	19509.60059	0.167825781	0.7820681	Lead	0	2800000	-0.8	33348.19021	0.105532254	0	2040000	-0.53	108373.5626	0.035033357	0	Nickel	2.35	490000	-0.57	20858.59131	0.1586944	0.37293184	2210000	-0.76	32848.14131	0.106966932	0.2513723	Silver		2390000	-1.03	7964.114277	0.330670413	0	2390000	-1.03	7964.114277	0.330670413	0	Zinc	54.3	1250000	-0.7	25902.09976	0.1318691	7.16049211	3340000	-0.68	77316.74632	0.048424217	2.629435
Stream Linear Partition Coefficient						Lake Linear Partition Coefficient																																																																																																																		
Total Metals	Total Value	Kpo	alpha (a)	Kp	C/Ci	Dissolved Value in Stream	Kpo	alpha (a)	Kp	C/Ci	Dissolved Value in Lake																																																																																																													
Arsenic		480000	-0.73	8423.895681	0.31836819	#VALUE!	480000	-0.73	8423.895681	0.31836819	#VALUE!																																																																																																													
Chromium III	0.82	3360000	-0.93	19480.02813	0.168037744	0.13779095	2170000	-0.27	486497.6977	0.008022575	0.0065785																																																																																																													
Copper	4.66	1040000	-0.74	17268.47594	0.185564705	0.86473152	2850000	-0.9	19509.60059	0.167825781	0.7820681																																																																																																													
Lead	0	2800000	-0.8	33348.19021	0.105532254	0	2040000	-0.53	108373.5626	0.035033357	0																																																																																																													
Nickel	2.35	490000	-0.57	20858.59131	0.1586944	0.37293184	2210000	-0.76	32848.14131	0.106966932	0.2513723																																																																																																													
Silver		2390000	-1.03	7964.114277	0.330670413	0	2390000	-1.03	7964.114277	0.330670413	0																																																																																																													
Zinc	54.3	1250000	-0.7	25902.09976	0.1318691	7.16049211	3340000	-0.68	77316.74632	0.048424217	2.629435																																																																																																													
The following formula is used to calculate hardness dependent criteria (Please refer to State Water Quality Standards for details)																																																																																																																								
<table border="1"> <thead> <tr> <th colspan="4"></th> <th>Dissolved</th> <th>WQC (ug/l)</th> </tr> </thead> <tbody> <tr> <td rowspan="2">Aluminum (T)</td> <td>Acute</td> <td colspan="2"></td> <td>$e^{(1.3695 \ln(\text{hardness})) + 1.8308}$</td> <td>377.4565069</td> <td>If Stream pH < 6.5, enter 750 in cell O114</td> </tr> <tr> <td>Chronic</td> <td colspan="2"></td> <td>$e^{(1.3695 \ln(\text{hardness})) + 0.9161}$</td> <td>151.2229667</td> <td>If Stream pH < 6.5, enter 87 in cell P114</td> </tr> <tr> <td rowspan="2">Cadmium (D)</td> <td>Acute</td> <td colspan="2"></td> <td>$e^{(0.8968 \ln(\text{hardness})) - 3.5699} * CF1$</td> <td>0.418091688</td> <td>CF1 = 1.136672 - 0.041838 * ln(hardness)</td> </tr> <tr> <td>Chronic</td> <td colspan="2"></td> <td>$e^{(0.7647 \ln(\text{hardness})) - 4.2180} * CF2$</td> <td>0.142116028</td> <td>CF2 = 1.101672 - 0.041838 * ln(hardness)</td> </tr> </tbody> </table>																	Dissolved	WQC (ug/l)	Aluminum (T)	Acute			$e^{(1.3695 \ln(\text{hardness})) + 1.8308}$	377.4565069	If Stream pH < 6.5, enter 750 in cell O114	Chronic			$e^{(1.3695 \ln(\text{hardness})) + 0.9161}$	151.2229667	If Stream pH < 6.5, enter 87 in cell P114	Cadmium (D)	Acute			$e^{(0.8968 \ln(\text{hardness})) - 3.5699} * CF1$	0.418091688	CF1 = 1.136672 - 0.041838 * ln(hardness)	Chronic			$e^{(0.7647 \ln(\text{hardness})) - 4.2180} * CF2$	0.142116028	CF2 = 1.101672 - 0.041838 * ln(hardness)																																																																												
				Dissolved	WQC (ug/l)																																																																																																																			
Aluminum (T)	Acute			$e^{(1.3695 \ln(\text{hardness})) + 1.8308}$	377.4565069	If Stream pH < 6.5, enter 750 in cell O114																																																																																																																		
	Chronic			$e^{(1.3695 \ln(\text{hardness})) + 0.9161}$	151.2229667	If Stream pH < 6.5, enter 87 in cell P114																																																																																																																		
Cadmium (D)	Acute			$e^{(0.8968 \ln(\text{hardness})) - 3.5699} * CF1$	0.418091688	CF1 = 1.136672 - 0.041838 * ln(hardness)																																																																																																																		
	Chronic			$e^{(0.7647 \ln(\text{hardness})) - 4.2180} * CF2$	0.142116028	CF2 = 1.101672 - 0.041838 * ln(hardness)																																																																																																																		

					Instream Waste Concentration							Livestock&	Acute	Chronic	Human	Need	
			Ambient	Effluent	Acute	Domestic	Chronic	Human	Domestic	Irrigation	Wildlife	Aquatic	Aquatic	Health	TMDL		
POLLUTANTS			Conc	Conc.	Aquatic	Supply	Aquatic	Health	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria			
		CAS No.	MQL	Ca (ug/l)	Ce (ug/l)	2.13*Ce	Cd,dom (ug/l)	Cd (ug/l)	Cd,hh (ug/l)	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l		
Mercury, dissolved		7439-97-6	0.005	7	34	0	0	0	0	1E+100	1E+100	1E+100	1.4	0.77	1E+100	N/A	
Mercury, total		7439-97-6	0.005			0	0	0	0	2	1E+100	0.77	1E+100	1E+100	1E+100	N/A	
Molybdenum, dissolved		7439-98-7				72.42	72.42	72.42	58.2385043	1E+100	1000	1E+100	1E+100	1E+100	1E+100	N/A	
Molybdenum, total recoverable		7439-98-7				78.81	78.81	78.81	61.7258717	1E+100	1E+100	1E+100	7920	1895	1E+100	N/A	
Nickel, dissolved (P)		7440-02-0	0.5			0.794344821	0.79434482	0.79434482	0.62214981	700	1E+100	1E+100	119.9874916	13.326906	4600	N/A	
Selenium, dissolved (P)		7782-49-2	5	0.372931841	7.160492115	0	0	0	0	50	130	50	1E+100	1E+100	4200	N/A	
Selenium, dis (SO4 >500 mg/l)		7782-49-2	5			0	0	0	0	50	250	50	1E+100	1E+100	4200	N/A	
Selenium, total recoverable		7782-49-2	5			10.3305	10.3305	10.3305	8.09109399	1E+100	1E+100	5	20	5	1E+100	N/A	
Silver, dissolved		7440-22-4	0.5			0	0	0	0	1E+100	1E+100	1E+100	0.201924903	1E+100	1E+100	N/A	
Thallium, dissolved (P)		7440-28-0	0.5			0	0	0	0	2	1E+100	1E+100	1E+100	1E+100	0.47	N/A	
Zinc, dissolved		7440-66-6	20	0	7.160492115	15.2518482	15.2518482	15.2518482	11.9456113	10500	2000	25000	37.02425804	28.048347	26000	N/A	
Cyanide, total recoverable		57-12-5	10			0	0	0	0	200	1E+100	5.2	22	5.2	140	N/A	
Dioxin		1746-01-6	0.00001			0	0	0	0	3.00E-05	1E+100	1E+100	1E+100	1E+100	5.1E-08	N/A	
VOLATILE COMPOUNDS																	
Acrolein		107-02-8	50			0	0	0	0	0	0	18	1E+100	1E+100	1E+100	1E+100	400
Acrylonitrile		107-13-0	20	0	0			0	0	0.65	1E+100	1E+100	1E+100	1E+100	70	N/A	
Benzene		71-43-2	10	0	0			0	0	5	1E+100	1E+100	1E+100	1E+100	160	N/A	
Bromoform		75-25-2	10	0	0			0	0	44	1E+100	1E+100	1E+100	1E+100	1200	N/A	
Carbon Tetrachloride		56-23-5	2	0	0			0	0	5	1E+100	1E+100	1E+100	1E+100	50	N/A	
Chlorobenzene		108-90-7	10	0	0			0	0	100	1E+100	1E+100	1E+100	1E+100	800	N/A	
Chlorodibromomethane		124-48-1	10	0	0			0	0	4.2	1E+100	1E+100	1E+100	1E+100	210	N/A	
Chloroform		67-66-3	50	0	0			0	0	57	1E+100	1E+100	1E+100	1E+100	2000	N/A	
Dichlorobromomethane		75-27-4	10	0	0			0	0	5.6	1E+100	1E+100	1E+100	1E+100	270	N/A	
1,2-Dichloroethane		107-06-2	10	0	0			0	0	5	1E+100	1E+100	1E+100	1E+100	6500	N/A	
1,1-Dichloroethylene		75-35-4	10	0	0			0	0	7	1E+100	1E+100	1E+100	1E+100	20000	N/A	
1,2-Dichloropropane		78-87-5	10	0	0			0	0	5	1E+100	1E+100	1E+100	1E+100	310	N/A	
1,3-Dichloropropylene		542-75-6	10	0	0			0	0	3.5	1E+100	1E+100	1E+100	1E+100	120	N/A	
Ethylbenzene		100-41-4	10	0	0			0	0	700	1E+100	1E+100	1E+100	1E+100	130	N/A	
Methyl Bromide		74-83-9	50	0	0			0	0	49	1E+100	1E+100	1E+100	1E+100	10000	N/A	
Methylene Chloride		75-09-2	20	0	0			0	0	5	1E+100	1E+100	1E+100	1E+100	10000	N/A	
1,2,4,5-Tetrachlorobenzene		95-94-3		0	0			0	0	1E+100	1E+100	1E+100	1E+100	1E+100	0.03	N/A	
1,1,2,2-Tetrachloroethane		79-34-5	10	0	0			0	0	1.8	1E+100	1E+100	1E+100	1E+100	30	N/A	
Tetrachloroethylene		127-18-4	10	0	0			0	0	5	1E+100	1E+100	1E+100	1E+100	290	N/A	
Toluene		108-88-3	10	0	0			0	0	1000	1E+100	1E+100	1E+100	1E+100	520	N/A	
1,2-trans-Dichloroethylene		156-60-5	10	0	0			0	0	100	1E+100	1E+100	1E+100	1E+100	4000	N/A	
1,1,1-Trichloroethane		71-55-6		0	0			0	0	200	1E+100	1E+100	1E+100	1E+100	200000	N/A	
1,1,2-Trichloroethane		79-00-5	10	0	0			0	0	5	1E+100	1E+100	1E+100	1E+100	89	N/A	
Trichloroethylene		79-01-6	10	0	0			0	0	5	1E+100	1E+100	1E+100	1E+100	70	N/A	
Vinyl Chloride		75-01-4	10	0	0			0	0	2	1E+100	1E+100	1E+100	1E+100	16	N/A	
ACID COMPOUNDS																	
2-Chlorophenol		95-57-8	10			0	0	0	0	175	1E+100	1E+100	1E+100	1E+100	800	N/A	
2,4-Dichlorophenol		120-83-2	10			0	0	0	0	105	1E+100	1E+100	1E+100	1E+100	60	N/A	
2,4-Dimethylphenol		105-67-9	10			0	0	0	0	700	1E+100	1E+100	1E+100	1E+100	3000	N/A	
3-Methyl-4-chlorophenol		59-50-7				0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	2000	N/A	
2-Methyl-4,6-dinitrophenol		534-52-1	50			0	0	0	0	14	1E+100	1E+100	1E+100	1E+100	30	N/A	

				Instream Waste Concentration								Livestock&	Acute	Chronic	Human	Need
				Ambient	Effluent			Domestic		Irrigation	Wildlife	Acute	Chronic	Human	TMDL	
POLLUTANTS				Conc	Conc.	Aquatic	Supply	Aquatic	Health	Criteria	Criteria	Criteria	Criteria	Criteria	Criteria	
		CAS No.	MLQ	Ca (ug/l)	Ce (ug/l)	2.13°Ce	Cd.dom (ug/l)	Cd (ug/l)	Cd,hh (ug/l)	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	
PESTICIDES AND PCBs																
Aldrin		309-00-2	0.01	0	0	0	0	0	0	0.021	1E+100	1E+100	3	1E+100	0.0000077	NA
Alpha-BHC		319-84-6	0.05			0	0	0	0	0.056	1E+100	1E+100	1E+100	1E+100	0.0039	NA
Beta-BHC		319-85-7	0.05			0	0	0	0	0.091	1E+100	1E+100	1E+100	1E+100	0.14	NA
gamma-BHC (Lindane)		58-89-9	0.05			0	0	0	0	0.2	1E+100	1E+100	0.95	1E+100	4.4	NA
Chlordane		57-74-9	0.2	0	0	0	0	0	0	2	1E+100	1E+100	2.4	0.0043	0.0032	NA
Dichlorodiphenyldichloroethane (DDD)						0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	0.0012	NA
Dichlorodiphenyldichloroethylene (DDE)						0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	0.00018	NA
Dichlorodiphenyltrichloroethane (DDT)						0	0	0	0	1E+100	1E+100	1E+100	1E+100	1E+100	0.0003	NA
4,4'-DDT and derivatives		50-29-3	0.02	0	0	0	0	0	0	1	1E+100	0.001	1.1	0.001	1E+100	NA
Dieldrin		60-57-1	0.02	0	0	0	0	0	0	0.022	1E+100	1E+100	0.24	0.056	0.000012	NA
Diazinon		333-41-5				0	0	0	0	1E+100	1E+100	1E+100	0.17	0.17	1E+100	NA
Alpha-Endosulfan		959-98-8	0.01			0	0	0	0	62	1E+100	1E+100	0.22	0.056	30	NA
Beta-Endosulfan		33213-65-9	0.02			0	0	0	0	62	1E+100	1E+100	0.22	0.056	40	NA
Endosulfan sulfate		1031-7-8	0.1	0	0	0	0	0	0	62	1E+100	1E+100	1E+100	1E+100	40	NA
Endrin		72-20-8	0.02	0	0	0	0	0	0	2	1E+100	1E+100	0.086	0.036	0.03	NA
Endrin Aldehyde		7421-93-4	0.1			0	0	0	0	10.5	1E+100	1E+100	1E+100	1E+100	1	NA
Heptachlor		76-44-8	0.01	0	0	0	0	0	0	0.4	1E+100	1E+100	0.52	0.0038	0.000059	NA
Heptachlor Epoxide		1024-57-3	0.01			0	0	0	0	0.2	1E+100	1E+100	0.52	0.0038	0.00032	NA
PCBs		336-36-3	0.2			0	0	0	0	0.5	1E+100	0.014	2	0.014	0.00064	NA
Toxaphene		8001-35-2	0.3	0	0	0	0	0	0	3	1E+100	1E+100	0.73	0.0002	0.0071	NA
STEP 3: SCAN POTENTIAL INSTREAM WASTE CONCENTRATIONS AGAINST WATER QUALITY CRITERIA																
AND ESTABLISH EFFLUENT LIMITATIONS FOR ALL APPLICABLE PARAMETERS																
No limits are established if the receiving stream is not designated for the particular uses.																
No limits are established if the potential instream waste concentrations are less than the chronic water quality criteria.																
The most applicable stringent criteria are used to establish effluent limitations for a given parameter.																
Water quality criteria apply at the end-of-pipe for acute aquatic life criteria and discharges to public lakes.																
If background concentration exceeds the water quality criteria, water quality criteria apply. And "Need TMDL" shown to the next column of Avg. Mass																
Monthly avg concentration = daily max. / 1.5.																
APPLICABLE WATER QUALITY-BASED LIMITS																
The following formula is used to calculate the allowable daily maximum effluent concentration																
See the current "Procedures for Implementing NPDES Permits in New Mexico"																
Daily Max. Conc. = Cs + (Cs - Ca)(F)Qa/Qe																
Monthly Avg. Conc. = Daily Max. Conc. / 1.5																
Where:	Cs = Applicable water quality standard															
	Ca = Ambient stream concentration															
	F = Fraction of stream allowed for mixing (1.0 is assigned to domestic water supply and human health uses)															
	Qe = Plant effluent flow															
	Qa = Criteria Low flow (4Q3) or Harmonic Mean flow for Human Health Criteria															

							Livestock	Acute	Chronic	Human	Daily	Monthly	Daily Max	Mon. Avg	Daily	Monthly
POLLUTANTS		CAS No.	STORET		Domestic	Irrigation	or Wildlife	Aquatic	Aquatic	Health	Max Conc	Avg Conc	Total	Total	Max Load	Avg Load
					Limits	Limits	Limits	Limits	Limits	Limits	ug/l	ug/l	ug/l	ug/l	lb/day	lb/day
Radioactivity, Nutrients, and Chlorine, as Total																
Aluminum, Total		7429-90-5	01105		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Aluminum, dissolved		7429-90-5			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Barium, Total		7440-39-3	01007		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Boron, Total		7440-42-8	01022		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cobalt, Total		7440-48-4	01037		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Uranium, Total		7440-61-1	22706		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Vanadium, Total		7440-62-2	01087		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Ra-226 and Ra-228 (pCi/l)			11503		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Strontium (pCi/l)			13501		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Tritium (pCi/l)			04124		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Gross Alpha (pCi/l)			80029		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Asbestos (fibers/l)					N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total Residual Chlorine		7782-50-5	50060		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Ammonia as N, total (mg/l)					N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrate as N (mg/l)			00620		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrite + Nitrate (mg/l)			00630		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
METALS AND CYANIDE, as Total																
Antimony, Total (P)		7440-36-0	01097		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Arsenic, Total (P)		7440-38-2	1002		N/A	N/A	N/A	N/A	N/A	10.38387097	10.38387097	9	32.61591862	28.269156	0.27201676	0.235764761
Beryllium, Total		7440-41-7	01012		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cadmium, Total		7440-43-9	01027		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chromium (III), dissolved		16065-83-1	01033		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chromium (VI), dissolved		18540-29-9	01034		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chromium, Total		7440-47-3	01034		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Copper, Total		7440-50-8	01042		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Lead, Total		7439-92-1	01051		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Manganese, dissolved		7439-96-5	01056		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mercury, Dissolved		7439-97-6	71900		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mercury, Total		7439-97-6	71900		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Molybdenum, dissolved		7439-98-7	1060		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Molybdenum, total recoverable		7439-98-7	01062		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nickel, Total (P)		7440-02-0	01067		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Selenium, Total (P)		7782-49-2	01147		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Selenium, Total (SO4 >500 mg/l)			01147		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Selenium, Total recoverable		7782-49-2	01147		N/A	N/A	5	N/A	5	N/A	5	5	5	5	0.0417	0.0417
Silver, Total		7440-22-4	01077		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Thallium, Total (P)		7440-28-0	01059		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Zinc, Total		7440-66-6	1092		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cyanide, total recoverable		57-12-5	00720		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
DIOXIN																0
2,3,7,8-TCDD		1746-01-6	34675		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
VOLATILE COMPOUNDS																
Acrolein		107-02-8	34210		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Acrylonitrile		107-13-0	34215		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Benzene		71-43-2	34030		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Bromoform		75-25-2	32104		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Carbon Tetrachloride		56-23-5	32102		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
POLLUTANTS		CAS No.	STORET		Domestic	Irrigation	or Wildlife	Aquatic	Aquatic	Health	Max Conc	Avg Conc	Total	Total	Max Load	Avg Load
					Limits	Limits	Limits	Limits	Limits	Limits	ug/l	ug/l	ug/l	ug/l	lb/day	lb/day
Chlorobenzene		108-90-7	34301		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clorodibromomethane		124-48-1	32105		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chloroform		67-66-3	32106		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Dichlorobromomethane		75-27-4	32101		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,2-Dichloroethane		107-06-2	34531		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,1-Dichloroethylene		75-35-4	34501		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,2-Dichloropropane		78-87-5	34541		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,3-Dichloropropylene		542-75-6	34561		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Ethylbenzene		100-41-4	34371		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Methyl Bromide		74-83-9	34413		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Methylene Chloride		75-09-2	34423		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,2,4,5-Tetrachlorobenzene		95-94-3			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,1,2,2-Tetrachloroethane		79-34-5	34516		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Tetrachloroethylene		127-18-4	34475		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Toluene		108-88-3	34010		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,2-trans-Dichloroethylene		156-60-5	34546		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,1,1-Trichloroethane		71-55-6			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,1,2-Trichloroethane		79-00-5	34511		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Trichloroethylene		79-01-6	39180		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Vinyl Chloride		75-01-4	39175		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
ACID COMPOUNDS																
2-Chlorophenol		95-57-8	34586		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2,4-Dichlorophenol		120-83-2	34601		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2,4-Dimethylphenol		105-67-9	34606		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3-Methyl-4-chlorophenol		59-50-7			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2-Methyl-4,6-dinitrophenol		534-52-1	34657		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2,4-Dinitrophenol		51-28-5	34616		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Pentachlorophenol		87-86-5	39032		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Phenol		108-95-2	34694		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2,4,5-Trichlorophenol		95-95-4			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2,4,6-Trichlorophenol		88-06-2	34621		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2-(2,4,5Trichlorophenoxy)propionic acid (Silvex)																
BASE/NEUTRAL																
Acenaphthene		83-32-9	34205		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Anthracene		120-12-7	34220		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Benzidine		92-87-5	39120		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Benzo(a)anthracene		56-55-3	34526		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Benzo(a)pyrene		50-32-8	34247		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3,4-Benzofluoranthene		205-99-2	34230		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Benzo(k)fluoranthene		207-08-9	34242		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Bis(2-chloroethyl)Ether		111-44-4	34273		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Bis(2-chloro-1-methylethyl) ethe		108-60-1	34283		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Bis(2-ethylexyl)Phthalate		117-81-7	39100		N/A	N/A	N/A	N/A	N/A	4.663174194	4.663174194	3.7	4.663174194	3.7	0.03889087	0.030858
Bis(chloromethyl) ether		542-88-1			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Butyl Benzyl Phthalate		85-68-7	34292		N/A	N/A	N/A	N/A	N/A	1.229722581	1.229722581	1	1.229722581	1	0.01025589	0.00834
2-Chloronaphthalene		91-58-7	34581		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chrysene		218-01-9	34320		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2,4-Dichlorophenoxyacetic acid		94-75-7			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Dbenzo(a,h)anthracene		53-70-3	34556		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,2-Dichlorobenzene		95-50-1	34536		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

						Livestock	Acute	Chronic	Human	Daily	Monthly	Daily Max	Mon. Avg	Daily	Daily	
POLLUTANTS		CAS No.	STORET		Domestic	Irrigation	or Wildlife	Aquatic	Chronic	Human	Daily	Monthly	Daily Max	Mon. Avg	Daily	Daily
					Limits	Limits	Limits	Limits	Limits	Health	Max Conc	Avg Conc	Total	Total	Max Load	Avg Load
1,3-Dichlorobenzene		541-73-1	34566		N/A	N/A	N/A	N/A	N/A	N/A	ug/l	ug/l	ug/l	N/A	N/A	N/A
1,4-Dichlorobenzene		106-46-7	34571		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3,3'-Dichlorobenzidine		91-94-1	34631		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Diethyl Phthalate		84-66-2	34336		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Dimethyl Phthalate		131-11-3	34341		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Di-n-Butyl Phthalate		84-74-2	39110		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2,4-Dinitrotoluene		121-14-2	34611		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,2-Diphenylhydrazine		122-66-7	34346		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Fluoranthene		206-44-0	34376		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Fluorene		86-73-7	34381		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Hexachlorobenzene		118-74-1	39700		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Hexachlorobutadiene		87-68-3	34391		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Hexachlorocyclohexane (HCH)-		608-73-1			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Hexachlorocyclopentadiene		77-47-4	34386		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Hexachloroethane		67-72-1	34396		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Indeno(1,2,3-cd)Pyrene		193-39-5	34403		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Isophorone		78-59-1	34408		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrobenzene		98-95-3	34447		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrosamines		Various			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrosodibutylamine		924-16-3			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrosodiethylamine		55-18-5			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
n-Nitrosodimethylamine		62-75-9	34438		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
n-Nitrosodi-n-Propylamine		621-64-7	34428		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
n-Nitrosodiphenylamine		86-30-6	34433		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
N-Nitrosopyrrolidine		930-55-2			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nonylphenol		84852-15-3			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Pentachlorobenzene		608-93-5			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Pyrene		129-00-0	34469		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1,2,4-Trichlorobenzene		120-82-1	34551		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
PESTICIDES AND PCBs																
Aldrin		309-00-2	39330		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Alpha-BHC		319-84-6	39337		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Beta-BHC		319-85-7	39338		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Gamma-BHC		58-89-9	39340		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chlordane		57-74-9	39350		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Dichlorodiphenyldichloroethane (DDD)					N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Dichlorodiphenyldichloroethylene (DDE)					N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Dichlorodiphenyltrichloroethane (DDT)					N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4,4'-DDT and derivatives		50-29-3	39300		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Dieldrin		60-57-1	39380		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Diazinon		333-41-5	39570		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Alpha-Endosulfan		959-98-8	34361		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Beta-Endosulfan		33213-65-9	34356		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Endosulfan sulfate		1031-7-8	34351		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Endrin		72-20-8	39390		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Endrin Aldehyde		7421-93-4	34366		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Heptachlor		76-44-8	39410		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Heptachlor Epoxide		1024-57-3	39420		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
PCBs		336-36-3	39516		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Toxaphene		8001-35-2	39400		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

