



JANET T. MILLS
GOVERNOR

STATE OF MAINE
DEPARTMENT OF ENVIRONMENTAL PROTECTION



MELANIE LOYZIM
COMMISSIONER

July 14, 2025

Mr. Bill Delnicki
Woodland Pulp LLC
Baileyville, ME 04694
William.delnicki@igic.com

*Sent via electronic mail
Delivery confirmation requested*

RE: *Maine Pollutant Discharge Elimination System (MEPDES) Permit #ME0022063
Maine Waste Discharge License (WDL) Application #W000508-5O-K-R
Proposed Draft MEPDES Permit Renewal*

Dear Mr. Delnicki,

Enclosed is a **proposed draft** MEPDES renewal permit and Maine WDL which the Department proposes to issue as a final document after opportunity for your review and comment. By transmittal of this letter, you are provided with an opportunity to comment on the proposed draft permit and its special and standard conditions. If it contains errors or does not accurately reflect present or proposed conditions, please respond to this Department so that changes can be considered.

By copy of this letter, the Department is requesting comments on the proposed draft permit from various state and federal agencies and from any other parties who have notified the Department of their interest in this matter.

The comment period begins today, Monday, July 14, 2025, and ends on Thursday, August 14, 2025. All comments on the proposed draft permit must be received in the Department of Environmental Protection office on or before the close of business **Thursday, August 14, 2025**. Failure to submit comments in a timely fashion may result in the proposed draft/license permit document being issued as drafted.

Comments in writing should be submitted to my attention at the following address:

Maine Department of Environmental Protection
Bureau of Water Quality
Division of Water Quality Management
17 State House Station
Augusta, ME 04333-0017

AUGUSTA
17 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0017
(207) 287-7688 FAX: (207) 287-7826

BANGOR
106 HOGAN ROAD, SUITE 6
BANGOR, MAINE 04401
(207) 941-4570 FAX: (207) 941-4584

PORTLAND
312 CANCO ROAD
PORTLAND, MAINE 04103
(207) 822-6300 FAX: (207) 822-6303

PRESQUE ISLE
1235 CENTRAL DRIVE, SKYWAY PARK
PRESQUE ISLE, MAINE 04769
(207) 764-0477 FAX: (207) 760-3143

Bill Delnicki, Woodland Pulp North
July 14, 2025
Page 2 of 2

If you have any questions regarding the matter, please feel free to call me at 207-458-8706 or email me at Bekah.Farmer@maine.gov

Sincerely,

Bekah Farmer
Division of Water Quality Management
Bureau of Water Quality

Enclosure

cc: Laura Crossley, DEP
Mike Loughlin, DEP
Wendy Garland, DEP
Gary Brooks, DEP
Gregg Wood, DEP
Holly Ireland, DEP
Lori Mitchell, DEP
Kathryn Rosenburg, EPA
Michael Cobb, EPA
Richard Carvalho, EPA
U.S. Fish & Wildlife Service
Inland Fisheries & Wildlife
Department of Marine Resources
Trevor White, Indian Township Tribal Government
Marvin Cling Jr., Passamaquoddy Tribal Government
Billy Longfellow, Passamaquoddy Tribal Government
Sean Mahoney, Conservation Law Foundation



STATE OF MAINE
DEPARTMENT OF ENVIRONMENTAL PROTECTION
17 STATE HOUSE STATION AUGUSTA, MAINE 04333-0017

DEPARTMENT ORDER

IN THE MATTER OF

WOODLAND PULP, LLC.)	MAINE POLLUTANT DISCHARGE
BAILEYVILLE, WASHINGTON COUNTY, ME)	ELIMINATION SYSTEM PERMIT
NON-CONTACT COOLING WATERS)	AND
#ME0022063)	WASTE DISCHARGE LICENSE
#W000508-5O-K-R)	RENEWAL
		APPROVAL

In compliance with the applicable provisions of *Pollution Control*, 38 M.R.S. §§ 411 – 424-C, *Water Classification Program*, 38 M.R.S. §§ 464 – 470 and *Federal Water Pollution Control Act*, Title 33 U.S.C. § 1251 *et seq.*, *Conditions of licenses*, 38 M.R.S. § 414-A, *Regulations Relating to Temperature*, 06-096 C.M.R. 582 (effective date May 4, 1996), and applicable rules of the Department of Environmental Protection (Department), the Department has considered the application of WOODLAND PULP LLC (“Woodland”, “permittee”) with its supportive data, agency review comments, and other related materials on file and FINDS THE FOLLOWING FACTS:

APPLICATION SUMMARY

On December 8, 2022, Woodland submitted a timely and complete application to the Department for renewal of combination Maine Pollutant Discharge Elimination System (MEPDES) permit #ME0022063/ Maine Waste Discharge License (WDL) #W000508-5O-J-R, which was issued on May 14, 2018, for a five-year term. The May 14, 2018 permit authorized the discharge of up to a monthly average flow of 15.0 million gallons per day (MGD) of non-contact cooling water and a monthly average flow of up to 0.160 MGD of miscellaneous non-process waste waters (primarily boiler blowdown and water softener backwash) from the Woodland Pulp North (WPN) site from two outfalls to the St. Croix River, Class C, in Baileyville, Maine.

It is noted that the natural gas associated wood fired boiler and associated steam turbine which supply wastewaters to Outfalls #001 and #002, respectively, have been shut down for over ten years. As a result, monitoring requirements for Outfalls #001 and #002 were suspended. The facility has been put on notice by the Department that if the facility commences operations in the future, the Department will review said operations to determine if this permit should be modified to establish terms and conditions consistent with the activities performed at the facility. See Special Condition G, *Commencement of Operations*, of this permit.

PERMIT SUMMARY

This permitting action carries forward all the terms and conditions established in the previous permitting action, except that this permitting action is:

1. Clarifying that the facility may not cause the temperature of the St. Croix River to exceed 85°F outside of the assigned mixing zone; and
2. Establishing Special Condition H, *Sedimentation Pond Maintenance*, based on new information.

CONCLUSIONS

Based on the findings summarized in the attached Fact Sheet dated July 30, 2025, and subject to the Conditions listed below, the Department makes the following CONCLUSIONS:

- a) The discharge, either by itself or in combination with other discharges, will not lower the quality of any classified body of water below such classification.
- b) The discharge, either by itself or in combination with other discharges, will not lower the quality of any unclassified body of water below the classification which the Department expects to adopt in accordance with state law.
- c) The provisions of the State's antidegradation policy, *Classification of Maine waters*, 38 M.R.S. § 464(4)(F), will be met, in that:
 1. Existing in-stream water uses and the level of water quality necessary to protect and maintain those existing uses will be maintained and protected;
 2. Where high quality waters of the State constitute an outstanding national resource, that water quality will be maintained and protected;
 3. Where the standards of classification of the receiving water body are not met, the discharge will not cause or contribute to the failure of the water body to meet the standards of classification;
 4. Where the actual quality of any classified receiving water body exceeds the minimum standards of the next highest classification that higher water quality will be maintained and protected; and
 5. Where a discharge will result in lowering the existing water quality of any water body, the Department has made the finding, following opportunity for public participation, that this action is necessary to achieve important economic or social benefits to the State.
- d) The discharges will be subject to effluent limitations that require application of best practicable treatment as defined in *Conditions of licenses*, 38 M.R.S. § 414-A(1)(D).

ACTION

THEREFORE, the Department APPROVES the above noted application of the WOODLAND PULP LLC to discharge an average monthly flow of 15.0 MGD of non-contact cooling waters and an average monthly flow of 0.160 MGD of miscellaneous non-process wastewater to the St. Croix River, Class C, in Baileyville, Maine, SUBJECT TO THE ATTACHED CONDITIONS, and all applicable standards and regulations including:

1. “*Maine Pollutant Discharge Elimination System Permit Standard Conditions Applicable To All Permits*,” revised July 1, 2002, copy attached.
2. The attached Special Conditions, including any effluent limitations and monitoring requirements.
3. This permit and the authorization to discharge becomes effective upon the date of signature below and expires at midnight five (5) years from the effective date. If a renewal application is timely submitted and accepted as complete for processing prior to the expiration of this permit, the authorization to discharge and the terms and conditions of this permit and all subsequent modifications and minor revisions thereto remain in effect until a final Department decision on the renewal application becomes effective. [*Maine Administrative Procedure Act and Other Administrative Matters*, 5 M.R.S. § 10002 and *Rules Concerning the Processing of Applications and Other Administrative Matters*, 06-096 C.M.R. 2(20)(A) (effective September 15, 2024)].

PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

DONE AND DATED AT AUGUSTA, MAINE, THIS ____ DAY OF _____ 2025.

DEPARTMENT OF ENVIRONMENTAL PROTECTION

BY: _____
Melanie Loyzim, Acting Commissioner

Date of initial receipt of application: December 8, 2022

Date of application acceptance: December 9, 2022

This Order prepared by Bekah Farmer, BUREAU OF WATER QUALITY

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. The permittee is authorized to discharge from **OUTFALL #001** to the St. Croix River. Such discharges are limited and must be monitored by the permittee as specified below⁽¹⁾.

OUTFALL #001 - Boiler blowdown, softener backwash, cooling waters and miscellaneous non-process wastewaters.

Effluent Characteristic	Discharge Limitations				Monitoring Requirements	
	Monthly Average	Daily Maximum	Monthly Average	Daily Maximum	Measurement Frequency	Sample Type
Flow [50050]	0.160 MGD [03]	Report (MGD) [03]	---	---	5/Week [05/07]	Measured [MS]
Biochemical Oxygen Demand (BOD5) [00310]	67 lbs/day [26]	---	---	50 mg/L [19]	1/Month [01/30]	Grab [GR]
Total Suspended Solids (TSS) [00530]	80 lbs/day [26]	---	---	60 mg/L [19]	1/Month [01/30]	Grab [GR]
Settleable Solids [00545]	---	---	---	0.5 ml/L [25]	1/Month [01/30]	Grab [GR]
Oil & Grease [00556]	---	---	---	15 mg/L [19]	1/Month [01/30]	Grab [GR]
pH (Std. Units) ⁽²⁾ [00400]	---	---	---	6.0-9.0 SU [12]	1/Month [01/30]	Grab [GR]

The italicized numeric values bracketed in the table and in subsequent text are code numbers that Department personnel utilize to code the monthly Discharge Monitoring Reports.

FOOTNOTES: See Pages 6 through 7 of this permit for applicable footnotes.

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

2. The permittee is authorized to discharge from **OUTFALL #002** to the St. Croix River. Such discharges are limited and shall be monitored by the permittee as specified below ⁽¹⁾.

OUTFALL #002 - Non-contact cooling waters

Effluent Characteristic	Discharge Limitations					Monitoring Requirements	
	Monthly Average	Daily Maximum	Monthly Average	Weekly Average	Daily Maximum	Measurement Frequency	Sample Type
Flow (MGD) [50050]	15.0 MGD [03]	Report MGD [03]	---	---	---	5/Week [05/07]	Calculate [CA]
Temperature ⁽³⁾ [00011] June 1 – September 30 October 1 – May 31	---	---	---	---	110°F [15] 110°F [15]	5/Week [05/07] 1/Week [01/07]	Grab [GR] Grab [GR]
Thermal Load June 1 – September 30 [00017]	---	---	---	2.29x10 ⁹⁽⁴⁾ BTUs/Day [34]	2.29 x10 ⁹⁽⁵⁾ BTUs/Day [34]	5/Week [05/07]	Calculate [CA]
Predicted River Temperature Increase (PRTI) ⁽⁶⁾ June 1 – September 30 [70013]	---	---	---	---	0.5°F [15]	5/Week [05/07]	Calculate [CA]
pH (Std. Unit) ⁽²⁾ [00400]	---	---	---	---	6.0 – 8.5 SU [12]	1/Month [01/30]	Grab [GR]

The italicized numeric values bracketed in the table and in subsequent text are code numbers that Department personnel utilize to code the monthly Discharge Monitoring Reports.

FOOTNOTES: See Pages 6 through 7 of this permit for applicable footnotes.

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Sampling Locations:

Outfall #001 – Sampling for all parameters in Special Condition A(1) of this permit must be conducted at the terminus of the culvert from the East sedimentation pond.

Outfall #002 - Sampling for Flow, Temperature, and pH in Special Condition A(2) of this permit must be conducted at the outfall at the non-contact cooling water pump station. To calculate Thermal Load and River Temperature Increase, upstream and downstream receiving water temperature must be sampled in compliance with Special Conditions E and F of the permit and must be conducted as follows: Upstream river temperature must be measured at the intake for the WPN site turbine and downstream river temperature must be measured at the intake for the Woodland mill.

FOOTNOTES:

1. **Sampling** – Any change in the sampling locations must be approved by the Department in writing. Sampling and analysis must be conducted in accordance with; a) methods approved by 40 Code of Federal Regulations (CFR) Part 136, b) alternative methods approved by the Department in accordance with the procedures in 40 CFR Part 136, or c) as otherwise specified by the Department. Samples that are sent out for analysis must be analyzed by a laboratory certified by the State of Maine's Department of Health and Human Services for wastewater. Samples that are analyzed by laboratories operated by waste discharge facilities licensed pursuant to *Waste discharge licenses*, 38 M.R.S. § 413 are subject to the provisions and restrictions of *Maine Comprehensive and Limited Environmental Laboratory Accreditation Rule*, 10-144 C.M.R. 263 (last amended March 15, 2023). If the permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR part 136 or as specified in this permit, all results of this monitoring must be included in the calculation and reporting of the data submitted in the Discharge Monitoring Report.

In accordance with 40 C.F.R. § 122.44(i)(1)(iv), the permittee must monitor according to sufficiently sensitive test procedures (i.e., methods) approved under 40 C.F.R. Part 136 or required under 40 C.F.R. chapter I, subchapter N or O, for the analysis of pollutants or pollutant parameters (except WET). A method is "sufficiently sensitive" when: 1) The method minimum level (ML) is at or below the level of the effluent limitation established in the permit for the measured pollutant or pollutant parameter; or 2) The method has the lowest ML of the analytical methods approved under 40 C.F.R. Part 136 or required under 40 C.F.R. chapter I, subchapter N or O for the measured pollutant or pollutant parameter. The term "minimum level" refers either to the sample concentration equivalent to the lowest calibration point in a method or a multiple of the method detection limit (MDL), whichever is higher. Minimum levels may be obtained in the following ways: they may be published in a method; they may be based on the lowest acceptable calibration point used by a laboratory; or they may be calculated by multiplying the MDL in a method, or the MDL determined by a laboratory, by a factor.

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

FOOTNOTES (cont'd)

2. **pH** - Pursuant to *Effluent Guidelines and Standards*, 06-096 C.M.R. 525(4)(VIII)(a) (effective January 12, 2001) the permittee may conduct continuous pH monitoring. The permittee must specify on the monthly DMRs the sample type method for pH reporting (i.e. grab sample or continuous monitoring).

The pH of the effluent shall not be less than or greater than specified standard units unless exceedances are due to natural causes in the ambient receiving waters or precipitation. In such cases, the effluent discharge shall not be more than 0.5 standard units outside the background pH. Background sampling shall be conducted at the facility's intake sampling station on the same day as sampling of the effluent is conducted.

3. **Temperature** – The maximum temperature for the discharge at the sampling location on any day.
4. **Weekly Average Thermal Load** - This is a weekly rolling average thermal load limitation in British Thermal Units (BTUs) per day that becomes effective during the period of June 1 to September 30 when the weekly rolling average temperature of the intake water from the St. Croix River is greater than or equal to 66°F and less than 73°F ($\geq 66^{\circ}\text{F}$ and $< 73^{\circ}\text{F}$). **See Special Condition E of this permit for the equation to calculate the thermal load.**
5. **Daily Maximum Thermal Load** - This is a daily maximum thermal load limitation in British Thermal Units (BTUs) per day that becomes effective during the period of June 1 to September 30 when the temperature of the intake water from the St. Croix River is greater than or equal to 73°F and the flow of the receiving water is at or above 850 cfs. **See Special Condition E of this permit for the equation to calculate the thermal load.**
6. **Predicted River Temperature Increase (PRTI)** - This is the maximum temperature increase allowed between upstream ambient temperature and downstream river temperature outside the zone of dilution during the period of June 1 to September 30. It must be calculated when the receiving water temperature is $\geq 73^{\circ}\text{F}$ and the flow is below the regulated low flow of 850 cfs (549 MGD).

B. NARRATIVE EFFLUENT LIMITATIONS

1. The permittee must not discharge wastewater that contains a visible oil sheen, foam, or floating solids at any time that would impair the designated uses or habitat characteristics of the receiving waters or would otherwise lower the quality of the receiving water below its assigned classification.

SPECIAL CONDITIONS

B. NARRATIVE EFFLUENT LIMITATIONS (cont'd)

2. The permittee must not discharge effluent that contains materials in concentrations or combinations which are hazardous or toxic to aquatic life, or which would impair the usages designated for the classification of the receiving waters.
3. The permittee must not discharge wastewater that imparts color, taste, turbidity, toxicity, radioactivity or other properties which cause those waters to be unsuitable for the designated uses and characteristics ascribed to their classification.
4. The permittee must not discharge effluent that lowers the quality of any classified body of water below such classification or lowers the existing quality of any body of water if the existing quality is higher than the classification.
5. The permittee must notify the Department immediately of the discharge of any pollutants other than heat from the facility. The permittee must also notify the Department of any changes in facility design, operation or generating capacity that may affect the flow or temperature of the cooling water discharge.
6. All miscellaneous facility leakage and lubrication waters that may become contaminated with oil or grease are subject to Best Management Practices (BMPs) designed to prevent the release of contaminants to the waters of the State. **Within 90 days of permit issuance**, the permittee must review and revise as necessary its written BMPs and shall make the BMPs available to the Department for review and comment upon request. BMPs must consist of, but not be limited to, the following, as appropriate: development and implementation of a spill prevention plan; use of oil absorbent pads or booms and/or physical berms to contain spills or leaks of hydraulic and lubrication oils; and the treatment of water collected in floor drains and sumps through an oil/grease trap or oil-water separator. Where bearing cooling water is used, BMPs must include the maintenance of a written log or record of bearing oil levels and maintenance activities. Where floor drains and sumps are used, BMPs must include (1) written procedures for the cleaning and maintenance of any oil-grease trap, oil skimmer or oil-water separator and (2) maintenance of a written log or record of visual inspections of sumps for oil and grease and of actions taken to prevent the discharge of oil or grease from the facility.

C. AUTHORIZED DISCHARGES

The permittee is authorized to discharge only in accordance with: 1) the Woodland General Application for Waste Discharge Permit, accepted for processing on December 9, 2022; 2) the terms and conditions of this permit; and 3) only from Outfall #001 and Outfall #002. Discharges of wastewater from any other point source(s) are not authorized by this permit, and must be reported by the permittee in accordance with Standard Condition D(1)(f), *Twenty-four hour reporting*, of this permit.

SPECIAL CONDITIONS

D. NOTIFICATION REQUIREMENT

1. In accordance with Standard Condition D, the permittee must notify the Department of any substantial change in the volume or character of pollutants being introduced into the wastewater collection and treatment system by a source introducing pollutants into the system after the time of permit issuance.
2. For the purposes of this section, adequate notice must include information on:
 - i. The quality and quantity of wastewater introduced to the wastewater collection and treatment system; and
 - ii. Any anticipated impact of the change in the quantity or quality of the wastewater to be discharged from the treatment system.

E. THERMAL DISCHARGE

During the period June 1 to September 30, the permittee is limited to a weekly average thermal load of 2.29×10^9 BTUs/Day, daily maximum thermal load of 2.29×10^9 BTUs/Day, and/or predicted river temperature increase (PRTI) of 0.5°F. The applicable limit that needs to be calculated is based on the receiving water temperature. In no event shall any discharge alone or in combination with other discharges cause the temperature of the receiving water body to exceed 85°F at a point outside the mixing zone. The Department does not deem it likely that the water body will naturally exceed 85°F. These limits are in accordance with *Regulations Relating to Temperature*, 06-096 C.M.R. 582 (effective date May 4, 1996).

1. Weekly Average Thermal Load - The weekly average thermal load limit applies when the receiving water temperature is $\geq 66^\circ\text{F}$ and $< 73^\circ\text{F}$. The Department interprets the term “weekly average temperature” to mean a seven (7) day rolling average. For Discharge Monitoring Report (DMR) reporting purposes, report the thermal load associated with the highest seven (7) consecutive days during a calendar month. If the weekly rolling average receiving water temperature is not $\geq 66^\circ\text{F}$ during a month between June and September (inclusive) the permittee shall report “NODI-9” on the applicable columns for the monthly DMR.
2. Daily Maximum Thermal Load - The daily maximum limit applies when the receiving water temperature is $\geq 73^\circ\text{F}$ and the receiving water flow is at or above the regulated low flow of 850 cfs. The thermal load discharged from Outfall #002 must be calculated for each operating day during the applicable limitation period. For DMR reporting purposes, report the highest daily thermal load (expressed as BTUs/Day) during a calendar month.
3. Predicted River Temperature Increase (PRTI) – The PRTI limit applies when the receiving water temperature is $\geq 73^\circ\text{F}$ and the flow is below the regulated low flow of 850 cfs (549 MGD). During this time, the permittee is limited to a daily thermal load that will not increase the receiving water temperature (ΔT) by more than 0.5°F.

SPECIAL CONDITIONS

E. THERMAL DISCHARGE (cont'd)

For each operating day during the applicable limitation period, the permittee shall calculate the thermal load from Outfall #002 to the receiving waters according to the following equation:

$$\text{Thermal Load (BTUs/Day)} = [(Q_{e002}) (T_{e002} - T_r)] (8.34 \text{ lbs/gal}) \text{ where,}$$

Q_e = Effluent flow in gallons
 T_e = Effluent temperature (°F)
 T_r = Upstream river water (intake for WPN mill) temperature (°F)

For each operating day during the applicable limitation period, the permittee shall calculate the Predicted River Temperature Increase (PRTI) from Outfall #002 to the receiving waters according to the following equation:

$$\text{PRTI (°F)} = \frac{(Q_{e002}) (T_{e002} - T_r)}{Q_r}$$

where,

Q_r = River flow as measured at the gauging station at the Woodland mill approximately two miles downstream of the WPN mill complex. (cfs or MGD, must be consistent with the Q_e units)
 Q_e = Effluent flow in cfs or MGD, (must be consistent with the Q_r units)
 T_e = Effluent temperature (°F)
 T_r = Upstream river water temperature (°F)

The daily recorded and calculated values of Q_r , Q_e , T_r , T_e , and Thermal Load must be reported to the Department as an attachment to the Discharge Monitoring Reports (DMRs) for the months of June, July, August, and September of each year. PRTI must only be calculated when the receiving water is $\geq 73^\circ\text{F}$ and the flow is below the regulated flow of 850 cfs (549 MGD).

Example DMR Reporting Form Attachment

<u>Date</u>	<u>Q_r (MGD)</u>	<u>Q_e (MGD)</u>	<u>T_r (°F)</u>	<u>T_e (°F)</u>	<u>PRTI (°F)</u>	<u>Heat(BTU)</u>
6/1/2025	405	11.5	75°F	91°F	0.45°F	1.5×10^9

F. AMBIENT TEMPERATURE MONITORING

Between June 1 and September 30 of each year, the permittee must monitor the upstream ambient temperature of the receiving water at the intake for WPN site and downstream receiving water temperature at the end of the zone of initial dilution to verify the Actual River Temperature Increase (ARTI) of $\leq 0.5^\circ\text{F}$ is being achieved. The permittee must supplement the reporting format cited above with additional columns to record T_r (intake for the Woodland mill at the Woodland Dam) and the ARTI.

SPECIAL CONDITIONS

G. COMMENCEMENT OF OPERATIONS

No later than ninety (90) days prior to commencing production/operations that will result in a discharge of wastewater, the permittee must meet with the Department's permitting and compliance inspection staff to review the applicability of the permit limitations, monitoring requirements and reporting requirements. Should the Department determine the proposed production/operations are significantly different than what has been presented in the December 9, 2022 approved permit application materials, the Department may require the permittee to submit an application to modify the permit. All procedural requirements for processing applications, including public notice and availability of a draft decision, apply. When operations are commenced, monitoring and reporting is required to immediately resume.

H. SEDIMENTATION POND MAINTENANCE

1. The banks of the pond must be inspected at least two times per year and properly maintained at all times. There must be no overflow through or over the banks. Any signs of leaks, destructive animal activity or soil erosion of the banks must be repaired immediately.
2. The banks of the pond must be maintained to keep them free of woody vegetation and other vegetation that may be detrimental to the integrity of the bank and/or pond liner. The pond must be kept free of all vegetation (i.e., grasses, reeds, cattails, etc.) that hinders the operation of the pond.
3. For each pond, the licensee must maintain at least two (2) feet of freeboard or design levels, whichever is greater.
4. The sedimentation pond must be dredged as necessary to maintain the proper operating depths in the pond that will provide best practicable treatment of the wastewater. All material removed from the pond must be properly disposed of in accordance with all applicable State and Federal rules and regulations.

I. MONITORING AND REPORTING

Electronic Reporting

NPDES Electronic Reporting, 40 C.F.R. 127, requires MEPDES permit holders to submit monitoring results obtained during the previous month on an electronic discharge monitoring report to the regulatory agency utilizing the USEPA electronic system.

Electronic Discharge Monitoring Reports (DMRs) submitted using the USEPA NetDMR system, must be:

1. Submitted by a facility authorized signatory; and

SPECIAL CONDITIONS

I. MONITORING AND REPORTING (cont'd)

2. Submitted no later than **midnight on the 15th day of the month** following the completed reporting period.

Documentation submitted in support of the electronic DMR may be attached to the electronic DMR. Documentation submitted electronically to the Department in support of the electronic DMR must be submitted no later than midnight on the 15th day of the month following the completed reporting period.

J. REOPENING OF PERMIT FOR MODIFICATIONS

In accordance with *Conditions of Licenses*, 38 M.R.S. § 414-A(5) and upon evaluation of the tests results or monitoring requirements specified in Special Conditions of this permitting action, new site specific information, or any other pertinent test results or information obtained during the term of this permit, the Department may, at any time and with notice to the permittee, modify this permit to: 1) include effluent limits necessary to control specific pollutants or whole effluent toxicity where there is a reasonable potential that the effluent may cause water quality criteria to be exceeded, (2) require additional monitoring if results on file are inconclusive; or (3) change monitoring requirements or limitations based on new information.

K. SEVERABILITY

In the event that any provision(s), or part thereof, of this permit is declared to be unlawful by a reviewing court, the remainder of the permit shall remain in full force and effect, and must be construed and enforced in all aspects as if such unlawful provision, or part thereof, had been omitted, unless otherwise ordered by the court.

**MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT
MAINE WASTE DISCHARGE LICENSE**

PROPOSED FACT SHEET

DATE: **July 30, 2025**

PERMIT NUMBER: **#ME0022063**

WASTE DISCHARGE LICENSE: **W000508-5O-K-R**

NAME AND ADDRESS OF APPLICANT:

**WOODLAND PULP LLC
Woodland PULP North site
144 Maine Street
Baileyville, MAINE 04694**

COUNTY: **Washington**

NAME AND ADDRESS WHERE DISCHARGE(S) OCCUR(S):

**WOODLAND PULP NORTH SITE
187 Track Road
Baileyville, Maine 04694**

RECEIVING WATER AND CLASSIFICATION:
St. Croix River/ Class C

COGNIZANT OFFICIAL AND TELEPHONE #:
**Mr. Bill Delnicki, Environmental Team Leader
(207) 214-9818
e-mail: william.delnicki@igic.com**

1. APPLICATION SUMMARY

- a. Application: Woodland Pulp LLC (Woodland/permittee hereinafter) **submitted** a timely and complete application to the Department for renewal of combination Maine Pollutant Discharge Elimination System (MEPDES) permit #ME0022063/ Maine Waste Discharge License (WDL) #W000508-5O-J-R, which was issued on May 14, 2018, for a five-year term. The May 14, 2018 permit authorized the daily maximum discharge of 15.0 million gallons per day (MGD) of non-contact cooling water, and the daily maximum discharge of 0.160 MGD of miscellaneous non-process wastewaters (primarily boiler blowdown and water softener backwash) from the Woodland Pulp North (WPN) site from two outfalls to the St. Croix River, Class C, in Baileyville, Maine. See Attachment A of this Fact Sheet for a location map.

1. APPLICATION SUMMARY (cont'd)

It is noted that the natural gas associated wood fired boiler and associated steam turbine which supply wastewaters to Outfalls #001 and #002, respectively, have been shut down for over ten years. As a result, monitoring requirements for Outfalls #001 and #002 were suspended. The facility has been put on notice by the Department that if and when the facility commences operations in the future, the Department will review said operations to determine if this permit should be modified to establish terms and conditions consistent with the activities performed at the facility. See Special Condition G, *Commencement of Operations*, of this permit.

- b. Source Description –When the Georgia Pacific Corporation (GPC) owned and operated the Baileyville mill, the facility was comprised of two separate manufacturing operations on a common site. One manufacturing facility was a stud mill that produced approximately 70 million board feet per year of spruce and fir 2" x 4" studs, while another facility manufactured 4' x 8' sheets of oriented strand board (OSB) a product similar to plywood. A centrally located wood fired boiler and turbine operated continually supplying steam, compressed air, and electricity to both mills. The electrical output of the power plant and the electrical demand of the complex are balanced with excess electricity consumed by the Woodland pulp mill two miles downstream.

Both manufacturing operations have been shut down for more than two decades. The Louisiana Pacific Corporation (LPC) proposed to reopen the OSB plant in June of 2003 but did not and subsequently sold both manufacturing facilities to Woodland Pulp LLC (Woodland) in October of 2011, renaming the site Woodland Pulp North. At this time the entire OSB facility was dismantled and the stud mill was partially dismantled.

Currently the former OSB and warehouse buildings are leased to a natural gas compressing and delivery business which began operations at the site in January 2013. Future plans may include expanding the natural gas processing operations at this site, opening the site to other business opportunities, and operating the natural gas fired boiler and associated turbine to produce power for use on site as well as export. The wood storage and processing area remain and are used to cover wood that is used for chips and fuel. Processing equipment includes stationary and portable chippers and grinders.

The site has three outfalls that discharge to the St. Croix River. A process flow diagram, which includes the locations of the outfalls, was submitted by the permittee and is included as Fact Sheet Attachment B.

Outfall #001 wastewaters are directly related to the operation of the boiler, which include boiler blowdown, sand filter and softener backwashes, floor rinses, graywater from sinks, and drinking water sources within the boiler building. Minor contributions to Outfall #001 include air compressor coils and runoff from occasional use of water spray on the saw log decks and adjacent storage area. The water spray wetted the logs during dry periods and minimized saw blade wear. The average daily flow associated with the aforementioned sources prior to facility shut down had been approximately 60,000 gallons per day (GPD) but could be as high as 160,000 GPD.

1. APPLICATION SUMMARY (cont'd)

Outfall #002 wastewaters consist of non-contact cooling water used to condense low pressure steam from the outlet of the turbine back to water before being returned to the boiler. The cooling water source is the St. Croix River and the discharge flow has historically been reported to be approximately 14 million gallons per day (MGD) but can be as high as 15 MGD. Also contributing to this outfall are small sump pumps within pump-houses which discharge infiltration/seepage water, pump packing, seal water, and other miscellaneous minor water from the pump-house interior.

Outfall #003 is a stormwater outfall. The outfall was previously covered by this permit but removed from the 2018 permit due to coverage under the Department's Multi-Sector General Permit, permit #MER05B608, issued on January 13, 2017.

Other minor discharges at the facility include stormwater and ground water from a vehicle scale pit. The permittee has indicated the discharge does not come into contact with any pollutants, such as lubricating fluids or oil and grease, as the purpose of the discharge is to remove groundwater and stormwater from the pit to prevent corrosion of the springs for the scale. The intermittent flow is discharged to the surface of the land, a grassy area adjacent to the facility's sub-surface wastewater disposal system. It is noted the Department considered these minor discharges as being *de minimis* in nature and did not establish limitations or monitoring requirements for these waste streams.

- c. Wastewater Treatment - Boiler building wastewaters discharge through Outfall #001 receive a primary level of treatment. Wastewater exits the boiler building and pass through an oil/water separator before being conveyed to a settling/stabilization pond. The pond is approximately four feet deep with a surface area of approximately 3,000 square feet. A culvert with invert inlet is present for the purpose of dispersing the effluent. The final outfall pipe is a 24-inch diameter corrugated metal pipe with a grease trapped outlet. The pipe outlets three feet above the surface of the receiving waters and meanders through a vegetated channel to the river.

Outfall #002 receives no treatment as the wastewaters are non-contact cooling waters that are uncontaminated except for heat, which is regulated in the permit. The outfall pipe is a 24-inch diameter steel pipe equipped with a stilling basin. The pipe outlets two feet above the surface of the receiving waters.

Sanitary wastewaters generated at the mill complex are disposed of in a conventional on-site subsurface disposal system.

2. PERMIT SUMMARY

- a. Terms and Conditions - This permitting action carries forward all the terms and conditions established in the previous permitting action, except that this permitting action is:
 - 1. Clarifying that the facility may not cause the temperature of the St. Croix River to exceed 85°F outside of the assigned mixing zone; and

2. PERMIT SUMMARY (cont'd)

2. Establishing Special Condition H, *Sedimentation Pond Maintenance*, based on new information.

b. History - The most current relevant regulatory actions include:

January 12, 2001 – The Department received authorization from the U. S. Environmental Protection Agency (USEPA) to administer the National Pollutant Discharge Elimination System (NPDES) permitting program in Maine, excluding areas of special interest to Maine Indian Tribes. From this point forward, the program has been referred to as the Maine Pollutant Discharge Elimination System (MEPDES) program, and MEPDES permit #ME0022063 has been utilized for this facility. On March 26, 2011, the USEPA authorized the Department to administer the MEPDES program in Indian territories of the Penobscot Nation and Passamaquoddy Tribe.

September 13, 2002 – Georgia Pacific Corporation (“GPC”) sold the Baileyville OSB/stud mill to the Louisiana Pacific Corporation (“LPC”).

January 28, 2003 – The LPC filed an application with the Department to transfer all licenses and permits for the mill complex. Licenses and permits issued to date have been issued in the name of the former owner of the facility, the GPC. The “global” transfer of the licenses and permits (other than this permit) were issued under a separate Department order.

September 15, 2006 – The Department approved a halt in monitoring at the facility due to the mill shutdown.

October 21, 2011 – The Department issued a global transfer of Department permits and licenses from Louisiana Pacific Corp. to Woodland Pulp LLC.

May 14, 2018 - The Department issued combination WDL #W000508-5O-J-R / MEPDES #ME0022063 for a five-year term. Outfall #003 was transferred from this permit to a U.S. Environmental Protection Agency Multi-Sector General Permit. The May 14, 2018 permit superseded previous WDLs issued on June 3, 2013; September 3, 2008; June 10, 2003; September 13, 1999; November 3, 1994; and October 21, 1976.

December 8, 2022 - WP submitted a timely and complete application to the Department to renew the MEPDES permit. The application was accepted for processing on December 9, 2022 and was assigned WDL #W000508-5O-K-R / MEPDES #ME0022063.

3. RECEIVING WATER QUALITY STANDARDS

Classification of major river basins, 38 M.R.S. § 467(13)(A)(3) classifies the Woodland Lake impoundment of the St. Croix River main stem as a Class C waters. *Standards for classification of fresh surface waters*, 38 M.R.S. § 465(4) describes the standards for Class C waters as follows:

Class C shall be the 4th highest classification.

3. RECEIVING WATER QUALITY STANDARDS (cont'd)

- A Class C waters must be of such quality that they are suitable for the designated uses of drinking water supply after treatment; fishing; agriculture; recreation in and on the water; industrial process and cooling water supply; hydroelectric power generation, except as prohibited under Title 12, section 403; navigation; and as a habitat for fish and other aquatic life.*
- B. Class C waters must be of sufficient quality to support all species of fish indigenous to those waters and to maintain the structure and function of the resident biological community. The dissolved oxygen content of Class C water may be not less than 5 parts per million or 60% of saturation, whichever is higher, except that in identified salmonid spawning areas where water quality is sufficient to ensure spawning, egg incubation and survival of early life stages, that water quality sufficient for these purposes must be maintained. In order to provide additional protection for the growth of indigenous fish, the following standards apply.*

(1) The 30-day average dissolved oxygen criterion of a Class C water is 6.5 parts per million using a temperature of 22 degrees centigrade or the ambient temperature of the water body, whichever is less, if:

- (a) A license or water quality certificate other than a general permit was issued prior to March 16, 2004 for the Class C water and was not based on a 6.5 parts per million 30-day average dissolved oxygen criterion; or*
- (b) A discharge or a hydropower project was in existence on March 16, 2005 and required but did not have a license or water quality certificate other than a general permit for the Class C water.*

This criterion for the water body applies to licenses and water quality certificates issued on or after March 16, 2004.

(2) In Class C waters not governed by subparagraph (1), dissolved oxygen may not be less than 6.5 parts per million as a 30-day average based upon a temperature of 24 degrees centigrade or the ambient temperature of the water body, whichever is less. This criterion for the water body applies to licenses and water quality certificates issued on or after March 16, 2004.

The department may negotiate and enter into agreements with licensees and water quality certificate holders in order to provide further protection for the growth of indigenous fish. Agreements entered into under this paragraph are enforceable as department orders according to the provisions of sections 347-A to 349.

Between April 15th and October 31st, the number of Escherichia coli bacteria in Class C waters may not exceed a geometric mean of 100 CFU or MPN per 100 milliliters over a 90-day interval or 236 CFU or MPN per 100 milliliters in more than 10% of the samples in any 90-day interval. The board shall adopt rules governing the procedure for designation of spawning areas. Those rules must include provision for periodic review of designated

3. RECEIVING WATER QUALITY STANDARDS (cont'd)

spawning areas and consultation with affected persons prior to designation of a stretch of water as a spawning area. [PL 2021, c. 551, §12 (AMD).]

C. Discharges to Class C waters may cause some changes to aquatic life, except that the receiving waters must be of sufficient quality to support all species of fish indigenous to the receiving waters and maintain the structure and function of the resident biological community. For the purpose of allowing the discharge of aquatic pesticides or chemicals approved by the department and conducted by the department, the Department of Inland Fisheries and Wildlife or an agent of either agency to restore biological communities affected by an invasive species, the department may find that the discharged effluent will not cause unacceptable changes to aquatic life as long as the materials and methods used will ensure the support of all species of indigenous fish and the structure and function of the resident biological community and will allow restoration of nontarget species.

4. RECEIVING WATER QUALITY CONDITIONS

The State of Maine Department of Environmental Protection 2018/2020/2022 Integrated Water Quality Monitoring and Assessment Report (Report), prepared by the Department pursuant to Sections 303(d) and 305(b) of the Federal Water Pollution Control Act, lists the Woodland Impoundment of the St. Croix River main stem (Assessment Unit ID ME0105000108_505R_01) as: "Category 3: Rivers and Streams with Insufficient Data or Information to Determine if Designated Uses are Attained (One or More Uses may be Impaired)."

In addition, the Report lists all of Maine's fresh waters as, "Category 4-A: Rivers and Streams Impaired by Atmospheric Deposition of Mercury." Impairment in this context refers to a statewide fish consumption advisory due to elevated levels of mercury in some fish tissues. The Report states, " All freshwaters are listed in Category 4-A (TMDL Completed) due to

US EPA approval of a Regional Mercury TMDL in December 2007. Maine has a fish consumption advisory for fish taken from all freshwaters due to mercury. Many waters, and many fish from any given water, do not exceed the action level for mercury. However, because it is impossible for someone consuming a fish to know whether the mercury level exceeds the action level, the Maine Department of Health and Human Services decided to establish a statewide advisory recommending limits on consumption for all freshwater fish. Maine has instituted statewide programs for removal and reduction of mercury sources.

5. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

- a. **Outfall #001** - Boiler blowdown, softener backwash, cooling waters and miscellaneous non-process wastewaters.

The monthly average and daily maximum mass and/or concentration limits established for flow, biochemical oxygen demand, total suspended solids, settleable solids, oil & grease, and pH in the previous permitting action are being carried forward in this permitting action. These limits were based on best professional judgment of best practicable treatment for the sources of wastewater being generated.

5. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Being that the facility has been shut down since the early 2000's, and the permittee does not plan to resume operations of the oriented strand board operation and stud mill in the foreseeable future, not all sources of wastewaters previously regulated will be realized.

Therefore, the Department will re-evaluate the applicability of the parameters, limitations, and monitoring requirements for this outfall based on changes in operation of the mill complex and the applicability of New Source Performance Standards.

b. **Outfall #002** – Non-contact cooling waters

1. Flow- The daily average flow limitation of 15.0 MGD in the previous permitting action is being carried forward in this permitting action. The permittee has indicated that the flow limitation should be representative of future operations of the Woodland Pulp North site turbine.
2. pH – The daily range limitation of 6.0 – 8.5 SU in the previous permitting action is being carried forward in this permitting action.
3. Temperature/Thermal Discharge – The daily maximum effluent temperature limit of 110°F in the previous permitting action is being carried forward in this permitting action. This temperature limit is based on a Department best professional judgment of effluent temperatures that are representative of the facility operating at full capacity. This permit is also carrying forward a summer limitation of weekly or daily thermal loads of 2.29×10^9 BTUs/Day and a daily maximum predicted river temperature increase (PRTI) limitation of 0.5°F to comply with *Regulations Relating to Temperature*, 06-096 C.M.R. 582 (effective date May 4, 1996).

06-096 C.M.R. 582 (1) states in part that:

No discharge of pollutants shall cause the ambient temperature of any freshwater body, as measured outside a mixing zone, to be raised more than 5° F.

and

In no event shall any discharge cause the temperature of any freshwater body to exceed 85° F at a point outside a mixing zone.

In addition, the rule limits thermal discharges to an in-stream temperature increase of 0.5° F above the ambient receiving water temperature when the discharge may cause the temperature of the water to exceed the U.S. Environmental Protection Agency's national ambient water quality criteria established to protect all species of fish indigenous to the receiving waters at any point outside a mixing zone established by the Board. The established temperature thresholds are based on USEPA water quality criterion found in the Quality Criteria for Water (Gold Book) for the protection of brook trout and Atlantic salmon, species indigenous to the St. Croix River. During the summer months, the weekly average temperature of 66° F was derived to provide for normal growth of brook trout and the daily maximum threshold temperature of 73° F protects for the survival of juveniles and adult Atlantic salmon. As a point of

5. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

clarification, the Department interprets the term "weekly average temperature" to mean a seven (7) day rolling average.

Compliance with the weekly rolling average and daily maximum PRTI of 0.5°F is determined by calculating the thermal load (expressed in BTUs/Day) associated with the regulated river flow (850 cfs = 549 MGD), actual river temperature, actual discharge flow, and actual discharge temperature from the mill. When the receiving water temperature is $\geq 73^{\circ}\text{F}$ and the receiving water flow is below the regulated low flow of 850 cfs, compliance with the RTI of 0.5°F is evaluated on a daily basis using the actual receiving water flow, actual receiving water temperature, actual discharge flow, and actual discharge temperature from the mill.

It is noted that 850 cfs is considered the regulated low flow due to the fact the St. Croix River is regulated to provide 850 cfs via the International Joint Commission (IJC) at the USGS gauge at Baring (#10121000) as a typical minimum flow. However, following evaluation of the historic flow at the USGS gauge at Baring, ME (#10121000) downstream of the Woodland dam, it was determined there is a possibility the river may fall below that flow. The new low flows of 1Q10 and 7Q10 are 703 cfs (454 MGD) and 713 cfs (461 MGD) respectively. Since the possibility of the flow dropping below 850 cfs was accounted for in determining the limits, no changes will be made to this permit. If the river flow is at or above 850 cfs, the limit of 2.29×10^9 BTUs/day will limit the PRTI to equal to or less than 0.5°F.

The calculations that follow are to determine the assimilative capacity of the receiving water during summer and non-summer seasons:

Allowable thermal load is determined by finding the thermal load that would increase the temperature of the receiving water by the maximum allowable °F.
Allowable thermal load (BTUs/Day) = $(Q_r)(\Delta T_a)(K)$

Discharged thermal load (BTUs/Day) = $(Q_e)(T_e - T_r)(K)$

Predicted river temperature increase = $[(Q_e)(T_e - T_r)]/Q_r$

Where

Q_r	=	Low River Flow (gallons/day)
Q_e	=	Effluent Flow (gallons/day)
T_r	=	Temperature of receiving water (°F)
T_e	=	Temperature of effluent (°F)
ΔT_a	=	Allowable temperature different (°F)
K	=	Conversion factor of 8.34 lbs/gallon

Non-summer (October 1st – May 31st)

The previous permitting action established, and this permitting action is carrying forward, a non-summer effluent temperature limitation of 110°F based on the following calculations:

5. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Using the regulated low flow, the allowable thermal load for non-summer seasons is:

$$(549,000,000 \text{ gallons/day})(5.0^{\circ}\text{F})(8.34 \text{ lbs/gal}) = 2.29 \times 10^{10} \text{ BTUs/Day}$$

Assuming the St. Croix River temperature is 35°F and the discharge flow and temperature are at the full permitted flow of 15 MGD and 110°F, the thermal load discharged would be:

$$(15,000,000 \text{ gal})(110^{\circ}\text{F} - 35^{\circ}\text{F})(8.34 \text{ lbs/gal}) = 0.938 \times 10^{10} \text{ BTUs/Day}$$

The predicted river temperature increase (PRTI) at the full permitted flow and temperature and the regulated low flow conditions in the St. Croix River would be:

$$\frac{(15,000,000 \text{ gal/day})(110^{\circ}\text{F} - 35^{\circ}\text{F})}{549,000,000 \text{ gal/day}} = 2.0^{\circ}\text{F}$$

Therefore, during the non-summer months when the facility is discharging at full permitted flow and temperature, the Department has made the determination based on the calculations above that the discharge does not exceed or have a reasonable potential to exceed the water quality standard in 06-096 CMR 582, an allowable RTI of less than 5°F above ambient temperature.

Summer (June 1st – September 30th)

The previous permitting action established, and this permitting action is carrying forward, a summer (June 1st – September 30th) thermal load limitation of 2.29×10^9 BTUs/Day when the river flow is equal to or above 850 cfs based on the following calculations:

The allowable thermal load for summer is:

$$(549,000,000 \text{ gallons/day})(0.5^{\circ}\text{F})(8.34 \text{ lbs/gal}) = 2.29 \times 10^9 \text{ BTUs/Day}$$

Assuming the St. Croix River temperature is 66°F and the discharge is at the full permitted flow and temperature of 15 MGD and 110°F, the thermal load discharged would be:

$$(15,000,000 \text{ gal})(110^{\circ}\text{F} - 66^{\circ}\text{F})(8.34 \text{ lbs/gal}) = 5.50 \times 10^9 \text{ BTUs/Day}$$

The PRTI at the full permitted flow and temperature and the regulated low flow conditions in the St. Croix River would be:

$$\frac{(15,000,000 \text{ gal/day})(110^{\circ}\text{F} - 66^{\circ}\text{F})}{549,000,000 \text{ gal/day}} = 1.2^{\circ}\text{F}$$

Therefore, during the summer months when the facility is discharging at full permitted flow and temperature, the Department has made the determination based on the calculations above that the discharge would exceed the water quality standard in 06-096 C.M.R. Ch. 582 of an allowable RTI of 0.5°F.

5. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Therefore, this permitting action is carrying forward a water quality-based summertime thermal load limitation of 2.29×10^9 BTUs/Day that is to be calculated on a daily basis between June 1st and September 30th. When the receiving water is greater than or equal to 66°F and less than 73°F, the thermal load limitation is a weekly rolling average limitation. When the receiving water is greater than or equal to 73°F and below 85°F, the thermal load limitation is a daily maximum limitation.

If the river flow falls below the regulated flow of 850 cfs, the allowable thermal discharge would decrease and the PRTI would change based on the actual flow. Therefore, between June 1st and September 30th, when the receiving water is greater than or equal to 73°F and the river flow falls below 850 cfs, the permittee must limit the PRTI to 0.5°F and calculate the PRTI daily.

Special Condition F, *Ambient Temperature Monitoring*, of this permit requires the permittee to monitor upstream and downstream receiving water temperature to verify the actual RTI of $\leq 0.5^\circ$ F in 06-096 C.M.R. 582 is being achieved during the summer months. The Department is utilizing the Woodland Dam spill way as the end of the mixing zone where during low flow conditions approaching 850 cfs, most if not all the flow in the St. Croix River passes through the turbines of the Woodland Dam, which promotes further mixing.

Enforcement generally, 38 M.R.S. §451 states in part that:

The purpose of a mixing zone is to allow a reasonable opportunity for dilution, diffusion or mixture of pollutants with the receiving waters before the receiving waters below or surrounding a discharge will be tested for classification violations. In determining the extent of any mixing zone to be established under this section, the department may require from the applicant testimony concerning the nature and rate of the discharge; the nature and rate of existing discharges to the waterway; the size of the waterway and the rate of flow therein; any relevant seasonal, climatic, tidal and natural variations in such size, flow, nature and rate; the uses of the waterways in the vicinity of the discharge, and such other and further evidence as in the department's judgment will enable it to establish a reasonable mixing zone for such discharge.

The two mile segment of river between the point of discharge to the spillway of the Woodland Dam is considered to be the area of reasonable opportunity for heat transfer to the atmosphere provided by 38 M.R.S. §451.

Being that Woodland and any potential interested parties have not finalized future development plans for the facility and it is unknown what process(es) will be brought back on line, Special Condition G, *Commencement of Operations* of this facility requires that:

At a minimum of ninety (90) days prior to commencing production/operations, the permittee must meet with the Department's permitting and compliance inspection staff to review applicability of the permit limitations, monitoring requirements and reporting requirements. Should the Department determine the proposed production/operations are

5. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

significantly different than what has been presented in the December 8, 2022 application materials, the Department may require the permittee to submit a revised application to modify the permit.

6. DISCHARGE IMPACT ON RECEIVING WATER QUALITY

As permitted, the Department has determined the existing water usages will be maintained and protected and the discharge will not cause or contribute to the failure of the water body to meet standards for Class C classification.

7. ANTI-BACKSLIDING

Federal regulation 40 C.F.R. §122.44(l) contains the criteria for what is often referred to as the anti-backsliding provisions of the Federal Water Pollution Control Act (Clean Water Act). In general, the regulation states that except for provisions specified in the regulation, effluent limitations, standards, or conditions must be at least as stringent as the final effluent limitations, standards or conditions in the previous permit.

Applicable exceptions include: (1) material and substantial alterations or additions to the permitted facility occurred after permit issuance which justify the application of a less stringent effluent limitation and (2) information is available which was not available at the time of the permit issuance (other than revised regulations, guidance, or test methods) and which would justify the application of less stringent effluent limitations at the time of permit issuance. All limitations in this permit are equally or more stringent than those in the previous permit.

8. ANTI-DEGREDAATION

As permitted, the Department has determined the existing water usages will be maintained and protected and the discharge will not cause or contribute to the failure of the waterbody to meet standards for Class C.

9. ISSUANCE OF COOLING WATER INTAKE STRUCTURE PERMITS

Although a MEPDES permit for a facility with regulated discharges would typically also need to include requirements under CWA § 316(b) for any associated cooling water intake structures (CWISs), such as one present at this facility, Maine DEP's permits are not required to do so under the CWA because Maine DEP has not yet been authorized to administer CWA § 316(b). In 2001, EPA Region 1 authorized the Maine DEP to administer the NPDES permit program, except for the permitting of CWISs under CWA § 316(b). Because the state had not yet adopted legislation or regulations to implement CWA § 316(b) at the time of the Region's approval, Region 1 approved Maine's NPDES program on a partial, phased basis pursuant to CWA § 402(n)(4). Until this remaining portion of NPDES authorization is complete, Region 1 is responsible for making NPDES permitting determinations under CWA § 316(b), including where CWA § 316(b) applies and, in the situations where it applies, the resultant permit conditions. Until the state is authorized to implement CWA § 316(b), Maine DEP issues NPDES permits addressing all issues other than § 316(b) and Region 1 is

9. ISSUANCE OF COOLING WATER INTAKE STRUCTURE PERMITS (cont'd)

responsible for issuing supplemental permits to address CWISs under § 316(b), if § 316(b) is applicable. Furthermore, there is no expressed or implied legal requirement that the permits be issued jointly or simultaneously.

10. PUBLIC COMMENTS

Public notice of this application was made in the *Calais Advertiser* newspaper on or about December 16, 2022. The Department receives public comments on an application until the date a final agency action is taken on the application. Those persons receiving copies of draft permits shall have at least 30 days in which to submit comments on the draft or to request a public hearing, pursuant to *Application Processing Procedures for Waste Discharge Licenses*, 06-096 CMR 522 (effective January 12, 2001).

11. DEPARTMENT CONTACTS


Additional information concerning this permitting action may be obtained from, and written comments should be sent to:

Bekah Farmer
Department of Environmental Protection
Bureau of Water Quality
Division of Water Quality Management
17 State House Station
Augusta, Maine 04333-0017 Telephone: (207) 458-8706 Fax: (207) 287-3435
bekah.farmer@maine.gov

12. RESPONSE TO COMMENTS

Reserved for public comment.

ATTACHMENT A



ATTACHMENT B

fall #003

Outfall #001

Outfall #002

Outfall #003

Outfall #001

Outfall #002