



United States Environmental Protection Agency
Region 2
Water Division
290 Broadway
New York, New York 10007

NPDES NO. PR0025984

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

The following Permittee is authorized to discharge subject to the requirements set forth in this permit:

Permittee (mailing address)	Facility (location address)
EcoEléctrica, L.P.	EcoEléctrica, L.P.
641 Road 337 Firm Delivery	641 Road 337 Firm Delivery
Peñuelas, PR 00624	Peñuelas, PR 00624
EPA has classified this discharge as a major discharge.	

The Permittee may discharge from the discharge points identified below:

Outfall	Effluent description	Outfall latitude	Outfall longitude	Receiving water name and classification
001	1) Cooling tower blowdown (boiler blowdown, desalination plant brine blowdown, and backwash water from the remineralization system) 2) Treated stream from the neutralization system (demineralizer, wastewater laboratory drains, tank washes, and chemical dike drains) 3) Demineralizer backwash 4) Treated stream from the oil/water separators (oil from plant floor drains and equipment drain lines, and remineralizer drains)	17.00 °, 58.00', 13.00" N	-66.00 °, 45.00', 59.00" W	Guayanilla Bay, Class SB

Issuance date	Effective date (EDP)	Expiration date	Renewal application date
<Issuance Date>	<Effective Date>	<Enter date 5 years from EDP>	<Enter date 180 days prior to Exp. Date>

To meet the provisions of the Clean Water Act (CWA) as amended, 33 *United States Code* (U.S.C.) 1251 *et seq.* and its implementing regulations, the Permittee must comply with the requirements in this permit.

I, Javier Laureano, Director, do hereby certify that this permit with all attachments is a full, true, and correct copy of the permit issued by EPA and certified by the Puerto Rico Department of Natural and Environmental Resources (DNER), on **<Issuance Date>**.

Javier Laureano Perez, Director
Water Division
U.S. Environmental Protection Agency Region 2

Contents

PART I. Background.....	1
PART II. Effluent Limitations and Monitoring Requirements.....	2
A. Final Effluent Limitations—Outfall Number 001	2
B. Interim Effluent Limitations	3
C. Narrative Limitations	3
D. Monitoring Requirements	3
E. Monitoring Locations	4
PART III. Reporting Requirements and Compliance Determination	4
A. Reporting Requirements.....	4
B. Compliance Determination	5
PART IV. Standard and Special Conditions	6
A. Standard Conditions	6
B. Special Conditions	7
Attachment A: 126 Priority pollutants	17
Attachment B: Definitions	1
Attachment C: Standard Conditions	1

PART IV. BACKGROUND

- A. Rationale for Permit Requirements.** This permit is issued pursuant to CWA section 402 and implementing regulations adopted by EPA. EPA developed the requirements in this permit on the basis of information submitted as part of the complete application and monitoring and reporting requirements, and other available information. This permit contains TBELS based on Effluent Limitations Guidelines and Standards for the Steam Electric Power Generating Point Source Category in Part 423 and WQBELS based on the Puerto Rico Water Quality Standards Regulation (PRWQS), as amended. The accompanying Fact Sheet contains detailed information and rationale for permit requirements.
- B. Water Quality Certificate.** Pursuant to CWA section 401(a)(1), after due consideration of the applicable provisions established in the PRWQS and CWA sections 208(e), 301, 302, 303, 304(e), 306 and 307, on December 12, 2022 the Puerto Rico Department of Natural and Environmental Resources (DNER) certified that there is reasonable assurance that the allowed discharge will not cause violations to the applicable water quality standards for the receiving water body if the limitations and monitoring requirements in the Water Quality Certificate are met. Additional requirements could be required to comply with other sections of the CWA. **Permit conditions marked with an asterisk (*) are pursuant to the WQC.**
- C. Impaired Waters and Total Maximum Daily Loads (TMDLs).** This facility discharges to an impaired water. A TMDL has not been developed for the impaired waterbody. The effluent limitations in this permit are sufficient to ensure compliance with the applicable water quality standards [40 CFR 122.44(d)(1)(vii)(A)].
- D. Mixing Zone/Dilution Allowance.** DNER has not approved a mixing zone or dilution allowance for this discharge.
- E. Antidegradation and Anti-backsliding Requirements.** The discharge is consistent with the federal anti-degradation provisions at 40 CFR 131.12, 72 Federal Register 238 (December 12, 2007, pages 70517-70526), and DNER's *Anti-Degradation Policy Implementation Procedure* in Attachment A of PRWQS. In addition, all effluent limitations in this permit are at least as stringent as the effluent limitations in the previous permit and are consistent with the anti-backsliding requirements at 40 CFR 122.44(l).
- F. Public Participation.** Federal regulations at 40 CFR 124 require EPA to consider all significant comments on the draft permit received during the public comment period in the development of the final permit. Any comments received will be provided in a Responsiveness Summary issued with the final permit.

PART V. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**A. Final Effluent Limitations—Outfall Number 001**

The Permittee must maintain compliance with the following effluent limitations at Outfall 001, with compliance measured at Monitoring Location. The discharge 001 consists of wastewater consisting of the following: cooling tower blowdown (boiler blowdown, desalination plant brine blowdown and backwash water from the remineralization system); treated stream from the neutralization system (demineralizer wastewater, laboratory drains, tank washes and chemical dike drains) and demineralizer backwash; and treated stream from the oil/water separators (oil water from plant floor drains and equipment drain lines, and remineralizer drains).

Effluent Limitations Table

Parameter	Units	Effluent limitations			Monitoring requirements		Footnotes
		Average monthly	Average weekly	Maximum daily	Sample type	Minimum sampling frequency	
Arsenic* (As)	ug/L	--	--	Monitor Only	Grab	Annually	
BOD ₅ *	mg/L	30.0	--	--	Composite	Monthly	--
Chlorine, Available	mg/L	0.2	--	0.5	Grab	Daily	6
Chlorine, Total Residual*	ug/L	--	--	20.0	Grab	Daily	6, 7
Chromium, Total	mg/L	0.2	--	0.2	Grab	Weekly	---
Color*	Pt-Co	--	--	--	Grab	Monthly	10, 11
Copper (Cu) *	ug/L	--	--	3.73	Grab	Annually	10
Cyanide, Free (Cn) *	ug/L	--	--	1.0	Monthly	Grab	10
Dissolved Oxygen*	mg/L	Shall not be less than 5.0			Grab	Daily	---
Flow*	m ³ /day			81,007	Continuous Recording		2, 3
	MGD			21.4			
Mercury (Hg) *	ug/L	--	--	0.051	Grab	Annually	10
Oil and Grease	mg/L	15.0	--	20.0	Grab	Twice Monthly	---
	mg/L	--	--	--	Grab	Twice Monthly	12*
pH*	standard unit	Within the range of 7.3 and 8.5			Grab	Daily	---
Suspended, Colloidal, or Settleable Solids	mg/L	--	--	--	Grab	Monthly	13
Temperature*	°F (°C)	Discharge water temperature comply with one of the following: not exceed 90°F (32.2°C), or not exceed intake water temperature by more than 1.8°F (1.0°C)			Grab	Daily	8

Parameter	Units	Effluent limitations			Monitoring requirements		Footnotes
		Average monthly	Average weekly	Maximum daily	Sample type	Minimum sampling frequency	
Temperature Difference Between Intake Water and Discharge*	°F (°C)	Shall not exceed 1.8°F (1.0°C), if the discharge temperature is more than 90°F (32.2°C).			Grab	Daily	8
Total Suspended Solids	mg/L	30.0	--	100.0	Composite	Twice Monthly	10
Turbidity*	NTU	--	--	10.0	Grab	Quarterly	10
Whole Effluent Toxicity, Acute*	LC50%	--	--	--	24-hr Composite	See Part IV.B.2.	5
Zinc (Zn) *	ug/L	--	--	81.0	Grab	Annually	10
126 Priority Pollutants (see Appendix A)	mg/L	No detectable amounts			Composite	Annually	9

Notes, Footnotes and Abbreviations

Dashes (--) indicate there are no effluent limitations or monitoring requirements for this parameter.

Asterisk (*) indicate conditions pursuant to the WQC.

(1) No longer applicable. Retained to preserve footnote numbering.

(2) See Part IV.B.1 *Special Conditions from the WQC* for additional narrative conditions for flow.

(3) See Part IV.B.1 *Special Conditions from the WQC* for additional narrative conditions for flow.

(4) No longer applicable. Retained to preserve footnote numbering.

(5) See additional conditions from the WQC in Part IV.B.2. *Whole Effluent Toxicity Testing from the WQC* for monitoring and reporting requirements for acute and chronic WET.

(6) Neither free available chlorine nor total residual chlorine may be discharged from any unit for more than two hours in any one day and not more than one unit in any plant may discharge free available or total residual chlorine at any one time unless the utility can demonstrate to the Regional Administrator of the State, if the State has NPDES permit issuing authority, that the units in a particular location cannot operate at or below this level of chlorination.

(7) Total residual chlorine may not be discharged from any single generating unit for more than two hours per day unless the discharger demonstrates to the permitting authority that discharge for more than two hours per day is required for macroinvertebrate control.

(8) See Part IV.B.1 *Special Conditions from the WQC* for additional narrative conditions for temperature.

(9) There must be no detectable amounts of the 126 priority pollutants (Appendix A) in the discharge, except for chromium and zinc (effluent limits shown in the table above). Discharge of any product registered under the Federal Insecticide, Fungicide and Rodenticide Act is prohibited unless specifically authorized elsewhere in the permit. The first monitoring/sampling event must be performed within six (6) months following commencement of the discharge, and at twelve-month intervals thereafter.

(10) See Part IV.B.1 *Special Conditions from the WQC* for additional narrative No Net Addition Limitations.

(11) See Part IV.B.1 *Special Conditions from the WQC* for additional narrative conditions for color.

(12) See Part IV.B.1 *Special Conditions from the WQC* for additional narrative conditions for oil and grease.

(13) See Part IV.B.1 *Special Conditions from the WQC* for additional narrative conditions for suspended, colloidal, and settleable solids.

B. Interim Effluent Limitations

There are no interim effluent limitations applicable to this facility.

C. Narrative Limitations

See Part IV.B.1 *Special Conditions from the WQC* for additional narrative conditions.

D. Monitoring Requirements

- Effluent monitoring and analyses must be conducted in accordance with EPA test procedures approved under 40 CFR Part 136, *Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act*, as amended. For situations where there may be interference, refer to *Solutions to Analytical Chemistry Problems with Clean Water Act Methods* (EPA 821-R-07-002). For effluent analyses, the Permittee must use a *Minimum Level (ML)* that is lower than the effluent limitations described in Effluent Limitations Table of this permit. If all published MLs are higher than the effluent limitations, the Permittee must use the test method procedure with the lowest ML. The Permittee must ensure that the laboratory uses a standard

calibration where the lowest standard point is equal to or less than the ML. Priority pollutant analysis for metals must measure *total metal*, except as provided under 40 CFR 122.45(c). EPA method 1631E must be used for mercury analysis. Priority pollutant analysis for benzene, ethylbenzene, toluene and xylene must employ either EPA Method 602 or 624. Effluent analysis for xylene must measure *total xylene*.

2. The regulations at 40 CFR 122.48 require that all NPDES permits specify monitoring and reporting requirements. All monitoring must be in accordance with Standard Condition 10. *Monitoring and records* in Attachment B of this permit.
3. Sampling point for Outfall 001 must be located immediately after the primary flow measuring device of the effluent of the treatment system.
4. The Permittee must develop and implement a quality assurance (QA) plan for laboratory analyses for effluent and/or receiving water monitoring.
5. All sample collection, preservation, and analysis must be carried out in accordance with 40 CFR part 136. A licensed chemist authorized to practice in the profession in Puerto Rico must certify all chemical analyses. All bacteriological tests must be certified by a microbiologist or licensed medical technologist authorized to practice the profession in Puerto Rico.
6. The samples taken for the analysis of free cyanide and mercury must be analyzed using the analytical method approved by the EPA with the lowest possible detection level, in accordance with Rule 1306.8 of the Puerto Rico Water Quality Standards Regulation as amended.
7. The Permittee must use the EPA approved analytical method, with the lowest possible detection limit, in accordance with the 40 CFR Part 136 for Sulfide (as S). Also, the Permittee must complete the calculations specified in Method 4500-S²-F, Calculation of Un-ionized Hydrogen Sulfide, of Standards Methods 18th Edition, 1992, to determine the concentration of undissociated H₂S. If the sample results of dissolved sulfide are below the detection limit of the EPA approved method established in 40 CFR Part 136, the concentration of undissociated H₂S must be reported as "below detection limit."

E. Monitoring Locations

The Permittee must establish the following monitoring locations to demonstrate compliance with the effluent limitations and other requirements in this permit:

Monitoring Locations Table

Outfall	Monitoring location	Monitoring location description
001	001	The monitoring location must be located immediately after the primary flow-measuring device for the effluent.

PART VI. REPORTING REQUIREMENTS AND COMPLIANCE DETERMINATION

A. Reporting Requirements

1. **Standard Conditions.** The Permittee must comply with all Standard Conditions in Part IV.A below and Attachment B of this permit related to monitoring, reporting, and recordkeeping.
2. **Monitoring data submission.** The Permittee shall submit monitoring data to EPA electronically using NetDMR, a web-based tool that allows Permittees to electronically submit discharge monitoring reports (DMRs) via a secure internet connection. Specific requirements regarding submittal of data and reports in hard copy form and for submittal using NetDMR are described below:
 - a. **Submittal of Reports Using NetDMR.** DMR submittals must be submitted in accordance with Standard Condition 12.d. *Monitoring reports* in Attachment B of this permit. The Permittee will report the results for all monitoring specified in this permit. The Permittee shall submit monthly DMRs including the results of all required monitoring using EPA-approved test methods or other test methods specified in this permit as required. If the Permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR Part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring must be included in the

calculation and reporting of the data submitted in the DMR. DMRs and reports submitted electronically to EPA must be done using NetDMR at <http://www.epa.gov/netdmr>.

- b. **Submittal of Reports in Hard Copy.** Non-DMR reports must be submitted in accordance with III.A.3. Permittees shall continue to send hard copies of reports other than DMRs to the EPA and DNER until further notice from the EPA and DNER.
 - c. **Timing of submissions.** DMRs shall be submitted to EPA no later than the 28th day of the month following the completed reporting period. Monitoring results shall be summarized and reported using netDMR. The first report is due on 28th day of month after EDP.
3. **Other Reports.** Until further notice from EPA of additional electronic reporting requirements, all other reports (i.e., any report besides a DMR report) must be signed and certified as required by Standard Condition 11. *Signatory requirements* in Attachment B of this permit. The Permittee must submit the signed reports required in this permit to the addresses below:
- a. U.S. Environmental Protection Agency, Region 2
290 Broadway, 21st Floor
New York, NY 10007-1866
Attention: Compliance Assistance and Program Support Branch

or

via electronic mail at Teitelbaum.daniel@epa.gov
 - b. Puerto Rico Department of Natural and Environmental Resources
San Jose Industrial Park
1375 Ave. Ponce de Leon
San Juan, PR 00926

or

via electronic mail at fuentesprecisadas@drna.pr.gov.
4. **Analytical Determinations.** The Permittee must report the results on the DMR of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:
- a. Sample results greater than or equal to the ML must be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
 - b. Sample results less than the ML must be reported as <ML, where the ML equals the ML reported by the laboratory.
 - c. Permittees are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Permittee to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.

B. Compliance Determination

Compliance with effluent limitations contained in this permit will be determined as specified below:

1. **General.** Compliance with effluent limitations for priority pollutants must be determined using sample reporting protocols defined in section III. A and Attachment A. *Definitions*.
2. **Average Monthly Discharge Limitation (AML).** If the average or, when applicable, the median of daily discharges that were measured in a calendar month exceeds the AML for a given parameter, this will represent a single violation, though the Permittee will be considered out of compliance for each day of that month for that parameter (e.g., resulting in 31 days of noncompliance in a 31-day month). If only a single sample is taken during the calendar month and the analytical result for that sample exceeds the AML, the Permittee will be considered out of compliance for that calendar month. The Permittee will be considered out of compliance for only the days when the discharge occurs. For any one calendar month during which no sample (daily discharge) is taken yet sampling is required, the Permittee will be considered out of compliance for that calendar month.

3. **Average Weekly Discharge Limitation (AWL).** If the average or, when applicable, the median of daily discharges over a calendar week exceeds the AWL for a given parameter, this will represent a single violation, though the Permittee will be considered out of compliance for each day of that week for that parameter, resulting in 7 days of noncompliance. If only a single sample is taken during the calendar week and the analytical result for that sample exceeds the AWL, the Permittee will be considered out of compliance for that calendar week. The Permittee will be considered out of compliance for only the days when the discharge occurs. For any one calendar week during which no sample (daily discharge) is taken yet sampling is required, the Permittee will be considered out of compliance for that calendar week.
4. **Maximum Daily Discharge Limitation (MDL).** If a daily discharge exceeds the MDL for a given parameter, the Permittee will be considered out of compliance for that parameter for that 1 day only in the reporting period. For any one day during which no sample is taken yet a sampling is required, the Permittee will be considered out of compliance for that day.

PART VII. STANDARD AND SPECIAL CONDITIONS

C. Standard Conditions

Standard Conditions Applicable to All Facilities

- a. The Permittee must comply with all Standard Conditions that apply to all NPDES permits in accordance with 40 CFR 122.41 (Attachment B of this permit), and additional conditions applicable to specific categories of facilities in accordance with 40 CFR 122.42.
- b. The Permittee must comply with the Reopener Clause in Standard Condition 17. *Reopener clause for toxic effluent limitations*, in Attachment B of this permit, which applies to all NPDES permits in accordance with 40 CFR 122.44(b). EPA reserves the right to revoke and reissue or modify this permit to establish effluent limitations, additional monitoring, schedules of compliance or other permit conditions based on new information, including any changes to the final Water Quality Certificate from DNER.

Standard Conditions Applicable to Specific Facilities—Notification Levels

Existing manufacturing, commercial, mining, and silvicultural dischargers must notify EPA as soon as they know or have reason to believe [40 CFR 122.42(a)]:

- a. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in this permit, if that discharge will exceed the highest of any one of the following *notification levels* [40 CFR 122.42(a)(1)]:
 - 1) 100 micrograms per liter (µg/L) [40 CFR 122.42(a)(1)(i)].
 - 2) 200 µg/L for acrolein and acrylonitrile; 500 µg/L for 2,4 dinitrophenol and 2 methyl 4,6 dinitrophenol; and 1 milligrams per liter (mg/L) for antimony [40 CFR 122.42(a)(1)(ii)].
 - 3) Five times the maximum concentration value reported for that pollutant in the DMR [40 CFR 122.42(a)(1)(iii)].
 - 4) The level established by EPA in accordance with 40 CFR 122.44(f) [40 CFR 122.42(a)(1)(iv)].
- b. That any activity has occurred or will occur that would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant that is not limited in this permit, if that discharge will exceed the highest of any one of the following *notification levels* [40 CFR 122.42(a)(2)]:
 - 1) 500 µg/L [40 CFR 122.42(a)(2)(i)].
 - 2) 1 mg/L for antimony [40 CFR 122.42(a)(2)(ii)].
 - 3) Ten times the maximum concentration value reported for that pollutant in the DMR [40 CFR 122.42(a)(2)(iii)].
 - 4) The level established by EPA in accordance with 40 CFR 122.44(f) [40 CFR 122.42(a)(2)(iv)].

B. Special Conditions

1. Special Conditions from the Water Quality Certificate

Note: All requirements in this section are pursuant to the WQC.

- a. *Flow.*
 - 1) The flow of discharge 001 must not exceed the limitation of 81,007 m³/day (21.4 MGD) as the daily maximum. No increase in flow of discharge 001 shall be authorized without recertification from the Department of Natural and Environmental Resources (DNER).
 - 2) The flow measuring device for the Outfall 001 must be periodically calibrated and properly maintained. Calibration and maintenance records must be kept in compliance with the Applicable Rules and Regulations.
- b. *Temperature.* Except by natural causes, no heat may be added to the waters of Puerto Rico which would cause the temperature of any site to exceed 90°F. No thermal discharge or combination of thermal discharges into or onto the surface, estuarine and coastal waters shall be injurious to fish, shellfish or the culture or propagation of a balanced indigenous population thereof nor in any way affect the designated uses.
- c. *No Net Addition Limitations.*
 - 1) If the applicable water quality standard is not exceeded in the inlet, the established effluent limitation shall not be exceeded at the discharge point.
 - 2) If the applicable water quality standard is not achieved in the inlet, the same measurement shall be achieved at the discharge point.
 - 3) In order to demonstrate compliance with the No Net Addition Limitation, influent (raw water from Guayanilla Bay) and effluent (filters backwash and sedimentation tank drain) monitoring must be conducted at the frequency specified herein. The permittee shall take into consideration the residence time of the influent when screening influent and effluent monitoring. The permittee shall report the results of these measurements in the Discharge Monitoring Reports. Alternatively, the permittee may forgo influent monitoring and comply with the applicable water quality standard as effluent limitation at the end of the pipe of discharge.
- d. *Color.* Shall not be altered by other than natural causes.
- e. *Oil and Grease.* The water of Puerto Rico shall be substantially free from floating non-petroleum oils and greases, as well as petroleum-derived oils and greases.
- f. *Suspended Colloidal and Settleable Solids.* Solids from wastewater sources shall not cause deposition in or be deleterious to the existing or designated uses of the water body.
- g. *Oil sheen.* The discharge 001 must not cause the presence of oil sheen in the receiving water body.
- h. *Floating Debris, Scum, or Other Floating Materials.* The waters of Puerto Rico must not contain floating debris, scum, or other floating materials attributable to discharges in amounts sufficient to be unsightly or deleterious to the existing or designated uses of the water body.
- i. *Taste & Odor Producing Substances.* Taste and odor-producing substances must not be present in amounts that will interfere with primary contact recreation or will render any undesirable taste or odor to edible aquatic life.
- j. *Toxic or Undesirable Physiological Responses.* The waters of Puerto Rico must not contain any substance, attributable to the discharge at such concentration which, either alone or as result of synergistic effects with other substances, is toxic or produces undesirable physiological responses in humans, fish, or other fauna or flora.
- k. *Toxic Substances.* No toxic substances shall be discharged, in toxic concentrations, other than those allowed as specified in the NPDES permit. Those toxic substances included in the permit renewal

application, but not regulated by the NPDES permit, must not exceed the concentrations specified in the applicable regulatory limitations.

- l. No changes in the design or capacity of the treatment system will be permitted without the previous authorization of the DNER.
- m. Prior to the construction of any additional treatment system or the modification of the existing one, the permittee shall obtain the approval from the DNER of the engineering report, plans and specifications.
- n. The permittee shall install, maintain and operate all water pollution control equipment in such manner as to be in compliance with the Applicable Rules and Regulations.
- o. The sampling point for discharge 001 shall be labeled with an 18 inches per 12 inches (minimum dimensions) sign that reads as follows:

“Punto de Muestreo para la Descarga 001”

- p. All water and wastewater treatment facilities, whether publicly or privately owned, must be operated by a person licensed by the Examination Board of Water and Wastewater Treatment Plants Operators of Puerto Rico.
- q. No later than one hundred eighty (180) days after the Effective Date of this Special Condition (EDSC), the permittee shall conduct semiannually acute toxicity tests for a period of one (1) year, after which the tests shall be performed annually, of its wastewater discharge through outfall serial number 001 in accordance with the following:
 - 1) The test species should be silverside (*Menidia beryllina*) and mysid (*Mysidopsis bahia*). The tests should be static renewal type.
 - 2) The toxicity tests shall be conducted in accordance with the EPA publication, EPA 821-R-02-012 Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms (Fifth Edition), October 2002, or the most recent edition of this publication if such edition is available.
 - 3) The tests shall provide a measure of the acute toxicity as determined by the wastewater concentration, which cause 50 percent mortality of the test organisms over a 48-hour period. The test results shall be expressed in terms of Lethal Concentration (LC) and reported as 48-hour LC₅₀.
 - 4) A procedure report shall be submitted within ninety (90) days after the EDSC. The following information shall be included in the procedure report:
 - i) An identification of the organization responsible for conducting the tests and the species to be tested.
 - ii) A detailed description of the methodology to be utilized in the conduct of the tests, including equipment, sample collection, dilution water and source of test organisms.
 - iii) A schematic diagram, which depicts the effluent sampling location in relation to the wastewater treatment facility and the discharge monitoring point.
 - 5) The results of the tests conducted shall be submitted to the Clean Water Regulatory Branch, Water Division of EPA's Region 2 and the DNER's Water Quality Area, within sixty (60) days of completion of each test. Based on the review of the test results, the Regional Administrator of EPA or the DNER can require additional toxicity tests, including chronic and toxicity/treatability studies, and may impose toxicity limitation.

Whole Effluent Toxicity Testing from the Water Quality Certificate

NOTE: This special condition shall not become effective until DNER has determined the applicability to the respective facility and has notified the permittee and the EPA, in writing, of the necessity to comply with this special condition. All requirements in this section are pursuant to the WQC.

a. **Acute Whole Effluent Toxicity Testing**

- 1) **Monitoring Frequency and Sample Type.** Not later than **Effective Date of This Special Condition (EDSC) +180 days** the Permittee must conduct semiannual acute toxicity tests on a 24-hour composite effluent sample for a period of one year, after which tests shall be annual. Acute toxicity test samples must be collected for each point of discharge at the designated monitoring location for the effluent (i.e., downstream from the last treatment process and any in-plant flow return flows where a representative effluent sample can be obtained).
- 2) **Methods.** The acute toxicity tests must be conducted in accordance with the EPA document, *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (EPA-821-R-02-012, Fifth Edition, 2002) and Table IA of 40 CFR Part 136. Tests must provide a measure of the acute toxicity as determined by the effluent concentration that causes 50 percent mortality of the test organisms over a 48-hour period.

The tests must be static renewal tests. The acute toxicity tests must provide a measure of the acute toxicity as determined by the effluent concentration that represents the LC₅₀. Test results must be expressed in terms of the LC₅₀ and reported in TU_a on the monthly DMR, where $TU_a = 100 / LC_{50}$.

If the acute WET test does not meet all test acceptability criteria as specified in the test method, the Permittee must re-sample and re-test as soon possible, not to exceed 14 days following notification of invalid test results. Data from invalid and valid tests must be submitted in the Permittee's DMR.
- 3) **Test Species.** The test species must be silverside (*Menidia Beryllina*) and mysid (*Mysidopsis bahia*).
- 4) **Numeric Effluent Limitation or Trigger.** There is no acute WET effluent limitation for this discharge. *There is, however, an acute WET trigger of an LC50 result less than 100%.* This permit requires additional toxicity testing if the acute WET limit or trigger is exceeded (see *Accelerated Toxicity Testing and TRE Initiation* of this part).
- 5) **Dilution Allowance.** For this discharge, DNER has not authorized a mixing zone or dilution allowance for acute toxicity.

b. **Chronic Whole Effluent Toxicity Testing**

There are no chronic WET testing requirement applicable to this facility.

- c. **WET Notification Requirements.** The Permittee must notify EPA within 48-hours after the receipt of test results exceeding the effluent limitation or monitoring trigger during regular or accelerated monitoring.
- d. **Toxicity Reduction Evaluation (TRE) Workplan.** Within 90 days after the effective date of this special condition, the Permittee must prepare and submit a TRE Workplan to EPA, which must include steps the Permittee intends to follow if toxicity is measured in the effluent. The workplan must include, at a minimum:
 - 1) A description of the investigation and evaluation techniques that would be used to identify potential causes and sources of toxicity, effluent variability, and treatment system efficiency.
 - 2) A description of methods for maximizing in-house treatment system efficiency, good housekeeping practices, and a list of all chemicals used in operations at the facility.
 - 3) Potential actions to be undertaken by the Permittee to investigate, identify, and correct the causes, and prevent the recurrence of toxicity.
 - 4) Identification of responsible persons/parties for conducting the TRE.
 - 5) Possible source reduction measures and pollution prevention measures opportunities to reduce toxicity.
- e. **Accelerated Toxicity Testing and TRE Initiation.** If the discharge displays an acute or chronic toxicity result that exceeds the effluent limitation or trigger, the Permittee must conduct six additional toxicity tests

of the discharge using the same species and test method as that of the observed toxicity, every two weeks, over a 12 week period.

- 1) Accelerated testing must begin within 14 days of the Permittee's receipt of the test result exceeding the effluent limit or trigger. If none of the six additional toxicity tests exceeds the effluent limit or trigger, then the Permittee may return to its regular testing frequency. All accelerated laboratory test results must be submitted to EPA and DNER within 30 days of receipt by the Permittee, as required in the Reporting of Toxicity Monitoring Results section below.
 - 2) If the result of any accelerated toxicity test for the discharge exceeds the effluent limit or trigger, the Permittee is in violation of this permit and must cease accelerated monitoring and initiate a TRE within 14 days of receipt of this test result to investigate the cause(s) of, and identify corrective actions to reduce or eliminate effluent toxicity. The TRE must use the same species and test method as that of the observed toxicity. The Permittee must use the following EPA guidance manual to conduct the TRE: *Generalized Methodology for Conducting Industrial Toxicity Reduction Evaluations* (EPA-600-2-88-070, 1989).
 - 3) The Permittee may also use the following manuals for Toxicity Identification Evaluation (TIE) to identify and abate the causes of toxicity:
 - a. *Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I* (EPA-600-6-91-005F, 1992).
 - i. *Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity* (EPA-600-R-92-080, 1993).
 - b. *Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity* (EPA-600-R-92-081, 1993).
 - c. *Marine Toxicity Identification Evaluation (TIE): Phase I Guidance Document* (EPA-600-R-96-054, 1996).
 - 4) The Permittee must submit accelerated test results within 30 days after the Permittee's receipt of the laboratory reports for accelerated monitoring. Test results that were conducted because of accelerated monitoring may be used to satisfy the normal acute Toxicity Testing requirements above, provided that all requirements (including species, test type, frequency, timing, and sample requirements) are met.
- f. **Reporting of Toxicity Monitoring Results.** For any WET testing event, the Permittee must report the WET results in TU_a on the DMR for the month in which the toxicity test was conducted. In addition, a full laboratory report must be submitted to the addresses in Part III.A.3 of this permit as an attachment to the DMR, reported according to the test methods manual chapter on report preparation and test review, and must include, at a minimum, the following:
- 1) The acute WET toxicity results expressed in LC₅₀ and TU_a. For tests where the IWC is 100 percent effluent that does not result in a toxic response, the result must be reported at <0.3 TU_a.
 - 2) The dates of sample collection and initiation of each toxicity test.
 - 3) The statistical methods used to calculate endpoints.
 - 4) The statistical output page, which includes the calculation of the percent minimum significant difference (PMSD).
 - 5) All results for effluent parameters monitored concurrently with the toxicity test(s).
 - 6) The results compared to the numeric toxicity effluent limitation or trigger.
 - 7) Progress reports on any TRE/TIE investigations.

Toxicity Reporting Table

Task	Due Date
Submit a TRE Workplan	EDSC + 90 days
Submit WET Report for quarterly monitoring	28 th day of the month following the completed monitoring

Submit WET Report for annual monitoring	28 th day of the month following the completed monitoring
Notify Toxicity in Effluent	<48 hours of receipt of test results that exceed limit or trigger
Conduct Accelerated Monitoring	≤ 14 days of exceedance of limit or trigger
Submit Accelerated Monitoring Report	≤ 30 days of receipt of test results
Initiate a TRE	≤ 14 days of accelerated test results that exceed limit or trigger

- g. **Reopener Clause for Toxicity.** In accordance with 40 CFR Parts 122 and 124, this permit may be reopened to establish additional toxicity requirements to address toxicity in the effluent or receiving water, including other toxicity/treatability studies, effluent limitations or monitoring requirements.

3. Best Management Practices and Pollution Prevention

Preventative Maintenance Plan (PMP) and Pollution Prevention

- 1) The Permittee must during the term of this permit operate the facility in accordance with the existing PMP and in accordance with subsequent amendments to the plan. The Permittee must amend the plan to incorporate practices to achieve the objectives and specific requirements listed below, and a copy of the amended plan must be submitted to the addresses in Part III.A.3 of this permit within six months of the EDP. The amended plan must be implemented as soon as possible but not later than nine months from the EDP.
- 2) **Purpose.** Through implementation of the PMP, the Permittee must prevent or minimize the generation and the potential for the release of pollutants from the facility to the waters of the United States through normal operations and ancillary activities.
- 3) **Objectives.** The Permittee must develop and amend the PMP consistent with the following objectives for the control of pollutants.
 - i) The number and quantity of pollutants and the toxicity of effluent generated, discharged, or potentially discharged at the facility must be minimized by the Permittee to the extent feasible by managing each influent waste stream in the most appropriate manner.
 - ii) Under the PMP, and any Standard Operating Procedures (SOPs) included in the plan, the Permittee must ensure proper operation and maintenance of the treatment facility as required by 40 CFR 122.41(e).
 - iii) The Permittee must establish specific objectives for the control of pollutants by conducting the following evaluations:
 - (a) Each facility component or system must be examined for its waste minimization opportunities and its potential for causing a release of significant amounts of pollutants to waters of the United States because of equipment failure, improper operation, and natural phenomena such as rain or snowfall, etc. The examination must include all normal operations and ancillary activities including material storage areas, plant site runoff, in-plant transfer, process and material handling areas, loading or unloading operations, spillage or leaks, sludge and waste disposal, or drainage from raw material storage.
 - (b) Where experience indicates a reasonable potential for equipment failure (e.g., a tank overflow or leakage), natural condition (e.g., precipitation), or other circumstances that could result in significant amounts of pollutants reaching surface waters, the program should include a prediction of the direction, rate of flow, and total quantity of pollutants that could be discharged from the facility as a result of each condition or circumstance.
 - (c) PFAS pollution prevention/source reduction evaluation:
 - (1) The Permittee shall include in the PMP an evaluation of whether the facility uses or has recently used any products containing PFAS, whether use of those products or legacy contamination reasonably can be reduced or eliminated, and a plan to implement those steps.

- (2) Within 15 months of the effective date of the permit, the Permittee shall implement the plan in accordance with the PFAS pollution prevention/source reduction evaluation. Results should be recorded annually.
- (d) The Permittee shall use best management practices to prevent the discharge of fire protection foam, which shall be detailed in the PMP. The Permittee shall, to the maximum extent practicable:
 - (1) Utilize non-PFAS alternative firefighting foam products that exhibit high biodegradability, and that do not contain fluorosurfactants;
 - (2) Conduct pilot tests in bermed areas away from storm drain inlets, drainage facilities or water bodies;
 - (3) Configure the discharge area with a sump to allow collection and disposal of foam to the sanitary sewer system; and
 - (4) Discharge foam waste to a sanitary sewer to the maximum extent practicable.
 - (5) If applicable, the requirements of Part IV.B.3.d.2-4 can be satisfied with a brief discussion in the PMP describing how facility design and firefighting drill procedures prevent the discharge of fire protection foam to storm water or sanitary sewer systems.
- 4) **Requirements.** The PMP must be consistent with the objectives in the Objectives section above and the general guidance contained in the publication titled *Guidance Manual for Developing Best Management Practices (BMPs)* (EPA 833-B-93-004, 1993) or any subsequent revisions to the guidance document.
 - a. The PMP must be documented in narrative form, include any necessary plot plans, drawings or maps, and be developed in accordance with good engineering practices. The PMP must be organized and written with the following structure:
 - (a) Name and location of the facility
 - (b) Statement of PMP policy
 - (c) Structure, functions, and procedures of the PMP Committee.
 - (d) Specific management practices and standard operating procedures to achieve the above objectives, including modifying equipment, facilities, technology, processes, and procedures; reformulating or redesigning products; substituting materials; and improving management, inventory control, materials handling or general operational phases of the facility.
 - (e) Risk identification and assessment.
 - (f) Reporting of PMP incidents.
 - (g) Materials compatibility.
 - (h) Good housekeeping.
 - (i) Preventative maintenance.
 - (j) Inspection and records.
 - (k) Security
 - (l) Employee training.
 - b. The PMP must include the following provisions concerning PMP review:
 - (a) Review by plant engineering staff and the plant manager.
 - (b) Review and endorsement by the Permittee's PMP Committee.
 - (c) A statement that the above reviews have been completed and that the PMP fulfills the requirements set forth in this permit. The statement must include the dated signatures of each BMP Committee member as certification of the reviews.

- c. The PMP must establish specific BMPs to meet the objectives identified in the Objectives section above, addressing each component or system capable of generating or causing a release of significant amounts of pollutants, and identifying specific preventive or remedial measures to be implemented.
- d. The PMP must establish specific BMPs or other measures that ensure that the following specific requirements are met:
 - (a) Ensure proper management of solid and hazardous waste in accordance with regulations promulgated under the Resource Conservation and Recovery Act (RCRA). Management practices required under RCRA regulations must be referenced in the BMP plan.
 - (b) Reflect requirements for Spill Prevention, Control, and Countermeasure (SPCC) plans under CWA section 311 and 40 CFR Part 112 and may incorporate any part of such plans into the PMP by reference.
 - (c) Reflect requirements for stormwater control under CWA section 402(p) and the regulations at 40 CFR 122.26 and 122.44, and otherwise eliminate to the extent practicable, contamination of stormwater runoff.
- 5) **Documentation.** The Permittee must maintain a copy of the PMP at the facility and must make the plan available to EPA upon request.
- 6) **PMP Modification.** The Permittee must amend the PMP whenever there is a change in the facility or in the operation of the facility that materially increases the generation of pollutants or their release or potential release to the receiving waters. The Permittee must also amend the plan, as appropriate, when plant operations covered by the PMP change. Any such changes to the PMP must be consistent with the objectives and specific requirements listed above. All changes in the PMP must be reported to EPA in writing.
- 7) **Modification for Ineffectiveness.** If at any time the PMP proves to be ineffective in achieving the general objective of preventing and minimizing the generation of pollutants and their release and potential release to the receiving waters and/or the specific requirements above, the permit and/or the PMP must be subject to modification to incorporate revised BMP requirements.

4. Biological Monitoring Program Plan

- a. The permittee must continue to implement the *EcoEléctrica NPDES Biological Monitoring Program Plan, 2nd Draft, August 2015*, as approved by EPA in March 2016 or subsequent revisions of the *BMPP Proposal* approved by EPA. EPA reserved the right to require more frequent or additional monitoring in the future, should the need arise for information in support of CWA Section 403(c) requirements for Ocean Discharges or evaluation of impacts from impingement or entrainment under CWA Section 316(b).
- b. The program report and test results must be submitted to Region2_NPDES@epa.gov.

C. Compliance Schedules

This permit does not authorize any compliance schedules.

D. Additional Special Conditions

1. **Coastal Zone Management Consistency Reopener Clause.** In addition to any other grounds specified herein, this permit must be modified or revoked at any time based on the conditions required by the Puerto Rico Planning Board as part of a determination of consistency with the State Coastal Zone Management Program.
2. **Ocean Discharge Reopener Clause.** In addition to any other grounds specified herein, this permit must be modified or revoked at any time if, on the basis of any new data, the director determines that continued discharges may cause unreasonable degradation of the marine environment, pursuant to 40 CFR 125.123(d).
3. **Solid Waste.** The solid wastes such as sludge, screenings and grit, generated due to the operation of the treatment system must be:
 - a. Disposed in compliance with the applicable requirements established in the 40 CFR Part 257. A report must be submitted to DNER and EPA notifying the method or methods used to dispose the solid wastes generated in the facility in a term no later than thirty (30) days after such solids are generated. Also, a copy of the approval or permit applicable to the disposal method used must be submitted, if any.

- b. Transported adequately in such way that access is not gained to any water body or soil. In the event of a spill of solid wastes on land or into a water body, the permittee must notify the Point Sources Permits Division of DNER's Water Quality Area in writing within a term no longer than twenty-four (24) hours after the spill to the following electronic address: bypass@drna.pr.gov. This notification shall include the following information:

- 1) Spilled material
- 2) Spilled volume
- 3) measure taken to prevent the spilled material to gain access to any water body

This special condition does not relieve the Permittee from its responsibility to obtain the corresponding permits from DNER's Land Pollution Control Area and other state and federal agencies, if any.

- c. A log book must be kept for the material removed from the treatment system, such as sludge, screenings and grit, detailing the following items:

- 1) description of removed material, date of removal, and source of material;
- 2) approximate volume and weight of material;
- 3) method by which material was removed and transported;
- 4) final disposal and location of material;
- 5) name, title and affiliation of person that performs the service;

A copy of the Non-Hazardous Solid Wastes Collection and Transportation Service Permit issued by the authorized official from DNER must be attached to the log book. The material removal log book must remain on-site and be available to DNER and EPA at all times.

E. Cooling Water Intake Structure.

1. *Best Technology Available.* The design, location, construction and capacity of the permittee's cooling water intake structures (CWIS) shall reflect best technology available (BTA) for minimizing adverse environmental impacts from the impingement and entrainment of various life stages of fish (e.g. eggs, larvae, juveniles, adults) by the CWIS. The permittee has submitted numerous studies and reports characterizing the potential impacts to aquatic life from the CWIS, and measures taken to minimize such impacts.

EPA has made the final determination that the best technology available for minimizing adverse environmental impact due to impingement or entrainment at the cooling water intake structure shall be:

- a. Passive filtration system consisting of 2mm (0.079") slot opening screens, with 53% open area,
- b. Remote cleaning of the screens using the air backwash system,
- c. Maintaining the design intake flow of 0.5 feet per second (fps) or less; and
- d. Continued operation of the closed cycle cooling system.

2. *Annual certification statement and report.* An annual certification statement signed by the responsible corporate officer as defined in 40 CFR § 122.22. The reporting period will for EDP to EDP+12 months and every subsequent 12 month period. The report must be submitted to EPA within 3 months of the end of the reporting period. The permittee shall send hard copies of the annual certification to EPA until further notified of electronic reporting requirements.

This annual certification shall include:

- a. The status of any structural or operational improvements,
- b. The status of any required studies,
- c. A statement that the technology identified as BTA is operating as BTA standards and is minimizing adverse environmental impacts;

- d. If the following information contained in the previous year's annual certification is still pertinent, the permittee may state as such. This statement, along with any applicable data submission requirements specified in this section shall constitute the annual certification.
- e. If the permittee has substantially modified operation of any unit at the facility the impacts cooling water withdrawals or operation of the cooling water intake structures, the permittee must provide a summary of those changes in the report.
- f. For any documented take of threatened or endangered species, the permittee shall report:
 - 1) Species Latin name,
 - 2) Species common name,
 - 3) Number of organisms – If possible, the number of organisms should be by life stage (e.g. egg, larvae, juvenile, adult).
 - 4) Method of take – Impinged, entrained or other,
 - 5) Type of take – death, injury, or other,
- g. If there were no impacts to threatened or endangered species, the permittee shall certify "No Take Reported" in the annual report. Nothing in this permit authorizes the take of endangered or threatened species under the Endangered Species Act.

F. Chemical and Material Usage.

- 1) The permittee is permitted to use chemical to control biofouling in the service cooling towers, or for fire protection foam, provided that they meet the following conditions:
 - a. The discharge shall not cause a violation of any permit limit,
 - b. The testing of use of such chemical and/or materials shall not cause a violation of any permit limit or cause a prohibited discharge.
 - c. At the time of the test, the permittee shall take a grab sample of the effluent from the outfall to which the material or chemical discharges and analyze for all parameters monitoring as required by the NPDES permit in effect at the time of the test. The analytical testing must be representative of the conditions of the normal outfall discharge with the addition of the material or chemical being tested. The permittee shall report on the timing of the test and sample location in the report required under Item v of this section.
 - d. The permittee shall perform an acute whole effluent toxicity (WET) test of the effluent sampled at the monitoring station where the chemical and material is discharged. The acute toxicity analysis shall be performed on a grab sample of the effluent containing the material or chemical. The test shall be stopped if toxicity is observed in the sample. For the purposes of this test, an LC50 result of $\leq 100\%$ shall be considered to be an indicator of toxicity.
 - e. The permittee shall provide a report of the pilot test to the EPA within 30 days of completion of the test. The report shall include:
 - 1) The time, duration, amount and location of each dosage of chemical or material tested;
 - 2) Documentation that adequate process controls were in place to ensure that excessive levels of the chemical or material were not subsequently discharged;
 - 3) The optimum product dosage necessary to ensure no deleterious effects to the aquatic toxicity of the effluent;
 - 4) Results of all analytical testing, including the testing of the discharge for parameters limited by this permit, as well as the results of the acute toxicity testing'
 - 5) A description of future plans for the use of the material or chemical tested.
 - 6) All report shall be provided to the EPA via hardcopy, until otherwise notified.
 - g. The permittee may consider the use of the tested chemical or material conditionally approved as of 60 days following the completion of a test, provided that all permit limitations and conditions are met. The use of this chemical will be considered conditionally approved unless and until the EPA provided notification to the permittee that the use of the tested chemical or material will be prohibited or controlled due to potential to cause an exceedance of permit limitations or toxicity. The EPA reserves the right to prohibit use of a chemical or material at any time.

G. Hydrostatic Test Water Requirements.

- 1) All tanks being hydrostatically tested must complete the following procedure:
 - a. After construction or reconstruction of the tank, sandblasting or another technique will be used to clean the tank,
 - b. A vacuum truck or other equipment will remove all residues from the tank prior to testing,
 - c. The water source for the hydrostatic testing will be fresh (potable) water supplied by the Puerto Rico Aqueduct or Sewer Authority (PRASA) or other source of fresh water.
- 2) The permittee will follow ASTM hydrostatic test standard # E1003-95 or other valid procedure before the discharge. Oil and grease analyses will be performed on the surface and the middle depth of the tank. Also, visual inspection will be performed after the test to look for oil sheen in the used hydrostatic test water. If oil sheen is observed, the discharge shall be stopped. The permittee will include a written report in the DMR-Addendum stating the date of each discharge. This test water can be discharged through Outfall 001 if the oil/grease analysis results are below 15.0mg/l.

ATTACHEMENT A: 126 PRIORITY POLLUTANTS

As provided by 40 CFR Part 423, Appendix A, below is the current list of 126 Priority Pollutants.

- | | | |
|----------------------------------|---------------------------------|-------------------------------|
| 1. Acenaphthene | 44. Methylene chloride | 88. Vinyl chloride |
| 2. Acrolein | 45. Methyl chloride | 89. Aldrin |
| 3. Acrylonitrile | 46. Methyl bromide | 90. Dieldrin |
| 4. Benzene | 47. Bromoform | 91. Chlordane |
| 5. Benzidine | 48. Dichlorobromomethane | 92. 4,4-DDT |
| 6. Carbon tetrachloride | 49. (Removed) | 93. 4,4-DDE |
| 7. Chlorobenzene | 50. (Removed) | 94. 4,4-DDD |
| 8. 1,2,4-trichlorobenzene | 51. Chlorodibromomethane | 95. Alpha-endosulfan |
| 9. Hexachlorobenzene | 52. Hexachlorobutadiene | 96. Beta-endosulfan |
| 10. 1,2-dichloroethane | 53. Hexachlorocyclopentadiene | 97. Endosulfan sulfate |
| 11. 1,1,1-trichloroethane | 54. Isophorone | 98. Endrin |
| 12. Hexachloroethane | 55. Naphthalene | 99. Endrin aldehyde |
| 13. 1,1-dichloroethane | 56. Nitrobenzene | 100. Heptachlor |
| 14. 1,1,2-trichloroethane | 57. 2-nitrophenol | 101. Heptachlor epoxide |
| 15. 1,1,2,2-tetrachloroethane | 58. 4-nitrophenol | 102. Alpha-BHC |
| 16. Chloroethane | 59. 2,4-dinitrophenol | 103. Beta-BHC |
| 17. (Removed) | 60. 4,6-dinitro-o-cresol | 104. Gamma-BHC |
| 18. Bis(2-chloroethyl) ether | 61. N-nitrosodimethylamine | 105. Delta-BHC |
| 19. 2-chloroethyl vinyl ethers | 62. N-nitrosodiphenylamine | 106. PCB-1242 (Arochlor 1242) |
| 20. 2-chloronaphthalene | 63. N-nitrosodi-n-propylamine | 107. PCB-1254 (Arochlor 1254) |
| 21. 2,4,6-trichlorophenol | 64. Pentachlorophenol | 108. PCB-1221 (Arochlor 1221) |
| 22. Parachlorometa cresol | 65. Phenol | 109. PCB-1232 (Arochlor 1232) |
| 23. Chloroform | 66. Bis(2-ethylhexyl) phthalate | 110. PCB-1248 (Arochlor 1248) |
| 24. 2-chlorophenol | 67. Butyl benzyl phthalate | 111. PCB-1260 (Arochlor 1260) |
| 25. 1,2-dichlorobenzene | 68. Di-N-Butyl Phthalate | 112. PCB-1016 (Arochlor 1016) |
| 26. 1,3-dichlorobenzene | 69. Di-n-octyl phthalate | 113. Toxaphene |
| 27. 1,4-dichlorobenzene | 70. Diethyl Phthalate | 114. Antimony |
| 28. 3,3-dichlorobenzidine | 71. Dimethyl phthalate | 115. Arsenic |
| 29. 1,1-dichloroethylene | 72. Benzo(a) anthracene | 116. Asbestos |
| 30. 1,2-trans-dichloroethylene | 73. Benzo(a) pyrene | 117. Beryllium |
| 31. 2,4-dichlorophenol | 74. Benzo(b) fluoranthene | 118. Cadmium |
| 32. 1,2-dichloropropane | 75. Benzo(k) fluoranthene | 119. Chromium |
| 33. 1,3-dichloropropylene | 76. Chrysene | 120. Copper |
| 34. 2,4-dimethylphenol | 77. Acenaphthylene | 121. Cyanide, Total |
| 35. 2,4-dinitrotoluene | 78. Anthracene | 122. Lead |
| 36. 2,6-dinitrotoluene | 79. Benzo(ghi) perylene | 123. Mercury |
| 37. 1,2-diphenylhydrazine | 80. Fluorene | 124. Nickel |
| 38. Ethylbenzene | 81. Phenanthrene | 125. Selenium |
| 39. Fluoranthene | 82. Dibenzo(h) anthracene | 126. Silver |
| 40. 4-chlorophenyl phenyl ether | 83. Indeno (1,2,3-cd) pyrene | 127. Thallium |
| 41. 4-bromophenyl phenyl ether | 84. Pyrene | 128. Zinc |
| 42. Bis(2-chloroisopropyl) ether | 85. Tetrachloroethylene | 129. 2,3,7,8-TCDD |
| 43. Bis(2-chloroethoxy) methane | 86. Toluene | |
| | 87. Trichloroethylene | |

ATTACHMENT B: DEFINITIONS

Acute Toxicity Test means any toxicity test designed to determine the concentration in which a response to a stimulus, such as a total effluent, specific substance or combinations of these, has sufficient severity to induce an adverse effect on a group of test organisms during a period of 96 hours or less; even if said effect is not necessarily the death of the organisms.

Acute Toxicity Unit (TU_a) means the reciprocal of the effluent concentration that causes 50 percent of the organisms to die in an acute toxicity test or induce a response halfway between the base line and maximum as defined by the following equation:

$$TU_a = 100 / (LC_{50})$$

(The LC_{50} should be expressed in terms of the percent of effluent in the dilution water.)

Average Monthly Discharge Limitation (AML) means the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. [40 CFR 122.2]

Average Weekly Discharge Limitation (AWL) means the highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week. [40 CFR 122.2]

Best Management Practices (BMP) means the most effective practicable means of preventing or reducing the amount of pollution generated by nonpoint and point sources to a level more compatible to the water quality goals, including, but not limited to, structural and non-structural controls and operating and maintenance procedures. [40 CFR 122.2]

Biosolids means non-hazardous sewage sludge, as defined in 40 CFR Part 503.9. Sewage sludge that is hazardous, as defined in 40 CFR Part 261, must be disposed of in accordance with Resource Conservation and Recovery Act.

Bypass means the intentional diversion of waste streams from any portion of a treatment facility as discussed in 13. Bypass of Attachment B of this permit. [40 CFR 122.41(m)]

Composite means a combination of individual (or continuously taken) samples obtained at regular intervals over the entire discharge day. The volume of each sample must be proportional to the discharge flow rate. For a continuous discharge, a minimum of 24 individual grab samples (at hourly intervals) must be collected and combined to constitute a 24-hour composite sample. For intermittent discharges of more than 4 hours duration, grab samples must be taken at a minimum of 30-minute intervals.

Chronic Toxicity Test means any toxicity test designed to determine the concentration in which a response to a stimulus, such as a total effluent, a specific substance, or combination of these, has sufficient severity to induce a long-term adverse effect on a group of test organisms. A chronic effect could be lethality, reduction of growth rate, reduction of reproduction rate, etc.

Chronic Toxicity Unit (TU_c) means the reciprocal of the effluent concentration that causes no observable effect on the test organisms by the end of the chronic exposure period obtained during a chronic toxicity test as defined by the following equation:

$$TU_c = 100 / NOEC$$

(The NOEC value should be expressed in terms of the percent of effluent in the dilution water.)

Critical Initial Dilution means the minimum dilution to be determined by means of the use of a mathematical model to be approved by DNER, and according to the procedures described in the *Mixing Zone and Bioassay Guidelines*, approved by DNER.

Daily Discharge is defined as either (1) the total mass of the constituent discharged over the calendar day (12:00 a.m. through 11:59 p.m.) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass; or (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day. For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends. [40 CFR 122.2]

Director means the *Regional Administrator* or the *State Director*, as the context requires, or an authorized representative. Until Puerto Rico has an approved state program authorized by EPA under 40 CFR Part 123, *Director* means the Regional Administrator. Following authorization, *Director* means the State Director. Even in such circumstances, EPA may retain authority to take certain action (see, for example, 40 CFR 123.1(d), 45 *Federal Register* 14178, April 1, 1983, on the retention of jurisdiction over permits EPA issued before program approval). If any condition of this permit requires the reporting of information or other actions to both the Regional Administrator and the State Director, regardless of who has permit issuing authority, the terms *Regional Administrator* and *State Director* will be used in place of *Director*. [40 CFR 122.2]

Discharge Monitoring Report (DMR) means EPA uniform national form, including any subsequent additions, revisions, or modifications, for the reporting of self-monitoring results by the Permittee. [40 CFR 122.2]

Geometric Mean means the n th root of the product of n numbers.

Grab means an individual sample collected in less than 15 minutes.

ICIS means EPA's Integrated Compliance Information System that provides web access to enforcement and compliance assurance data to EPA and state agencies.

Inhibition Concentration 25 (IC₂₅) means a point estimate of the effluent concentration that would cause a 25-percent reduction in a non-lethal (e.g., reproduction, growth) or lethal (mortality) biological measurement.

Lethal Concentration (LC₅₀) means the concentration of effluent, specific substances or combination of these that is lethal to 50 percent of test organisms exposed during a specific period in a toxicity test.

Lowest Observable Effects Concentration (LOEC) means the lowest concentration of an effluent or toxicant that results in adverse effects on the test organisms. That is, where the values for the observed endpoints are statistically different from the control.

Maximum Daily Discharge Limitation (MDL) means the highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median is the middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, the median = $X_{(n+1)/2}$. If n is even, the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Minimum Level (ML) is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method-specified sample weights, volumes, and processing steps have been followed.

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects on the overall water body.

Monthly means one day each month (the same day each month) and a normal operating day (e.g., the 2nd Tuesday of each month).

No Observed Effect Concentration (NOEC) means the highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specific time of observation.

Not Detected (ND) are those sample results less than the ML.

Regional Administrator means the Regional Administrator of EPA Region 2 or the authorized representative of the Regional Administrator.

Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

Toxic pollutant means any of the pollutants listed in 40 CFR 401.15 (45 *Federal Register* 44503, July 30, 1979) and any modification to that list in accordance with CWA section 307(a)(1). [40 CFR 122.2]

Toxicity Reduction Evaluation (TRE) is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of collecting data relevant to the toxicity, including additional toxicity testing, and evaluating facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

Total Maximum Daily Loads (TMDLs) are calculations of the maximum amount of a pollutant that a water body can receive and still safely meet water quality standards. TMDLs are the sum of the individual wasteload allocations for point sources and load allocations for nonpoint sources and natural background. [40 CFR 130.2(i)]

Upset is an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation as discussed in 14. Upset of Attachment B of this permit. [40 CFR 122.41(n)]

Waters of Puerto Rico means all coastal waters, surface waters, estuarine waters, ground waters and wetland as defined in Puerto Rico Water Quality Standards Regulations, as amended.

Weekly means every seventh day (the same day of each week) and a normal operating day

ATTACHMENT C: STANDARD CONDITIONS

General Conditions language in this attachment for sections 1 through 14, and 17 is based on the *Code of Federal Regulations* (CFR) published on July 1, 2013. Reference to provisions in the *United States Code* (U.S.C.) is based on the date of permit issuance.

Table of Regulatory References for General Conditions

<u>Section</u>	<u>Section Title</u>	<u>Reference</u>
1.	Duty to comply	40 CFR 122.41(a)
2.	Duty to reapply	40 CFR 122.41(b)
3.	Need to halt or reduce not a defense	40 CFR 122.41(c)
4.	Duty to mitigate	40 CFR 122.41(d)
5.	Proper operation and maintenance	40 CFR 122.41(e)
6.	Permit actions	40 CFR 122.41(f)
7.	Property rights	40 CFR 122.41(g)
8.	Duty to provide information	40 CFR 122.41(h)
9.	Inspection and entry	40 CFR 122.41(i)
10.	Monitoring and records	40 CFR 122.41(j)
11.	Signatory requirements	40 CFR 122.41(k)
12.	Reporting requirements	40 CFR 122.41(l)
13.	Bypass	40 CFR 122.41(m)
14.	Upset	40 CFR 122.41(n)
15.	Removed substances	33 U.S.C. 1311
16.	Oil and hazardous substance liability	33 U.S.C. 1321
17.	Reopener clause for toxic effluent limitations	40 CFR 122.44(b)(1)
18.	State laws	33 U.S.C. 1370
19.	Availability of information	33 U.S.C. 1318
20.	Severability	-

1. Duty to Comply [40 CFR 122.41(a)].

- a. The Permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- b. The Permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
- c. The Clean Water Act provides that any person who violates sections 301, 302, 306, 307, 308, 318 or 405 of the Clean Water Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Clean Water Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation (\$37,500 as adjusted by 40 CFR Part 19).
- d. The Clean Water Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Clean Water Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402 of the Clean Water Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Clean Water Act, is subject to criminal penalties of not less than \$2,500 nor more than \$25,000 per day of violation, or imprisonment of not more than 1 year, or both. In the case of a second or subsequent conviction for a negligent violation

of the Clean Water Act, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than 2 years, or both.

- e. The Clean Water Act provides that any person who knowingly violates sections 301, 302, 306, 307, 308, 318, or 405 of the Clean Water Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Clean Water Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Clean Water Act, is subject to criminal penalties of not less than \$5,000 nor more than \$50,000 per day of violation, or imprisonment for not more than 3 years, or both. In the case of a second or subsequent conviction for a knowing violation of the Clean Water Act, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.
 - f. Any person who knowingly violates sections 301, 302, 303, 306, 307, 308, 318 or 405 of the Clean Water Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Clean Water Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. A person which is an organization, as defined at 33 U.S.C. 309(c)(3)(B)(iii), shall, upon conviction be subject to a fine of not more than \$1,000,000. In the case of a second or subsequent conviction for a knowing endangerment violation of the Clean Water Act, the maximum punishment shall be doubled with respect to both fine and imprisonment.
 - g. Any person who knowingly makes any false material statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under the Clean Water Act or who knowingly falsifies, tampers with, or renders inaccurate any monitoring device or method required to be maintained under this chapter, shall upon conviction, be punished by a fine of not more than \$10,000, or imprisonment for not more than 2 years, or both. In the case of a second or subsequent conviction, under this paragraph, punishment shall be by a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both.
 - h. Any person may be assessed an administrative penalty by the Administrator for violating sections 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation (\$16,000 as adjusted by 40 CFR Part 19), with the maximum amount of any Class I penalty assessed not to exceed \$25,000 (\$37,500 as adjusted by 40 CFR Part 19). Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues (\$16,000 as adjusted by 40 CFR Part 19), with the maximum amount of any Class II penalty not to exceed \$125,000 (\$177,500 as adjusted by 40 CFR Part 19).
2. Duty to Reapply [40 CFR 122.41(b)]. This permit and the authorization to discharge shall terminate on the expiration date indicated on the first page. In order to receive authorization to discharge after the expiration date of this permit, the Permittee shall apply for and obtain a new permit. If the permit issuing authority remains the EPA, the Permittee shall complete, sign, and submit an application to the Director no later than 180 days before the expiration date. All applications must be submitted to:

Javier Laureano, Director
Water Division
U.S. Environmental Protection Agency, Region 2
290 Broadway, 24th Floor
New York, NY 10007-1866
Attention: Clean Water Regulatory Branch
 3. Need to Halt or Reduce not a Defense [40 CFR 122.41(c)]. It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
 4. Duty to Mitigate [40 CFR 122.41(d)]. The Permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
 5. Proper operation and maintenance [40 CFR 122.41(e)]. The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Permittee to achieve compliance with the conditions of this permit. Proper operation and

maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back up or auxiliary facilities or similar systems which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

6. Permit actions [40 CFR 122.41(f)]. This permit may be modified, revoked and reissued, or terminated during its term pursuant to 40 CFR Part 122, Subpart D. The filing of a request by the Permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.
7. Property rights [40 CFR 122.41(g)]. This permit does not convey any property rights of any sort, or any exclusive privileges.
8. Duty to provide information [40 CFR 122.41(h)]. The Permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The Permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.
9. Inspection and Entry [40 CFR 122.41(i)]. The Permittee shall allow the Director, or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon presentation of credentials and other documents as may be required by law, to:
 - a. Enter upon the Permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
 - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
 - c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
 - d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.
10. Monitoring and records [40 CFR 122.41(j)].
 - a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
 - b. Except for records of monitoring information required by this permit related to the Permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), the Permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement report or application. This period may be extended by request of the Director at any time.
 - c. Records of monitoring information shall include:
 - 1) The date, exact place, and time of sampling or measurements;
 - 2) The individual(s) who performed the sampling or measurements;
 - 3) The date(s) analyses were performed;
 - 4) The individual(s) who performed the analyses;
 - 5) The analytical techniques or methods used; and
 - 6) The results of such analyses.
 - d. Monitoring must be conducted according to test procedures approved under 40 CFR Part 136 and any subsequent changes to the methods contained therein unless another method is required under 40 CFR subchapters N or O.
 - e. The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or by both. If a conviction of a person is for a violation committed after a first conviction of such person

under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both. [See U.S.C. 1319(c)(4)].

11. Signatory requirements [40 CFR 122.41(k)]. All applications, reports, or information submitted to the Director shall be signed and certified. (See 40 CFR 122.22)

a. Applications. All permit applications shall be signed as follows:

- 1) For a corporation. By a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

Note: EPA does not require specific assignments or delegations of authority to responsible corporate officers identified in 40 CFR 122.22(a)(1)(i). EPA will presume that these responsible corporate officers have the requisite authority to sign permit applications unless the corporation has notified the Director to the contrary. Corporate procedures governing authority to sign permit applications may provide for assignment or delegation to applicable corporate positions under 40 CFR 122.22(a)(1)(ii) rather than to specific individuals.

- 2) For a partnership or sole proprietorship. By a general partner or the proprietor, respectively; or
 - 3) For a municipality, state, federal, or other public agency. By either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a federal agency includes: a) The chief executive officer of the agency, or b) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of EPA).
- b. All reports required by permits, and other information requested by the Director shall be signed by a person described in paragraph 11.a of Part II.B, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
- 1) The authorization is made in writing by a person described in paragraph 11.a;
 - 2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company, (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) and,
 - 3) The written authorization is submitted to the Regional Administrator, U.S. Environmental Protection Agency, Region 2, 290 Broadway, New York, NY 10007-1866, Attention: Compliance Assistance Program Support Branch, and to DNER.
- c. Changes to authorization. If an authorization under paragraph 11.b of Part II.B is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph 11.b of Part II.B must be submitted to the Director prior to or together with any reports, information, or applications to be signed by an authorized representative.
- d. Certification. Any person signing a document under paragraph 11.a or 11.b of Part II.B shall make the following certification:
- I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is,

to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

- e. The Clean Water Act provides that any person who knowingly makes any false material statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by imprisonment for not more than 6 months per violation, or by both. If a conviction is for a violation committed after a first conviction of such person under this paragraph, punishment shall be by a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both. (See CWA section 309.c.4).

12. Reporting Requirements [40 CFR 122.41(l)].

- a. Planned changes. The Permittee shall give notice to the Director as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:
 - 1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b);
 - 2) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under paragraph 4.a of Part I.B (40 CFR 122.42(a)(1)); or
 - 3) The alteration or addition results in a significant change in the Permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. Anticipated noncompliance. The Permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- c. Transfers. This permit is not transferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the Permittee and incorporate such other requirements as may be necessary under the Clean Water Act. (See 40 CFR 122.61; in some cases, modification or revocation and reissuance is mandatory.)
- d. Monitoring reports. Monitoring results shall be reported at the intervals specified in Part III of this permit.
 - 1) Monitoring results shall be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Director for reporting results of monitoring of sludge use or disposal practices.
 - 2) If the Permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR Part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Director.
 - 3) Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Director in the permit.
- e. Compliance Schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
- f. Twenty-four-hour reporting.
 - 1) The Permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Permittee becomes aware of the circumstances to EPA Region 2, Caribbean Environmental Protection Division at (787) 977-5870 and State Director. A written submission shall also be provided within 5 days of the time the Permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if

the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

- 2) The following shall be included as information which must be reported within 24 hours under this paragraph.
 - a) Any unanticipated bypass (see 13 below) which exceeds any effluent limitation in the permit. [See 40 CFR 122.41(g)].
 - b) Any upset (see 14 below) which exceeds any effluent limitation in the permit.
 - c) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in the permit to be reported within 24 hours. (See 40 CFR 122.44(g)).
- 3) The Director may waive the written report on a case by case basis for reports under paragraph 12.f.(2) of Part II.B if the oral report has been received within 24 hours.
- g. Other noncompliance. The Permittee shall report all instances of noncompliance not reported under paragraphs 12.d, e, and f of Part II.B, at the time the monitoring reports are submitted. The reports shall contain the information listed in paragraph 12.f of Part II.B.
- h. Other information. Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

13. Bypass [40 CFR 122.41(m)].

- a. Bypass not exceeding limitations. The Permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 13.b. and 13.c of Part II.B.
- b. Notice.
 - 1) Anticipated bypass. If the Permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
 - 2) Unanticipated bypass. The Permittee shall submit notice of an unanticipated bypass as required in paragraph 12.f of Part II.B (24-hour notice).
- c. Prohibition of bypass.
 - 1) Bypass is prohibited, and the Director may take enforcement action against a Permittee for bypass, unless:
 - a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - c) The Permittee submitted notices as required under paragraph 13.b of Part II.B.
 - 2) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 13.b.(1) of Part II.B.

14. Upset [40 CFR 122.41(n)].

- a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of paragraph 14.(b) of Part II.B are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- b. Conditions necessary for a demonstration of upset. A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - 1) An upset occurred and that the Permittee can identify the cause(s) of the upset;

- 2) The permitted facility was at the time being properly operated;
 - 3) The Permittee submitted notice of the upset as required in paragraph 12.f.(2)(b) of Part II.B (24 hour notice); and
 - 4) The Permittee complied with any remedial measures required under paragraph 4 of Part II.B (duty to mitigate).
- c. Burden of proof. In any enforcement proceeding the Permittee seeking to establish the occurrence of an upset has the burden of proof.
15. Removed substances (33 U.S.C. 1311). Pursuant to section 301 of the Clean Water Act, solids, sludges, filter backwash or other pollutants removed in the course of treatment or control of wastewaters and/or the treatment of intake waters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering navigable waters. The following data shall be reported together with the monitoring data required in paragraph 2 of Part I.B:
- a. The sources of the materials to be disposed of;
 - b. The approximate volumes and weights;
 - c. The method by which they were removed and transported; and
 - d. Their final disposal locations.
16. Oil and hazardous substance liability (33 U.S.C. 1321). The imposition of responsibilities upon, or the institution of any legal action against the Permittee under CWA section 311 shall be in conformance with regulations promulgated pursuant to Section 311 to discharges from facilities with NPDES permits.
17. Reopener clause for toxic effluent limitations [40 CFR 122.44(B)(1)]. Other effluent limitations and standards under CWA sections 301, 302, 303, 307, 318 and 405. If any applicable toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under CWA section 307(a) for a toxic pollutant and that standard or prohibition is more stringent than any limitation on the pollutant in the permit, the Director shall institute proceedings under these regulations to modify or revoke and reissue the permit to conform to the toxic effluent standard or prohibition. See also 40 CFR 122.41(a).
18. State laws (33 U.S.C. 1370). Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by CWA section 510. The issuance of this permit does not preempt any duty to obtain state or local assent required by law for the discharge.
19. Availability of information (33 U.S.C. 1318). (CWA section 308)
- a. NPDES permits, effluent data, and information required by NPDES application forms provided by the Director under 40 CFR 122.21 (including information submitted on the forms themselves and any attachments used to supply information required by the forms) shall be available for public inspection at the offices of the Regional Administrator and State Director.
 - b. In addition to the information set forth in subsection a., any other information submitted to EPA in accordance with the conditions of this permit shall be made available to the public without further notice unless a claim of business confidentiality is asserted at the time of submission in accordance with the procedures in 40 CFR Part 2 (Public Information).
 - c. If a claim of confidentiality is made for information other than that enumerated in subsection a., that information shall be treated in accordance with the procedures in 40 CFR Part 2. Only information determined to be confidential under those procedures shall not be made available by EPA for public inspection.
20. Severability. The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.