



## **FACT SHEET**

**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 3  
1650 Arch Street  
Philadelphia, Pennsylvania 19103-2029**

**NPDES Permit No. DC0000019**

**The United States Environmental Protection Agency (EPA) Proposed the Reissuance of a National Pollutant Discharge Elimination System (NPDES) Permit to Discharge Pollutants Pursuant to the Provisions of the Clean Water Act (CWA) For:**

**Department of the Army  
Baltimore District, Corps of Engineers  
Washington Aqueduct Division**

**FACILITY LOCATION:  
5900 MacArthur Boulevard, NW  
Washington, D.C. 20016-2514**

**RECEIVING WATERS:  
Potomac River, Rock Creek, Mill Creek**

### **ACTION TO BE TAKEN:**

EPA is finalizing the reissuance of the NPDES permit for the Washington Aqueduct. The final permit is intended to replace the 2008 permit which was administratively continued past the October 20, 2013 expiration date. The effective date of this reissued permit is June 1, 2021.

## Table of Contents

1.0	Public Notice and Comment .....	3
2.0	Summary of Changes Made.....	3
3.0	Facility Summary .....	6
3.1	General.....	6
3.2	Discharge Description .....	7
4.0	Receiving Water Characterization .....	8
5.0	Total Maximum Daily Loads (TMDLs) .....	9
5.1	The Potomac River TMDLs .....	9
5.2	The Rock Creek TMDLs .....	10
5.3	The 2010 Chesapeake Bay TMDL .....	10
6.0	Basis for Effluent Limitations.....	13
7.0	Technology-Based Effluent Limitations (TBELs).....	13
8.0	Water Quality-Based Effluent Limitations (WQBELs).....	13
9.0	Reasonable Potential (RP) Analysis .....	14
10.0	Developing Water-Quality Based Effluent Limits .....	23
11.0	Discussion.....	26
12.0	Effluent Limits Summary .....	27
13.0	Solid Management Facility .....	29
14.0	Endangered species protection.....	29
15.0	National Historic Preservation Act .....	30
16.0	Anti-Backsliding Provision.....	30
17.0	Antidegradation Statement.....	30
18.0	401 Certification .....	31
	Attachment 1 Response to Comments .....	32

## 1.0 Public Notice and Comment

EPA published a draft permit for this facility for public notice and comment on August 1, 2019 and accepted comments until September 3, 2019 because August 31, 2019 fell on a weekend and September 1, 2019 was a holiday. EPA made substantial changes to that draft permit as a result of public comments and other information received, as discussed below. As a result of those substantial changes, EPA made the revised draft permit and fact sheet available for public notice and comment again from December 7, 2020 to January 7, 2021. Although EPA received some public comments on that revised draft permit and fact sheet, none of those comments led to changes to the final permit. However, EPA did make one change to the final permit as a result of DC's 401 certification, as described below. See Attachment 1 to this fact sheet for the Response to Comments document.

## 2.0 Summary of Changes Made

EPA received comments from multiple commenters on the first draft permit during the first public notice and comment period. EPA also received comments on the first draft permit from Maryland in its communication pursuant to Clean Water Act section 401(a)(2). EPA also received comments from two commenters on the revised draft permit during the second public notice and comment period and from DC in its January 26, 2021 CWA section 401 certification of the revised draft permit. The certification contained conditions that were incorporated into the final permit in accordance with Clean Water Act Section 401, 33 U.S.C. § 1341, and federal regulations at 40 C.F.R. §§ 121.10 and 121.12.

EPA made certain changes to the permit and fact sheet as a result of those comments and CWA section 401 certifications, as well as additional review undertaken. These changes are described in detail throughout this fact sheet but are summarized here. The primary differences between the first draft permit and the final permit are:

- Changed the name of Outfall 002 to Outfall 002A to minimize confusion with Outfall 002Q, the continuous discharge. The permittee provided documentation that 002 and 002Q are two separate outfalls, not one outfall with both a continuous and intermittent discharge as was previously understood. Therefore, because these are two distinct outfalls, the name for Outfall 002 was changed to 002A which is consistent with how this outfall is identified in EPA's Integrated Compliance Information System for electronic reporting.
- Added aluminum water quality-based effluent limits for discharges from outfalls 003, 004, 007, 008, and 009 because the technology based effluent limits in the previous permit were less stringent than the calculated water quality-based effluent limits.
- Removed the mass based average monthly limits for aluminum for all intermittent discharges – i.e., discharges from all outfalls other than 002Q because an average monthly limit is not appropriate for intermittent or non-continuous discharges. The effluent limits for the non-continuous discharges are expressed as maximum daily limits consistent with 40 C.F.R. §122.45(e). Also, recalculated the daily maximum effluent limits for aluminum based on the new concentration-based WQBELs.
- The monitoring frequency for pH and total residual chlorine for Outfalls 003 and 004 have been changed from daily to once per discharge since the discharges from these outfalls are intermittent

and to be consistent with the monitoring requirements for these parameters at Outfalls 006, 007, 008, and 009.

- Part III Section A of the permit has been revised to add the following language: “the permittee is authorized to discharge in accordance with the terms and conditions set forth in Part I of this permit” to be consistent with similar language specified in Part III Section B.
- The total suspended solids influent monitoring requirements at Outfalls 002A, 003 and 004 have been removed from the permit because the permit does not contain a percent removal requirement due to the construction and implementation of the residual processing facility.
- The fact sheet was revised to specify that a hardness value of 100 mg/L was used to calculate the hardness dependent metals water quality criteria<sup>1</sup>. The hardness concentration of 100 mg/L is used as the default value.
- EPA performed a reasonable potential (RP) analysis for barium at Outfalls 006 and 007 and chloride at Outfalls 002A, 003, 004 using the federal water quality criteria for these parameters as an interpretation of the District of Columbia narrative water quality criterion as allowed in 40 C.F.R. § 122.44(d)(1)(vi)(A).
- EPA performed a RP analysis for iron at Outfalls 002A, 003, 004, and 008 using discharge monitoring report (DMR) data for the past 4 years (from 3/1/2015 to 11/20/2019). This time frame is representative of the current and future discharges at these outfalls. Discharge sampling that occurred prior to and including February 2015 was before the residual processing facility was fully functional, therefore not representative of the facility’s current and future discharge quality. The RP analysis showed that iron water quality based effluent limits are not required for Outfalls 002A, 003, 004, and 008. Outfalls 006, 007, and 009 reported a “no discharge” for the time period above, therefore, a RP analysis was not conducted at these outfalls for iron.
- EPA performed a RP analysis on Outfall 002Q using data reported on the permittee’s DMRs and the effluent characterization data from the 2008 permit. Because the permit application did not include an effluent characterization of Outfall 002Q, a special condition was also added to Part III Section C of the permit requiring an effluent characterization of Outfall 002Q to be submitted to EPA within six months of the permit effective date.
- EPA performed a RP analysis for fluoride at all the outfalls using the National Primary Drinking Water Regulation’s maximum contaminant level<sup>2</sup> (MCL) of 4.0 mg/L for this parameter. The District does not have a numeric water quality criterion for fluoride, therefore, the MCL was used as an interpretation of the District Columbia narrative water quality criterion<sup>3</sup> as allowed in 40 C.F.R. § 122.44(d)(1)(vi)(C). On May 18, 2020 the permittee provided updated fluoride data for Outfalls 003, 004, 008, and 009. These updated fluoride data were used in the RP analysis at these outfalls. The RP analysis showed water quality based effluent limits were not necessary.

---

<sup>1</sup> Calculations of the metals criteria can be found in Chapter 21-1105, Table 2 of the D.C. Municipal Regulations for water quality standards.

<sup>2</sup> The fluoride MCL can be found on EPA’s website: <https://www.epa.gov/ground-water-and-drinking-water/national-primary-drinking-water-regulations>

<sup>3</sup> See the District of Columbia’s Municipal Regulations, Title 21 Section 21-1104.1 for the narrative water quality criteria.

- The fact sheet has been revised to define the term “instream waste concentration” as the ratio between effluent flow and stream flow as specified in the EPA 1985 Technical Support Document for Water Quality-based Toxics Control.
- The fact sheet has been revised to clarify that the term “instream background concentration” is the same as “background concentration.” The background concentration data specified in the fact sheet were based on instream monitoring data provided by the permittee to EPA.
- EPA corrected a typo on the source of StreamStats to indicate it is a U.S. Geological Survey (USGS) website instead of National Oceanic Atmospheric Administration or NOAA. EPA used the 1Q10 flow from the StreamStats website. This information was provided in the form of a footnote in the previous fact sheet (footnote 3). This revised fact sheet removes footnote 3 and incorporates this information into the body of the fact sheet on page 20.
- EPA used the recently promulgated federal aluminum instream water quality criterion (83 Fed. Reg. 65,663 Dec. 21, 2018) as an interpretation of the District of Columbia narrative water quality criterion because the District does not have a numeric water quality criterion for aluminum (see the District of Columbia’s Municipal Regulations, Title 21 Section 21-1104.1 for the narrative water quality criteria). The aluminum criterion was calculated using the Aluminum Criteria Calculator v2.0, which can be found in the permit’s administrative record. The calculator requires the input of site-specific data for pH, hardness and dissolved organic carbon, data which were provided by the permittee. Since the pH, hardness and dissolved organic carbon can vary for each stream, the aluminum criteria calculated for Outfalls 003 and 004 are different than the aluminum water quality criterion calculated for Outfall 006 because the input values varied at each stream.
- The fact sheet has been revised to correct a typo for the copper instream criterion specified on page 11 of the previous fact sheet; the correct criterion is 0.0134 mg/L instead of 0.134 mg/L.
- The fact sheet has been revised to identify Total Suspended Solids (TSS) as parameter of concern for the Chesapeake Bay Total Maximum Daily Load (TMDL). The TSS effluent limits in the permit and the permittee’s use of the solid management facility will ensure compliance with the Chesapeake Bay TMDL for this pollutant.
- Added Chesapeake Bay TMDL requirements into the permit at all the outfalls.
- The Endangered Species Act (ESA) section of the fact sheet has been revised to include references to both the Shortnose Sturgeon and the Atlantic Sturgeon; the ESA analysis included both species of sturgeon but the previous fact sheet inadvertently omitted reference to the Atlantic Sturgeon.
- Added regulatory requirements for using sufficiently sensitive test methods for compliance testing to Part I Section H of the permit.
- Added more detailed electronic reporting requirements to Part I Section J.2 and Section J.3 of the permit.

- Added Part III Section F to the permit to include CWA Section 401(a) Certification Conditions in accordance with Clean Water Act Section 401, 33 U.S.C. § 1341, and federal regulations at 40 C.F.R. §§ 121.10 and 121.12.

### 3.0 Facility Summary

#### 3.1 General

The United States Army Corps of Engineers (“the Corps”) owns and operates the Dalecarlia and McMillan Water Treatment Plants, which supply potable (i.e., drinking) water to approximately one million residents in the District of Columbia via the District of Columbia Water and Sewer Authority (DC Water); Arlington County, Virginia; and Fairfax, Virginia via the Fairfax County Water Authority (Fairfax Water). The plants provide water at cost to the Wholesale Customers, which are the District of Columbia; Arlington County, Virginia; and the City of Falls Church, Virginia. The Wholesale Customers approve the capital construction budget and are responsible for depositing sufficient funds with the Corps to cover their respective proportional share of the total cost of running and funding improvements at the plants. Together, the Dalecarlia and McMillan Water Treatment Plants are referred to as the Washington Aqueduct.

An act of Congress created the Washington Aqueduct Division water supply system in the mid-1800’s with the construction of the Great Falls Dam and intake, which is located in Maryland on the Potomac River. There is a second intake at Little Falls, also located in Maryland, which the Corps uses intermittently. Water flows by gravity from the Great Falls intake to the Dalecarlia Reservoir. From the forebay, a low-lift booster pump station pumps water into the Dalecarlia Reservoir. The Little Falls pumping station can also deliver water directly to the Dalecarlia Reservoir.

The Dalecarlia Reservoir is a 46-acre earthen basin that serves as a pretreatment reservoir for the two water treatment plants. Approximately 51% of the untreated sediments, which are naturally occurring solids in the raw water taken from the Potomac River, are separated from the aqueous portion of the untreated water in the Dalecarlia Reservoir. The untreated sediments from the Dalecarlia Reservoir are periodically removed. (Depending on situation-specific market conditions, the sediments may be land applied, beneficially reused, or disposed of by other land-based means.)

Water from the Dalecarlia Reservoir is delivered by gravity to both the Dalecarlia Water Treatment Plant (Dalecarlia Sedimentation Basins) and the Georgetown Sedimentation Basins, which are locally known as the Georgetown Reservoir. Water from the Georgetown Sedimentation Basins is delivered to the McMillan Water Treatment Plant.

Water from the Dalecarlia Sedimentation Basins is treated at the Dalecarlia Water Treatment Plant. Regardless of which plant processes the water, treatment is a three-step process that includes sedimentation, filtration, and disinfection. The average total production of the Dalecarlia and McMillan Water Treatment Plants is 150 million gallons per day; however, during the summer, the peak may approach 265 million gallons per day.

Water delivered to the sedimentation basins at Dalecarlia and the Georgetown Sedimentation Basins contains solids that did not physically settle out at the Dalecarlia Reservoir. To make the water drinkable, these solids must be chemically treated. The Corps does this by adding aluminum sulfate (alum), which is considered a drinking water coagulant.

The Dalecarlia facility uses 36 rapid dual media filters and the McMillan facility uses 12 rapid dual media filters. Except for the filter backwash water at the McMillan Water Treatment Plant, which is recycled to the McMillan Reservoir, and the filter backwash water at the Dalecarlia Water Treatment Plant, which is recycled to the Dalecarlia Reservoir, all sedimentation residuals are collected in the Residual Processing Facility.

### 3.2 Discharge Description

The Washington Aqueduct Water Treatment Plant consists of eight Outfalls: 002A, 002Q, 003, 004, 006, 007, 008, and 009. Discharges from all of these outfalls other than 002Q are intermittent. Based on information provided in the permit application, the intermittent discharges are assumed to occur at the following frequencies:

- Outfalls 002A, 003, 004, 007, and 009: 1 discharge event lasting 2 days every 5 years
- Outfall 006: 1 discharge event lasting 1 day every 3 years

Table 1 below lists the receiving streams for each outfall along with other relevant information. Figure 1 below is a process flow diagram depicting the various processes at the Washington Aqueduct.


Table 1. Washington Aqueduct Outfalls, receiving streams, and other information

Discharge Streams and Expected Contaminants						
	Outfall 002A	Outfall 002Q <sup>4</sup>	Outfalls 003 and 004	Outfall 006	Outfall 007	Outfalls 008 and 009
<b>Waste Streams</b>	Dalecarlia Flocculation – Sedimentation Basins	Leakage or Discharge from Spring at Hydro Building	Georgetown Basins	Georgetown Conduit	City Tunnel	Potable Water 2 <sup>nd</sup> /3 <sup>rd</sup> High Reservoir
<b>Receiving Waters</b>	Potomac River	Potomac River	Potomac River	Unnamed Tributary to the Potomac River	Rock Creek	Mill Creek
<b>Coagulated Water</b>	Yes	No	Yes	Yes	No	No
<b>Settled Water</b>	No	No	No	No	Yes	No
<b>Finished Drinking Water</b>	No	No	No	No	No	Yes
<b>Groundwater</b>	No	Yes	No	No	No	No
<b>Basin Leakage</b>	No	Yes	No	No	No	No
<b>Expected Contaminants Based on Treatment Chemicals and Effluent Characterization</b>	TSS pH Total Al Sulfate Chloride Total Copper Manganese	Total Al Perchlorate Iron TSS Chloroform pH	TSS pH Total Al Sulfate Fluoride Total Copper Chloride Manganese Zinc	TSS pH Total Al Sulfate Fluoride Barium Chloride Total Copper Iron Manganese Zinc	TSS pH Fluoride Total Al Barium Chloride Total Copper Manganese Sulfate Zinc	TSS Chlorine pH Fluoride Ammonia Phosphate Total Al

<sup>4</sup> The yearly flow for Outfall 002Q is 19.3 MGD.

Approximate Controlled Max Daily Flow, MGD	7	0.05	40/40	5	5	7/10
--	---	------	-------	---	---	------

Figure 1. Process flow diagram for the Washington Aqueduct showing the various treatments of Potomac River water as it moves through the system.



#### 4.0 Receiving Water Characterization

The table below lists the seven discharge points, their associated receiving waters and designated uses. The designated uses are based on the District's 2018 Integrated Report. The applicable TMDLs are discussed below in Section 5.0.

Outfall No.	Latitude	Longitude	Receiving Water	Designated Uses*
002A	N 38° 55' 57"	W 77° 07' 03"	Potomac River	A, B, C, D, E
002Q	N 38° 56' 04.38"	W 77° 06' 56.13"	Potomac River	A, B, C, D, E
003	N 38° 54' 41.5"	W 77° 05' 57"	Potomac River	A, B, C, D, E
004	N 38° 54' 27.5"	W 77° 05' 36"	Potomac River	A, B, C, D, E
006	N 38° 55' 14"	W 77° 06' 00"	Unnamed Tributary of the Potomac River	A, B, C, D, E
007	N 38° 54' 58"	W 77° 03' 32"	Rock Creek	A, B, C, D, E
008	N 38° 56' 35"	W 77° 05' 20"	Mill Creek, tributary of the Middle Potomac River	A, B, C, D, E
009	N 38° 57' 08"	W 77° 04' 40"	Mill Creek	A, B, C, D, E



**\*Classifications of the District's Waters, Defined:**

- Class A – Primary Contact Recreation
- Class B – Secondary Contact Recreation
- Class C – Protection and propagation fish, shellfish and wildlife
- Class D – Protection of human health related to consumption of fish and shellfish
- Class E – Navigation

**5.0 Total Maximum Daily Loads (TMDLs)**

According to 40 C.F.R. § 122.44 (d)(1)(vii)(B), the effluent limits developed to protect a narrative water quality criterion, a numeric water quality criterion, or both, must be consistent with the assumptions and requirements of any available wasteload allocation for the discharge in a TMDL established or approved by EPA pursuant to 40 C.F.R. § 130.7. The table below lists the established or approved TMDLs for the receiving streams to which the permittee discharges.

TMDLs applicable to this permit:

	Pollutants	Applicable Outfall
Potomac Watershed TMDLs	E.coli (revised 2014) PCB (approved 2007)	002A, 002Q 003, 004, 006, 008, 009
Chesapeake Bay TMDL (established 2010)	Total Nitrogen (TN), Total Phosphorus (TP), and TSS that address Dissolved Oxygen (DO), pH, Chlorophyll <i>a</i> impairments	All outfalls
Rock Creek Watershed TMDLs	E.coli (revised 2014) Arsenic (approved 2004) Copper (approved 2004) Lead (approved 2004) Zinc (approved 2004)	007

**5.1 The Potomac River TMDLs****5.1.1 E.coli**

The Potomac River TMDL for E.coli does not assign a wasteload allocation to the Washington Aqueduct. The TMDL for E.coli identifies the potential sources of E.coli in the Potomac River as coming from the combined sewer overflows, separate sanitary sewer overflows which can result from leaky or undersized sewer pipes, stormwater runoff, and direct deposits of feces into the water from wildlife sources. EPA does not believe E.coli is a pollutant of concern for this facility because discharges from the basins are comprised of drinking water and drinking water does not contain E.coli<sup>5</sup>. As such, the permit does not contain requirements for E.coli at this time.

**5.1.2 PCBs**

The Potomac River TMDL for PCBs identifies the point sources of PCB loadings to the Potomac River to be wastewater treatment plants, regulated stormwater, and CSOs. Because PCBs are man-made

<sup>5</sup> In February 13, 2013 EPA published the Revised Total Coliform Rule that set the maximum contaminant level goal for E.coli to zero. More information can be found on EPA's website: <https://www.epa.gov/dwreginfo/revised-total-coliform-rule-and-total-coliform-rule#:~:text=Contaminant%20Level,-Addresses%20the%20presence&text=coli%20in%20drinking%20water,includes%20routine%20and%20repeat%20samples.>

compounds used for a variety of industrial applications, including coolants and lubricants in electrical equipment, it is not expected to be a pollutant of concern for the Washington Aqueduct. As such, the permit does not contain requirements for PCBs at this time.

## 5.2 The Rock Creek TMDLs

### 5.2.1 Copper, lead, mercury, and zinc

The Rock Creek TMDLs for copper, lead, mercury, and zinc do not identify the Washington Aqueduct as a source of those pollutants to Rock Creek. The TMDL identifies the potential sources of these metals as stormwater discharges, combined sewer overflow discharges, and non-point source discharges. Outfall 007 discharges to Rock Creek and data submitted by the permittee show non-detect levels for lead and mercury for this outfall. As described in Section 7 below, the data for zinc show there is no reasonable potential to cause or contribute to an excursion above water quality criteria at Outfall 007. However, the data for copper show there is reasonable potential to cause or contribute to an excursion above water quality criteria at Outfall 007, therefore, EPA established a WQBEL for copper at this outfall and included it in the permit. Since the TMDL does not require reductions for copper, the WQBEL will ensure this discharge is not contributing to excursions above water quality criteria in Rock Creek.

### 5.2.2 E.coli

The Rock Creek TMDL for E.coli does not identify the Washington Aqueduct as a source of E.coli impairment to Rock Creek. The Rock Creek TMDL for E.coli identifies the potential sources of E.coli as coming from the combined sewer overflows, separate sanitary sewer overflows which can result from leaky or undersized sewer pipes, stormwater runoff, and direct deposits of feces into the water from wildlife sources. EPA does not believe E.coli is a pollutant of concern for this facility because discharges from the basins are comprised of drinking water and drinking water does not contain E.coli. As such, the permit does not contain requirements for E.coli at this time.

## 5.3 The 2010 Chesapeake Bay TMDL

EPA established the Chesapeake Bay TMDL for nitrogen, phosphorus, and sediment (Bay TMDL) in 2010 as a result of significant involvement and investment by the Chesapeake Bay Program (CBP) partnership. See EPA's website for more information on the development of the Bay TMDL: <https://www.epa.gov/chesapeake-bay-tmdl/chesapeake-bay-tmdl-document>. The Bay TMDL identified 478 individual wasteload allocations (WLAs) for significant facilities across the 92 river segments and identified aggregate WLAs for non-significant facilities. The CBP partners, including the District, have been implementing the Bay TMDL since 2010; most recently, the Bay states developed Phase III Watershed Implementation Plans (WIPs) to provide further information on how they intend to continue implementing the Bay TMDL.<sup>6</sup>

---

<sup>6</sup> As described on EPA's website <https://www.epa.gov/chesapeake-bay-tmdl/chesapeake-bay-watershed-implementation-plans-wips>, the Watershed Implementation Plans are the roadmap for how the Bay jurisdictions, in partnership with federal and local governments, will achieve the Bay TMDL allocations.

### 5.3.1 Nonsignificant Dischargers and the Bay TMDL

The Bay TMDL categorizes the Washington Aqueduct as a non-significant discharger and includes it in the aggregate wasteload allocations (WLAs) for TN, TP, and TSS for the DC portion of the Potomac Tidal Fresh (POTTF\_MD) segment. For facilities included within an aggregate WLA, the TMDL assumes permitting authorities will explain in the permit fact sheet that the limits assigned to the individual facility are included as part of the aggregate TMDL WLA (Section 8.3.3 of the Bay TMDL). Appendix Q of the Bay TMDL lists annual aggregate WLAs for the nonsignificant Chesapeake Bay dischargers. The Aqueduct permit is the only nonsignificant permit listed under the aggregate for its associated stream segment. The table below contains the relevant information extracted from the Appendix Q spreadsheet of the Bay TMDL:

Row number	Facility	NPDES	EOS <sup>7</sup> TN WLA (lbs/yr)	DEL <sup>8</sup> TN WLA (lbs/yr)	EOS TP WLA (lbs/yr)	DEL TP WLA (lbs/yr)	EOS TSS WLA (lbs/yr)	DEL TSS WLA (lbs/yr)
3286	Aggregate	See Permit Numbers Below	952.96	934.85	204.20	106.71	136,136.53	90,563.68
3288	WASH AQUEDUCT- DALECARLIA	DC0000019						

The Bay TMDL used Discharge Monitoring Report data from industrial facilities where available to derive loadings in Appendix Q. If DMR data were not available, then default values were used to estimate loads (Section 4.5.2 of the Bay TMDL). EPA initially included the entire aggregate edge of stream wasteload allocations for TN, TP, and TSS as maximum cumulative annual loads at all the outfalls in the final permit. However, the Aqueduct had concerns with applying maximum cumulative loads at all the outfalls asserting that there is a high likelihood that the mass limits for TN and TP would be exceeded solely due to concentrations of these pollutants present in the Potomac River. As a result, the Aqueduct recommended the application of net limits in the permit as well as conducting a sampling study of the Potomac River. EPA evaluated the Aqueduct's request to replace the annual cumulative limits with net limits and has determined that there is insufficient data to make the recommended changes to the permit. Instead EPA determined that monitoring for TN and TP over the next permit term is appropriate at this time and is discussed in more detail below.

The Bay TMDL contemplated that permittees would submit TN and TP monitoring data with their permit applications, however, EPA has not received this monitoring data from the Aqueduct. This information must be gathered to be consistent with the assumptions and requirements of the Bay TMDL and to evaluate whether net limits are appropriate. Therefore, the permit includes monitoring for TN and TP over the next permit term. EPA will evaluate the data to determine whether the discharges at the outfalls are consistent with the assumptions and requirements for Nonsignificant facilities in the Bay TMDL. Moreover, EPA agrees with the Aqueduct's recommendation to add a special condition to the permit that requires the sampling of both raw Potomac River water at the intakes and the discharges at the outfalls and has included this requirement in Part III.C of the permit. This special condition requires the Aqueduct to conduct a background study that includes sampling for TN and TP at each of the intakes

<sup>7</sup> Edge of Stream load is the amount of a pollutant reaching a simulated stream segment from a point in that stream's watershed. (Section 11 of the Bay TMDL)

<sup>8</sup> Delivered load is the amount of a pollutant delivered to the tidal waters of the Chesapeake Bay or its tidal tributaries from an upstream point of discharge/runoff after accounting for permanent reductions in pollutant loads due to natural in-stream processes in nontidal rivers.

and outfalls over the next permit term. Once data are collected and submitted to EPA for review, EPA will evaluate the data and determine appropriate effluent limitations or additional permit conditions as necessary.

### 5.3.2 The District's 2019 Phase III Watershed Implementation Plan (WIP)

The District's Phase III WIP, which was finalized in 2019, describes the District's strategy for continuing to reduce nitrogen, phosphorus, and sediment in the Chesapeake Bay. The District's Phase III WIP guides the District's continued implementation of the Bay TMDL and outlines the various pollutant reduction strategies the District plans to implement to meet planning targets. These planning targets were calculated by EPA and agreed to by the CBP partnership. As part of its Phase III WIP, the District developed local planning goals for various source sectors, including individually permitted point sources.

Chapter 6 of the District's Phase III WIP includes planning goals for individually permitted municipal and industrial facilities. The planning goals for these facilities are based on existing permit limits at the time of WIP development and DMR data for the specific progress reporting period of July 2017 through June 2018. These data were used as inputs to the Chesapeake Assessment Scenario Tool<sup>9</sup> (CAST), which is a CBP partnership load estimator tool that provides estimates of load reductions for sources such as wastewater. States, federal agencies, and local governments use the results from CAST to identify which pollutant reduction strategies provide the greatest reduction in TN, TP, and TSS loads and to determine if WLAs are being met. DOEE used CAST to estimate load reductions and set planning goals for the nonsignificant permitted facilities in the District. See Table 6-5 of the District's Phase III WIP.

In an effort to better understand how the District's Phase III WIP planning goals for the nonsignificant permitted facilities are intended to implement the Bay TMDL aggregate WLAs, EPA Region 3 consulted with DOEE and the Chesapeake Bay Program Office. After several discussions, EPA Region 3 understands that the planning goals for the facilities listed in Table 6-5 of the District's Phase III WIP are not intended to be incorporated into NPDES permits as effluent limits. The District's Phase III WIP and the WLAs of the Bay TMDL both have the ultimate goal of reducing pollutant loadings into the Bay by 2025.

### 5.3.3 Concentration Based TSS Limits

As discussed above, the aggregate WLAs in the Bay TMDL were based on the DMR data of facilities, where available. The concentration limits for TSS from the 2008 permit are being retained in the new permit because these were the same limits that were in the permit when the Bay TMDL was developed. EPA believes that maintaining the same concentration limits for TSS is consistent with the assumptions and requirements of the Bay TMDL for nonsignificant facilities. Regarding concentrations of nitrogen and phosphorus, the permittee was not required to monitor for TN and TP at the time the TMDL was developed, therefore, there were no DMR data or effluent limits for these two pollutants. As such, there are no concentration limits for TN and TP in the permit, but the permit requires monitoring for TN, TP, and TSS at all the outfalls.

---

<sup>9</sup> For more information about CAST visit <https://cast.chesapeakebay.net/about>.

## 6.0 Basis for Effluent Limitations

In general, the Clean Water Act (Act) requires compliance with all applicable statutory and regulatory requirements, including effluent limitations based on the capabilities of technologies available to control pollutants (i.e., technology-based effluent limits) and limitations that are protective of the water quality standards of the receiving water (i.e., water quality-based effluent limits). Typically, technology-based effluent limitations (TBELs) are developed for all applicable pollutants of concern and water quality-based effluent limitations (WQBELs) are developed where TBELs are not adequate to meet applicable water quality standards (WQS) in the receiving water, which is determined by considering the instream water quality criterion, the background concentration and the dilution factor. The final effluent limitations will ensure that all applicable District of Columbia WQS are achieved.

## 7.0 Technology-Based Effluent Limitations (TBELs)

Federal regulations at 40 C.F.R. § 122.44(a) and § 125.3 require that permits include conditions requiring dischargers to meet applicable TBELs. When EPA has not promulgated effluent limitation guidelines (ELG) for an industry, permit limitations may be based on best professional judgment (BPJ). (40 C.F.R. § 125.3(c)).

The proposed effluent limits in this permit for TSS and Oil & Grease are TBELs for existing sources based on Best Conventional Pollutant Control Technology (BCT) available. These effluent limits are set at the same levels as in the 2008 permit to prevent backsliding (40 C.F.R. § 122.44(l)). In addition, the proposed effluent limits for aluminum from Outfall 002A are TBELs based on Best Available Technology (BAT) as determined by EPA in 2002 using BPJ. EPA's BPJ determination can be found in document number 38 of the permit's administrative record.

## 8.0 Water Quality-Based Effluent Limitations (WQBELs)

40 C.F.R. § 122.44(d)(1)(i) requires limitations to be established in permits to control all pollutants or pollutant parameters that are or may be discharged at a level that *cause*, have the *reasonable potential to cause*, or *contribute* to an excursion above any state WQS, including state narrative water quality criteria. The WQBELs in this permit will be as stringent as necessary to ensure that the designated uses of the Potomac River, Rock Creek, and Mill Creek are protected, maintained, and/or attained. EPA assessed the reasonable potential (RP) for the discharges from this facility to cause, have the RP to cause, or contribute to an exceedance of the District's applicable WQSs. EPA used the *Technical Support Document for Water Quality-based Toxics Control* (TSD) approach to conduct that analysis. The hardness used to calculate the WQBELs for metals was 100 mg/L, which is a default value used by the District of Columbia's Department of Energy and Environment.

## 9.1 Total Residual Chlorine & pH

The total residual chlorine and pH effluent limits in the permit are WQBELs designed to meet the District's WQS for those parameters. Specifically, this permit adopts the District's WQS for total residual chlorine and pH as the WQBELs for this permit. Therefore, no RP analysis is needed for these parameters. The WQBEL for total residual chlorine is that no chlorine shall be discharged in detectable amounts – i.e., the discharge of total residual chlorine shall not be greater than the non-detect level of less than 0.1 mg/L. The WQBEL for pH is 6.0 to 8.5 as specified in Section 21-1104.8 of the District of Columbia Municipal Regulations, Water Quality Standards.

## 9.0 Reasonable Potential (RP) Analysis

EPA performed a RP analysis for the parameters of concern other than TSS, oil and grease, total residual chlorine, and pH, using the TSD approach. For pollutants for which the RP analysis shows the potential to exceed in-stream water quality values, WQBELs must be calculated as required at 40 C.F.R. § 122.44(d).

The data that EPA used for the RP analyses were obtained from the 2013 application, the 2017 supplemental information submitted to EPA, and historical DMR data. However, not all of these data were used to evaluate RP at every outfall for the reasons explained below.

Outfalls 002A, 003, and 004: RP for these outfalls was calculated using data from the 2017 supplemental information as requested by EPA pursuant to CWA Section 308, the DMR data reported for the period of March 2015 – November 2019, and recent sampling data submitted by the permittee for iron and flouride. These recent data as well as the data from the selected DMR timeframe were used because it represents discharge conditions with the Residual Processing Facility in operation. Data reported on the 2013 application and DMR data prior to March 2015 represents discharge conditions prior to the completion of the Residual Processing Facility, thus not representative of current and future discharge and therefore not used in the RP analysis for these outfalls.

Outfalls 002Q, 006, 007: RP for these outfalls was calculated using data from the 2013 permit application, the 2017 supplemental information as requested by EPA pursuant to CWA Section 308, and DMR data reported over the last permit term from 2008-2019.

Outfalls 008, and 009: RP for these outfalls was calculated using data from the 2013 permit application, the 2017 supplemental information as requested by EPA pursuant to CWA Section 308, and DMR data reported over the last permit term from 2008-2019. The permittee also collected 3,258 flouride measurements in 2019 as part of a special study and general process monitoring activities. These flouride data were used in the RP analysis because they more accurately represent current conditions at these outfalls.

The Washington Aqueduct Water Treatment Plant consists of eight outfalls: 002A, 002Q, 003, 004, 006, 007, 008, and 009. These outfalls only have intermittent discharges with the exception of Outfall 002Q, which is a continuous discharge. The duration of each of these intermittent discharges is assumed to be 48 hours or less.

The District of Columbia WQS define the Criterion Continuous Concentration (chronic aquatic life criterion) as an extended period of time of 96 hours (4 days). Therefore, since the intermittent discharges are less than 96 hours, EPA made the determination to use the District of Columbia's acute criterion for all outfalls with intermittent discharges (outfalls 002A, 003, 004, 006, 007, 008, 009). Using the acute water quality criteria for the intermittent discharges will be protective of the receiving streams.

Outfall 002Q is a continuous discharge and, therefore, was evaluated using both the acute and the chronic criteria for all parameters of concern.

The permit application did not contain an effluent characterization for Outfall 002Q so EPA used the effluent characterization from the prior permit in the RP analysis. The special condition in Part III.C.3 of the permit requires the permittee to submit an effluent characterization for Outfall 002Q within six months of the reissuance of this permit.

The permit includes special conditions that apply if the duration of the intermittent discharge is equal or greater than 96 hours. Should the duration of the intermittent discharges be equal or greater than 96 hours, EPA will assess compliance with the chronic quality criteria and modify the permit as necessary.

Using a more detailed version of the TSD approach, the following is a description of the steps used to conduct the RP analysis:

1. Determine the total number of effluent data values for the pollutant of interest (n) and identify the Highest Effluent Concentration (HEC), which is the highest value of the dataset for that parameter.<sup>10</sup>
  2. Determine the coefficient of variation (CV) of the dataset. The CV is equal to the standard of deviation divided by the long-term average, rounded to one decimal place.<sup>11</sup> The default CV for fewer than 10 data values is 0.6, as specified in Box 3-2 of the TSD.
  3. Determine the appropriate confidence level for the RP analysis (for this permit, EPA used the 99<sup>th</sup> confidence level, recommended by the TSD in section 5.5.4) and determine the Reasonable Potential Multiplier (RPM), using Table 3-1 of the TSD. If n is greater than 20, the TSD states to use the multiplier assigned to 20 samples as identified on Table 3-1 of the TSD.
  4. Calculate the Adjusted Effluent Concentration (AEC):  $AEC = HEC \times RPM$ .
  5. Determine if the AEC is greater than the Water Quality Criterion (WQC). For those parameters where the  $AEC > WQC$ , continue with the RP analysis.<sup>12</sup>
  6. Calculate the Dilution Factor.
  7. Calculate the Maximum Receiving Water Concentration (MRWC), using the AEC, the Instream Background Concentration, and the Dilution Factor.
  8. Compare the MRWC to the WQC. If  $MRWC > WQC$ , then RP is found.
- 9.1 Steps 1-4 of the RP Analysis:
- Step 1. Determine the HEC and (n)
  - Step 2. Determine CV
  - Step 3. Determine RP Multiplier
  - Step 4. Calculate the AEC

Outfall 002A					
Parameters of concern	Number of samples (n)	HEC (mg/L)	CV	RP Multiplier	AEC (mg/L)
Aluminum	2	0.121	0.6	7.4	0.891

<sup>10</sup> These values are provided in the RP analysis spreadsheet which can be found in the Administrative Record for this permit.

<sup>11</sup> For values other than the default value, see the calculations provided in the RP analysis spreadsheet.

<sup>12</sup> This step is not part of the TSD approach. However, if the AEC is less than the WQC, then there is no way, after adjusting for dilution and calculating the MRWC, that the MRWC will be greater than the WQC, so there is no need to continue the RP analysis for those parameters.

Chloride	1	0.036	0.6	13.2	0.475
Copper	2	0.003	0.6	7.4	0.0194
Manganese	2	0.0591	0.6	7.4	0.437
Sulfate	1	0.0477	0.6	13.2	0.629
Iron	26	8.00	0.002	1.00	8.02
Barium	2	0.0419	0.6	7.4	0.310
Flouride	1	0.0001	0.6	13.2	0.00167
Zinc	2	0.0077	0.6	7.4	0.0572

Outfall 002Q					
Parameters of concern	Number of samples (n)	HEC (mg/L)	CV	RP Multiplier	AEC (mg/L)
Aluminum	119	3.04	0.77	1.49	4.53
Iron	6	0.024	0.6	3.8	0.091
Chloroform	118	4.10	2.45	2.27	9.32
Perchlorate	26	0.00130	0.46	1.86	0.00242

Outfall 003					
Parameters of concern	Number of samples (n)	HEC (mg/L)	CV	RP Multiplier	AEC (mg/L)
Aluminum	11	0.573	0.5	2.5	1.43
Chloride	11	62.0	0.3	1.8	112
Copper	11	0.005	0.6	2.9	0.0154
Manganese	11	0.0507	0.2	1.5	0.0760
Sulfate	11	49.0	0.1	1.2	58.8
Zinc	11	0.006	0.4	2.1	0.0126
Fluoride	3,258	0.89	0.09	1.2	1.0680
Iron	11	0.038	0.6	2.9	0.110

Outfall 004					
Parameters of concern	Number of samples (n)	HEC (mg/L)	CV	RP Multiplier	AEC (mg/L)
Aluminum	11	0.573	0.5	2.5	1.43
Chloride	11	62.0	0.3	1.8	112
Copper	11	0.005	0.6	2.9	0.0154
Manganese	11	0.0507	0.2	1.5	0.0760
Sulfate	11	49.0	0.1	1.2	58.8
Zinc	11	0.006	0.4	2.1	0.0126
Fluoride	3,258	0.89	0.09	1.2	1.0680
Iron	11	0.038	0.6	2.9	0.110
Outfall 006					
Parameters of concern	Number of samples (n)	HEC (mg/L)	CV	RP Multiplier	AEC (mg/L)
Aluminum	10	1.3136	0.3	1.8	2.36
Barium	2	0.0416	0.6	7.4	0.308



Chloride	11	0.0590	0.3	1.8	0.104
Copper	305	0.0042	0.3	1	0.00415
Fluoride	1	0.0008	0.6	13.2	0.0102
Iron	19	0.3349	0.7	2.6	0.844
Manganese	11	0.0668	0.2	1.5	0.0982
Sulfate	11	49.60	0.2	1.3	66.7
Zinc	11	0.00368	0.3	1.8	0.00643

Outfall 007					
Parameters of concern	Number of samples (n)	HEC (mg/L)	CV	RP Multiplier	AEC (mg/L)
Aluminum	10	0.4155	0.3	1.8	0.748
Barium	2	0.0388	0.6	7.4	0.287
Chloride	11	52.50	0.3	1.7	89.0
Copper	2	0.0186	0.6	7.4	0.137
Fluoride	1	0.001	0.6	13.2	0.0107
Manganese	11	0.0447	0.3	1.5	0.0655
Sulfate	11	48.70	0.1	1.3	63.6
Zinc	11	0.0037	0.4	0	0.00761

Outfall 008					
Parameters of concern	Number of samples (n)	HEC (mg/L)	CV	RP Multiplier	AEC(mg/L)
Aluminum	345	0.320	0.6	2.3	0.736
Fluoride	52	0.860	0.09	1.2	1.032
Iron	4	0.043	0.6	4.7	0.202

Outfall 009					
Parameters of concern	Number of samples (n)	HEC (mg/L)	CV	RP Multiplier	AEC(mg/L)
Aluminum	345	0.320	0.6	2.3	0.736
Fluoride	51	0.790	0.08	1.2	0.948
Iron	4	0.043	0.6	4.7	0.202

## 9.2 Steps 5-8 of the RP Analysis

Step 5. Determine if the AEC is greater than the Water Quality Criterion (WQC).

If yes, continue with the RP analysis. If no, there is no reason to continue with the RP analysis.

Where possible, EPA used DC's WQS to determine the acute numeric WQC. The DC water quality standards do not contain a numeric WQC for aluminum. Therefore, the permittee developed and calculated the WQBELs for aluminum based on its interpretation of DC's

narrative WQC using EPA's aluminum criterion calculator<sup>13</sup> as allowed in 40 C.F.R. § 122.44(d)(1)(vi)(A). EPA reviewed the calculations submitted by the permittee and found that they were consistent with the EPA final Aquatic Life Ambient WQC for Aluminum 2017. These aluminum calculations conducted by the permittee were in accordance with TSD and included in the RP discussion in this section. The aluminum calculations conducted by the permittee are included in the permit's administrative record.

For barium and chloride, DC has no numeric WQC, so EPA used its National Recommended Water Quality Criteria for Human Health to interpret the narrative WQC for these parameters.

For sulfate, neither DC nor EPA has numeric WQC for sulfate, so EPA used its National Secondary Drinking Water Standard of 250 mg/L for sulfate to interpret the DC narrative WQC.

Finally, for flouride, neither DC nor EPA has a numeric WQC for fluoride, so EPA used the federal maximum contaminant level (MCL) of 4.0 mg/L for the protection of drinking water as an interpretation of the DC narrative WQC.

Outfall 002A – Chronic Conditions				
Parameter of concern	AEC (mg/L)	WQC (mg/L)	DC WQC or Federal WQC or MCL	Is AEC > WQC?
Aluminum	0.891	1.90	Federal WQC	No
Chloride	0.4752	860.0	Federal WQC	No
Copper	0.0194	0.0134	DC WQC	Yes
Manganese	0.437	0.100	DC WQC	Yes
Sulfate	629	250.0	Federal WQC	Yes
Iron	8.02	1.00	DC WQC	Yes
Barium	0.310	1.00	Federal WQC	No
Flouride	0.00167	4.00	Federal MCL	No
Zinc	0.0572	0.1172	DC WQC	No

Outfall 002Q – Acute Conditions				
Parameter of concern	AEC (mg/L)	WQC (mg/L)	DC WQC or Federal WQC or MCL	Is AEC > WQC?
Aluminum	4.53	1.90	Federal	Yes
Iron	0.091	1.00	DC	No
Chloroform	9.32	0.470	DC	Yes
Perchlorate	0.00242	0.015	Federal	No

Outfall 002Q – Chronic Conditions				
Parameter of concern	AEC (mg/L)	WQC (mg/L)	DC WQC or Federal WQC or MCL	Is AEC > WQC?
Aluminum	4.53	1.1	Federal	Yes
Iron	0.091	1.00	DC	No
Chloroform	9.32	3.00	DC	Yes
Perchlorate	0.00242	0.015	Federal	No

<sup>13</sup> EPA's Final Aquatic Life Criteria for Aluminum in Freshwater was used. See <https://www.epa.gov/wqc/2018-final-aquatic-life-criteria-aluminum-freshwater> or 83 FR 65663.

<b>Outfall 003 – Acute Conditions</b>				
Parameter of concern	AEC (mg/L)	WQC (mg/L)	DC WQC or Federal WQC or MCL	Is AEC > WQC?
Aluminum	1.43	1.10	Federal WQC	Yes
Chloride	112	860.0	Federal WQC	No
Copper	0.0154	0.0134	DC WQC	Yes
Manganese	0.0760	0.100	DC WQC	No
Sulfate	58.8	250.0	Federal WQC	No
Zinc	0.0126	0.117	DC WQC	No
Fluoride	1.068	4.00	Federal MCL	No
Iron	0.110	1.00	DC WQC	No

<b>Outfall 004 – Acute Conditions</b>				
Parameter of concern	AEC (mg/L)	WQC (mg/L)	DC WQC or Federal WQC or MCL	Is AEC > WQC?
Aluminum	1.43	1.10	Federal WQC	Yes
Chloride	112	860.0	Federal WQC	No
Copper	0.0154	0.0134	DC WQC	Yes
Manganese	0.0760	0.100	DC WQC	No
Sulfate	58.8	250.0	Federal WQC	No
Zinc	0.0126	0.117	DC WQC	No
Fluoride	1.068	4.00	Federal MCL	No
Iron	0.110	1.00	DC WQC	No

<b>Outfall 006 – Acute Conditions</b>				
Parameter of concern	AEC (mg/L)	WQC (mg/L)	DC WQC or Federal WQC or MCL	Is AEC > WQC?
Aluminum	2.36	1.20	Federal WQC	Yes
Barium	0.307	1.00	Federal WQC	No
Chloride	0.104	860.0	Federal WQC	No
Copper	0.00415	0.0134	DC WQC	No
Fluoride	0.0102	4.00	Federal MCL	No
Iron	0.844	1.00	DC WQC	No
Manganese	0.0982	0.100	DC WQC	No
Sulfate	66.7	250.0	Federal WQC	No
Zinc	0.00643	0.117	DC WQC	No

<b>Outfall 007 – Acute Conditions</b>				
Parameter of concern	AEC (mg/L)	WQC (mg/L)	DC WQC or Federal WQC or MCL	Is AEC > WQC?
Aluminum	0.748	1.30	Federal WQC	No
Barium	0.287	1.00	Federal WQC	No
Chloride	89.0	860.0	Federal WQC	No
Copper	0.137	0.0134	DC WQC	Yes
Fluoride	0.0107	4.00	Federal MCL	No
Manganese	0.0655	0.100	DC WQC	No

Sulfate	63.6	250.0	Federal WQC	No
Zinc	0.00761	0.117	DC WQC	No

Outfall 008 – Acute Conditions				
Parameter of concern	AEC (mg/L)	WQC (mg/L)	DC WQC or Federal WQC or MCL	Is AEC > WQC?
Aluminum	0.320	1.70	Federal	No
Iron	0.202	1.00	DC	No

Outfall 009 – Acute Conditions				
Parameter of concern	AEC (mg/L)	WQC (mg/L)	DC WQC or Federal WQC or MCL	Is AEC > WQC?
Aluminum	0.320	1.70	Federal	No
Iron	0.202	1.00	DC	No

Step 6. Calculate the Dilution Factor (DF):

The DF is a determination of how much the receiving water will dilute the discharge. The DF can be calculated using different mixing zone approaches, as specified in the TSD.

For Outfalls 002A, 002Q, 003, and 004, for which the receiving water is the Potomac River, EPA used the mixing zone dilution factors found in the water quality study submitted by the permittee to EPA in 2001. This study, titled “Water Quality Studies in the Vicinity of Washington Aqueduct,” used CORMIX modeling to determine acute and chronic dilution factors for Outfalls 002A, 002Q, 003, and 004. The use of CORMIX in the mixing zone study is consistent with the District’s WQS mixing zone regulations. Therefore, EPA used the dilution factors determined by the 2001 study for Outfalls 002, 003, and 004. The 2008 permit also used the acute mixing zone dilution factors from the 2001 study for Outfalls 002A, 002Q, 003, and 004, however, since Outfall 002Q is a continuous discharge EPA also evaluated chronic conditions using the chronic mixing zone dilution factor at this outfall.

	Dilution Factor	Mixing Zone
Outfall 002A	169	Acute Mixing
Outfall 002Q	169	Acute Mixing
Outfall 002Q	51	Chronic Mixing
Outfall 003	2.3	Acute Mixing
Outfall 004	2.3	Acute Mixing

For Outfalls 006, 007, 008, and 009, for which the receiving waters are an unnamed tributary to the Potomac River (Outfall 006), Rock Creek (Outfall 007), and Mill Creek (Outfalls 008 and 009), EPA first calculated Instream Waste Concentration (IWC). The IWC is defined in the TSD as  $IWC = \text{Effluent Flow} / (\text{Stream Flow} + \text{Effluent Flow})$ . To calculate the IWC, EPA used information such as physical characteristics and streamflow statistics from the U.S. Geological Survey (USGS) website Stream Stats, available at <https://streamstats.usgs.gov/ss/>. Because the calculated IWCs for these outfalls are greater than 50%, the stream is effluent dominated, so EPA assumed that there is rapid and complete mixing from these outfalls. EPA then determined the dilution factor (DF) using the equation:  $DF = (1/\text{Instream Waste Concentration}) \times 100$ .

Outfall No.	Stream Flow (MGD)	Effluent Flow (MGD)	IWC (%)	Is IWC > 50%?	Dilution Factor	Mixing Zone
006	3.56	5	58	Yes	1.72	Rapid Mixing
007	3.56	5	58	Yes	1.72	Rapid Mixing
008	0.00162 (1.62 x 10 <sup>-3</sup> )	7	100	Yes	1.0	Rapid Mixing
009	0.00000060 (66.06 x 10 <sup>-7</sup> )	10	100	Yes	1.0	Rapid Mixing

Step 7. Calculate the Maximum Receiving Water Concentration (MRWC) for the parameters where the AEC > WQC:

MRWC = ((AEC – IBC)/DF) + IBC, where:

*AEC* is the Adjusted Effluent Concentration

*IBC* is the Instream Background Concentration –the concentration of a given parameter in the receiving stream. Background data was obtained from “Historical Potomac River Water Characterization Data” submitted by the permittee with its permit application.

*DF* is the Dilution Factor

Outfall 002A – Acute Conditions				
Parameter of concern	AEC (mg/L)	IBC (mg/L)	DF	MRWC (mg/L)
Copper	0.0194	0.00179	169	0.00189
Manganese	0.437	0.0438	169	0.0461
Sulfate	629	31.1	169	34.7
Iron	8.02	0.193	169	0.239

Outfall 002Q – Acute Conditions				
Parameter of concern	AEC (mg/L)	IBC (mg/L)	DF	MRWC (mg/L)
Aluminum	4.53	0.298	169	0.323
Chloroform	9.32	0.00118	169	0.0563
Outfall 002Q – Chronic Conditions				
Parameter of concern	AEC (mg/L)	IBC (mg/L)	DF	MRWC (mg/L)
Aluminum	4.53	0.298	51	0.381
Chloroform	9.32	0.00118	51	0.184

Outfall 003 – Acute Conditions				
Parameter of concern	AEC (mg/L)	IBC (mg/L)	DF	MRWC (mg/L)
Aluminum	1.43	0.298	2.3	0.791
Copper	0.0154	0.00179	2.3	0.00769

<b>Outfall 004 – Acute Conditions</b>				
Parameter of concern	AEC (mg/L)	IBC (mg/L)	DF	MRWC (mg/L)
Aluminum	1.43	0.298	2.3	0.791
Copper	0.0154	0.00179	2.3	0.00769

<b>Outfall 006 – Acute Conditions</b>				
Parameter of concern	AEC (mg/L)	IBC (mg/L)	DF	MRWC (mg/L)
Aluminum	2.36	No data	1.72	1.37

<b>Outfall 007 – Acute Conditions</b>				
Parameter of concern	AEC (mg/L)	IBC (mg/L)	DF	MRWC (mg/L)
Copper	0.138	No data	1.72	0.0800

Step 8. Determine if the Maximum Receiving Water Concentration (MRWC) is greater than the WQC. If so, EPA concludes that there is a reasonable potential (RP) for the pollutant to cause or contribute to an exceedance of the WQC and a WQBEL must be developed for this parameter. If not, there is no RP to cause or contribute to an instream excursion above the applicable WQC based on the TSD RP procedures (40 C.F.R 122.44(d)(1)(ii)).

<b>Outfall 002A – Acute Conditions</b>			
Parameter of concern	MRWC (mg/L)	WQC (mg/L)	MRWC > WQC?
Copper	0.00189	0.0134	No
Manganese	0.0461	0.100	No
Sulfate	34.66	250	No
Iron	0.197	1.00	No
<b>Outfall 002Q Acute Conditions</b>			
Parameter of concern	MRWC (mg/L)	WQC (mg/L)	MRWC > WQC?
Aluminum	0.323	1.90	No
Chloroform	0.0563	0.470	No
<b>Outfall 002Q Chronic Conditions</b>			
Parameter of concern	MRWC (mg/L)	WQC (mg/L)	MRWC > WQC?
Aluminum	0.381	1.10	No
Chloroform	0.184	3.00	No
<b>Outfall 003 – Acute Conditions</b>			
Parameter of concern	MRWC (mg/L)	WQC (mg/L)	MRWC > WQC?
Aluminum	0.791	1.10	No
Copper	0.00769	0.0134	No
<b>Outfall 004 – Acute Conditions</b>			
Parameter of concern	MRWC (mg/L)	WQC (mg/L)	MRWC > WQC?
Aluminum	0.791	1.10	No
Copper	0.00769	0.0134	No
<b>Outfall 006 – Acute Conditions</b>			
Parameter of concern	MRWC (mg/L)	WQC (mg/L)	MRWC > WQC?
Aluminum	1.37	1.20	Yes

<b>Outfall 007 – Acute Conditions</b>			
Parameter of concern	MRWC (mg/L)	WQC (mg/L)	MRWC > WQC?
Copper	0.0800	0.0134	Yes

## 10.0 Developing Water-Quality Based Effluent Limits

The next step is the development of a WQBEL, which is required for each pollutant where there is a reasonable potential to cause or contribute to an exceedance of applicable WQSs. If the 2008 permit contained a TBEL, EPA calculated a WQBEL to compare the calculated WQBEL with the TBEL to determine which one is more protective. The procedure for calculating a WQBEL is described at Section 5.4 of the TSD and shown below.

### 10.1 Compute the Wasteload Allocation (WLA): $WLA = ((WQC - IBC) * DF) + IBC$ , where:

WQC – Water Quality Criterion

IBC – Instream Background Concentration

DF – Dilution Factor

<b>Outfall 002A – Acute Conditions</b>				
Parameter	WQC (mg/L)	IBC (mg/L)	DF	WLA (mg/L)
Aluminum	1.90	0.371	169	259

<b>Outfall 002Q – Acute and Chronic Conditions</b>				
Parameter	WQC (mg/L)	IBC (mg/L)	DF	WLA (mg/L)
Aluminum – acute	1.90	0.298	169	271
Aluminum – chronic	1.1	0.298	51	41.2

<b>Outfall 003 – Acute Conditions</b>				
Parameter	WQC (mg/L)	IBC (mg/L)	DF	WLA (mg/L)
Aluminum	1.1	0.298	2.3	2.14

<b>Outfall 004 – Acute Conditions</b>				
Parameter	WQC (mg/L)	IBC (mg/L)	DF	WLA (mg/L)
Aluminum	1.1	0.298	2.3	2.14

<b>Outfall 006 – Acute Conditions</b>				
Parameter	WQC (mg/L)	IBC (mg/L)	DF	WLA (mg/L)
Aluminum	1.2	No data	1.72	2.06

<b>Outfall 007 – Acute Conditions</b>				
Parameter	WQC (mg/L)	IBC (mg/L)	DF	WLA (mg/L)
Aluminum	1.30	No data	1.72	2.24
Copper	0.0134	No data	1.72	0.0231

Outfall 008 – Acute Conditions				
Parameter	WQC (mg/L)	IBC (mg/L)	DF	WLA (mg/L)
Aluminum	1.70	No data	1	1.70

Outfall 009 – Acute Conditions				
Parameter	WQC (mg/L)	IBC (mg/L)	DF	WLA (mg/L)
Aluminum	1.70	No data	1	1.70

- 10.2 Calculate the Long-Term Average (LTA), Maximum Daily Limit (MDL) and the Average Monthly Limit (AML). The LTA calculation is based on the 99<sup>th</sup> confidence level as reflected with the z score of 2.326.

- i.  $LTA = WLA * e^{(0.5 * \sigma^2 - 2.326 * \sigma)}$   
 Sigma square =  $\ln(CV^2 + 1)$   
 Sigma = square root of Sigma Squared
- ii.  $MDL = LTA * e^{(2.326 * \sigma - 0.5 * \sigma^2)}$   
 Sigma square =  $\ln(CV^2 + 1)$   
 Sigma = square root of Sigma Squared
- iii.  $AML = LTA * e^{(1.645 * \sigma - 0.5 * \sigma^2)}$   
 Sigma square =  $\ln(CV^2 + 1)$   
 Sigma = square root of Sigma Squared

Outfall 002A						
Parameters of concern	z	CV	Sigma Square	Sigma	LTA (mg/L)	MDL (mg/L)
Aluminum	2.326	0.6	0.307	0.555	83.09	259

Outfall 002Q							
Parameters of concern	z	CV	Sigma Square	Sigma	LTA (mg/L)	MDL (mg/L)	AML (mg/L)
Aluminum	2.326	0.8	0.495	0.703	67.60	271	168

Outfall 003						
Parameters of concern	z	CV	Sigma Square	Sigma	LTA (mg/L)	MDL (mg/L)
Aluminum	2.326	0.5	0.223	0.472	0.800	2.14

Outfall 004						
Parameters of concern	z	CV	Sigma Square	Sigma	LTA (mg/L)	MDL (mg/L)
Aluminum	2.326	0.5	0.223	0.472	0.800	2.14



<b>Outfall 006</b>						
Parameters of concern	z	CV	Sigma Square	Sigma	LTA (mg/L)	MDL (mg/L)
Aluminum	2.326	0.3	0.086	0.294	1.09	2.07

<b>Outfall 007</b>						
Parameters of concern	z	CV	Sigma Square	Sigma	LTA (mg/L)	MDL (mg/L)
Aluminum	2.326	0.3	0.0862	0.294	1.18	2.24
Copper	2.326	0.6	0.307	0.555	0.00742	0.0231

<b>Outfall 008</b>						
Parameters of concern	z	CV	Sigma Square	Sigma	LTA (mg/L)	MDL (mg/L)
Aluminum	2.326	0.6	0.307	0.555	0.546	1.70

<b>Outfall 009</b>						
Parameters of concern	z	CV	Sigma Square	Sigma	LTA (mg/L)	MDL (mg/L)
Aluminum	2.326	0.6	0.307	0.555	0.546	1.70

### 10.3 Compare the Water Quality Based Effluent Limits (WQBELs) with the Technology Based Effluent Limits (TBELs)

EPA compared the WQBELs with the TBELs as indicated below; whichever is more stringent is included in the permit. The limits are consistent with the anti-backsliding requirements in the Clean Water Act and federal regulations. CWA Section 402(o), 33 U.S.C. § 1342(o); 40 C.F.R. § 122.44(l).

The August 2019 draft permit retained the aluminum TBELs from the prior permit in order to be consistent with the anti-backsliding regulation specified in 40 C.F.R. § 122.44(l). However, when the Maryland Department of Environment provided its 401 Certification after the public comment period closed, it pointed out that while the effluent did not exhibit RP for aluminum at some of the outfalls, the TBELs that were retained in the permit may not be as protective as the WQBEL. As a result, EPA evaluated the aluminum TBELs against a calculated WQBEL for all the outfalls to determine whether they were protective of the receiving streams. The more protective limit was included in the permit. This approach was used even when there was no RP for aluminum because the flocculent the facility uses in its treatment system contains aluminum.

	Parameter	2019 TBELs (mg/L)	Calculated WQBEL MDL (mg/L)	Rationale
Outfall 002	Aluminum	8.0	259	There is no RP for aluminum, and the calculated WQBEL is less stringent than the TBEL, therefore the permit uses the TBEL.

	<b>Parameter</b>	<b>2019 TBELs (mg/L)</b>	<b>Calculated WQBEL MDL (mg/L)</b>	<b>Rationale</b>
Outfall 002Q	Aluminum	8.0	271	There is no RP for aluminum, and the calculated WQBEL is less stringent than the TBEL, therefore the permit uses the TBEL.
Outfalls 003 & 004	Aluminum	8.0	2.14	There is no RP for aluminum, but the calculated WQBEL is more stringent than the TBEL, therefore the permit uses the WQBEL.
Outfall 006	Aluminum	8.0	2.07	There is RP for aluminum, and the WQBEL is more stringent than the TBEL, so the permit uses the WQBEL.
Outfall 007	Aluminum	8.0	2.24	There is no RP for aluminum, but the calculated WQBEL is more stringent than the TBEL, therefore the permit uses the WQBEL.
Outfall 008	Aluminum	8.0	1.70	There is no RP for aluminum, but the calculated WQBEL is more stringent than the TBEL, therefore the permit uses the WQBEL.
Outfall 009	Aluminum	8.0	1.70	There is no RP for aluminum, but the calculated WQBEL is more stringent than the TBEL, therefore the permit uses the WQBEL.

## 11.0 Discussion

The 2008 Washington Aqueduct NPDES permit included a TBEL for iron at all the outfalls. However, neither the 2003 permit nor the 2004 modifications to the 2003 permit contained TBELs for iron. EPA determined that technical mistakes were made in issuing the 2008 permit, and therefore is not including the technology based effluent limitation for iron at the outfalls; removal of the TBEL for iron does not constitute backsliding per 40 C.F.R. § 122.44(l)(2)(i)(B)(2).

The District of Columbia water quality criterion for copper is expressed as dissolved. EPA is assuming a 1:1 translator using a conservative approach to convert the total dissolved metals criterion to total effluent limits, consistent with EPA Metal Translator Guidance. The permittee could submit a request for a site-specific metal translator in the next permit.

The permittee requested a change in the average monthly limit for total aluminum from 4.0 mg/L to 6.0 mg/L and retention of the daily maximum limit at 8.0 mg/L for the Outfalls where the TBEL is used. Since these are non-continuous discharge outfalls, the permit requires daily maximum limits for consistent with 40 C.F.R. § 122.45(e) but does not require an average monthly limit. All the outfalls are considered intermittent or non-continuous (intermittent) discharges except Outfall 002Q, which is a continuous discharge. The effluent limits for the non-continuous discharges are expressed as maximum daily limits consistent with 40 C.F.R. § 122.45(e). The effluent limits for the continuous discharge

(Outfall 002Q) are expressed as both maximum daily and average monthly limits per 40 C.F.R. § 122.45(d). Therefore, EPA removed the average monthly limit for the intermittent outfalls.

Since D.C.'s water quality criteria are expressed as concentrations, mass-based limits were not included in the permit as permissible by § 40 C.F.R 122.45(f)(ii). This does not apply to pollutants with a wasteload allocation associated with a TMDL.

## 12.0 Effluent Limits Summary

Discharge Limitations for <b>Outfall 002A</b>			
Parameter	Mass Units (lbs/day)	Concentration Units (mg/L)	Basis
	Maximum Daily	Maximum Daily	
Flow (MGD)	Report Only		Same as 2008 permit
Total Suspended Solids	N/A	60	TBEL*
Total Aluminum	N/A	8.0	TBEL
Total Nitrogen	Report	Report	TMDL
Total Phosphorus	Report	Report	TMDL
pH (Std units)	6.0 - 8.5		WQS*
Total Residual Chlorine	No detectable amounts		WOS*

\*Same as 2008 permit

Discharge Limitations for <b>Outfall 002Q</b>					
Parameter	Mass Units (lbs/day)		Concentration Units (mg/L)		Basis
	Average Monthly	Maximum Daily	Average Monthly	Maximum Daily	
Flow (MGD)	Report Only				Same as 2008 permit
Total Suspended Solids	Report		30	60	TMDL
Total Aluminum	N/A		4.0	8.0	TBEL
Total Nitrogen	Report		Report		TMDL
Total Phosphorus	Report		Report		TMDL
Perchlorate	Report	Report	Report	Report	Report Only*
pH (Std units)	6.0 - 8.5				WQS*
Total Residual Chlorine	No detectable amounts				Report Only*

\*Same as 2008 permit

Discharge Limitations for <b>Outfall 003</b>			
Parameter	Mass Units (lbs/day)	Concentration Units (mg/L)	Basis
	Maximum Daily	Maximum Daily	
Flow (MGD)	Report Only		Same as 2008 permit
Total Suspended Solids	N/A	60	TBEL*
Total Aluminum	N/A	2.14	WQBEL
Total Nitrogen	Report	Report	TMDL
Total Phosphorus	Report	Report	TMDL
pH (Std units)	6.0 - 8.5		WQS*

Total Residual Chlorine	No detectable amounts	Report Only*
-------------------------	-----------------------	--------------

\*Same as 2008 permit

Discharge Limitations for <b>Outfall 004</b>			
Parameter	Mass Units (lbs/day)	Concentration Units (mg/L)	Basis
	Maximum Daily	Maximum Daily	
Flow (MGD)	Report Only		Same as 2008 permit
Total Suspended Solids	N/A	60	TBEL*
Total Aluminum	N/A	2.14	WQBEL
Total Nitrogen	Report	Report	TMDL
Total Phosphorus	Report	Report	TMDL
pH (Std units)	6.0 - 8.5		WQS*
Total Residual Chlorine	No detectable amounts		Report Only*

\*Same as 2008 permit

Discharge Limitations for <b>Outfall 006</b>			
Parameter	Mass Units (lbs/day)	Concentration Units (mg/L)	Basis
	Maximum Daily	Maximum Daily	
Flow (MGD)	Report Only		Same as 2008 permit
Total Suspended Solids	N/A	60	TBEL*
Total Aluminum	N/A	2.07	WQBEL
Total Nitrogen	Report	Report	TMDL
Total Phosphorus	Report	Report	TMDL
pH (Std units)	6.0 - 8.5		WQS*
Total Residual Chlorine	No detectable amounts		Report Only*

\*Same as 2008 permit

Discharge Limitations for <b>Outfall 007</b>			
Parameter	Mass Units (lbs/day)	Concentration Units (mg/L)	Basis
	Maximum Daily	Maximum Daily	
Flow (MGD)	Report Only		Same as 2008 permit
Total Suspended Solids	N/A	60	TBEL*
Total Aluminum	N/A	2.24	WQBEL
Total Copper	N/A	0.0231	WQBEL
Total Nitrogen	Report	Report	TMDL
Total Phosphorus	Report	Report	TMDL
pH (Std units)	6.0 - 8.5		WQS*
Total Residual Chlorine	No detectable amounts		Report Only*

\*Same as 2008 permit

Discharge Limitations for <b>Outfall 008</b>			
Parameter	Mass Units (lbs/day)	Concentration Units (mg/L)	Basis

	Maximum Daily	Maximum Daily	
Flow (MGD)	Report Only		Same as 2008 permit
Total suspended Solid	N/A	60	TBEL*
Total Aluminum	N/A	1.7	WQBEL
Total Nitrogen	Report	Report	TMDL
Total Phosphorus	Report	Report	TMDL
pH (Std units)	6.0 - 8.5		WQS*
Total Residual Chlorine	No detectable amounts		Report only*

\*Same as 2008 permit

Discharge Limitation for <b>Outfall 009</b>			
Parameter	Mass Units (lbs/day)	Concentration Units (mg/L)	Basis
	Maximum Daily	Maximum Daily	
Flow (MGD)	Report Only		Same as 2008 permit
Total Suspended Solids	N/A	60	TBEL*
Total Aluminum	N/A	1.7	WQBEL
pH (Std units)	6.0 - 8.5		WQS*
Total Residual Chlorine <sup>2</sup>	No detectable amounts		Report Only*

\*Same as 2008 permit

### 13.0 Solid Management Facility

The 2008 permit required TSS effluent limits, average monthly limits equal to 30 mg/L and daily maximum effluent equal to 60 mg/L. This permit carries forward the maximum daily effluent limits, consistent with the anti-backsliding regulation specified in 40 C.F.R. § 122.44(l). The permittee shall ensure proper operation and maintenance of the Residual Processing Facility to comply with the effluent limits consistent with 40 C.F.R. § 122.41(e).

### 14.0 Endangered species protection

EPA requested an official species list from the U.S. Fish and Wildlife Service (U.S. FWS) using their *Information for Planning and Consultation* tool found on their website at: <https://ecos.fws.gov/ipac> to determine if there are any federally listed threatened or endangered species or their designated critical habit(s) that will be affected by Washington Aqueduct discharge. The National Oceanic and Atmospheric Administration National Marine Fisheries Service (NOAA Fisheries) has indicated that the endangered Shortnose Sturgeon and the Atlantic Sturgeon have been known to exist in the Potomac River drainage basin and may occur within the waters of the District of Columbia.

The permittee submitted a letter to EPA requesting the removal of Special Conditions for Sedimentation Discharges during the Sturgeon Spring Spawning Season, explaining that the permittee's past practice was to allow residuals/sediments to accumulate within the sedimentation basins over several months and then to release the accumulated concentrated sediments back to the Potomac River by flushing the sedimentation basins over a few days but, since the construction of the Residual Processing Facility, the permittee does not discharge sediments to the Potomac River. Consequently, the permittee believes that

the prohibition of discharging sediment during the Sturgeon Spring Spawning Season is no longer necessary. However, as a precaution, EPA is retaining the prohibition on discharging sediment during the Sturgeon Spring Spawning Season in the permit.

During the Sturgeon Spring Spawning Season, the permittee shall not discharge residuals from the sedimentation basins through Outfalls 002A, 003 or 004 and shall not allow any bypass from these outfalls.

The permittee will not be allowed any discharge or bypass that would exceed the effluent limitation at any Outfalls.

Per the requirements under Section 7 of the Endangered Species Act (50 C.F.R. Part 402; 16 U.S.C. § 1536(c)), EPA submitted a Biological Evaluation to the U.S. National Marine Fisheries Service (NMFS) on August 26, 2019. On September 4, 2019, NMFS concurred that issuance of the permit was not likely to adversely affect any ESA-listed species or critical habitat under its jurisdiction. EPA notified NMFS of the revisions to the draft permit and that these changes are not likely to adversely affect listed species or critical habitats under its jurisdiction. Since the final revisions will not adversely affect the listed species or critical habitat considered in the biological opinion submitted by EPA on August 26, 2019 or written concurrence submitted by NMFS on September 4, 2019, a re-initiation of consultation is not required per 50 C.F.R. § 402.16.

#### 15.0 National Historic Preservation Act

The National Historic Preservation Act of 1966, and implementing regulations (36 C.F.R. Part 800) requires federal agencies to take into account the effects of their undertakings on historic properties and afford the Advisory Council on Historic Preservation, or designee, the opportunity to comment on such undertakings. See Section 106, 54 U.S.C. § 306108. On August 21, 2019, EPA notified the DC State Historic Preservation Officer (DC SHPO) of its proposed reissuance of the permit and that it had determined that the permit does not have the potential to affect historic properties in D.C. See 36 C.F.R. § 800.3(1). The revisions to the permit will not change EPA's historic preservation determination made on August 21, 2019.

#### 16.0 Anti-Backsliding Provision

Section 402(o) of the CWA and 40 C.F.R. § 122.44(l) prohibit the renewal, reissuance or modification of an existing NPDES permit that contains effluent limits, permit conditions, or standards that are less stringent than those established in the existing permit, unless certain exceptions are met. Effluent limits in the permit are either identical to or more stringent than those in the 2008 permit with the exception of iron. The 2008 permit included TBELs for iron at all the outfalls, however, EPA determined that mistakes were made in issuing the 2008 permit. As such, removing the TBELs for iron does not constitute backsliding per 40 C.F.R. § 122.44(l)(2)(i)(B)(2).

#### 17.0 Antidegradation Statement

The permit contains WQBELs and TBELs that will ensure compliance with the DC water quality standards and the antidegradation policy.

## 18.0 401 Certification

In accordance with CWA 401(a)(1), EPA requested a water quality certification from the District of Columbia, via DOEE, to ensure compliance with the District's WQS. EPA also notified Maryland and Virginia of EPA's proposed issuance of the permit.

401 certification request mailed to DOEE: 8/1/2019

401 certification request received from DOEE: 8/28/2019

Revised 401 certification request emailed to DOEE: 8/8/2020

Revised 401 certification received from DOEE: 1/26/2021

401(a)(2) notification letter mailed to MDE: 8/01/2019

401(a)(2) response letter received from MDE: 9/06/2019

Revised 401(a)(2) notification letter emailed to MDE: 2/4/2021

401(a)(2) response received from MDE: N/A

401(a)(2) notification letter mailed to VA DEQ: 08/01/2019

401(a)(2) response received from VA DEQ: N/A

Revised 401(a)(2) notification letter emailed to VA DEQ: 2/4/2021

401(a)(2) response received from VA DEQ: N/A

## Attachment 1 Response to Comments

**NPDES Permit No. DC0000019**  
**Washington Aqueduct**  
**5900 MacArthur Boulevard, NW**  
**Washington, D.C. 20016-2514**

The U.S. Environmental Protection Agency's Region 3 (EPA) is issuing a Final National Pollutant Discharge Elimination System (NPDES) Permit to the Army Corps of Engineers (permittee) for the operation of the Washington Aqueduct facility and to discharge treated and untreated drinking water from Outfalls 002A, 002Q, 003, 004, 006, 007, 008, and 009 to Rock Creek, Mill Creek, and the Potomac River. This permit is being issued under the Federal Clean Water Act (CWA), 33 U.S.C., §§ 1251 et. seq.

EPA solicited public comments on two drafts of the permit: from August 1, 2019 through September 3, 2019, on the first draft of the permit, and from December 7, 2020 through January 7, 2021, on the revised draft permit. In accordance with federal regulations at 40 CFR §124.17, this document presents EPA's responses to comments received on the initial and revised drafts of NPDES Permit No. DC0000019. The Response to Comments explains and supports EPA's determinations that form the basis of the final permit (the Final Permit).

**The First Public Notice and Comment Period.** During the first round of public notice and comment (August to September 2019), EPA received 14 comments. Other than numbering the comments received for easier readability, the comments are reproduced below verbatim as received; they have not been edited. Those comments, and EPA's responses to them, are as follows:

Comments received from the District of Columbia's Department of Energy and Environment (DOEE) on the Fact Sheet, dated August 28, 2019:

The following comments from DOEE can be found in the administrative record, document number 28b.

1. Page 5. What hardness was used for the hardness dependent metals?

**EPA Response:** The hardness used to calculate the Water Quality Based Effluent Limits (WQBELs) for metals was 100 mg/L, which is a default value used by the District of Columbia's Department of Energy and Environment. This information was added to the fact sheet to provide clarity.

2. Pages 7 and 8. The District does not have a WQC for chloride or barium, but there are federal WQC for these parameters. Would it be helpful to indicate where the WQC is coming from in the tables? For example, DC WQS or federal? In addition, I noticed that in some instances, there is not a DC surface WQC or a federal criterion. For example, fluoride. DC does, however, have a WQS for fluoride in groundwater (Class G1 waters) and the value in the factsheet is the same value as in the DC WQS. Is this the source of the value? If so, referencing it might be helpful. If it is, is it appropriate to use?



**EPA Response:** EPA agrees that indicating the source of the water quality criterion for all pollutants provides transparency to the reasonable potential analysis and has revised the fact sheet to include this information.

3. Page 8. I am sure I am missing something or not fully understanding. But how can an equation that has all flow parameters = an instream concentration. The result of the equation is unitless and should be expressed as a fractional amount. Please add sentences that further explain or provide perspective.

**EPA Response:** EPA agrees this was not made clear in the first version of the fact sheet and has revised the fact sheet to include a definition of “instream waste concentration.” The instream waste concentration is the ratio between effluent flow and receiving stream flow, which is a unitless number that is sometimes expressed as a percentage when multiplied by 100.

4. Page 9. The table at the top of the page notes “Instream Concentration” as a “% (MGD)”; however, the following tables on page 9 note “Instream Background Concentration (mg/l)”. Could a brief explanation be included to describe the difference? Amend footnote 3. StreamStats is a USGS website not a “NOAA” website. iii. What stream flow information was used from the website? How was the instream background concentration calculated? Please briefly describe or reference appropriately.

**EPA Response:** EPA revised the fact sheet to include a definition of “instream background concentration” which is the same as “background concentration.” EPA acknowledges the error in identifying StreamStats as a National Oceanic and Atmospheric Association (NOAA) website and has revised the fact sheet to explain that StreamStats is a United States Geological Survey (USGS) website. The streamflow information that was used from the website is included in the Reasonable Potential Spreadsheet which is document number 36 in the administrative record. EPA did not calculate the instream background concentration. The instream background concentrations were provided by the permittee with its permit application. These background data are included in the permit’s administrative record, document numbers 8a – 8h.

5. Page 10. Table pertaining to outfall 007. Is the copper value of 0.0134 calculated based on an assumed or measured hardness? Can the difference between the WQC for Al in outfalls 3 & 4 relative to outfall 6 be explained? Maybe past work or permits could be cited to help explain.

**EPA Response:** The copper value of 0.0134 was calculated based on a default hardness value of 100 mg/L. Section 8.0 of the fact sheet includes a statement that a default hardness value of 100 mg/L was used to calculate the WQBELs for metals.

The water quality criterion for aluminium at outfalls 003/004 and 006 differ because the aluminum criterion is a calculation that requires the input of site-specific data for pH, hardness, and dissolved organic carbon. Since the pH, hardness and dissolved organic carbon can vary for each stream, the aluminum criteria calculated for Outfalls 003 and 004 are different than the aluminum water quality criterion calculated for Outfall 006 because the input values varied at each stream. The fact sheet was revised to include the following explanation:

EPA used the recently promulgated federal aluminum instream water quality criterion (83 Fed. Reg. 65,663 Dec. 21, 2018) as an interpretation of the District of Columbia narrative

water quality criterion because the District does not have a numeric water quality criterion for aluminum (see the District of Columbia's Municipal Regulations, Title 21 Section 21-1104.1 for the narrative water quality criteria). The aluminum criterion was calculated using the Aluminum Criteria Calculator v2.0, which can be found in the permit's administrative record. The calculator requires the input of site-specific data for pH, hardness and dissolved organic carbon, data which were provided by the permittee. Since the pH, hardness and dissolved organic carbon can vary for each stream, the aluminum criteria calculated for Outfalls 003 and 004 are different than the aluminum water quality criterion calculated for Outfall 006 because the input values varied at each stream.

6. Page 10 and 11. Last table on page 10 and second table on page 11. The WQC for copper on page 10 is cited as 0.0134; however, the WQC for copper on page 11 is cited as 0.134. Which one is correct?

**EPA Response:** EPA acknowledged and corrected this typo in the fact sheet. The correct criterion is 0.0134. The fact sheet was revised to reflect the correct copper instream criterion of 0.0134 mg/L.

7. Page 13, TMDL Section Remarks associated with the Receiving Stream, the Chesapeake Bay. Is TSS a parameter of concern? If not, suggest stating so. If so, suggest including a statement.

**EPA Response:** EPA has identified Total Suspended Solids (TSS) as a parameter of concern for the Chesapeake Bay Total Maximum Daily Load (TMDL). The fact sheet has been revised to reflect this determination.

Comment from the Maryland Department of the Environment (MDE) in its communication pursuant to Clean Water Act Section 401(a)(2) dated September 6, 2019:

The following comment from MDE can be found in the administrative record, document number 29a.

8. Maryland has no objection to the issuance of this permit. I would like to point out, however, a philosophical difference. This permit implements some limits based on technology requirements that are less stringent than a dilution-based water quality limitation. For outfalls 003 and 004, the applied aluminum limit is 8.0 mg/l, which is based on a technology standard. Given that the EPA water quality standard for aluminum is 1.1 mg/l, and the statistical prediction of the highest instream effluent level is 0.8 mg/l, that is only about a .3 mg/l margin of safety, which is acceptable. However, somehow the rationale is that because there is no reasonable potential to violate the water quality standard in-stream, the appropriate limit can be relaxed considerably all the way up to 8 mg/l. We believe that sends the wrong message to the permittee and to the public regarding the safe levels of aluminum that are allowed at the outfalls. Please understand I am only commenting on the "optics" of the permit as I agree with the fact sheet's conclusion that the effluent itself exhibits no reasonable potential to violate the water quality standard.

**EPA Response:** EPA carried over the aluminum Technology Based Effluent Limits (TBELs) to be consistent with the anti-backsliding regulation specified in 40 C.F.R. § 122.44(l). TBELs represent the minimum level of control that must be imposed in a permit, however, if the TBELs will not achieve the applicable water quality standards (i.e., are not sufficient to protect water

quality) then WQBELs are developed and included in a permit. However, due to an oversight, EPA did not assess the need for WQBELs during the first draft of the permit and appreciates MDE bringing this to our attention. As a result, EPA evaluated the aluminum TBELs against a calculated WQBEL for each the outfalls to determine whether they were protective of the receiving streams. The more protective limit (TBEL or WQBEL) was included in the final permit. This approach was used even when there was no RP for aluminum because the flocculent the facility uses in its treatment system contains aluminum.

Comments from the Potomac River Keeper Network (PKRN) dated September 3, 2019:

The PKRN comment letter can be found the administrative record, document number 34.

9. PRKN generally supports renewal of this NPDES permit, and appreciates the work done by the permittee and EPA to regulate discharges of solids into the Potomac River. PRKN also notes that the discharges of metals, including aluminum and copper, into the Potomac River continues to be of concern due to their potential impact on the aquatic environment. Any future modifications of this permit that may be required due to exceedance of the water quality criteria for aluminum from any of the permitted Outfalls should be classified as a major modification and made available for public notice and comment.

**EPA Response:** EPA appreciates the comment from the Potomac River Keeper Network (PRKN) and also acknowledges the work done to address the discharge of solids into the Potomac River. Should EPA determine that there is cause for a permit modification under 40 C.F.R § 122.62(a), and the modifications do not satisfy the criteria under 40 C.F.R § 122.63 for minor modifications, the revised draft permit will be offered for public notice and comment in accordance with 40 C.F.R § 122.62 and 124.10.

10. PRKN also notes that the information in the Fact Sheet and draft NPDES permit regarding compliance with the Endangered Species Act appears to be incomplete. The Fact Sheet states that endangered Shortnose Sturgeon are known to exist in the Potomac River drainage basin, and may occur within DC waters. Fact Sheet at 14. The Fact Sheet fails to mention that endangered Atlantic Sturgeon are found in the Potomac River, and the Chesapeake Bay Distinct Population Segment (DPS) were listed as endangered in 2012 (Footnote 2: See <https://www.federalregister.gov/documents/2012/02/06/2012-1946/endangered-and-threatened-wildlife-and-plants-threatened-and-endangered-status-for-distinct>.) In addition, the Potomac River from Little Falls Dam to the confluence with Chesapeake Bay was designated as Critical Habitat for Atlantic Sturgeon in 2017. The Fact Sheet notes that EPA will be submitting a Biological Evaluation (B.E.) to FWS and NMFS, but does not specify whether the B.E. will evaluate the impacts of the permit reissuance and continued operation of the Washington Aqueduct facilities on both Shortnose and Atlantic Sturgeon, or only Shortnose. Neither the Fact Sheet nor the draft NPDES permit make any mention of the need for a Biological Assessment of the potential impact of this facility's operation on designated Critical Habitat for Atlantic Sturgeon in the Potomac River. Given the fact that the permittee's discharges are just upstream of the critical habitat area, and the potential adverse effect that discharges of metals could have on both habitat and Atlantic Sturgeon directly, EPA should engage in formal consultation with FWS and NMFS to assess whether operation of the Washington Aqueduct and discharges from it will adversely affect Atlantic and Shortnose Sturgeon, and Atlantic Sturgeon Critical Habitat in the Potomac River. In addition, the

B.E. and any Biological Assessment prepared by EPA should be made available for public comment prior to any decision by EPA to renew or modify the NPDES permit at issue here.

**EPA Response:** EPA's biological evaluation included both Shortnose and Atlantic sturgeon in its analysis. Due to an oversight, this was not made clear in the draft fact sheet that was made available for public notice and comment in August 2019. EPA engaged in consultation with both the U.S. Fish and Wildlife Service (US FWS) and the U.S. National Marine Fisheries Service (NMFS) during the first and second public notice and comment periods. EPA's biological evaluation and consultation with USFWS and NMFS was made available to the public during each of the public notice and comment periods. The Endangered Species Act (ESA) section of the fact sheet has been revised to include references to both the Shortnose Sturgeon and the Atlantic Sturgeon. .

Comments from the U.S. Army Corps of Engineers (permittee) dated August 28, 2019:

The following comments from the U.S. Army Corps of Engineers (permittee) can be found in the administrative record, document number 27a.

11. In the permit's tables under Outfalls 002, 003, and 004, the sample frequency for pH and Total Residual Chlorine are listed as "Daily". To be consistent with the monitoring requirements for other constituents in Outfalls 002, 003 and 004 as well as requirements for Outfalls 006, 007, 008, and 009, we request that the monitoring requirements be changed from "Daily" to "1/discharge".

**EPA Response:** EPA agrees that a daily monitoring frequency is not appropriate for the outfalls with an intermittent discharge, which is all outfalls except Outfall 002Q, as on most days there would be no discharge to monitor. Therefore, EPA revised the permit to include a monitoring frequency of "per discharge" for all the intermittent outfalls and once per quarter or "1/quarter" for Outfall 002Q, the continuous discharge.

12. On page 5 of the permit, under Outfall 002Q, the nitrogen and phosphorus sample frequency was listed as "1/discharge". We believe this was an editing error and that it should be "1/quarter" because this outfall is a continuous discharge.

**EPA Response:** EPA agrees that this was an editing error and changed the monitoring frequency at Outfall 002Q to "1/quarter."

13. On page 28 of the permit, there is an introductory paragraph to Section B that should also be inserted immediately under Section A, as follows, to make it read similarly: "The permittee is authorized to discharge in accordance with the terms and conditions set forth in Part I of this permit. In addition, ..."

**EPA Response:** Page 28 of the first draft of the permit is Part III Section A, therefore, EPA understands this comment to be referencing Part III Section A and Part III Section B of the permit. EPA revised Part III Section A of the permit for consistency and clarity.

14. In contrast to the Outfalls 006, 007, 008 and 009, Outfalls 002, 003 and 004 contain a monitoring requirement for TSS influent. As we have discussed in previous comments, we add a coagulant

to facilitate treatment and clarification and this measurement is not relevant to our operations. Thus, we request that this monitoring requirement be deleted.

**EPA Response:** In previous discussions with EPA, the permittee provided information and documentation regarding the coagulant used to treat for TSS. This treatment along with the installation of the residual processing facility has eliminated the need for a percent removal requirement and influent monitoring in the permit. These requirements were inadvertently carried over from the 2008 permit. The total suspended solids influent monitoring requirements at Outfalls 002A, 003 and 004 have been removed from the permit because the permit does not contain a percent removal requirement due to the construction and implementation of the residual processing facility.

EPA made substantial changes to the first draft permit as a result of public comments and other information received, as discussed above. As a result of those substantial changes, EPA made the revised draft permit and fact sheet available for public notice and comment again from December 7, 2020 to January 7, 2021.

**The Second Public Notice and Comment Period.** During the second round of public notice and comment (December 2020 to January 2021), EPA received 4 comments: 3 comments from the permittee and 1 comment from the District Department of Energy and Environment. Other than numbering the comments received for easier readability, the comments are reproduced below verbatim as received; they have not been edited. Those comments, and EPA's responses to them, are as follows:

Comments from U.S. Army Corps of Engineers (permittee) dated January 5, 2021:

The following comments from the permittee can be found in the administrative record, document number 83.

15. Since the TMDL load limits are expressed on an annual basis, comparison of representative or actual discharge concentrations to Potomac River intake concentrations should be conducted on an annual basis. Comparison of representative discharge concentrations to intake concentrations on a daily basis may not be appropriate due to varying detention times.

**EPA's response:** The Chesapeake Bay TMDL for nitrogen, phosphorus, and sediment expresses allocations in terms of daily loads. The Bay TMDL does assign a wasteload allocation to the Aqueduct. Special Condition in Part III.C of the permit requires the permittee to conduct a study of the Potomac River water that is withdrawn at each intake and the effluent at each outfall. EPA initially included the entire aggregate edge of stream wasteload allocations for TN, TP, and TSS as maximum cumulative annual loads at all the outfalls in the draft permit to address Chesapeake Bay TMDL requirements. However, the Aqueduct had concerns with applying maximum cumulative loads at all the outfalls asserting that there is a high likelihood that the mass limits for TN and TP would be exceeded solely due to concentrations of these pollutants present in the Potomac River (i.e., the influent). As a result, the Aqueduct recommended the application of net limits in the permit as well as conducting a sampling study of the Potomac River. EPA agreed with the Aqueduct's recommendation to add a special condition to the permit that requires the sampling of both raw Potomac River water at the intakes and the discharges at the outfalls and has included this requirement in Part III.C of the final permit. Quarterly sampling is required at each intake and at Outfall 002Q, and during each discharge for the intermittent discharges (i.e.,

those from outfalls other than 002Q). These sampling frequencies are necessary to compare the influent with the effluent with statistical validity. EPA believes that annual sampling as proposed by the permittee will not provide adequate data to evaluate and determine appropriate effluent limitations or additional permit conditions. Therefore, the sampling frequency will remain as quarterly for outfall 002Q and the intakes, and on a “per discharge” basis for the outfalls other than 002Q.

The Rock Creek TMDL for copper, lead, mercury, and zinc does not assign a wasteload allocation to the Aqueduct; one outfall has a copper limit, which is included in the permit as a result of the Reasonable Potential analysis.

The reporting units are not intended to restrict the number of samples the permittee takes. EPA expects the permittee to sample, at a minimum, what is required in the permit for each outfall. If the permittee chooses to sample more than the minimum frequency, these results must also be reported in NetDMR.

16. Determination of hydraulic detention times is very difficult and varies from day to day dependent upon usage rates and operational conditions. This will create implementation issues relative to sampling. Thus, comparison of intake and representative discharge concentrations should be conducted on an annual basis.

**EPA’s response:** EPA understands this comment to be the same as Comment #15. Accordingly, please see the response to Comment #15.

17. Washington Aqueduct would also like to request that as data are generated, Aqueduct staff be included in discussions regarding data interpretation and implications with respect to the permit.

**EPA’s response:** The permit requires the data be submitted via NetDMR with the quarterly sampling reports submitted via email no later than the 28<sup>th</sup> day of the month following the completed quarterly monitoring period. Should EPA have any questions about the data and other information being evaluated, EPA will notify the permittee.

Comment from the District of Columbia’s Department of Energy and Environment (DOEE), dated January 4, 2021:

The following comments from DOEE can be found in the administrative record, document number 82, 82a, and 88.

18. Draft Permit: Part IIIA Special Conditions

Due to the extremely high concentration of solids in past discharges, DOEE requests the permit include a special provision requiring prior notification (at least 72 hours) of all planned discharges (except Outfall 002Q) by the Aqueduct to DOEE and Region III so that DOEE can plan to observe discharges.

**EPA Response:** In 2015, the permittee constructed and implemented a Residual Processing Facility that collects sediments from the basins which reduces the amount of sediment discharged from the outfalls. The permittee is required to operate and maintain the Residual Processing Facility to comply with the effluent limitations in the permit. DOEE provided a

Clean Water Act Section 401(a) certification of the permit that includes a condition requiring the permittee to notify DOEE at least 72 hours prior to planned discharges. EPA pointed out to DOEE that the 401 condition is the same as the condition described in its comment above. As such, both EPA and DOEE agree that since these two notifications are the same, the 401 condition that is included in the permit is also sufficient to satisfy this comment. EPA asked DOEE for specific contact information of the person who should be notified to include this information in the permit. This contact information was added in Part III Section F of the final permit.

Although EPA's decision-making process has benefited from the comments submitted, the information and arguments presented did not raise any substantial new questions concerning the permit that warrants EPA exercising its discretion to reopen the public comment period. EPA did, however, make certain changes to the permit as described above in response to the public comments EPA received on the revised draft permit and revised draft Fact Sheet.

A copy of the Final Permit and this response to comments document will be posted on the EPA Region 3 web site: <https://www.epa.gov/npdes-permits/district-columbia-npdes-permits>. A copy of the Final Permit may be also obtained by emailing or calling Carissa Moncavage at Telephone: (215) 814-5798; Email [moncavage.carissa@epa.gov](mailto:moncavage.carissa@epa.gov)