

Pollutant	Conc. Units	DF	C _s ¹	C _e ²		C _d ³		Criteria * 0.9		Reasonable Potential		Limits	
				Acute	Chronic	Acute	Chronic	Acute	Chronic	Acute	Chronic	Acute	Chronic
Cadmium	µg/L	100.0	0	0.3	0.3	0.0	0.0	29.9	7.2	N	N	N/A	N/A
Copper	µg/L	100.0	0	6.7	6.7	0.1	0.1	5.2	3.4	N	N	N/A	N/A
Lead	µg/L	100.0	0	0.3	0.3	0.0	0.0	198.7	7.7	N	N	N/A	N/A
Nickel	µg/L	100.0	0	4.2	4.2	0.0	0.0	67.3	7.5	N	N	N/A	N/A
Zinc	µg/L	100.0	0	50.0	50.0	0.5	0.5	85.6	77.1	N	N	N/A	N/A
Ammonia (Cold)	mg/L	100.0	0	3.4	3.4	0.0	0.0	29.5	4.5	N	N	N/A	N/A
Ammonia (Warm)	mg/L	100.0	0	3.4	3.4	0.0	0.0	7.1	1.1	N	N	N/A	N/A

¹Median concentration for the receiving water upstream of the zone of influence of the facility's discharge taken from the WET testing data during the review period (see Appendix A).

²Values represent the 95th percentile (for n ≥ 10) or maximum (for n < 10) concentrations from the DMR data and/or WET testing data during the review period (see Appendix A). If the pollutant already has a limit (for either acute or chronic conditions), the value represents the existing limit.