

Permit Number: 36-6041
Expiration Date: 10/1/84
Page 1 of 1 Pages

AIR CONTAMINANT DISCHARGE PERMIT

Department of Environmental Quality
522 SW Fifth, Portland, OR 97204
Mailing Address: Box 1760, Portland, OR 97207
Telephone: (503) 229-5696

Issued in accordance with the provisions of ORS 468.310

ISSUED TO:

Spaulding Pulp and Paper Co.
Box 70
Newberg, OR 97132

REFERENCE INFORMATION:

Application No. N/A
Date Received: June 27, 1980

PLANT SITE:

Publishers Paper Mill
Wynooski Street
Newberg, Oregon

ISSUED BY DEPARTMENT OF ENVIRONMENTAL QUALITY

William H. Young
WILLIAM H. YOUNG, Director

DEC 11 1980

Dated

ADDENDUM NO. 1

In accordance with OAR Chapter 340, Section 14-040, Air Contaminant Discharge Permit No. 36-6041, Conditions 4 and 9 now read as follows:

4. Annual emissions from the boiler shall not exceed 240 tons of particulate and 189 tons of Volatile Organic Compounds (VOC).
9. The permittee shall secure and have in effect emission reductions (offsets) in the amount of 189 tons/year or more to offset boiler Volatile Organic Compound emissions prior to operation of the boiler. These offsets may be obtained from any source within the broad vicinity of Newberg but not outside of Air Quality Control Region 193. Emission offsets shall be consistent with definitions and guidelines in the Emission Offset Interpretative Ruling, FR Vol. 44 No. 11, Jan 16, 1979.

Conditions 16 and 17 are hereby added as follows:

16. The No. 9 wood waste boiler at the Newberg Mill (Bumstead-Woolford) shall be operated within the following constraints to ensure an annual VOC offset of 12 tons to be applied to the adjacent No. 10 boiler:
 - a. The total non-fossil fuel quantity burned in the No. 9 boiler shall not exceed 15.3 million therms per year (equivalent to approximately 95,000 ODT of fuel per year).
 - b. Maximum superheated steam production (hourly average) shall not exceed the following:
 - 1) 145,000 pph during simultaneous operation of No. 9 and No. 10 boilers unless at least 15 therms/hr of fossil fuel is fired per 1000 pph steam above 145,000 pph up to a maximum of 160,000 pph.
 - 2) 160,000 pph during periods when No. 10 boiler is not operating.
 - c. Records of operating conditions sufficient to document compliance with these constraints shall be kept on file.
17. The Publishers Paper Portland Division facility located at 6637 SE 160th Avenue, Portland, shall be permanently shut down. In the event the Publishers Paper Company or any other operator wishes to restart this facility, total offsets for volatile organic compounds must be secured and placed into effect before such startup.

P36604.1A (a)