

NPDES authorization to discharge to waters of the United States, Permit No. NM0028011

The applicant's mailing address is:

Village of Jemez Springs WWTP  
P.O. Box 269  
Jemez Springs, NM 87025

The facility is authorized to discharge from a facility located at 14609 Highway 4, approximately 2 miles south of Jemez Springs, Sandoval County, New Mexico from Outfall 001 located at Latitude 35° 43' 36" North, Longitude 106° 42' 48" West. Discharges from the facility for the described activities are to Jemez River thence to the Rio Grande in Waterbody Segment No. 20.6.4.107 of the Rio Grande Basin.

Under the Standard Industrial Classification (SIC) Code 4952, the applicant operates a POTW with a design flow capacity of 0.075 MGD serving 198 people.

This is a renewal of a permit issued April 29, 2021, with an effective date of June 01, 2021, and an expiration date of May 31, 2026.

Changes from the previous permit are:

- Aluminum monitoring and limitation requirement has been removed based on the updated TMDL.
- WET dilution series has been updated based on new critical flow conditions.
- Total Recoverable Aluminum and Boron Sanitary Sewer Study have been removed from the schedule of compliance requirement.
- PFAS analytes schedule of compliance has been incorporated on PART I.B. of the permit.

A fact sheet is available.

State Certification:

The notice also serves as Public Notice of the intent of the New Mexico Environment Department, Surface Water Quality Bureau to consider issuing Clean Water Act (CWA) Section 401 Certification. The purpose of such certification is to reasonably ensure that the permitted activities will be conducted in a manner that will comply with applicable New Mexico water quality standards, including the antidegradation policy, and the statewide water quality management plan. The NPDES permit will not be issued until the certification requirements of Section 401 have been met.

If you want to comment on State Certification submit written comments within the 30-day period to:

Susan A. Lukas-Kamat  
Program Manager-PSRS  
New Mexico Environment Department  
Surface Water Quality Bureau (N2050)  
1190 Saint Francis Drive  
P.O. Box 5469  
Santa Fe, NM 87502-5469  
Phone: 505-946-8924  
[Susan.LucasKamat@state.nm.us](mailto:Susan.LucasKamat@state.nm.us)