

ALABAMA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

Air Division

Chapter 335-3-5
Control of Sulfur Compound Emissions

335-3-5-.01 Fuel Combustion

- (1) (a) **Sulfur Dioxide Category I Counties.** No person shall cause or permit the operation of a fuel burning installation in a Sulfur Dioxide Category I County or in Jefferson County in such a manner that sulfur oxides, measured as sulfur dioxide, are emitted in excess of 1.8 pounds per million BTU heat input. *(Amended March 25, 1975)*
- (b) **Sulfur Dioxide Category II Counties.** No person shall cause or permit the operation of a fuel burning installation in a Sulfur Dioxide Category II County in such a manner that sulfur oxides, measured as sulfur dioxide, are emitted in excess of 4.0 pounds per million BTU heat input. *(Amended March 25, 1975)*
- (c) **Sulfur Dioxide - Jackson County.** No person shall cause or permit the operation of an electric utility steam generating installation having a total rated capacity greater than 5,000 million BTU per hour in Jackson County in such a manner that sulfur oxides, measured as sulfur dioxide, are emitted in excess of 1.2 pounds per million BTU heat input. *(Adopted August 28, 1979)*
- (d) **Sulfur Dioxide - Colbert County.** No person shall cause or permit the operation of an electric utility steam generating installation having a total rated capacity greater than 1,000 million BTU per hour in Jackson County in such a manner that sulfur oxides, measured as sulfur dioxide, are emitted in excess of 2.2 pounds per million BTU heat input.
1. Compliance with this paragraph shall be achieved no later than the dates in the following schedule:
- (i) Specification for emission control equipment shall be completed by October 1, 1987.
 - (ii) Initiation of on-site construction shall begin by April 1, 1988
 - (iii) Contracts for the emission control system shall be awarded by May 1, 1988.
 - (iv) Contracts for compliance coal shall be awarded by February 1,

- 1990.
- (v) The first electric utility steam generating unit shall be in compliance with the paragraph by May 1, 1990.
 - (vi) The second electric steam generating unit shall be in compliance with the paragraph by August 1, 1990.
 - (vii) The third electric steam generating unit shall be in compliance with the paragraph by November 1, 1990.
 - (viii) The fourth electric utility steam generating unit shall be in compliance with the paragraph by January 1, 1991.
- (e) **Sulfur Dioxide - Shelby County.** No person shall cause or permit the operation of an electric utility steam generating installation having a total rated capacity greater than 5,000 million BTU per hour in Jackson County in such a manner that sulfur oxides, measured as sulfur dioxide, are emitted in excess of 3.8 pounds per million BTU heat input.
- (2) **Air Quality Demonstration.** In addition to the requirements of paragraph (1) of this Rule, every owner or operator of a fuel burning installation having a total rated capacity greater than 1500 million BTU per hour shall:
- (a) Demonstrate, to the satisfaction of the Director, that the sulfur oxides emitted, either alone or in contribution to other sources, will not interfere with attainment and maintenance of any primary or secondary ambient air quality standard prescribed at Rule 335-3-1-.03.
 - (b) Demonstrate, to the satisfaction of the Director, that in meeting the emission limitations of paragraph (1) of this Rule, the installation will not increase emissions to the extent that resulting air quality concentrations will be greater than:
 - 1. those concentrations (either measured or calculated) which existed in 1970; or
 - 2. those concentrations (either measured or calculated) which existed during the first year of operation of any installation which began operating after January 1, 1970.
 - (c) Upon the direction of the Director, install and maintain air quality sensors to monitor attainment and maintenance of ambient air quality standards in the areas influenced by the emissions from such installation. Results of such monitoring shall be provided to the Director in a manner and form as he shall direct.
- (3) For purposes of this Part, the total heat input from all similar fuel combustion units at a

plant, premises, or installation shall be used for determining the maximum allowable emission of sulfur dioxide that passes through a stack or stacks. Units constructed and operated to conform with the New Source Performance Standards shall not be considered similar to other units at a plant, premises, or installation. *(Amended March 25, 1975)*

- (4) All calculations performed pursuant to demonstrations required by paragraph (2) of this Rule shall assume that the fuel burning installation is operating at or above the maximum capacity which such installation is capable of being operated. *[Submitted July 25, 1975, Approved May 27, 1976 (41 FR 21638)]*
- (5) No person shall cause or permit the emission or combustion of any refinery process gas stream that contains H₂S in concentrations greater than 150 ppm without removal of the hydrogen sulfide in excess of this concentration.
- (6) To ensure that ambient air quality standards are met, an annual review of Sulfur Dioxide Category I and II Counties will be made by the staff. Initial Sulfur Dioxide Category classifications and any subsequent changes to Sulfur Dioxide Category classifications will be the subject of a public hearing. *(Amended March 25, 1975)*

Author: James W. Cooper and John E. Daniel

Statutory Authority: Code of Alabama 1975, Secs. 22-28-14, 22-22A-5, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective date: January 18, 1972.

Amended: May 29, 1973; March 25, 1975; August 28, 1979; August 10, 1987.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	MAY 1, 1975	SEP 28, 1976	41 FR 19220
1st Revision	OCT 9, 1975	SEP 28, 1976	41 FR 19220
2nd Revision	OCT 31, 1989	MAR 19, 1990	55 FR 10062
3rd Revision	OCTT 30, 1996	AUG 05, 1997	62 FR 30991

335-3-5-.02 Sulfuric Acid Plants *(Amended April 22, 1975)*

- (1) **Applicability.** For existing sulfuric acid plants operating as of January 18, 1972, the following applies:
 - (1) No person shall cause or permit sulfur dioxide tail gas emissions from sulfuric

acid manufacturing plants to exceed 27 pounds per ton of 100 percent sulfuric acid produced; provided, however, that no sulfuric acid manufacturing plant emitting less than 27 lbs. per ton of 100 percent sulfuric acid produced shall be allowed to increase its emission rate.

- (2) No person shall cause or permit tail gas acid mist emissions to exceed 0.5 pounds per ton of sulfuric acid produced, and the sulfur trioxide emissions are not to exceed 0.2 pounds per ton of sulfuric acid produced.

(b) For all sulfuric acid plants not included in subparagraph (a) above, the following applies:

- (1) No person shall cause or permit the discharge into the atmosphere of sulfur dioxide in excess of 4 lbs. per ton of sulfuric acid produced, maximum two-hour average.
- (2) No person shall cause or permit the discharge into the atmosphere of acid mist which is in excess of 0.15 pounds per ton of acid produced, maximum two-hour average, expressed in H₂SO₄.
- (2) There shall be installed, calibrated, maintained, and operated in any sulfuric acid production unit subject to the provisions of this Part, an instrument for continuously monitoring and recording emissions of sulfur dioxide.
- (3) Any instrument and sampling system installed and used pursuant to this Part shall be subject to the approval of the Director.

Author: James W. Cooper and John E. Daniel

Statutory Authority: Code of Alabama 1975, Secs. 22-28-14, 22-22A-5, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective date: January 18, 1972.

Amended: May 29, 1973; April 22, 1975

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	JUL 25, 1975	MAY 27, 1976	41 FR 21638
1st Revision	MAY 01, 1975	SEP 28, 1976	41 FR 42674
2nd Revision	OCT 09, 1975	SEP 28, 1976	41 FR 42674
3rd Revision	SEP 06, 1979	NOV 06, 1981	46 FR 55105
4th Revision	OCT 31, 1989	MAR 19, 1990	55 FR 10062
5th Revision	OCT 30, 1996	AUG 05, 1997	62 FR 30991

335-3-5-.03 Petroleum Production

- (1) Applicability. This regulation applies to facilities that handle natural gas or refinery gas that contains more than 5 grains of hydrogen sulfide per 100 standard cubic feet.
- (2) No person shall cause or permit the emission of a process gas stream containing hydrogen sulfide into the atmosphere unless it is properly burned to maintain the ground level concentrations of hydrogen sulfide to less than 10 parts per billion.
- (3) No person shall cause or permit the sulfur oxide emission from any facility designed to

dispose of or process natural gas containing more than 5 grains hydrogen sulfide per 100 standard cubic feet to exceed the following:

CATEGORY I COUNTIES

Available Sulfur (Long Tons/Day)	Permitted Emissions of Sulfur Dioxide
Up to 5	No Limit
5 to 35	373 lbs/hour
35 to 75	0.10 lbs/ SO2/lb. S processed
Over 75	0.08 lbs/SO2/lb. S processed

CATEGORY II COUNTIES

Available Sulfur (Long Tons/Day)	Permitted Emissions of Sulfur Dioxide
Up to 10	No Limit
10 to 50	560 lbs/hour
50 to 100	0.10 lbs/ SO2/lb. S processed
Over 100	0.08 lbs/SO2/lb. S processed

The allowable emissions, as a percent of plant inlet, are increased as follows to allow for dry acid gas streams containing less than 60 percent hydrogen sulfide:

Mol Percent of Hydrogen Sulfide in Dry Acid Gas	Additional SO2 Emissions Allowed
50% but less than 60%	0.02 lbs. SO2/lb. S processed
40% but less than 50%	0.04 lbs. SO2/lb. S processed
30% but less than 40%	0.06 lbs. SO2/lb. S processed
20% but less than 30%	0.10 lbs. SO2/lb. S processed
Less than 20%	Must utilize the best available control technology, with consideration to the technical practicability and economic reasonableness of reducing or eliminating the emissions from the facility.

(4) Applicability. In addition to the requirements of paragraph (3) of this Rule, the provisions of this paragraph apply to all natural gas processing facilities in Escambia County with capacities greater than 50 million standard cubic feet of sour gas per day.

(a) No person shall cause or permit the emissions of total sulfur compounds, measured as sulfur dioxide, from any affected facility to exceed the following:

Available Sulfur (Long Tons/Day	Permitted Emissions of Total Sulfur Compounds
Up to 575	0.140 pounds of total sulfur compounds per pound of available sulfur
575 to 1031	Pounds of total sulfur compounds per pound of available sulfur = $0.186 - 8.57 \times 10^{-7} S$ Where S=lb/hr of available sulfur
Over 1031	10,008 lb/hr

(b) Compliance with subparagraph (a) of this paragraph shall be determined continuously by monitors which measure the total sulfur compounds, measured as sulfur dioxide, emitted by the facility and total available sulfur to the facility or by other equivalent methods approved by the Director.

(5) For purposes of this Rule, the following counties are classified as Category I Counties: Jackson, Jefferson, and Mobile. The remaining counties in the state are classified as Category II Counties.

(6) Compliance with these regulations is determined both by long-term material balances and stack sampling. New plants with an inlet stream containing more than 50 long tons per day of sulfur are required to install monitors to continuously determine the sulfur oxide emissions in terms of mass per unit of time.

(7) In calculating the ground level concentration that results from short-term or emergency flaring, it shall be assumed that only 75 percent of the heat of combustion is used to heat the products of combustion.

(8) Air Quality Demonstration. In addition to the requirements of paragraph (3) of this Rule, every owner or operator of a facility covered by Rule 335-3-5-.03 shall demonstrate, to the satisfaction of the Director, that the sulfur oxides emitted, either alone or in conjunction with other sources, will not interfere with attainment and maintenance of any primary or secondary ambient air quality standard.

- (9) To ensure that ambient air quality standards are met, an annual review of Sulfur Dioxide Category I and II Counties will be made by the staff. Initial Sulfur Dioxide Category Classifications and any subsequent changes to Sulfur Dioxide Category Classifications will be the subject of a public hearing.

Author: James W. Cooper and John E. Daniel

Statutory Authority: Code of Alabama 1975, Secs. 22-28-14, 22-22A-5, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective date: January 18, 1972.

Amended: May 29, 1973; April 22, 1975

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	JUL 21, 1976	OCT 19, 1977	42 FR 55810
1 st Revision	OCT 31, 1989	MAR 19, 1990	55 FR 10062
2 nd Revision	OCT 30, 1996	AUG 05, 1997	62 FR 30991
3 rd Revision	AUG 10, 2000	DEC 08, 2000	65 FR 76938

335-3-5-.04 Kraft Pulp Mills (*Adopted July 26, 1972*)

- (1) For the purposes of this Rule, the following definitions apply:
- (a) “Old Design Recovery Furnaces” shall mean recovery furnaces designed to burn black liquor after direct contact evaporation, as well as units built prior to 1970, converted to an indirect contact unit prior to 1990 and whose exhaust gases pass through a wet bottom electrostatic precipitator.
- (b) “New Design Recovery Furnaces” shall mean recovery furnaces designed to burn black liquor after indirect contact evaporation.
- (2) **Applicability.** This Rule applies to manufacturing facilities for the pulping of wood and the preparation and recovery of associated chemicals by the kraft process, including combined recovery systems serving other processes such as neutral sulfite pulping.

Author: James W. Cooper and John E. Daniel

Statutory Authority: Code of Alabama 1975, Secs. 22-28-14, 22-22A-5, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective date: July 26, 1972.

Amended: May 29, 1973

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	FEB 15, 1973	APR 23, 1974	39 FR 14338
1st Revision	OCT 31, 1989	MAR 19, 1990	55 FR 10062
2 nd Revision	AUG 10, 2000	DEC 08, 2000	65 FR 76938

335-3-5-.05 Process Industries - General (*Adopted May 5, 1976*)

- (1) **Applicability.** This part applies to facilities not regulated by Rules 335-3-5-.01 through 335-3-5-.04.
- (2) No person shall construct and operate a new or modified sulfur compound emission source that does not meet any and all applicable New Source Performance Standards and utilizes the best available control technology, with consideration to the technical practicability and economic reasonableness of reducing or eliminating the emissions from the facility.
- (3) No person shall construct and operate a new or modified emissions source that will cause or contribute to a new condition such that either the primary or the secondary sulfur dioxide ambient air quality standards are exceeded in the area.

Author: James W. Cooper and John E. Daniel

Statutory Authority: Code of Alabama 1975, Secs. 22-28-14, 22-22A-5, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective date: May 25, 1976.

Amended: August 10, 1976.

Date Submitted to EPA	Date Approved by EPA	Federal Register
--------------------------	-------------------------	---------------------

335-3-5-9

Original Reg	JUL 21, 1976	OCT 19, 1977	42 FR 55810
1st Revision	OCT 31, 1989	MAR 19, 1990	55 FR 10062

335-3-5-.06 TR SO2 Trading Program - Purpose and Definitions

(1) Purpose. Rules 335-3-5-.06 through 335-3-5-.36 set forth the general, designated representative, allowance, and monitoring provisions for the Transport Rule (TR) SO2 Group 2 Trading Program, under section 110 of the Clean Air Act, as a means of mitigating interstate transport of fine particulates and sulfur dioxide.

(2) Definitions. For the purpose of rules 335-3-5-.06 through 335-3-5-.36, the definitions listed in 40 CFR §97.702, Subpart DDDDD as of July 1, 2015, will apply.

(a) "Department" means the Alabama Department of Environmental Management.

(b) Word, Phrase, and Rule Substitutions. For the purpose of rule 335-3-5-.06 substitute:

1. Adem Administrative Coder. 335-3-5-.07 for 40 CFR §97.704.
2. Adem Administrative Code r. 335-3-5-.07(1)(b)2.(ii) and (iii) for §§97.704(b)(2)(i)(8) and (ii).
3. Adem Administrative Coder. 335-3-5-.08 for 40 CFR §97.705.
4. Adem Administrative Coder. 335-3-5-.12(1) for 40 CFR §97.710(a).
5. Adem Administrative Coder. 335-3-5-.12(2) for 40 CFR §97.710(b).
6. Adem Administrative Code r. 335-3-5-.13 for 40 CFR §97. 711.

7. Adem Administrative Code r. 335-3-5-. 13 for 40 CFR §97. 712.

(3) Measurements, Abbreviations, and Acronyms. Measurements, abbreviations, and acronyms used in this rule and in rules 335-3-5-.06 through 335-3-5-.36 are defined as follows:

- (a) Btu - British thermal unit
- (b) CO₂- carbon dioxide
- (c) H₂O -water
- (d) hr- hour
- (e) kW- kilowatt electrical
- (f) kWh - kilowatt hour
- (g) lb - pound
- (h) mmBtu - million Btu
- (i) MWe- megawatt electrical
- (j) MWh - megawatt hour
- (k) NO_x- nitrogen oxides
- (l) O₂ - oxygen
- (m) ppm - parts per million
- (n) scfh- standard cubic feet per hour
- (o) SO₂- sulfur dioxide
- (p) yr- year

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869

335-3-5-.07 TR SO2 Trading Program – Applicability

(1) Applicability.

(a) Except as provided in subparagraph (b) of this paragraph:

1. The following units in the State of Alabama shall be TR SO2 Group 2 units, and any source that includes one or more such units shall be a TR SO2 Group 2 source, subject to the requirements of rules 335-3-5-.06 through 335-3-5-.36: any stationary, fossil-fuel-fired boiler or stationary, fossil-fuel-fired combustion turbine serving at any time, on or after January 1, 2005, a generator with nameplate capacity of more than 25 MWe producing electricity for sale.

2. If a stationary boiler or stationary combustion turbine that, under subparagraph (a) 1. of this paragraph, is not a TR SO2 Group 2 unit begins to combust fossil fuel or to serve a generator with nameplate capacity of more than 25 MWe producing electricity for sale, the unit shall become a TR SO2 Group 2 unit as provided in subparagraph (a) 1. of this paragraph on the first date on which it both combusts fossil fuel and serves such generator.

(b) Any unit in the State that otherwise is a TR SO2 Group 2 unit under subparagraph (a) of this paragraph and that meets the requirements set forth in subparagraphs (b) 1.(i) and (ii) or 2.(i) and (ii) of this paragraph shall not be a TR SO2 Group 2 unit:

1. Any unit:

(i) Qualifying as a cogeneration unit throughout the later of 2005 or the 12-month period starting on the date the unit first produces electricity and continuing to qualify as a cogeneration unit throughout each calendar year ending after the later of 2005 or such 12-month period; and

(ii) Not supplying in 2005 or any calendar year thereafter more than one-third of the unit's potential electric output capacity or 219,000 MWh, whichever is greater, to any utility power distribution system for sale.

(iii) If, after qualifying under subparagraphs (b) 1.(i) and (ii) of this paragraph as not being a TR SO₂ Group 2 unit, a unit subsequently no longer meets all the requirements of subparagraphs (b) 1.(i) and (ii) of this paragraph, the unit shall become a TR SO₂ Group 2 unit starting on the earlier of January 1 after the first calendar year during which the unit first no longer qualifies as a cogeneration unit or January 1 after the first calendar year during which the unit no longer meets the requirements of subparagraph (b) 1.(ii) of this paragraph. The unit shall thereafter continue to be a TR SO₂ Group 2 unit.

2. Any unit:

(i) Qualifying as a solid waste incineration unit throughout the later of 2005 or the 12-month period starting on the date the unit first produces electricity and continuing to qualify as a solid waste incineration unit throughout each calendar year ending after the later of 2005 or such 12-month period; and

(ii) With an average annual fuel consumption of fossil fuel for the first 3 consecutive calendar years of operation starting no earlier than 2005 of less than 20 percent (on a Btu basis) and an average annual fuel consumption of fossil fuel for any 3 consecutive calendar years thereafter of less than 20 percent (on a Btu basis).

(iii) If, after qualifying under subparagraphs (b) 2.(i) and (ii) of this paragraph as not being a TR SO₂ Group 2 unit, a unit subsequently no longer meets all the requirements of subparagraphs (b) 2.(i) and (ii) of this paragraph, the unit shall become a TR SO₂ Group 2 unit starting on the earlier of January 1 after the first calendar year during which the unit first no longer qualifies as a solid waste incineration unit or January 1 after the first 3 consecutive calendar years after 2005 for which the unit has an average annual fuel consumption of fossil fuel of 20 percent or more. The unit shall thereafter continue to be a TR SO₂ Group 2 unit.

(c) A certifying official of an owner or operator of any unit or other equipment may submit a petition (including any supporting documents) to the Administrator at any time for a determination concerning the applicability, under subparagraphs (a) and (b) of this paragraph of the TR SO₂ Group 2 Trading Program to the unit or other equipment. The certifying official of an owner or operator of any unit or other equipment shall submit a copy of the petition (including any supporting documents) to the Department.

1. Petition content. The petition shall be in writing and include the identification of the unit or other equipment and the relevant facts about the unit or other equipment. The petition and any other documents provided to the Administrator in connection with the petition shall include the following certification statement, signed by the certifying official: "I am authorized to make this submission on behalf of the owners and operators of the unit or other equipment for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting

false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.”

2. Response. The Administrator will issue a written response to the petition and may request supplemental information determined by the Administrator to be relevant to such petition. The Administrator's determination concerning the applicability, under paragraphs (a) and (b) of this paragraph, of the TR SO~ Group 2 Trading Program to the unit or other equipment shall be binding on Alabama. the Department, and any other State or permitting authority, unless the Administrator determines that the petition contained significant, relevant errors or omissions.

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869

335-3-5-.08 TR SO2 Trading Program Retired Unit Exemption

(1) Any TR SO2 Group 2 unit that is permanently retired shall be exempt from 40 CFR §§97.706(b) and (c)(1), rule 335-3-5-.25, and rules 335-3-5-.31 through 335-3-5-.36.

(a) The exemption under paragraph (1) of this rule shall become effective the day on which the TR SO2 Group 2 unit is permanently retired. Within 30 days of the unit's permanent retirement, the designated representative shall submit a statement to the Administrator. The statement shall state, in a format prescribed by the Administrator, that the unit was permanently retired on a specified date and will comply with the requirements of paragraph (2) of this rule. The designated representative shall submit a copy of the statement to the Department.

(2) Special provisions.

(a) A unit exempt under paragraph (1) of this rule shall not emit any SO2, starting on the date that the exemption takes effect.

(b) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under paragraph (1) of this rule shall retain, at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time before the end of the period, in writing by the Administrator. The owners and operators bear the burden of proof that the unit is permanently retired.

(c) The owners and operators and, to the extent applicable, the designated representative of a unit exempt under paragraph (1) of this rule shall comply with the requirements of the TR SO2 Group 2 Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.

(d) A unit exempt under paragraph (1) of this rule shall lose its exemption on the first date on which the unit resumes operation. Such unit shall be treated, for purposes of applying allocation, monitoring, reporting, and recordkeeping requirements under TR SO2 Group 2 Trading Program, as a unit that commences commercial operation on the first date on which the unit resumes operation.

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14,

22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
335-3-5-.09 TR SO2 Trading Program - Standard Requirements			

(1) General. The Environmental Protection Agency's Standard Requirements for TR SO2 Sources, are incorporated by reference as they exist in 40 CFR §97.706, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

(2) Word, Phrase, and Rule Substitutions. For the purpose of rule 335-3-5-.09 substitute:

(a) Adem Administrative Coder. 335-3-16-.13(3) for 40 CFR §70.7(e)(2).

(b) Adem Administrative Code r. 335-3-16-.13(3)(a)2. for 40 CFR §70. 7(e)(2)(i)(B).

(c) Adem Administrative Coder. 335-3-5-.13 for 40 CFR §§97.711(a)(2) and (b).

(d) Adem Administrative Coder. 335-3-5-.13 for 40 CFR §97. 712.

(e) Adem Administrative Coder. 335-3-5-.08 for 40 CFR §97.705.

(f) Adem Administrative Coder. 335-3-5-.12(1) for 40 CFR §97.710(a).

(g) Adem Administrative Coder. 335-3-5-.12(2) for 40 CFR §97.710(b).

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11,22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869

335-3-5-.10 TR SO2 Trading Program - Computation of Time

The Environmental Protection Agency Regulations governing the Computation of Time under the TR SO2 Sources, are incorporated by reference as they exist in 40 CFR §97.707, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.11 Administrative Appeal Procedures.

The appeal procedures for decisions of the Administrator under rules 335-3-5-.06 through 335-3-5-.36 are set forth in 40 CFR 78.

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.12 SO2 Trading Budgets and Variability Limits

(1) The State SO2 trading budgets for allocations of TR SO2 Group 2 allowances for the control periods in 2017 and thereafter is 213,258 tons.

(2) The State SO2 variability limit for the State SO2 Group 2 trading budgets for the control periods in 2017 and thereafter is 38,386 tons.

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869

335-3-5-.13 TR SO2 Allowance Allocations.

(1) State SO2 Group 2 Trading Program Budget. The State trading budget for annual allocations of Transport Rule (TR) SO2 Group 2 allowances for the control periods 2017 and thereafter is 213,258 tons.

(2) Timing Requirements for SO2 Group 2 Allowance Allocations.

(a) By June 1, 2016, the Department will submit to the Administrator, in a format prescribed by the Administrator, the SO2 Group 2 allowance allocations, in accordance with paragraph (3) of this rule, for the control periods in 2017 and 2018.

(b) By June 1, 2017, the Department will submit to the Administrator, in a format prescribed by the Administrator, the SO2 Group 2 allowance allocations, in accordance with paragraph (3) of this rule, for the control periods in 2019 and 2020.

(c) By June 1, 2018, the Department will submit to the Administrator, in a format prescribed by the Administrator, the SO2 Group 2 allowance allocations, in accordance with paragraph (3) of this rule, for the control periods in 2021 and 2022.

(d) By June 1, 2019, and every other year thereafter, the Department shall submit to the Administrator, in a format prescribed by the Administrator, the SO2 Group 2 allocations, in accordance with paragraph (3) of this rule, for the control periods in the two years that are four and five years after the year of the applicable deadline for submission under this paragraph.

(3) SO2 Group 2 Allowance Allocations.

(a) Definitions. For the purpose of this rule, the following definitions apply:

1. Baseline TR SO2 Group 2 Unit. A TR SO2 Group 2 unit that either:

(i) Commenced operation on or before January 1, 2014; or

(ii) Submitted a permit application to the Department that was affirmatively deemed complete by the Department in writing on or before January 1, 2014.

2. New TR SO2 Group 2 Unit. A TR SO2 Group 2 unit that does not meet the definition of a Baseline SO2 Group 2 unit as defined in subparagraph (3)(a) 1. of this paragraph.

(b) Determination of Heat Input.

1. The heat input (in mmBtu) used for calculating TR SO2 Group 2 allowance allocations under subparagraph (2)(a) of this rule that are to be submitted to the Administrator by June 1, 2016 will be:

(i) For a Baseline SO₂ Group 2 unit, the average of the three (or less, if applicable) highest amounts of the unit's heat input for the control periods, in which the unit operated, in 2010, 2011, 2012, 2013, and 2014; or

(ii) For a Baseline TR SO₂ Group 2 unit that did not commence operation on or before January 1, 2014 but had submitted a permit application to the Department that was affirmatively deemed complete by the Department in writing on or before January 1, 2014, the expected actual annual heat input based on actual utilization data of similar sources.

(iii) For a New SO₂ Group 2 unit, the expected actual SO₂ heat input based on actual utilization data of similar sources.

2. The heat input (in mmBtu) used for calculating TR SO₂ Group 2 allowance allocations under subparagraph (2)(b) of this rule that are to be submitted to the Administrator by June 1, 2017 will be:

(i) For a Baseline TR SO₂ Group 2 unit, the average of the three (or less, if applicable) highest amounts of the unit's heat input for the control periods, in which the unit operated, in 2011, 2012, 2013, 2014, and 2015; or

(ii) For a Baseline TR SO₂ Group 2 unit that did not commence operation on or before January 1, 2015 but had submitted a permit application to the Department that was affirmatively deemed complete by the Department in writing on or before January 1, 2014, the expected actual annual heat input based on actual utilization data of similar sources.

(iii) For a New TR SO₂ Group 2 unit that commenced operation on or before January 1, 2015, the average of the three (or less, if applicable) highest amounts of the unit's heat input for the control periods, in which the unit operated in 2014 and 2015.

(iv) For a New TR SO₂ Group 2 unit that did not commence operation on or before January 1, 2015, the expected actual so₂ heat input based on actual utilization data of similar sources.

3. The heat input (in mmBtu) used for calculating TR SO₂ Group 2 allowance allocations under subparagraph (2)(c) of this rule that are to be submitted to the Administrator by June 1, 2018 will be:

(i) For a Baseline TR SO₂ Group 2 unit, the average of the three (or less, if applicable) highest amounts of the unit's heat input, in which the unit operated in 2012, 2013, 2014, 2015, and 2016.

(ii) For a New TR SO₂ Group 2 unit that commenced operation on or before January 1 2016, the average of the three (or less, if applicable) highest amounts of the unit's heat input for the control period in which the unit operated in 2014, 2015, and 2016.

(iii) For a New TR SO₂ Group 2 unit that did not commence operation on or before January 1, 2016, the expected actual annual heat input based on actual utilization data of similar sources.

4. The heat input (in mmBtu) used for calculating TR SO2 Group 2 allowance allocations under subparagraph (2)(d) of this rule that are to be submitted to the Administrator by June 1, 2019, and all subsequent allocation years will be:

(i) a Baseline TR SO2 Group 2 unit, the average of the three (or less, if applicable) highest amounts of the unit's heat input, for the control periods in which the unit operated for the five most recent control periods available prior to the deadline submission year.

(ii) For a New TR SO2 Group 2 unit that commenced operation prior to January 1 of the most recent control period available prior to the submission year, the average of the three (or less, if applicable) highest amounts of the unit's heat input, for the control periods in which the unit operated, for the five most recent control periods available prior to the submission year; or

(iii) For a New SO2 Group 2 unit that did not commence operation prior to January 1 of the most recent control period available prior to the submission year, the expected actual annual heat input based on actual utilization data of similar sources.

5. The unit's total heat input for the control period in each year specified under subparagraph (b) of this paragraph will be determined in accordance with 40 CFR 75 if the TR SO2 Group 2 unit was otherwise subject to the requirements of 40 CFR 75 for the year, or will be based on the best available data reported to the Administrator and the Department for the unit if the unit was not otherwise subject to the requirements of 40 CFR 75 for the year.

(c) Establishment of Baseline and Retired Unit Allowance Pools. At the time Transport Rule (TR) SO2 Group 2 allowances are initially allocated to baseline TR SO2 Group 2 units under subparagraph (2)(a) of this rule, each unit's allocation will be permanently recorded as that unit's "Baseline Allowance". This value will be used to calculate the following:

1. Baseline Allowance Pool. The Baseline Allowance Pool shall be calculated each time TR SO2 Group 2 allowances are allocated under paragraph (2) of this rule and shall equal the State SO2 Group 2 Trading Program Budget minus the total of the Baseline Allowances for all baseline TR SO2 Group 2 units that have retired in accordance with 335-3-5-.08.

2. Retired Unit Allowance Pool. The Retired Unit Allowance Pool shall be calculated each time TR SO2 Group 2 allowances are allocated under paragraph (2) of this rule and shall equal the sum of the Baseline Allowances for all TR SO2 Group 2 units that have retired in accordance with 335-3-5-.08.

(d) Maximum Historic Emission Cap. The maximum historic emission cap is identified by using an 8 year historic emission period for each TR SO2 Group 2 unit. The last year of the 8 year period will be the same year as the last year used for determination of heat input under paragraph (3)(b) of this rule. The maximum historic emission cap is the maximum SO2 emissions (in tons) that occurred during any control period during the 8 year historic emission period. Data used for this purpose shall be obtained from the EPA Clean Air Markets Division (CAMD). An additional emission cap may be applied if a TR SO2 Group 2 unit has an enforcement action or permit limit

in place. The 8 year historic emission values will update every two years to coincide with the allocation control period.

(e) Calculation of TR SO2 Group 2 Allowances for Baseline TR SO2 Group 2 Units.

1. For each control period under subparagraph (2) of this rule, the Department will allocate TR SO2 Group 2 allowances from the Baseline Allowance Pool to all baseline TR SO2 Group 2 units in accordance with the following procedures:

(i) The Department will allocate TR SO2 Group 2 allowances to each TR SO2 Group 2 unit under 335-3-5-.07(l)(a) in an amount equaling the unit's share of the State's total 3 year average of heat input determined in accordance with subparagraph (b) of this paragraph, multiplied by the baseline allowance pool. If a TR SO2 Group 2 unit has an initial historic heat input based allocation that exceeds its maximum historic emission cap as defined in subparagraph (3)(e) of this rule, then its allocation will equal the maximum historic emission cap for that TR SO2 Group 2 unit.

(ii) Allocations remaining after the application of the maximum historic emission cap are reapportioned on the same basis to baseline TR SO2 Group 2 units whose historic heat input based allocation does not exceed its maximum historic emission cap, if applicable. These steps are repeated until the entire Baseline Allocation Pool is allocated. The resulting TR SO2 Group 2 allocation value is rounded to the nearest whole ton.

(f) Calculation of SO2 Allowances for New TR SO2 Group 2 Units. For each control period under paragraph (2) of this rule, after calculating SO2 allowances for all baseline TR SO2 Group 2 units that have not retired in accordance with 335-3-5-.08, the Department will allocate SO2 allowances in the Retired Unit Allowance Pool to all new SO2 Group 2 season units, in accordance with the following procedures:

1. For each new TR SO2 Group 2 unit under 335-3-5-.07(l)(a), that commenced operation or submitted a permit application affirmatively deemed complete by the Department in writing on or before March 1 of the year allocations are to be submitted to the Administrator under paragraph (2) of this rule, the number of TR SO2 Group 2 allowances allocated for each applicable control period will be equal to the unit's share of the State's total 3 year average of heat input for all new TR SO2 Group 2 units, determined in accordance with subparagraph (b) of this paragraph multiplied by the Retired Unit Allowance Pool. If a new TR SO2 Group 2 unit has an initial historic heat input based allocation that exceeds its maximum historic emission cap as defined in subparagraph (3)(e) of this rule, then its allocation equals the maximum historic emission cap for that TR SO2 Group 2 unit .

2. Allocations remaining after application of the maximum historic emission cap are reapportioned on the same basis to new TR SO2 Group 2 units whose historic heat input based allocation does not exceed its maximum historic emission cap, if applicable. These steps are repeated until the entire Retired Unit Allowance Pool is allocated or until all new units receive allocations equal to its maximum historic emission cap. The resulting TR SO2 Group 2 allocation value is rounded to the nearest whole ton.

(g) Adjustment of Baseline SO2 Allowance Allocations. If TR SO2 Group 2 allowances remain in the Retired Unit Allowance Pool after allocations are made to all new TR SO2 Group 2 units in accordance with subparagraph (f) of this paragraph, these so2 allowances will be allocated on a pro rata basis to the baseline TR SO2 Group 2 units where historic heat input based allocation does not exceed its maximum historic emission cap, for the applicable control periods.

(h) SO2 allowances allocated to baseline TR SO2 Group 2 units based on heat inputs determined in accordance with subparagraph (b) 1.(ii) or (b)2.(ii) of this paragraph will be held in the State's general account until the unit commences operation, prior to or during the control period for which SO2 allowances were allocated. If the unit does not commence operations, the SO2 allowances will be transferred by the Department pro rata to Baseline TR SO2 Group 2 units that were allocated SO2 allowances in accordance with subparagraphs (b) 1./i) or /b)2./i) of this paragraph, and whose historic heat input based allocation does not exceed its maximum historic emission cap if applicable. By January 30 of the following year, the Department shall notify the Administrator of the appropriate SO2 allowance transfers.

1. SO2 allowances allocated to new TR SO2 Group 2 units based on heat inputs determined in accordance with subparagraphs (b) 1.(iii), (b)2.(iv), (b)3.(iii), or (b)4.(iii) of this paragraph will be held in the State's general account until the unit commences operation, prior to or during the control period for which SO2 allowances were allocated. If the unit does not commence operations, the SO2 allowances will be transferred by the Department pro rata to Baseline TR SO2 Group 2 units that were allocated SO2 allowances in accordance with subparagraphs (b) 1.(i) and (ii), (b)2.(i) and (ii), (b)3.(i), or (b)4.(i) of this paragraph, and whose historic heat input based allocation does not exceed its maximum historic emission cap if applicable. By January 30 of the following year, the Department shall notify the Administrator of the appropriate SO2 allowance transfers.

2. SO2 allowances will not be allocated to TR SO2 Group 2 units that retire under 335-3-5-.08 prior to the date SO2 allowance allocations are submitted to the Administrator under subparagraphs (2)(a), (b), (c), or (d) of this Rule.

3. The total SO2 Group 2 allowances allocated for any control period in accordance with subparagraphs (3)(f), and (g) of this paragraph shall not exceed the State SO2 Group 2 Trading Program Budget as determined by the applicable, approved State Implementation Plan.

(i) Distribution of remaining TR SO2 Group 2 Allowances. If any TR SO2 Group 2 allowances remain after allocations are completed in subparagraphs (e) through (h) of this paragraph, the remaining allowances shall be distributed proportional to the allocations made in subparagraphs (e) through (h) of this paragraph, the remaining allowances shall be distributed proportional to the allocations made in subparagraphs (e) through (h) of this paragraph beyond the unit's historical emissions cap. However, no unit may receive additional allocations that exceed any enforcement cap or permit limitation.

(j) Units Incorrectly Allocated TR SO2 Group 2 Allowances. The procedures for addressing units that were incorrectly allocated TR SO2 Group 2 allowances are incorporated by

reference as they exist in 40 CFR §97.711(c), Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1 st Revision	DEC 7, 2018	MAR 12, 2020	85 FR 14418

335-3-5-.14 Authorization of Designated Representative and Alternate Designated Representative.

The Environmental Protection Agency Regulations governing the Authorization of Designated Representative and Alternate Designated Representative for TR SO₂ Sources, are incorporated by reference as they exist in 40 CFR §97.713, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11,22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.15 Responsibilities of Designated Representative and Alternate Designated Representative.

The Environmental Protection Agency Regulations governing the Responsibilities of Designated Representative and Alternate Designated Representative for TR SO2 Sources, are incorporated by reference as they exist in 40 CFR §97.714, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.16 Changing Designated Representative and Alternate Designated Representative; Changes in Owners and Operators; Changes in Units at the Source.

The Environmental Protection Agency Regulations governing Changing Designated Representative and Alternate Designated Representative; Changes in Owners and Operators; Changes in Units at the Source for TR SO2 Sources, are incorporated by reference as they exist in 40 CFR §97.715, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.17 Certificate of Representation.

The Environmental Protection Agency Regulations governing Certificate of Representation, are incorporated by reference as they exist in 40 CFR §97.716, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

Date Submitted	Date Approved	Federal
----------------	---------------	---------

335-3-5-28

	to EPA	by EPA	Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.18 Objections Concerning Designated Representative and Alternate Designated Representative.

(1) General. The Environmental Protection Agency Regulations governing Objections Concerning Designated Representative and Alternate Designated Representative, are incorporated by reference as they exist in 40 CFR §97.717, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

(2) Word, Phrase, and Rule Substitutions. For the purpose of rule 335-3-5-.18 substitute:

(a) Only in 40 CFR §97 .717(c) substitute "Neither the Administrator nor the Department shall" for "The Administrator will not."

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869

335-3-5-.19 Delegation by Designated Representative and Alternate Designated Representative.

The Environmental Protection Agency Regulations governing Delegation by Designated Representative and Alternate Designated Representative, are incorporated by reference as they exist in 40 CFR §97.718, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.21 Establishment of Compliance Accounts, Assurance Accounts, and General Accounts.

(1) General. The Environmental Protection Agency Regulations governing Establishment of Compliance Accounts, Assurance Accounts, and General Accounts, are incorporated by reference as they exist in 40 CFR §97.720, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

(2) Word, Phrase, and Rule Substitutions. For the purpose of rule 335-3-5-.21 substitute:

(a) Only in 40 CFR §97.720(c)(4)(iii) substitute "Neither the Administrator nor the Department shall" for "The Administrator will not."

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

Date Submitted
to EPA

Date Approved
by EPA

Federal
Register

Original Reg

NOV 24, 2015

AUG 31, 2016

81 FR 59869

335-3-5-.22 Recordation of TR SO2 Allowance Allocations and Auction Results.

The Environmental Protection Agency Regulations governing Recordation of TR SO2 Allowance Allocations and Auction Results, are incorporated by reference as they exist in 40 CFR §97. 721, Subpart DDDDD as of July 1, 2015, except for the provisions found in 40 CFR §§97.721(a), (b), (h), and (i). (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.23 Submission of TR SO2 Allowance Transfers.

The Environmental Protection Agency Regulations governing Submission of TR NOx Annual Allowance Transfers, are incorporated by reference as they exist in 40 CFR §97.722, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.24 Recordation of TR SO2 Allowance Transfers.

The Environmental Protection Agency Regulations governing, Recordation of TR SO2 Allowance Transfers are incorporated by reference as they exist in 40 CFR §97.723, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11,22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.25 Compliance with TR SO2 Emissions Limitation.

The Environmental Protection Agency Regulations governing Compliance with TR SO2 Emissions Limitation, are incorporated by reference as they exist in 40 CFR §97.724, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.26 Compliance with TR SO2 Assurance Provisions.

The Environmental Protection Agency Regulations governing Compliance with TR SO2 Assurance Provisions, are incorporated by reference as they exist in 40 CFR §97.725, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.27 Banking.

(1) General. The Environmental Protection Agency Regulations governing Banking for TR SO2 Allowance, are incorporated by reference as they exist in 40 CFR §97.726, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

(2) Word, Phrase, and Rule Substitutions. For the purpose of rule 335-3-5-.27 substitute:

(a) Adem Administrative Coder. 335-3-5-.13(3)(j) for 40 CFR §97.711(c).

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869

335-3-5-.28 Account Error.

The Environmental Protection Agency Regulations governing Account Error, are incorporated by reference as they exist in 40 CFR §97.727, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-1 0, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.29 Administrator's Action on Submissions.

The Environmental Protection Agency Regulations governing Administrator's Action on Submissions, are incorporated by reference as they exist in 40 CFR §97.728, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.31 General Monitoring, Recordkeeping, and Reporting Requirements.

(1) General. The Environmental Protection Agency Regulations governing General Monitoring, Recordkeeping, and Reporting Requirements, are incorporated by reference as they exist in 40 CFR §97.730, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

(2) Word, Phrase, and Rule Substitutions. For the purpose of rule 335-3-5-.31 substitute:

(a) Adem Administrative Coder. 335-3-5-.08 for 40 CFR §97.705.

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869

335-3-5-.32 Initial Monitoring System Certification and Recertification Procedures.

(1) General. The Environmental Protection Agency Regulations governing Initial Monitoring System Certification and Recertification Procedures, are incorporated by reference as they exist in 40 CFR §97.731, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

(2) Word, Phrase, and Rule Substitutions. For the purpose of rule 335-3-5-.32 substitute:

(a) In §97. 731 (d)(3)(i) insert", the Department" after "Office."

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869

335-3-5-.33 Monitoring System Out-of-Control Periods

The Environmental Protection Agency Regulations governing Monitoring System Out-of-Control Periods, are incorporated by reference as they exist in 40 CFR §97.732, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.34 Notifications Concerning Monitoring.

The Environmental Protection Agency Regulations governing Notifications Concerning Monitoring, are incorporated by reference as they exist in 40 CFR §97.733, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.35 Recordkeeping and Reporting.

The Environmental Protection Agency Regulations governing Recordkeeping and Reporting, are incorporated by reference as they exist in 40 CFR §97.734, Subpart DDDDD as of July 1, 2015.

(The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652

335-3-5-.36 Petitions for Alternatives to Monitoring, Recordkeeping, or Reporting Requirements.

The Environmental Protection Agency Regulations governing Petitions for Alternatives to Monitoring, Recordkeeping, or Reporting Requirements, are incorporated by reference as they

exist in 40 CFR §97.735, Subpart DDDDD as of July 1, 2015. (The materials incorporated by reference are available for purchase and inspection at the Department's offices.)

Author: Ronald W. Gore.

Statutory Authority: Code of Alabama 1975, §§22-28-10, 22-28-11, 22-28-14, 22-28-18, 22-28-20, 22-28-22, 22-22A-5, 22-22A-6, and 22-22A-8.

History: Effective Date: November 24, 2015.

	Date Submitted to EPA	Date Approved by EPA	Federal Register
Original Reg	NOV 24, 2015	AUG 31, 2016	81 FR 59869
1st Revision	DEC 20, 2023	MAY 9, 2025	90 FR 19652