

Texas Commission on Environmental Quality

Chapter 117 – Control of Air Pollution from Nitrogen Compounds

Subchapter A: Definitions

7A Texas SIP 30 TAC 117.10. Definitions, SIP effective April 22, 2026 (TXd253),

As adopted by TCEQ March 4, 2020, state effective March 26, 2020 (7-35),

submitted to EPA May 12, 2020 (TX-427),

Regulations.gov document EPA-R06-OAR-2020-0164-0003 [TX222.03].

Approved by EPA March 23, 2026 (91 FR 13762) SIP effective April 22, 2026 (TXd253),

Regulations.gov document EPA-R06-OAR-2020-0164-0024 [TX222.24].

CHAPTER 117: CONTROL OF AIR POLLUTION FROM NITROGEN COMPOUNDS

SUBCHAPTER A: DEFINITIONS

§117.10

Statutory Authority

The amended section is adopted under Texas Water Code (TWC), §5.102, concerning General Powers, that provides the commission with the general powers to carry out its duties under the TWC; TWC, §5.103, concerning Rules, that authorizes the commission to adopt rules necessary to carry out its powers and duties under the TWC; TWC, §5.105, concerning General Policy, that authorizes the commission by rule to establish and approve all general policy of the commission; and under Texas Health and Safety Code (THSC), §382.017, concerning Rules, that authorizes the commission to adopt rules consistent with the policy and purposes of the Texas Clean Air Act. The amended section is also adopted under THSC, §382.002, concerning Policy and Purpose, that establishes the commission's purpose to safeguard the state's air resources, consistent with the protection of public health, general welfare, and physical property; THSC, §382.011, concerning General Powers and Duties, that authorizes the commission to control the quality of the state's air; THSC, §382.012, concerning State Air Control Plan, that authorizes the commission to prepare and develop a general, comprehensive plan for the proper control of the state's air; THSC, §382.016, concerning Monitoring Requirements; Examination of Records, that authorizes the commission to prescribe reasonable requirements for the measuring and monitoring of air contaminant emissions; and THSC, §382.021, concerning Sampling Methods and Procedures, that authorizes the commission to prescribe the sampling methods and procedures to determine compliance with its rules. The amended section is also adopted under

Federal Clean Air Act (FCAA), 42 United States Code (USC), §§7401, *et seq.*, which requires states to submit State Implementation Plan revisions that specify the manner in which the National Ambient Air Quality Standards will be achieved and maintained within each air quality control region of the state.

The amended section implements THSC, §§382.002, 382.011, 382.012, 382.016, 382.017, and 382.021; and FCAA, 42 USC, §§7401, *et seq.*

§117.10. Definitions.

Unless specifically defined in the Texas Clean Air Act or Chapter 101 of this title (relating to General Air Quality Rules), the terms in this chapter have the meanings commonly used in the field of air pollution control. Additionally, the following meanings apply, unless the context clearly indicates otherwise. Additional definitions for terms used in this chapter are found in §3.2 and §101.1 of this title (relating to Definitions).

(1) Annual capacity factor--The total annual fuel consumed by a unit divided by the fuel that could be consumed by the unit if operated at its maximum rated capacity for 8,760 hours per year.

(2) Applicable ozone nonattainment area--The following areas, as designated under the 1990 Federal Clean Air Act Amendments.

(A) Beaumont-Port Arthur ozone nonattainment area--An area consisting of Hardin, Jefferson, and Orange Counties.

(B) Dallas-Fort Worth eight-hour ozone nonattainment area--An area consisting of:

(i) for the purposes of Subchapter D of this chapter (relating to Combustion Control at Minor Sources in Ozone Nonattainment Areas), Collin, Dallas, Denton, Ellis, Johnson, Kaufman, Parker, Rockwall, and Tarrant Counties; or

(ii) for all other divisions of this chapter, Collin, Dallas, Denton, Ellis, Johnson, Kaufman, Parker, Rockwall, Tarrant, and Wise Counties.

(C) Houston-Galveston-Brazoria ozone nonattainment area--An area consisting of Brazoria, Chambers, Fort Bend, Galveston, Harris, Liberty, Montgomery, and Waller Counties.

(3) Auxiliary steam boiler--Any combustion equipment within an electric power generating system, as defined in this section, that is used to produce steam for purposes other than generating electricity. An auxiliary steam boiler produces steam as a replacement for steam produced by another piece of equipment that is not operating due to planned or unplanned maintenance.

(4) Average activity level for fuel oil firing--The product of an electric utility unit's maximum rated capacity for fuel oil firing and the average annual capacity factor for fuel oil firing for the period from January 1, 1990, to December 31, 1993.

(5) Block one-hour average--An hourly average of data, collected starting at the beginning of each clock hour of the day and continuing until the start of the next clock hour.

(6) Boiler--Any combustion equipment fired with solid, liquid, and/or gaseous fuel used to produce steam or to heat water.

(7) Btu--British thermal unit.

(8) Chemical processing gas turbine--A gas turbine that vents its exhaust gases into the operating stream of a chemical process.

(9) Continuous emissions monitoring system (CEMS)--The total equipment necessary for the continuous determination and recordkeeping of process gas concentrations and emission rates in units of the applicable emission limitation.

(10) Daily--A calendar day starting at midnight and continuing until midnight the following day.

(11) Diesel engine--A compression-ignited two- or four-stroke engine that liquid fuel injected into the combustion chamber ignites when the air charge has been compressed to a temperature sufficiently high for auto-ignition.

(12) Duct burner--A unit that combusts fuel and that is placed in the exhaust duct from another unit (such as a stationary gas turbine, stationary internal combustion engine, kiln, etc.) to allow the firing of additional fuel to heat the exhaust gases.

(13) Electric generating facility (EGF)--A unit that generates electric energy for compensation and is owned or operated by a person doing business in this state, including a municipal corporation, electric cooperative, or river authority.

(14) Electric power generating system--One electric power generating system consists of either:

(A) for the purposes of Subchapter C, Divisions 1 and 4 of this chapter (relating to Beaumont-Port Arthur Ozone Nonattainment Area Utility Electric Generation Sources; and Dallas-Fort Worth Eight-Hour Ozone Nonattainment Area Utility Electric Generation Sources), all boilers, auxiliary steam boilers, and stationary gas turbines (including duct burners used in turbine exhaust ducts) at electric generating facility (EGF) accounts that generate electric energy for compensation; are owned or operated by an electric cooperative, municipality, river authority, public utility, independent power producer, or a Public Utility Commission of Texas regulated

utility, or any of its successors; and are entirely located in one of the following ozone nonattainment areas:

(i) Beaumont-Port Arthur; or

(ii) Dallas-Fort Worth eight-hour;

(B) for the purposes of Subchapter C, Division 3 of this chapter (relating to Houston-Galveston-Brazoria Ozone Nonattainment Area Utility Electric Generation Sources), all boilers, auxiliary steam boilers, and stationary gas turbines (including duct burners used in turbine exhaust ducts) at EGF accounts that generate electric energy for compensation; are owned or operated by an electric cooperative, municipality, river authority, public utility, or a Public Utility Commission of Texas regulated utility, or any of its successors; and are entirely located in the Houston-Galveston-Brazoria ozone nonattainment area;

(C) for the purposes of Subchapter B, Division 3 of this chapter (relating to Houston-Galveston-Brazoria Ozone Nonattainment Area Major Sources), all units in the Houston-Galveston-Brazoria ozone nonattainment area that generate electricity but do not meet the conditions specified in subparagraph (B) of this paragraph, including, but not limited to, cogeneration units and units owned by independent power producers; or

(D) for the purposes of Subchapter E, Division 1 of this chapter (relating to Utility Electric Generation in East and Central Texas), all boilers, auxiliary

steam boilers, and stationary gas turbines at EGF accounts that generate electric energy for compensation; are owned or operated by an electric cooperative, independent power producer, municipality, river authority, or public utility, or any of its successors; and are located in Atascosa, Bastrop, Bexar, Brazos, Calhoun, Cherokee, Fannin, Fayette, Freestone, Goliad, Gregg, Grimes, Harrison, Henderson, Hood, Hunt, Lamar, Limestone, Marion, McLennan, Milam, Morris, Nueces, Parker, Red River, Robertson, Rusk, Titus, Travis, Victoria, or Wharton County.

(15) Emergency situation--As follows.

(A) An emergency situation is any of the following:

(i) an unforeseen electrical power failure from the serving electric power generating system;

(ii) the period of time that an Electric Reliability Council of Texas, Inc. (ERCOT)-issued emergency notice or energy emergency alert (EEA) (as defined in *ERCOT Nodal Protocols, Section 2: Definitions and Acronyms* (August 13, 2014) and issued as specified in *ERCOT Nodal Protocols, Section 6: Adjustment Period and Real-Time Operations* (August 13, 2014)) is applicable to the serving electric power generating system. The emergency situation is considered to end upon expiration of the emergency notice or EEA issued by ERCOT;

(iii) an unforeseen failure of on-site electrical transmission equipment (e.g., a transformer);

(iv) an unforeseen failure of natural gas service;

(v) an unforeseen flood or fire, or a life-threatening situation;

(vi) operation of emergency generators for Federal Aviation Administration licensed airports, military airports, or manned space flight control centers for the purposes of providing power in anticipation of a power failure due to severe storm activity; or

(vii) operation of an emergency generator as part of ERCOT's emergency response service (as defined *in ERCOT Nodal Protocols, Section 2: Definitions and Acronyms* (August 13, 2014)) if the operation is in direct response to an instruction by ERCOT during the period of an ERCOT EEA as specified in clause (ii) of this subparagraph.

(B) An emergency situation does not include:

(i) operation for training purposes or other foreseeable events; or

(ii) operation for purposes of supplying power for distribution to the electric grid, except as specified in subparagraph (A)(vii) of this paragraph.

(16) Functionally identical replacement--A unit that performs the same function as the existing unit that it replaces, with the condition that the unit replaced must be physically removed or rendered permanently inoperable before the unit replacing it is placed into service.

(17) Heat input--The chemical heat released due to fuel combustion in a unit, using the higher heating value of the fuel. This does not include the sensible heat of the incoming combustion air. In the case of carbon monoxide (CO) boilers, the heat input includes the enthalpy of all regenerator off-gases and the heat of combustion of the incoming CO and of the auxiliary fuel. The enthalpy change of the fluid catalytic cracking unit regenerator off-gases refers to the total heat content of the gas at the temperature it enters the CO boiler, referring to the heat content at 60 degrees Fahrenheit, as being zero.

(18) Heat treat furnace--A furnace that is used in the manufacturing, casting, or forging of metal to heat the metal so as to produce specific physical properties in that metal.

(19) High heat release rate--A ratio of boiler design heat input to firebox volume (as bounded by the front firebox wall where the burner is located, the firebox side waterwall, and extending to the level just below or in front of the first row of convection pass tubes) greater than or equal to 70,000 British thermal units per hour per cubic foot.

(20) Horsepower rating--The engine manufacturer's maximum continuous load rating at the lesser of the engine or driven equipment's maximum published continuous speed.

(21) Incinerator--As follows.

(A) For the purposes of this chapter, the term "incinerator" includes both of the following:

(i) a control device that combusts or oxidizes gases or vapors (e.g., thermal oxidizer, catalytic oxidizer, vapor combustor); and

(ii) an incinerator as defined in §101.1 of this title (relating to Definitions).

(B) The term "incinerator" does not apply to boilers or process heaters as defined in this section, or to flares as defined in §101.1 of this title.

(22) Industrial boiler--Any combustion equipment, not including utility or auxiliary steam boilers as defined in this section, fired with liquid, solid, or gaseous fuel, that is used to produce steam or to heat water.

(23) International Standards Organization (ISO) conditions--ISO standard conditions of 59 degrees Fahrenheit, 1.0 atmosphere, and 60% relative humidity.

(24) Large utility system--All boilers, auxiliary steam boilers, and stationary gas turbines that are located in the Dallas-Fort Worth eight-hour ozone nonattainment area, and were part of one electric power generating system on January 1, 2000, that had a combined electric generating capacity equal to or greater than 500 megawatts.

(25) Lean-burn engine--A spark-ignited or compression-ignited, Otto cycle, diesel cycle, or two-stroke engine that is not capable of being operated with an exhaust stream oxygen concentration equal to or less than 0.5% by volume, as originally designed by the manufacturer.

(26) Low annual capacity factor boiler, process heater, or gas turbine supplemental waste heat recovery unit--An industrial, commercial, or institutional boiler; process heater; or gas turbine supplemental waste heat recovery unit with maximum rated capacity:

(A) greater than or equal to 40 million British thermal units per hour (MMBtu/hr), but less than 100 MMBtu/hr and an annual heat input less than or equal to $2.8 (10^{11})$ British thermal units per year (Btu/yr), based on a rolling 12-month average; or

(B) greater than or equal to 100 MMBtu/hr and an annual heat input less than or equal to $2.2 (10^{11})$ Btu/yr, based on a rolling 12-month average.

(27) Low annual capacity factor stationary gas turbine or stationary internal combustion engine--A stationary gas turbine or stationary internal combustion engine that is demonstrated to operate less than 850 hours per year, based on a rolling 12-month average.

(28) Low heat release rate--A ratio of boiler design heat input to firebox volume less than 70,000 British thermal units per hour per cubic foot.

(29) Major source--Any stationary source or group of sources located within a contiguous area and under common control that emits or has the potential to emit:

(A) at least 50 tons per year (tpy) of nitrogen oxides (NO_x) and is located in the Beaumont-Port Arthur ozone nonattainment area;

(B) at least 50 tpy of NO_x and is located in the Dallas-Fort Worth eight-hour ozone nonattainment area;

(C) at least 25 tpy of NO_x and is located in the Houston-Galveston-Brazoria ozone nonattainment area; or

(D) the amount specified in the major source definition contained in the Prevention of Significant Deterioration of Air Quality regulations promulgated by the United States Environmental Protection Agency in 40 Code of Federal Regulations §52.21 as amended June 3, 1993 (effective June 3, 1994), and is located in Atascosa,

Bastrop, Bexar, Brazos, Calhoun, Cherokee, Comal, Fannin, Fayette, Freestone, Goliad, Gregg, Grimes, Harrison, Hays, Henderson, Hood, Hunt, Lamar, Limestone, Marion, McLennan, Milam, Morris, Nueces, Red River, Robertson, Rusk, Titus, Travis, Victoria, or Wharton County.

(30) Maximum rated capacity--The maximum design heat input, expressed in million British thermal units per hour, unless:

(A) the unit is a boiler, utility boiler, or process heater operated above the maximum design heat input (as averaged over any one-hour period), in which case the maximum operated hourly rate must be used as the maximum rated capacity; or

(B) the unit is limited by operating restriction or permit condition to a lesser heat input, in which case the limiting condition must be used as the maximum rated capacity; or

(C) the unit is a stationary gas turbine, in which case the manufacturer's rated heat consumption at the International Standards Organization (ISO) conditions must be used as the maximum rated capacity, unless limited by permit condition to a lesser heat input, in which case the limiting condition must be used as the maximum rated capacity; or

(D) the unit is a stationary, internal combustion engine, in which case the manufacturer's rated heat consumption at Diesel Equipment Manufacturer's

Association or ISO conditions must be used as the maximum rated capacity, unless limited by permit condition to a lesser heat input, in which case the limiting condition must be used as the maximum rated capacity.

(31) Megawatt (MW) rating--The continuous MW output rating or mechanical equivalent by a gas turbine manufacturer at International Standards Organization conditions, without consideration to the increase in gas turbine shaft output and/or the decrease in gas turbine fuel consumption by the addition of energy recovered from exhaust heat.

(32) Nitric acid--Nitric acid that is 30% to 100% in strength.

(33) Nitric acid production unit--Any source producing nitric acid by either the pressure or atmospheric pressure process.

(34) Nitrogen oxides (NO_x)--The sum of the nitric oxide and nitrogen dioxide in the flue gas or emission point, collectively expressed as nitrogen dioxide.

(35) Parts per million by volume (ppmv)--All ppmv emission specifications specified in this chapter are referenced on a dry basis. When required to adjust pollutant concentrations to a specified oxygen (O_2) correction basis, the following equation must be used.

Figure: 30 TAC §117.10(35) (No change to the figure as it currently exists in TAC.)

$$C_{adj} = C_{meas} \times \frac{(20.9\% - \%O_2 \text{ rule})}{(20.9\% - \%O_2 \text{ meas})}$$

Where:

C_{adj} = pollutant concentration adjusted to percent O_2 , dry basis, specified in applicable rule, in units of applicable standard (e.g., parts per million by volume);

C_{meas} = pollutant concentration measured on a dry basis, in units of applicable standard;

20.9% = O_2 concentration in air, percent;

$\%O_2$ rule = O_2 basis for adjustment specified in applicable rule (e.g., 3.0% for boilers and process heaters) on a dry basis, percent; and

$\%O_2$ meas = O_2 concentration measured simultaneous with pollutant concentration, percent.

(36) Peaking gas turbine or engine--A stationary gas turbine or engine used intermittently to produce energy on a demand basis.

(37) Plant-wide emission rate--The ratio of the total actual nitrogen oxides mass emissions rate discharged into the atmosphere from affected units at a major source when firing at their maximum rated capacity to the total maximum rated capacities for those units.

(38) Plant-wide emission specification--The ratio of the total allowable nitrogen oxides mass emissions rate dischargeable into the atmosphere from affected

units at a major source when firing at their maximum rated capacity to the total maximum rated capacities for those units.

(39) Predictive emissions monitoring system (PEMS)--The total equipment necessary for the continuous determination and recordkeeping of process gas concentrations and emission rates using process or control device operating parameter measurements and a conversion equation or computer program to produce results in units of the applicable emission limitation.

(40) Process heater--Any combustion equipment fired with liquid and/or gaseous fuel that is used to transfer heat from combustion gases to a process fluid, superheated steam, or water for the purpose of heating the process fluid or causing a chemical reaction. The term "process heater" does not apply to any unfired waste heat recovery heater that is used to recover sensible heat from the exhaust of any combustion equipment, or to boilers as defined in this section.

(41) Pyrolysis reactor--A unit that produces hydrocarbon products from the endothermic cracking of feedstocks such as ethane, propane, butane, and naphtha using combustion to provide indirect heating for the cracking process.

(42) Reheat furnace--A furnace that is used in the manufacturing, casting, or forging of metal to raise the temperature of that metal in the course of processing to a temperature suitable for hot working or shaping.

(43) Rich-burn engine--A spark-ignited, Otto cycle, four-stroke, naturally aspirated or turbocharged engine that is capable of being operated with an exhaust stream oxygen concentration equal to or less than 0.5% by volume, as originally designed by the manufacturer.

(44) Small utility system--All boilers, auxiliary steam boilers, and stationary gas turbines that are located in the Dallas-Fort Worth eight-hour ozone nonattainment area, and were part of one electric power generating system on January 1, 2000, that had a combined electric generating capacity less than 500 megawatts.

(45) Stationary gas turbine--Any gas turbine system that is gas and/or liquid fuel fired with or without power augmentation. This unit is either attached to a foundation or is portable equipment operated at a specific minor or major source for more than 90 days in any 12-month period. Two or more gas turbines powering one shaft must be treated as one unit.

(46) Stationary internal combustion engine--A reciprocating engine that remains or will remain at a location (a single site at a building, structure, facility, or installation) for more than 12 consecutive months. Included in this definition is any engine that, by itself or in or on a piece of equipment, is portable, meaning designed to be and capable of being carried or moved from one location to another. Indicia of portability include, but are not limited to, wheels, skids, carrying handles, dolly, trailer, or platform. Any engine (or engines) that replaces an engine at a location and that is intended to perform the same or similar function as the engine being replaced is included in calculating the consecutive residence time period. An engine is considered

stationary if it is removed from one location for a period and then returned to the same location in an attempt to circumvent the consecutive residence time requirement. Nonroad engines, as defined in 40 Code of Federal Regulations §89.2, are not considered stationary for the purposes of this chapter.

(47) System-wide emission rate--The ratio of the total actual nitrogen oxides mass emissions rate discharged into the atmosphere from affected units in an electric power generating system or portion thereof located within a single ozone nonattainment area when firing at their maximum rated capacity to the total maximum rated capacities for those units. For fuel oil firing, average activity levels must be used in lieu of maximum rated capacities for the purpose of calculating the system-wide emission rate.

(48) System-wide emission specification--The ratio of the total allowable nitrogen oxides mass emissions rate dischargeable into the atmosphere from affected units in an electric power generating system or portion thereof located within a single ozone nonattainment area when firing at their maximum rated capacity to the total maximum rated capacities for those units. For fuel oil firing, average activity levels must be used in lieu of maximum rated capacities for the purpose of calculating the system-wide emission specification.

(49) Thirty-day rolling average--An average, calculated for each day that fuel is combusted in a unit, of all the hourly emissions data for the preceding 30 days that fuel was combusted in the unit.

(50) Twenty-four hour rolling average--An average, calculated for each hour that fuel is combusted (or acid is produced, for a nitric or adipic acid production unit), of all the hourly emissions data for the preceding 24 hours that fuel was combusted in the unit.

(51) Unit--A unit consists of either:

(A) for the purposes of §§117.105, 117.305, 117.405, 117.1005, and 117.1205 of this title (relating to Emission Specifications for Reasonably Available Control Technology (RACT)) and each requirement of this chapter associated with §§117.105, 117.305, 117.405, 117.1005, and 117.1205 of this title, any boiler, process heater, stationary gas turbine, or stationary internal combustion engine, as defined in this section;

(B) for the purposes of §§117.110, 117.310, 117.1010, and 117.1210 of this title (relating to Emission Specifications for Attainment Demonstration) and each requirement of this chapter associated with §§117.110, 117.310, 117.1010, and 117.1210 of this title, any boiler, process heater, stationary gas turbine, or stationary internal combustion engine, as defined in this section, or any other stationary source of nitrogen oxides (NO_x) at a major source, as defined in this section;

(C) for the purposes of §117.2010 of this title (relating to Emission Specifications) and each requirement of this chapter associated with §117.2010 of this title, any boiler, process heater, stationary gas turbine (including any duct burner in

the turbine exhaust duct), or stationary internal combustion engine, as defined in this section;

(D) for the purposes of §117.2110 of this title (relating to Emission Specifications for Eight-Hour Attainment Demonstration) and each requirement of this chapter associated with §117.2110 of this title, any stationary internal combustion engine, as defined in this section;

(E) for the purposes of §117.3310 of this title (relating to Emission Specifications for Eight-Hour Attainment Demonstration) and each requirement of this chapter associated with §117.3310 of this title, any stationary internal combustion engine, as defined in this section; or

(F) for the purposes of §117.410 and §117.1310 of this title (relating to Emission Specifications for Eight-Hour Attainment Demonstration) and each requirement of this chapter associated with §117.410 and §117.1310 of this title, any boiler, process heater, stationary gas turbine, or stationary internal combustion engine, as defined in this section, or any other stationary source of NO_x at a major source, as defined in this section.

(52) Utility boiler--Any combustion equipment owned or operated by an electric cooperative, municipality, river authority, public utility, or Public Utility Commission of Texas regulated utility, fired with solid, liquid, and/or gaseous fuel, used to produce steam for the purpose of generating electricity. Stationary gas

turbines, including any associated duct burners and unfired waste heat boilers, are not considered to be utility boilers.

(53) Wood--Wood, wood residue, bark, or any derivative fuel or residue thereof in any form, including, but not limited to, sawdust, sander dust, wood chips, scraps, slabs, millings, shavings, and processed pellets made from wood or other forest residues.